

General Offices: 212 West Michigan Avenue, Jackson, Michigan 49201 • Area Code 517 788-0550

July 24, 1973

Mr. John F. O'Leary, Director Directorate of Licensing US Atomic Energy Commission Washington, DC 20545

Dear Mr. O'Leary:



Docket No 50-155 License No DPR-6

By letter dated January 5, 1973, Mr. Dennis L. Zieman requested additional information with respect to information submitted by Consumers Power Company concerning the Big Rock Point "Loss-of-Coolant Accident Analysis (LOCA)." This letter is written to provide requested information that is presently available.

At the present time, complete information is not available with respect to gamma smearing, further test data with respect to rod wetting and metal/water reaction taking into account the reaction on the interior of the cladding. It is our understanding that a topical report will be submitted by General Electric Company (GE) concerning gamma smearing within the next several months. This report will show that the 4% reduction in decay heat assumed in our previous analysis will be shown to be conservative. Further testing has been performed by GE with respect to unpowered rod wetting, and data reduction is still in progress. It is currently anticipated that the data reduction will be completed such that additional verification of the rod wetting model will be provided by the end of 1973. Inside and outside metal/water reaction has not been calculated because no models are presently available. We anticipate that this information can be provided, if appropriate, several months after a decision is reached in the ECCS rule-making hearings.

Sensitivity studies have been performed for Reload G fuel assemblies with respect to the gamma smearing allowance and number of unpowered rods in a fuel assembly. These studies are summarized below for the design basis accident (DBA):



5738

8101100735

Mr. John F. O'Lea Docket No 50-155 License No DPR-6 July 24, 1973

Fuel Rods W.th Local Power Factors of 1.0 (Same Bundle,

Average Power)

		Original Reload G	
		(1 Umpowered Zr Rod)	(4 Unpowered Zr Rods)
Α.	Base Case		
	4% Gamma Smearing Credit Unpowered Zircaloy Rod(s) Wet(s)	2284 ⁰ F	2036°F
В.	Gamma Smearing Effect		
	Same as A, Except NO Gamma Smearing Credit	2411°F	2092°F
c.	Rod Wetting Effect		
	Same as A, Except No Unpowered Zircaloy Rod Wetting Credit	2657°F	2658°F
D.	Unpowered Rod(s) Effect		
	Same as C, Except Unpower Zircaloy Rods Replaced Wi		

Peak Clad Temperature for DBA

2785°F

Attached is a copy of Special Report No 15 titled "Preliminary Description of Reactor Depressurization System, Big Rock Point." Although final design work is still in progress on the system described, the concepts are considered firm and we are moving ahead with procurement activities in order to meet the deadlines established by the Interim Policy Statement. Your expeditious review and comments on the system design will be appreciated. We intend to submit a final design report and proposed technical specification changes not later than January 1974.

2727°F

You will note in Special Report No 15 that three one-half capacity depressurization valves are being provided such that any single failure will not reduce the blowdown rate below the design value. In addition, the capacity of the valves is such that the inadvertent failure open of any one valve will not result in the core being uncovered (refer to Figure II of Attachment A of our February 9, 1970 letter to Dr. Peter A. Morris).

Docket No 50-155 License No DPR-6 July 24, 1973

Again, we will appreciate receiving any comments concerning the Reactor Depressurizing System as soon as possible.

Yours very truly,

Ralph B. Sewell

Nuclear Licensing Administrator

Logh B Deweef

RBS/map

GIBUTION FOR PART SU DOCKET MATERIAL CONTROL NO: 5738 (TEMPORARY FORM) FILE: DATE REC'D LTR MEMO RPT OTHER DATE OF DOC FROM: Consumers Power Company Jackson, Michigan 49201 7-24-73 Ralph B. Sewell 7-26-73 SENT AEC PDR ORIG OTHER TO: SENT LOCAL PDR Mr. O'Leary signed DOCKET NO: CLASS UNCLASS PROP INFO INPUT NO CYS REC'D 40 50-155 ENCLOSURES: DESCRIPTION: REPORT: Special Report No. 15 - Pre-Ltr re our 1-5-73 ltr....furnishing requested liminary Description of Reactor Deinfo concerning "Loss-of-Collant Accident Analysis(LOCA) ".....& trans the following: pressurization System for the Big Rock Point Plant. ACKNOWLEDGED (40 cvs rec'd) PLANT NAME: Do Not Remove Big Rock Point FOR ACTION/INFORMATION 7-26-73 REGAN(E) ZIEMANN(L) BUTLER(L) SCHWENCER(L) W/ 7Copies W/ Copies W/ Copies W/ Copies STOLZ(L) CLARK(L) DICKER(E) Copies W/ Copies W/ Copies W/ Copies KNIGHTON (E) VASSALLO(L) GOLLER (L) W/ Copies W/ Copies W/ Copies W/ Copies YOUNGBLOOD (E) KNIEL(L) SCHEMEL(L) W/ Copies W/ Copies W/ Copies W/ Copies INTERNAL DISTRIBUTION LIC ASST A/T IND REG FILE TECH REVIEW DENTON BROWN (E) **BRAITMAN** GRIMES AEC PDR HENDRIE DIGGS (L) SALTZMAN ✓ OGC. ROOM P-506A SCHROEDER GAMMILL GEARIN (L) MUNTZING/STAFF MACCARY KASTNER GOULBOURNE (L) PLANS BALLARD CASE KNIGHT MCDONALD SPANGLER LEE (L) GIAMBUSSO PAWLICKI DUBE MAIGRET (L) SHAO BOYD SERVICE (L) STELLO ENVIRO MOORE (L) (BWR) HOUSTON MULLER SHEPPARD (E) DEYOUNG(L) (PWR) C. MILES NOVAK DICKER SMITH (L) SKOVHOLT (L) TEETS (L) ROSS KNIGHTON P. COLLINS IPPOLITO WADE (E) YOUNGBLOOD REGAN WILLIAMS (E) REG OPR TEDESCO LONG PROJECT LDR WILSON (L) FILE & REGION(3) POOR ORIGINAL MORRIS LAINAS HARLESS STEELE BENAROYA VOLLMER EXTERNAL DISTRIBUTION 1 - LOCAL PDR 1-PDR-SAN/LA/NY (1)(2)(9)-NATIONAL LAB'S ✓ 1 - DTIE(ABERNATHY) 1-R.Schoonmaker, OC, GT, D-323 1-GERALD LELLOUCHE ✓ 1 - NSIC(BUCHANAN) 1-R. CATLIN, E-256-GT BROOKHAVEN NAT. LAB 1 - ASLB (TORE/SAYRE/

WOODARD/"H" ST.

1-CONSULTANT'S

16 - CYS ACRS HOLDING SENT TO LIC ASST.

NEWMARK/BLUME/AGBABIAN

R. DIGGS ON 7-26-73 1-GERALD ULRIKSON...ORNL

1-AGMED (WALTER KOESTEE

RM-C-427-GT

1-RD..MULLER..F-309 GT