



IMMEDIATE ACTION LETTER

UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION III
799 ROOSEVELT ROAD
GLEN ELLYN, ILLINOIS 60137

REGISTRATION
SERVICES

JAN 5 11 10 55

TC

December 24, 1980

Docket No. 50-358

Cincinnati Gas and Electric
Company
ATTN: Mr. Earl A. Borgmann
Senior Vice President
Engineering Services
and Electric Production
139 East 4th Street
Cincinnati, OH 45201

Gentlemen:

This refers to the discussion between you and Mr. Knop of this office on December 23, 1980 regarding work activities by Reactor Controls Incorporated (RCI) at the Zimmer Nuclear Power Station.

We understand that you have stopped further work by RCI (Stop Work No. 80-14), and that additionally, you will:


1. Verify the adequacy of work performed by RCI by conducting an extensive review of their work activities, including design, analysis, installation and quality verification.
2. Not allow any further work by RCI until the NRC has reviewed your corrective actions and determined that such actions are satisfactorily completed.

8101100824
Q

12/24/80

Please inform us immediately if your understanding differs from that stated above.

Sincerely,


James G. Keppler
Director

cc:

Mr. J. R. Schott, Plant
Superintendent

W. Laudan, IE:HQ

Central Files

Reproduction Unit NRC 20b

PDR

Local PDR

NSIC

TIC

Harold W. Kohn, Power Siting
Commission

Citizens Against a Radioactive
Environment

Helen W. Evans, State of Ohio