

1 APPEARANCES:

2 On behalf of the Licensee, Metropolitan Edison
Company:

3 GEORGE F. TROWBRIDGE, Esq.
4 THOMAS A. BAXTER
Shaw, Pittman, Potts and Trowbridge,
5 1800 M Street, N.W.,
Washington, D. C.

6 On behalf of the Commonwealth of Pennsylvania:

7 ROBERT ADLER, Esq.
8 Assistant Attorney General,
505 Executive House,
9 Harrisburg, Pennsylvania
WILLIAM DORNSIFE,
10 Nuclear Engineer
11 JAMES M. CUTCHIN, IV, Esq.
12 JAMES TOURTELLOTT, Esq.
Office of Executive Legal Director,
13 United States Nuclear Regulatory Commission,
Washington, D. C.

14
15
16
17
18
19
20
21
22
23
24
25

C O N T E N T S

1					
2	<u>WITNESS:</u>	<u>DIRECT</u>	<u>CROSS</u>	<u>REDIRECT</u>	<u>RECROSS</u>
	Robert W. Keaten				<u>BOARD</u>
3	Michael J. Ross				<u>ON BOARD</u>
	Robert C. Jones, Jr.				
4	By Mr. Baxter	10,617			
5					
				Afternoon Session p.	10,718
6	By Dr. Jordan				10,718
7	By Mr. Cutchin	10,722			
	By Mr. Dornsife	10,728			
8	By Mr. Baxter		10,786		
	By Dr. Jordan				10,787
9	By Mr. Dornsife				10,800
10	Laurence E. Phillips				
11	By Mr. Cutchin	10,805			
12					
13					
14					
15					
16					
17					
18					
19					
20					
21					
22					
23					
24					
25					

P R O C E E D I N G S

1
2 CHAIRMAN SMITH: Is there any preliminary
3 business?

4 (No response.)

5 CHAIRMAN SMITH: Mr. Cutchin, should we have a
6 cross-examination plan from the staff?

7 MR. CUTCHIN: You should, Mr. Chairman, but I am
8 only going to have three or four questions. And to be
9 candid with you, my witness only arrived about 10:00 o'clock
10 last night, and I have not had an opportunity to reduce it
11 to writing.

12 CHAIRMAN SMITH: Okay.

13 MR. BAXTER: Licensee is recalling to the stand
14 Robert W. Keaten, Michael J. Ross, and Robert C. Jones, Jr.,
15 all of whom have previously testified.
16 Whereupon,

17 ROBERT W. KEATEN

18 MICHAEL J. ROSS

19 ROBERT C. JONES, JR.

20 recalled as a witnesses by counsel for the Licensee,
21 Metropolitan Edison Company, having first been previously
22 duly sworn by the Chairman, were examined and testified
23 further as follows:

24 FURTHER DIRECT EXAMINATION:

25 BY MR. BAXTER:

1 Q Gentlemen, I call your attention to a document
2 which bears the caption of this proceeding. It is dated
3 September 15, 1980. It is entitled "Licensee's Testimony of
4 Robert W. Keaten, Michael J. Ross, and Robert C. Jones, Jr.,
5 in Response to UCS Contention Number 7, ANGRY Contention
6 Number 5B, and Sholly Contention Number 6B (Detection of
7 Inadequate Core Cooling)."

8 Is the material associated with your name in this
9 document, including attached statement of qualifications,
10 testimony which you have prepared or had prepared under your
11 direct supervision for presentation at this hearing, Mr.
12 Jones?

13 A (WITNESS JONES) Yes.

14 Q Mr. Keaten?

15 A (WITNESS KEATEN) Yes.

16 Q Mr. Ross?

17 A (WITNESS ROSS) Yes, it is.

18 Q Do you have any changes or corrections to make to
19 your testimony, Mr. Jones?

20 A (WITNESS JONES) No.

21 Q Mr. Keaten?

22 A (WITNESS KEATEN) No.

23 Q Mr. Ross?

24 A (WITNESS ROSS) No.

25 Q Is the testimony true and accurate to the best of

1 your knowledge and belief?

2 A (WITNESS JONES) Yes.

3 A (WITNESS KEATEN) Yes.

4 A (WITNESS ROSS) It is.

5 MR. BAXTER: Mr. Chairman, I move the receipt into
6 evidence of the testimony and ask that it be physically
7 incorporated into the transcript as if read.

8 CHAIRMAN SMITH: With no objections, the testimony
9 is received.

10 (The complete testimony follows.)

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

Layman 1/21 10,619

LIC 9/15/80

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

BEFORE THE ATOMIC SAFETY AND LICENSING BOARD

In the Matter of)	
)	
METROPOLITAN EDISON COMPANY)	Docket No. 50-289
)	(Restart)
(Three Mile Island Nuclear)	
Station, Unit No. 1))	

LICENSEE'S TESTIMONY OF
 ROBERT W. KEATEN, MICHAEL J. ROSS AND ROBERT C. JONES, JR.
 IN RESPONSE TO UCS CONTENTION NO. 7,
 ANGRY CONTENTION NO. V(B) AND SHOLLY CONTENTION NO. 6(b)
(DETECTION OF INADEQUATE CORE COOLING)

OUTLINE

The purposes and objectives of this testimony are to respond to UCS Contention 7 and ANGRY Contention V(B), which assert that instrumentation to directly indicate core coolant level is required. The testimony also responds to Sholly Contention 6(b) and certain NRC staff positions, which assert that additional instrumentation for the detection of inadequate core cooling should be installed. It is shown that core water level instrumentation is not required to assure adequate core cooling and that such instrumentation would not provide the basis for any incremental corrective action. Operator training, procedure revisions and instrumentation changes necessary to evaluate core cooling conditions and avoid the onset of inadequate core cooling are discussed. The testimony continues with a description of operating guidelines which have been developed and implemented to determine and respond to an inadequate core cooling situation should such occur. It is shown that unambiguous, easy-to-interpret, anticipatory indication of inadequate core cooling and the necessary instructions to take appropriate action to assure adequate core cooling conditions are provided.

INDEX

INTRODUCTION 1

RESPONSE TO UCS CONTENTION NO. 7
AND ANGRY CONTENTION V (B) 2

RESPONSE TO SHOLLY CONTENTION 6(b) 20

INTRODUCTION

This testimony, by Mr. Robert W. Keaten, GPU Manager of Systems Engineering, Michael J. Rose, TMI-1 Supervisor of Operations, GPU, and Robert C. Jones, Jr., Supervisory Engineer, ECCS Analysis Unit, Babcock & Wilcox Company, is addressed to the following contentions:

UCS CONTENTION NO. 7

NRC regulations require instrumentation to monitor variables as appropriate to ensure adequate safety (GDC 13) and that the instrumentation shall directly measure the desired variable. IEEE 279, § 4.8, as incorporated in 10 CFR 50.55a(h), states that:

To the extent feasible and practical protection system inputs shall be derived from signals which are direct measures of the desired variables.

TMI-1 has no capability to directly measure the water level in the fuel assemblies. The absence of such instrumentation delayed recognition of a low water level condition in the reactor for a long period of time. Nothing proposed by the staff would require a direct measure of water level or provide an equivalent level of protection. The absence of such instrumentation poses a threat to public health and safety.

ANGRY CONTENTION NO. V(B)

The NRC Order fails to require as conditions for restart the following modifications in the design of the TMI-1 reactor without which there can be no reasonable assurance that TMI-1 can be operated without endangering the public health and safety:

- (B) Installation of instrumentation providing reactor operators direct information as to the level of primary coolant in the reactor core.

SHOLLY CONTENTION NO. 6(b)

It is contended that the short-term actions identified in the Commission's Order and Notice of Hearing dated 9 August 1979 are insufficient to provide the requisite reasonable assurance of operation without endangering public health and safety because they do not include the following items:

- b. Completion of the installation of instrumentation for the detection of inadequate core cooling.

RESPONSE TO UCS CONTENTION NO. 7 AND ANGRY CONTENTION NO. V(B)

BY WITNESS JONES:

UCS Contention 7 asserts that since TMI-1 does not have instrumentation available to measure the water level in the fuel assemblies there is a threat to public health and safety. The lack of such instrumentation is also presented as being a violation of NRC General Design Criterion 13 and 10 CFR Part 50, Section 50.55a, Paragraph (h). The contention is not valid. (ANGRY Contention V(B) makes a similar assertion and is invalid as well.)

The goal of measuring the water level in the core, or any similar variable, would be to assure that the core is adequately cooled. To achieve this goal for power operation the safety analyses which have been performed for TMI-1 defined the parameters which must be monitored. These "desired" variables are then directly measured and input to the Reactor Protection System (RPS) and/or the Engineered Safety Features Actuation

System (ESFAS). They are reactor power, reactor coolant pressure, temperature and flow, and containment pressure.

The RPS serves, in part, to protect the reactor core by initiating a reactor trip upon the following conditions:

- (1) Reactor power exceeds a maximum level.
- (2) Reactor power exceeds a maximum level as determined by reactor coolant flow.
- (3) Reactor coolant temperature exceeds a maximum level.
- (4) Reactor coolant pressure exceeds a maximum level.
- (5) Reactor coolant pressure falls below a minimum level.
- (6) Reactor coolant pressure falls below a minimum level determined by reactor coolant temperature.
- (7) Containment pressure exceeds a maximum level.

That is, for power operation the variables appropriate to assure adequate safety have been defined and these parameters are directly measured and input to the protection system. Water level in the core is not a part of the required instrumentation and no incremental protection system action can be identified based on such indication. There is no known sequence of events which, from a power operation condition, could result in a low water level in the reactor vessel which would not be preceded by a reactor trip from the RPS.

Should an accident such as a loss of coolant accident (LOCA) occur, the ESFAS is designed to actuate the Emergency Core Cooling System (ECCS) upon the following conditions:

- (1) Reactor coolant pressure falls below a minimum level.
- (2) Containment pressure exceeds a maximum level.

The ECCS then provides sufficient inventory to assure that adequate core cooling is maintained. (Note that during the TMI-2 accident the RPS functioned as designed, tripping the reactor on high reactor coolant pressure promptly following the initiating event, loss of feedwater. The ESFAS also functioned as designed, actuating the ECCS on low reactor coolant pressure.)

Following reactor trip and engineered safeguards actuation, protection system input and actuation requirements are no longer applicable. Obviously, however, the goal of assuring adequate core cooling is ongoing and is achieved by maintaining subcooled conditions in the Reactor Coolant System (RCS) or, in the absence of such conditions, by providing sufficient reactor coolant inventory.

Reactor coolant subcooling is assessed by monitoring system temperature and pressure. The indications can be used directly in combination with steam table data to determine system status relative to saturation, or the indications can be processed by a saturation margin meter to display the same information. The temperature instrumentation utilized for this function is located in the RCS hot legs and saturated conditions will occur in the hot legs before core fluid conditions degrade below those necessary for adequate core cooling. The

existence of a saturated condition is a direct indication of an abnormal condition which requires use of ECCS. Pursuant to current criteria, therefore, maximum achievable ECCS flow will be provided. No additional action based on core water level instrumentation can be identified. (At TMI-2, saturated conditions were indicated several minutes after the reactor tripped and if sufficient injection flow had been maintained the core would have been adequately cooled and not damaged.)

If an accident occurs which results in core uncover, superheated reactor coolant conditions would be indicated by core exit thermocouples and the reactor coolant hot leg temperature instrumentation. As explained below, this indication would allow time for corrective action before the limits of 10 CFR 50.46 would be exceeded. Again, core water level instrumentation would not provide a basis for any additional action. (During the accident at TMI-2, indications of superheating in the RCS were available.)

BY WITNESS KEATEN:

Instrumentation for the detection of inadequate core cooling was among the subjects considered by the NRC Office of Nuclear Reactor Regulation TMI-2 Lessons Learned Task Force in its Status Report and Short-Term Recommendations (NUREG-0578). The Task Force concluded with the following positions:

1. Licensees shall develop procedures to be used by the operator to recognize inadequate core cooling with currently available instrumentation. The licensee shall provide a description of the existing instrumentation for the operators to use to recognize these conditions. A detailed description of the analyses needed to form the basis for operator training and procedure development shall be provided pursuant to another short-term requirement, "Analysis of Off-Normal Conditions, including Natural Circulation" (see Section 2.1.9 of this appendix).

In addition, each PWR shall install a primary coolant saturation meter to provide on-line indication of coolant saturation condition. Operator instruction as to use of this meter shall include consideration that it is not to be used exclusive of other related plant parameters.

2. Licensees shall provide a description of any additional instrumentation or controls (primary or backup) proposed for the plant to supplement those devices cited in the preceding section giving an unambiguous, easy-to-interpret indication of inadequate core cooling. A description of the functional design requirements for the system shall also be included. A description of the procedures to be used with the proposed equipment, the analysis used in developing these procedures, and a schedule for installing the equipment shall be provided.

Before addressing Licensee's response to these positions, it is important to recognize when inadequate core cooling occurs.

BY WITNESS JONES:

As I have already indicated, in a depressurization event the RCS must first reach saturation conditions before there is any danger of inadequate core cooling. If the RCS inventory subsequently is reduced and uncovering of the core begins,

temperatures in the uncovered region will increase, causing superheating of the steam. Heretofore, the term "inadequate core cooling" has generally been applied whenever the core is not covered by either liquid coolant or a two-phase mixture, thus resulting in superheated conditions being indicated by the core exit thermocouples. However, core uncover by itself does not mean that the core is being inadequately cooled. For example, design basis small-break LOCA analyses result in some core uncover without any clad damage occurring. Furthermore, the criteria for adequate core cooling for LOCA's are those contained in 10 CFR 50.46. Therefore, for purposes of this testimony, inadequate core cooling is considered to exist when the fuel is uncovered to an extent and/or for a period of time such that the limits of 10 CFR 50.46 would be exceeded.

BY WITNESS KEATEN:

In order to avoid the onset of inadequate core cooling conditions, specific steps have been taken at TMI to ensure that the operators understand the requirements for adequate core cooling and are provided the necessary information to evaluate core coolant conditions.

First, as Mr. Ross discusses below, the operator accelerated retraining program has included specific training in heat transfer and fluid dynamics, plant operating characteristics, plant response to transients and guidance for operator response to loss of coolant accidents (see Section 6 of the Restart Report).

Second, plant procedures have been revised to emphasize the importance of maintaining an adequate saturation margin in the reactor coolant system and to provide guidance for steps to be taken if the saturation margin is less than the required value. The procedures specify the conditions under which high pressure injection flow may be reduced and specify the conditions which require restoration of appropriate HPI flow.

Third, as recommended by the staff's TMI-2 Lessons Learned Task Force, a new meter will be installed in the control room, prior to restart, which directly indicates the margin to saturation conditions in the reactor coolant system (see Restart Report section 2.1.1.6), i.e., the margin between the actual primary system temperature and the saturation temperature for the existing primary system pressure. The temperature margin will be displayed in the control room, and an alarm will be initiated if the margin falls below a pre-set value. Redundancy will be provided by computing the saturation temperature margin independently for each reactor coolant loop. The plant computer, using the same parameters, can also indicate the saturation pressure and temperature, and saturation pressure and temperature margins, for logging and alarm. This new instrumentation will aid the operator in taking action to maintain or re-establish the subcooling margin, and would also assist in the detection of the approach to inadequate core cooling.

Fourth, all 52 of the core exit thermocouples have been connected to read-out in the control room (see Restart Report section 2.1.1.6).

Fifth, an expanded range (120°F-920°F) will be provided for the RCS hot leg temperature measurement prior to restart so that the saturation meter can be used to detect the approach to inadequate core cooling outside the normal operating temperature range (see Restart Report Section 2.1.1.6). As Mr. Jones has stated, this instrumentation, along with the core exit thermocouples, will indicate superheated reactor coolant conditions and provide direct indication of core uncover.

Finally, as discussed more fully below, a new emergency procedure has been written to define the use of the information available from the core exit thermocouples, RCS temperatures and the new saturation indicator in identifying when inadequate core cooling is approaching and to specify the operator action required to promptly enhance core cooling.

The training, procedures and instrumentation described assure that the operators take the following key actions during any approach to an inadequate core cooling condition:

1. Initiate high pressure injection;
2. Maintain steam generator level;
3. Trip the reactor coolant pumps if the engineered safety features actuation signal is initiated by low reactor coolant system pressure; and,

4. Monitor core exit thermocouple temperatures to assure that adequate core cooling exists.

No further action is required for design basis events.

BY WITNESS JONES:

For postulated events beyond the design basis, "inadequate core cooling" guidelines have been developed which define appropriate actions to prevent significant cladding damage and/or hydrogen generation. These guidelines are based on recognition of core uncover and provide guidance to aid in prevention of a situation deteriorating to an inadequate core cooling condition. To develop these guidelines, a series of calculations was performed to develop a correlation between core exit thermocouple temperatures and peak cladding temperature. Using this correlation, two levels of operator actions were identified (see Figure 1).

For the initial level of elevated temperature conditions (Curve 1, Figure 1), the operator is instructed to take the following steps:

1. Start one Reactor Coolant Pump (RCP) per loop.
2. Depressurize operative Once Through Steam Generator(s) (OTSG(s)) to 400 psig as rapidly as possible.
3. Open the Pressurizer Power Operated Relief Valve (PORV), as necessary to maintain RCS pressure within 50 psi of OTSG pressure.

4. Continue cooldown by maintaining 100°F/hr decrease in secondary saturation temperature to achieve 150 psig RCS pressure.

If the thermocouple temperatures continue to rise above the higher predetermined temperatures, specified in the procedure (Curve 2, Figure 1), which indicate a further increase in fuel clad temperature, the operator is instructed to take the following additional actions:

1. Start all RCP's.
2. Depressurize OTSG(s) to atmospheric pressure.
3. Open the PORV to depressurize the RCS and allow Low Pressure Injection to restore core cooling.

This procedure is based upon a recognition that recovery at the higher pressure is unlikely, and that while depressurization will cause more immediate core voiding, in the longer term it will result in improved core cooling by increasing reactor coolant inventory.

BY WITNESSES KEATEN, ROSS AND JONES:

The instrumentation and procedures described above, as well as the training which Mr. Ross describes below, assure that, as recommended in Position 2 of the NRC Staff's TMI-2 Lessons Learned Task Force (quoted above), operators have unambiguous, easy-to-interpret indication of the approach to

inadequate core cooling and the necessary guidance to take appropriate action to enhance adequate core cooling. Consequently, there is no need for additional instrumentation such as reactor vessel level indication -- for which no incremental operator or automatic action has been identified beyond those specified in response to presently monitored parameters. None of the current emergency procedures at TMI-1 require operator knowledge of reactor vessel water level.

BY WITNESS KEATEN:

The NRC staff to date has not recommended or required the installation of instrumentation to measure directly reactor vessel water level at TMI-1. The staff has explained this position as follows:

The inclusion of instrumentation to measure directly the water level in the pressure vessel, i.e., the "water level in the fuel assemblies," was not conclusively known to be feasible or practical. In addition, other considerations which entered into the decision not to make direct measurement level instrumentation a requirement were:

- a) Other methods available or in use may be as good, if not better, and more reliable.
- b) There are uncertainties in the accuracy of the responses of level instrumentation under conditions where two phase fluids might be present in the vessel.
- c) The applicant and reactor vendor are in a better position to assess the instrumentation best suited to determine water level within the vessel for their plant.

(NRC Staff Response to Union of Concerned Scientists First Set of Interrogatories, March 7, 1980, response to Interrogatory 67.) The staff has also stated: "It is our opinion that the existing plant instrumentation at TMI-1 provides sufficient information to the operator to indicate reduced reactor vessel coolant level, core voiding, and deteriorated core thermal conditions." (NRC Staff Response to Union of Concerned Scientists Interrogatories (Second Set), response to Question 202.) Nevertheless, the NRC staff went on to say: "Although these instruments can provide sufficient information to detect adverse core conditions, the NRC Lessons Learned Task Force concluded that a more direct indication of inadequate core cooling could be provided to the operator." The staff now appears to take the position that additional instrumentation should be installed. (Staff Restart Safety Evaluation, NUREG-0680, at C8-21.) The nature of the additional instrumentation and the basis for any such requirement is not clear.

BY WITNESSES KEATEN AND JONES:

It has been suggested that indication of loss of hot leg subcooling does not provide advance warning of inadequate core cooling because it could also be symptomatic of a severe overcooling transient. The required action for both situations, however, is the same -- initiation of high pressure injection flow -- because both situations involve a reduction in reactor coolant volume. It has also been asserted that the

measurement of superheated steam temperatures by the core exit thermocouples indicates inadequate core cooling imminent or already present. This indication, however, is anticipatory of inadequate core cooling, as explained earlier. It is also unambiguous and will not erroneously indicate inadequate core cooling.

We disagree, then, with the staff that additional instrumentation is required to detect inadequate core cooling. We also disagree with UCS and ~~ESRP~~^{TMI-KJ} that vessel water level indication should be installed at TMI-1.

BY WITNESS ROSS:

The NRC staff has stated that ". . . the detection of reduced coolant level or the existence of core voiding at TMI-1 can be readily determined with the saturation meter and other pre-existing [sic] instrumentation" and that "[t]he operator must be made aware of the available information and how to interpret it correctly." (Staff Restart Safety Evaluation, NUREG-0680, at C8-21.) The training provided to TMI-1 operators assures that the operators are aware of available information on the status of core cooling and how to interpret it correctly.

The operations personnel who will be on duty during TMI-1 power operation and would respond to any approaching inadequate core cooling condition include two licensed reactor operators (Control Room Operators), and two licensed senior reactor

operators (one Shift Supervisor and one Shift Foreman). All of the licensed TMI-1 operators have completed the Operator Accelerated Retraining Program (OARP) described in Section 6 of the Restart Report. This training, along with the ongoing requalification training program, assure that operators will recognize and respond to reactor coolant conditions approaching and following saturation, using the instrumentation described above by Mr. Keaten. In addition, each shift will have immediately available a Shift Technical Advisor, who holds an engineering degree.

The OARP included approximately 200 hours of classroom lectures, discussions and working sessions, about 62 hours of which relate directly to the recognition of and response to approaching inadequate core cooling conditions:

- o Heat Transfer and Fluid Dynamics (16 hours) - theory of core cooling and various loss of core cooling transients, including indications, response and results.
- o Small-Break LOCAs (4 hours) - symptoms, indications and actions to be taken for inadequate core cooling and small break accidents.
- o Safety Analysis Workshop (28 hours) - interactive (students-instructors) problem analysis of system conditions to ensure recognition and response to approaching inadequate core cooling, and selection of cooling mode.

- o Reactor Coolant System Elevations and Manometer Effects (4 hours) - theory of, and recognition and response to, manometric behavior during transients.
- o TMI-2 Transient (4 hours) - cause of and response to gas/steam binding affecting core cooling.
- o Procedure Review (4 hours) - identification and explanation of, and responses required for, all steps in the procedures for natural circulation, forced cooling, all LOCA cases, OTSG tube rupture and loss of decay heat removal.

As Supervisor of Operations, I presented a two-hour training session which stressed the importance of using procedures and verifying key plant parameters, using specific examples of plant operational conditions.

The OARP also included control room and simulator training sessions to permit "hands on" application of the guidance and training provided to TMI-1 operators. The control room sessions included a review of the specific instrumentation and information available in the TMI-1 Control Room to build an association of the operational concepts and guidance presented in the classroom with the actual system controls.

Training on the B&W simulator was a part of the OARP (four days per shift crew) and is part of the ongoing operator requalification training program (one week per each shift crew per year). The simulator training provides the opportunity for the operators to participate in plant operations as control

room operators and as supervisors of control room operators. The simulator has the capability of introducing over 60 individual casualties in reactor plant systems. The individual casualties can be combined to create multiple failure accidents or the instructor may fail equipment sequentially. Thus, the simulator gives the operator the opportunity to practice his training and diagnostic skills on complex problems.

These problem situations on the simulator include situations where core cooling either approaches or reaches saturated conditions, requiring the operators to recognize and rectify the degraded conditions and assure adequate core cooling. For example, one problem presented during the OARP included a small-break LOCA sequence in which, following HPI actuation, the throttling criterion of a 50°F subcooling margin was reached, with stable reactor conditions. The simulator instructors then introduced a larger break LOCA. The shift teams were required to diagnose this condition, and in all cases prevented an approach to inadequate core cooling by manually re-establishing full HPI flow before the primary system reached saturation conditions.

In the simulator training, the operator is required to demonstrate satisfactorily his ability to: (1) use and understand applicable emergency procedures; (2) properly manipulate the controls to place and maintain the plant in a safe configuration; (3) use available alarms and indications to evaluate and control the transient; (4) explain plant response;

and (5) explain plant conditions and recommend subsequent actions to his supervisor.

In addition to weekly quizzes, the OARP included a written and oral evaluation of the trainees, administered by an independent consultant, which was equivalent to an NRC initial licensing examination. TMI-1 licensed operators who have successfully completed the OARP will also be required to pass an NRC-administered oral and written license examination.

Following the OARP, the senior reactor operators and other plant management personnel participated in a five-day decision analysis training program. The program utilized a workshop technique in which scenarios were presented, based on actual and postulated plant responses, and personnel were called upon to diagnose plant symptoms and to identify appropriate operator responses. Follow-up discussions were then conducted to provide individual-to-individual team member feedback and to assure understanding of the problem exercise by all personnel.

Licensee's ongoing operator requalification training program requires every licensed operator to devote one week out of every six to training. This program, like the other training I have described, includes many elements which relate directly to the operators' ability to recognize and respond appropriately to an approaching inadequate core cooling condition.

All of this training emphasizes that the operators must maintain adequate reactor coolant saturation margin. The main points which are stressed repeatedly include:

- o Utilize procedures.
- o Verify critical parameters.
- o Proper use, interpretation of and response to saturation margin meter, core exit thermocouple, and hot leg and cold leg temperature indications.
- o Criteria for throttling HPI flow.

This training assures that the instrumentation described above will be adequate for operators to detect and respond correctly to conditions of reduced coolant volume or core voiding.

BY WITNESSES KEATEN AND JONES:

In summary, adequate instrumentation currently exists at TMI-1 to assess core cooling conditions. Even if core water level instrumentation were available, no incremental action can be specified based on such an indication beyond those automatically initiated or required of the operator in response to presently monitored variables. The lack of core water level instrumentation does not, therefore, violate regulatory requirements or pose a threat to public health and safety.


RESPONSE TO SHOLLY CONTENTION NO. 6(b)

BY WITNESS KEATEN:

As explained above in the response to UCS Contention 7 and ANGRY Contention V(B), Licensee has already completed installation of adequate instrumentation for the detection of inadequate core cooling.

FIGURE 1

CORE EXIT THERMOCOUPLE TEMPERATURE FOR INADEQUATE CORE COOLING



ROBERT W. KEATEN

Business Address:

GPU Service Corporation
100 Interpace Parkway
Parsippany, New Jersey 07054

Education:

B.S., Physics, Yale University, 1957.
Post-Graduate and Professional Courses
in Mathematics, Engineering and
Business, UCLA, 1960-1972.

Experience:

Manager, Systems Engineering Department, GPU Service Corporation, April 1978 to present. Responsible for the development and application of specialized analytical skills in such areas as nuclear core reloads and fuel management; plant dynamic and safety analysis; system generating plant process computers; control and safety systems analysis, and analysis of plant operating performance for nuclear and fossil plants. Served as Deputy Director of Technical Support at Three Mile Island during the post-accident period.

Program Manager, Light Metal Fast Breeder Reactor Technology, Atomics International Division of Rockwell International, 1974 to 1978. Managed research and development programs performed for U.S. Department of Energy, including programs in reactor physics, safety and component development.

Manager of Systems Engineering, Light Metal Fast Breeder Reactor Program, Atomics International Division of Rockwell International, 1968 to 1974. Responsible for performance of safety analyses, development of safety criteria and development of instrumentation, control and safety systems design.

American Representative to the OECD Halden Reactor Project in Norway, 1965-1968. Participated in research on nuclear fuel performance, application of digital computers to nuclear reactors, and on development and application of in-core instrumentation.

Supervisor of Engineering, Sodium Reactor Experiment, Atomics International, Division of Rockwell International, 1962-1965. Responsibilities included analysis and measurement of the nuclear heat transfer and hydraulic parameters of the reactor core and process systems; specification and installation of nuclear and process instrumentation; design and installation of new control systems.

Senior Physicist, Sodium Reactor Experiment, Atomics International, Division of Rockwell International, 1959-1962. Performed measurements and analyses of the nuclear and thermal parameters of the reactor.

Experimental Physics Group, DuPont Savannah River Plant, 1957-1959. Performed measurements and calculations of the nuclear parameters of the reactor lattices.

Honors and
Professional
Affiliations:

Member of the Nuclear Power Plant Standards Steering Committee of the American Nuclear Society.

Member and past Chairman of the LMFBR Design Criteria (ANS-54) Standards Committee of the American Nuclear Society.

Registered Professional Engineer (Nuclear Engineering), California.

Publications:

"Analysis of TMI-2 Sequence of Events Operator Response," presented to a special session of the American Nuclear Society Conference, San Francisco, November 1979; and to Edison Electric Institute Conference, Cleveland, October 1979.

"The Role of Instrumentation in the TMI-2 Accident," presented at the American Nuclear Society Conference, June 1980.

Safety and Environmental Aspects of Liquid Metal Fast Breeder Reactors" 35th Annual American Power Conference, Chicago, Ill., May 1973.

"Safety Aspects of the Design of Heat Transfer Systems in LMFBR's" International Conference on Engineering of Fast Reactors for Safe and Reliable Operation, Karlsruhe, Germany, October 1972.

"Safety Criteria and Design for an FBR Demonstration Plant," ASME Nuclear Engineering Conference at Palo Alto, Calif., March 1971.

"Evaluation of Thermocouples for Detecting Fuel Assembly Blockage in LMFBR's," American Nuclear Society Annual Meeting, Los Angeles, California, June 1970.

"A Mathematical Model Describing the Static and Dynamic Instability of the SRE Core II," Reactor Kinetics and Control, AEC Symposium Series 2. (Also published as NAA-SR-8431.)

"Reactivity Calculations and Measurements at the SRE," ANS Topical Meeting: Nuclear Performance of Power-Reactor Cores, September 1963.

"Measurement of Dynamic Temperature Coefficients by Forced Oscillations in Coolant Flow," Trans-American Nuclear Society 5, No. 1, June 1962.

"Analysis of Power Ramp Measurements
with an Analog Computer," Trans-
American Nuclear Society 5, No. 1,
June 1962.

"Reflected Reactor Kinetics,"
NAA-SR-7263.

Many other reports covering analytical
and experimental work.

MICHAEL J. ROSS

Business Address: Metropolitan Edison Company
Three Mile Island Nuclear Station
P.O. Box 480
Middletown, Pennsylvania 17057

Education: U.S. Navy Nuclear Power School, 1961. U.S.
Navy Nuclear Power Prototype School, 1961.

Experience: Supervisor of Operations, Three Mile Island
Unit 1, Metropolitan Edison Company, 1978
to present. Responsible for directing the
day-to-day operation of the plant to ensure
compliance with the conditions of the plant
operating license and technical spe-
cifications, including supervision of the
Radioactive Waste Processing and Shipment
Group and coordination of operations and
related maintenance activities with the
Superintendent of Maintenance.

Shift Supervisor, Three Mile Island Unit 1,
Metropolitan Edison Company, 1972 to 1978.
Responsible for the management of all
operations and maintenance activities,
including the manipulation of any controls,
equipment or components in physical plant
systems on his shift.

Shift Foreman, Three Mile Island Unit 1,
Metropolitan Edison Company, 1970 to 1972.
Responsible for performance of various
pre-operational activities, including
preparation of procedures and start-up
equipment checks.

Reactor Plant Technician, Saxton Nuclear
Experimental Corporation, 1968 to 1970.
Held position of reactor operator; addi-
tionally, was responsible for training
operations staff.

U.S. Navy, 1960 to 1968. Positions held include reactor operator aboard USS Haddo, Instructor at the Nuclear Power Training Unit, and AEC Field Representative at the Nuclear Power Training Unit

Professional
Affiliations:

Babcock & Wilcox Owner's Group, Fuel Handling Subcommittee.

ROBERT C. JONES, JR.

Business Address:

Babcock & Wilcox Company
Nuclear Power Generation Division
P.O. Box 1260
Lynchburg, Virginia 24505

Education:

B.S., Nuclear Engineering,
Pennsylvania State University, 1971.
Post Graduate Courses in Physics,
Lynchburg College.

Experience:

June 1971-June 1975: Engineer, ECCS
Analysis Unit, B&W. Performed both
large and small break ECCS analyses
under both the Interim Acceptance
Criteria and the present Acceptance
Criteria of 10 CFR 50.46 and Appendix
K.

June 1975-Present: Acting Supervisory
Engineer and Supervisory Engineer,
ECCS Analysis Unit, B&W. Responsible
for calculation of large and small
break ECCS evaluations, evaluations of
mass and energy releases to the
containment during a LOCA, and
performance of best estimate pretest
predictions of LOCA experiments as
part of the NRC Standard Problem
Program. Involved in the preparation
of operator guidelines for small-break
LOCA's and inadequate core cooling
mitigation.

1 MR. BAXTER: And I would note at this point in the
2 proceeding UCS Contention Number 7 and Sholly Contention 6B
3 have been withdrawn by those parties, but we will present
4 the testimony as originally filed with the Board.

5 I am going to have some questions on rebuttal now
6 to companion staff testimony filed on the Contentions.

7 From Mr. Lon B. Phillips there are two pieces of
8 testimony which we expect the staff to offer. One piece is
9 nine pages in length and was filed, to my memory,
10 approximately December 1, 1980. And the second piece of
11 testimony, which consists of five pages, was filed on
12 December 22. I assume they will be inserted into the record
13 in that order.

14 And I will refer to the larger piece of testimony
15 as Mr. Phillips' "first filing," and the shorter atestimony
16 as the "second filing."

17 BY MR. BAXTER: (Resuming)

18 Q Looking at the first piece of testimony filed by
19 Mr. Phillips, at page 3 he provides the following definition
20 of inadequate core cooling: "When the two-phase froth level
21 begins to drop below the top of the core, the exposed fuel
22 begins to heat up and will ultimately reach temperatures at
23 which fuel damage occurs. This is inadequate core
24 cooling."

25 Mr. Jones, giving us your understanding of that

1 definition, would you contrast it with the one presented in
2 your testimony and explain the basis for your explanation,
3 please?

4 A (WITNESS JONES) Well, first off, I have trouble
5 with the definition that Mr. Phillips has given, because it
6 is somewhat wrong in the sense that it makes the statement
7 that when the two-phase froth level begins to drop below the
8 top of the core and implies that ultimately reached
9 temperatures at which fuel damage occurs, that does not
10 necessarily have to occur.

11 If you keep the level up high in the core with the
12 steam cooling the rod relatively efficiently, you will not
13 reach fuel damage temperatures.

14 But even with that, I still have another problem
15 with it, in that really what is presented here, I am not
16 sure what he is using as a definition because there are two
17 definitions presented in my mind, reading this. The first
18 definition is: "Inadequate core cooling is when the
19 two-phase froth level begins to drop below the top of the
20 core." And you can interpret that to be the inadequate core
21 cooling definition that he is utilizing, or he may be using
22 the definition that where the two-phase froth level begins
23 to drop below the top of the core such that fuel damage
24 ultimately occurs, which would be indicative of the
25 temperature on the order of 1400 degrees on the cladding.

1 But irrespective of which definition he is using,
2 they are different from the one that we are using in this
3 proceeding and in our testimony. We have defined inadequate
4 core cooling basically based on the regulations as they
5 exist today. 10 CFR 50.46 defines what acceptable or
6 adequate core cooling is. That is, peak clad temperatures
7 less than 2200 degrees, along with several other conditions
8 that are implied within that criteria, in my mind, defines
9 what the regulatory basis is for inadequate core cooling.
10 That is, if you exceed those limits, you have inadequately
11 cooled the core. That is what we have used.

12 Now, there is some -- there has been some
13 interpretation or there has been some differences, apparent
14 differences, noted between our definition of inadequate core
15 cooling used in the testimony and the so-called "inadequate
16 core cooling guidelines," because the inadequate core
17 cooling guidelines themselves take action below the 10 CFR
18 50.46 threshold.

19 What has been done in developing those guidelines
20 is we related, or the thought process that went into it, was
21 if you have an event which leads to high cladding
22 temperatures beyond what you would normally calculate as a
23 design basis, you know you have something that is beyond the
24 design basis event happening. And the effort of the
25 guideline is to try to prevent and provide cooling to the

1 core prior to the cladding temperatures reaching the
2 so-called inadequate core cooling limit of 2200 degrees.

3 CHAIRMAN SMITH: When you say "we," Mr. Jones, you
4 are referring to your employer?

5 WITNESS JONES: Yes.

6 BY MR. BAXTER: (Resuming)

7 Q Turning now --

8 DR. JORDAN: I guess, Mr. Jones, I really did not
9 understand that last statement. And I guess I just have to
10 ask you to elaborate a little bit. I understood the words,
11 but I do not catch the implications.

12 WITNESS JONES: Okay. Well, it does not make sense
13 in my mind to put together a procedure that waits to do
14 something when the cladding temperature has reached the
15 so-called inadequate core cooling threshold that is defined
16 in the regulations. So the procedure has been developed to
17 take actions where the event is beyond what you would
18 normally have calculated the event to progress, any
19 small-break LOCA.

20 For example, the normal design basis calculations
21 performed for the plant to show compliance with 50.46 show
22 peak cladding temperatures on the order of 1100 degrees for
23 a small-break LOCA.

24 DR. JORDAN: For a small-break LOCA.

25 WITNESS JONES: For a small-break LOCA.

1 DR. JORDAN: But that is not inadequate core
2 cooling.

3 WITNESS JONES: That is correct. Now, the
4 inadequate core cooling guidelines take actions -- start to
5 take actions when you have in-core thermocouple readings
6 which are indicative of a cladding temperature of
7 approximately 1400 degrees.

8 DR. JORDAN: What guidelines do this?

9 WITNESS JONES: These are the inadequate core
10 cooling guidelines.

11 DR. JORDAN: Whose?

12 WITNESS JONES: These are the ones that have been
13 developed by BEW and submitted to Licensees for their
14 utilization in the development of procedures.

15 DR. JORDAN: These are the guidelines for dealing
16 with a small-break LOCA?

17 WITNESS JONES: These are guidelines for dealing
18 with an inadequate core cooling situation, basically,
19 irregardless or irrespective of how you got to it. What we
20 are saying is we do not know of any condition on normal
21 from, let's say, the secondary side of that which leads you
22 to core uncover. It should not occur. But you could use
23 the guidelines should something happen that somehow the
24 event should progress to that.

25 But they are mainly coupled to the small-break LOCA

1 procedure for their general use.

2 DR. JORDAN: But I guess -- what is the
3 significance of 1400? Are you saying that the guidelines
4 themselves say that if the temperature is below 1400 then no
5 action is required, but if it is above 1400 there is action
6 required?

7 WITNESS JONES: That is correct.

8 DR. JORDAN: But that means you know when you have
9 reached 1400.

10 WITNESS JONES: Yes. And what the guideline -- the
11 way the guideline is constructed is, first off, there is an
12 alert or something to alert the operator that the core is
13 starting to uncover, which are superheated temperature
14 indications on either the hot leg RTEs or the in-core
15 thermocouples.

16 DR. JORDAN: Are you saying that before 1400 is
17 reached or by the time 1400 is reached, the hot leg
18 thermocouple will start to read above normal and is that --
19 at that time is it only starting to read above normal?

20 WITNESS JONES: No. We would expect a hot leg
21 thermocouple to respond faster than that. But there are
22 also the in-core thermocouples which will respond even
23 faster than the hot leg RTEs. We have made use of both as
24 an alert statement for the operator to place him out of the
25 normal small-break procedure and into the inadequate core

1 cooling procedure or guidelines. Now --

2 DR. JORDAN: Let's see. Are there 50-some in-core
3 thermocouples? Do I remember properly, Mr. Keaten?

4 WITNESS KEATEN: There are 52.

5 DR. JORDAN: 52. And would you review for me where
6 those are located? I know they are located around the
7 various quadrants, but what actual elevations are those?

8 WITNESS KEATEN: They are located just above the
9 top of the active core.

10 DR. JORDAN: Top of the active core, but below the
11 grid plates and below the rods -- let's see -- above the
12 active uranium pellets there is a space with springs and
13 things like that; isn't that true? And are the
14 thermocouples then located about where the active pellets
15 end?

16 WITNESS ROSS: Our understanding is the
17 thermocouple itself is approximately five inches above the
18 active portion of the core.

19 DR. JORDAN: And by that you mean the uranium oxide
20 pellets?

21 WITNESS ROSS: That is correct.

22 DR. JORDAN: All right.

23 WITNESS JONES: Now, I forgot where I was.

24 DR. JORDAN: I am sorry.

25 WITNESS JONES: So we have gotten to the inadequate

1 core cooling guidelines by getting superheated temperature
2 indications either by the in-core temperature, in-core
3 thermocouples, or by the hot leg RTEs. That puts them into
4 the inadequate core cooling procedure.

5 At that point in time, the operator is to
6 continuously monitor the in-core thermocouple reading. And
7 as there is a curve that has been developed to correlate the
8 in-core temperature readings, in-core thermocouple
9 temperatures to cladding temperatures --

10 DR. JORDAN: I did not get that.

11 WITNESS JONES: The in-core thermocouples will
12 measure -- will not know the temperature of the fuel rod.
13 It measures the temperature of the steam that is coming off
14 the fuel rod. So we have developed a correlation between
15 the steam temperature and the maximum fuel rod temperature
16 and have developed a curve as a function of pressure, which
17 is built into the procedure.

18 DR. JORDAN: Doesn't that correlation depend upon
19 the rate of flow of the steam?

20 (Pause.)

21 WITNESS JONES: Yes, it does. But what you have is
22 a cool boiling situation in the covered portion of the rods,
23 which is essentially determining the steam flow rate coming
24 up, and then that flow goes up and it is superheated by the
25 heat transfer from the rod to the steam. And it

1 superheats.

2 Now, if the decay heat is down, then you have a
3 lower flow rate. But then again you get lower -- you don't
4 need as much flow, because the uncovered portion of the rods
5 also have less heat to remove.

6 DR. JORDAN: I see. So that you say there is a
7 good correlation between the reading of the thermocouple in
8 the steam which is being bathed in steam flowing by it from
9 the heating -- steam being heated from the lower end of the
10 core -- there is a good correlation between the temperature
11 of that steam and the temperature of the cladding
12 immediately adjacent, or the cladding where?

13 WITNESS JONES: It is the peak cladding temperature
14 on the rod. Now, what has been done, in actuality, we have
15 looked at various potential power -- axial flux shapes
16 within the core and have studied them. And in order to make
17 sure that the curve that we generate will bound the more or
18 less a spectrum of power distributions within the core. And
19 we put a number bound around it. And the design basis power
20 shape that is used for LOCA analysis is also the same one
21 that yields the curve which bounds the thermocouple
22 temperatures.

23 DR. JORDAN: I see.

24 Mr. Baxter, I am sorry.

25 MR. BAXTER: That's all right. I wanted to ask one

1 housekeeping question, if I might.

2 BY MR. BAXTER: (Resuming)

3 Q Mr. Jones, is this correlation between cladding
4 temperature and reactor coolant pressure-temperature
5 conditions reported in the document "Analysis Summary in
6 Support of Inadequate Core Cooling Guidelines for a Loss of
7 RCS Inventory" in attachment to question 45, supplement 1,
8 part 1, of Licensee's Restart Report, which is exhibit --
9 Licensee's Exhibit 1?

10 A (WITNESS JONES) Yes, it is.

11 DR. JORDAN: I see. All right. Thank you. We may
12 want to come back. I don't really go into any detail now,
13 Mr. Baxter. I was trying to understand what he was saying.
14 So you can go ahead.

15 MR. BAXTER: I appreciate the difficulty of
16 listening to this orally, and I welcome your questions as we
17 go along.

18 BY MR. BAXTER: (Resuming)

19 Q Turning to Mr. Phillips' second piece of testimony,
20 the one filed on December 22, at page 2 of that testimony,
21 Mr. Phillips criticizes reliance upon the saturation meter,
22 because it does not distinguish between anomalous transients
23 which can drain the pressurizer and cause primary loop
24 saturation due to cooling, and shrinking of coolant versus a
25 loss of coolant inventory which could lead to inadequate

1 core cooling. It is the first paragraph in the answer to 22
2 on page 2.

3 MR. CUTCHIN: Mr. Chairman, for clarity, is Mr.
4 Baxter now referring to the supplementary testimony of Mr.
5 Phillips that is labeled "Question 1F and Question 2F"?

6 MR. BAXTER: That is correct.

7 MR. CUTCHIN: That was filed on January 16, and
8 that is the document with which I provided the Board copies
9 yesterday afternoon.

10 MR. BAXTER: I am sorry, I have my dates confused.

11 CHAIRMAN SMITH: So we have three Phillips'
12 testimonies?

13 MR. BAXTER: No, we don't. We just have two. I
14 was mistaken about December 22.

15 DR. JORDAN: Two Phillips and one Rubin testimony.

16 MR. CUTCHIN: That is correct, sir, two Phillips
17 and one Mr. Rubin. Mr. Baxter correctly identified the
18 filing date of the first Phillips, which was December 1.
19 And the second Phillips is the document with which I
20 provided the Board copies after we closed the record
21 yesterday.

22 MR. BAXTER: I will refer to that as the
23 "supplementary testimony."

24 DR. JORDAN: All right. Now, identify again then
25 where we are.

1 MR. BAXTER: I am in the supplementary testimony,
2 page 2, the first paragraph, the answer to the second
3 question.

4 DR. JORDAN: At the end of the second question.
5 All right.

6 MR. BAXTER: The first paragraph of the answer.

7 CHAIRMAN SMITH: What are the first words of that?

8 MR. BAXTER: "The saturation meter, while providing
9 a basis for initial actions," it is the second sentence.
10 That is the sentence I am looking at.

11 DR. JORDAN: All right.

12 CHAIRMAN SMITH: Now I have a document entitled
13 "NRC Staff Testimony of Laurence Phillips," which was
14 received -- undated -- which was received by our office
15 December 2, 1980. Then I have a document entitled "NRC
16 Staff Testimony of Lawrence Philliips, Supplementary
17 Testimony to that of Laurence E. Phillips," filed December
18 1." And that is also undated. That is the one I received
19 last night.

20 MR. BAXTER: That is correct. My first question to
21 Mr. Jones went to the first piece you identified. The one I
22 am about to ask goes to the second.

23 CHAIRMAN SMITH: I cannot find that sentence.

24 MR. BAXTER: It is on page 2 in the answer to
25 question 2F.

1 CHAIRMAN SMITH: All right. Go ahead.

2 BY MR. BAXTER: (Resuming)

3 Q Let me start over. Mr. Phillips has criticized a
4 reliance upon the saturation meter, because it does not
5 distinguish between anomalous transients which can drain the
6 pressurizer and cause primary loop saturation due to cooling
7 and shrinkage of primary coolant, versus a loss of coolant
8 inventory which could lead to inadequate core cooling.

9 Now, to further confuse you I am going to be
10 referring to an answer to our interrogatories, if you have
11 those available. In explanation of why the operator needs
12 to distinguish between these transients, Mr. Phillips stated
13 in response to Licensee's interrogatory number 1, dated
14 January 14 - the answer dated January 14, 1981, that for an
15 anomalous overcooling transient, the operator should
16 determine the cause of the overcooling and correct it.

17 Mr. Jones, in such a situation, what is the
18 operator's first priority?

19 A (WITNESS JONES) The first priority of the operator
20 is to initially control the transient and assure adequate
21 core cooling.

22 Q Does he need to know that there is an overcooling
23 event in order to accomplish that goal?

24 A (WITNESS JONES) No. He really does not. And the
25 reason for that is if you have an overcooling transient

1 which causes you to drain the pressurizer and get to
2 saturation, you have a situation where you do not want to
3 be. The operator's function at that time, whether it is a
4 LOCA or an overcooling transient, is to restore primary
5 system inventory and pressure by using the high-pressure
6 injection pumps, the emergency core cooling systems, and
7 that there is no need to know what the event is in order to
8 do that.

9 If you saturate it in the primary loops, you have a
10 situation -- it is just a situation where you do not want
11 the plant to be in, and your goal is to provide the
12 inventory to assure or to restore the subcooled margin in
13 the plant.

14 Q When does the operator need to diagnose and correct
15 the overcooling event, and how would he do it without vessel
16 level indication?

17 A (WITNESS JONES) Well, first off, you do not really
18 go and diagnose an overcooling event from a primary system
19 parameter. You diagnose an overcooling event by looking at
20 the secondary side: Do you have too much water, do you have
21 too low a steam pressure in the steam generator? Those are
22 the distinguishing characteristics of an overcooling
23 transient.

24 In order to overcool, you have to be taking out too
25 much heat, and it would be reflected within the steam

1 generator parameters.

2 Now, as far as when he needs to do this, basically
3 he has a few items he would want to try to prevent
4 happening. First is to prevent an overfilling of the steam
5 generator so that water flows into the steam lines. That is
6 an indication he could only tell about how fast it is going
7 by looking at the secondary side water level barometer.

8 If he had a steam line break, for example, he would
9 want to assure that the broken steam line is isolated; that
10 is, that the automatic system functions to stop delivering
11 auxiliary feedwater or main feedwater to the broken steam
12 generator. Again, that is strictly a secondary side-type
13 diagnosis.

14 The only other indication -- or the only other
15 goals he might have that would rely on primary system
16 indication would be to not fill up the pressurizer and put
17 water on the floor for an overcooling transient, where you
18 put in so much water that he has filled the pressurizer and
19 he now has water exiting the system from the -- through one
20 of the relief valves.

21 Now, that can be done without a level indicator on
22 the vessel, by looking at the subcooling margin in the plant
23 and the pressurizer level. And again, the action is one
24 that is covered within both the small-break guidelines and
25 the inadequate -- and an overcooling-type transient

1 diagnostic.

2 He would be allowed to throttle HPI, provided you
3 have subcooled indication in the hot leg and the pressurizer
4 water level approaching or tending to go high -- towards
5 high and possible filling of the pressurizer. Then he could
6 take that action without knowing whether it is an
7 overcooling event or a small-break LOCA.

8 Q Returning again to Mr. Phillips' supplementary
9 testimony at page 2, this time moving onto the second
10 paragraph, he states that TMI-1 emergency procedure 1202-6B
11 requires the operator to distinguish between an overcooling
12 event and a small-break LOCA.

13 Mr. Ross, when in the procedure or scenario is
14 diagnosis required?

15 A (WITNESS ROSS) Our procedures call for that
16 diagnosis at approximately step seven under the immediate
17 action. The actions preceding that are the actions Mr.
18 Jones has discussed, basically verifying the reactor in fact
19 had tripped, verifying that if high-pressure injection is
20 initiated, we do have proper flows, if necessary, and
21 high-pressure injection has initiated automatically,
22 tripping reactor coolant pumps, isolating any obvious leaks,
23 ensuring we have emergency feedwater.

24 At that point, the operator is given directions to
25 evaluate this accident for an overcooling. He is also given

1 the parameters to look at, those being the parameters that
2 Mr. Jones has discussed, those being feedwater flow, steam
3 pressure, steam generator levels.

4 Q Mr. Ross, do you agree with the observation Mr.
5 Phillips makes at the bottom of the page that vessel level
6 instrumentation would permit a much quicker and more
7 reliable diagnosis of these transients, the transients being
8 overcooling and loss-of-coolant accident?

9 A (WITNESS ROSS) No, I do not.

10 A (WITNESS JONES) I would like to add a little
11 something to that answer, if I could. One of the things --
12 one of the problems with using a water level indicator to
13 distinguish between an overcooling event and a small-break
14 LOCA of each of the transients have very wide-ranging
15 potential impacts on the primary system, depending on the
16 nature of the overcooling event, for example, or the size of
17 the small-break LOCA.

18 If you had, for example, a very small LOCA in the
19 system, the primary system will remain liquid solid for a
20 fairly long period of time or could remain liquid solid for
21 several minutes, five-ten minutes, depending on the size of
22 the break. So you could not use the fact that, "Well, my
23 level has not dropped any," to say, "Ah-hah, I do not have a
24 small-break LOCA," when in fact you might.

25 Additionally, if you have an overcooling event, you

1 can end up, if it is a very rapid overcooling event with the
2 potential of pulling a steam bubble within the reactor
3 vessel head region. And a small-break LOCA ultimately and
4 for the larger size small-break LOCAs, it will occur very
5 quickly, will also lead to steam bubble formation in the
6 reactor vessel upper head. So you cannot distinguish it
7 from that, you know, not strictly just off a level
8 relationship or the fact that a level has dropped.

9 And finally, just an example of how it could be
10 confusing to an operator, if you just take the St. Lucie
11 event which occurred, where they pulled a bubble in the
12 upper vessel head during a natural circulation cooldown of
13 the plant, and that was not a LOCA situation. And yet, if
14 they had a vessel level instrumentation -- instrument
15 installed, if the operator was instructed to diagnose a LOCA
16 based on level indicator, he would have then been
17 considering St. Lucie to be a LOCA event when in fact it was
18 not.

19 CHAIRMAN SMITH: Of course, we would assume that
20 the operator would be aware of bubbles. I mean your
21 operators do know about bubbles; don't they?

22 WITNESS ROSS: Yes, our operators do know about
23 bubbles. As we have previously testified, they have been
24 trained in the way the bubble reacted in Unit 2. And in
25 particular, they have been trained in the St. Lucie incident

1 itself. That training consisted of a couple of ways the
2 first was immediate notification of the I&E bulletin of St.
3 Lucie, and then later sit-down sessions in the classroom
4 were instituted on the St. Lucie bubble and what the
5 indications were that that staff saw.

6 So I would answer, "Yes," they have been trained in
7 that particular incident and bubble-type incidents.

8 DR. JORDAN: You are saying now that the operator
9 would recognize a bubble in the upper head, that the
10 procedures include ways of recognizing and diagnosing a
11 bubble. Could you point to the procedure that does that?

12 WITNESS ROSS: In particular, the St. Lucie
13 incident involved a natural circulation cooldown, and that
14 particular procedure has been changed in two steps. The
15 first step is to put the cautions in. And I can give you
16 the number. I will have to look it up, to tell you the
17 truth, though. Put the cautions in on what St. Lucie saw.

18 A final version of that is coming up based on the
19 B&W guidelines instituted on natural circulation cooldown,
20 and it's expected to be through our final review chain very
21 shortly.

22 MR. BAXTER: We will come back to St. Lucie again
23 in a few minutes.

24 DR. JORDAN: All right.

25 BY MR. BAXTER: (Resuming)

1 Q Looking at the sentence at the bottom, that begins
2 at the bottom and runs over -- bottom of page 2 and runs
3 over to the top of page 3 of Mr. Phillips' supplementary
4 testimony, he states that: "For a small-break LOCA, an
5 orderly cooldown is required, but not necessarily for an
6 overcooling transient."

7 Mr. Keaten, do you agree with this observation?

8 A (WITNESS KEATEN) No, I do not. And I do not
9 really understand what Mr. Phillips is driving at here. If
10 we define an overcooling transient in an analogous way to
11 the way that we define a small-break LOCA as being outside
12 the normal behavior of the plant, and then following any
13 such overcooling behavior there is no question but what the
14 plant would have to be shut down and remain shut down for a
15 period of time while we evaluated the transient, and we did
16 the necessary notifications to the NRC and where we assured
17 ourselves that the plant was not damaged prior to the time
18 of restart.

19 So whether it is a small LOCA, whether it is an
20 overcooling transient, or whether it is any other type of
21 unexpected plant upset, there is no question but what the
22 plant has to be shut down.

23 DR. JORDAN: May I ask now for a definition. I
24 understand that your definition of inadequate cooling
25 disagrees with that of the staff. But now then, an

1 overcooling event, do you also disagree with the staff as to
2 what is meant by that? And are you saying that every
3 overcooling event, according to your definition, requires
4 shutdown?

5 WITNESS KEATEN: We are defining an overcooling
6 event, Dr. Jordan, as being something that is outside of the
7 normal expected response of the plant to a transient. I
8 honestly do not know what the staff means by their
9 definition. So I don't know whether there is a disagreement
10 or not.

11 But we would not define an overcooling event as the
12 type of small cooldown that we normally expect to get, for
13 example, when the reactor trips. We would define it as an
14 overcooling event only if it is outside of the normal
15 expected behavior of the plant.

16 And your point is anytime we get this type of
17 deviation from normal behavior, there is no question in my
18 mind but what they have to shut down the plant and do an
19 evaluation prior to restart.

20 DR. JORDAN: Okay. So any overcooling -- well, how
21 do you recognize an overcooling event? As a lack of
22 pressurizer level?

23 WITNESS KEATEN: Well, you look at it in two
24 different ways. From the standpoint of the immediate
25 operator response, what he will see is the behavior of the

1 primary cooling system, and he will see a drop in level in
2 the pressurizer, and he will see a decrease in the reactor
3 coolant system pressure.

4 And as Mr. Jones was saying, at that point in time,
5 he will not know, and he does not need to know, whether he
6 has an overcooling transient or whether he has a LOCA,
7 because the actions, both the automatic and the manual
8 actions, are exactly the same in terms of the ones that need
9 to be taken immediately. And that is to automatically or
10 manually initiate the high-pressure injection system and
11 make sure it is working.

12 DR. JORDAN: But you said before that although he
13 has a drop in pressure -- in pressurizer level -- and a drop
14 in temperature, as long as it is within -- inside of the
15 normal events, then this is not an overcooling event. And
16 so he has to look around and say, "Now, is this part of a
17 normal event, or is this an abnormal event?" And how does
18 he know?

19 WITNESS KEATEN: He knows by the extent of the
20 changes which occur. If it is -- if it is what I would call
21 a "normal" overcooling event, the type of small cooldown
22 that occurs associated with a reactor trip, he will get some
23 drop in the pressurizer level, he will get some decrease in
24 the reactor coolant system pressure but not enough to
25 initiate the high-pressure injection.

1 And what the operator normally does in that case is
2 to stop his letdown flow, and he may increase somewhat his
3 makeup flow, but he still is running with the normal makeup
4 letdown system. He is not relying on the emergency core
5 cooling system at that point.

6 If it is a major overcooling event, then he will
7 get a much more substantial drop in the level in the
8 pressurizer and a much more substantial decrease in the
9 reactor coolant system pressure. And he may in fact get an
10 automatic initiation of the high-pressure injection. And
11 this in fact has occurred at TMI.

12 DR. JORDAN: If he gets an ECCS signal, does that
13 mean the reactor has to be shut down, taken cold?

14 WITNESS KEATEN: Yes, sir. I would say in the
15 environment we are living in today, any time that we get an
16 automatic initiation of the emergency core cooling system,
17 we are facing a very careful evaluation of what happened
18 prior to the time we restart.

19 DR. JORDAN: Okay. Thank you.

20 BY MR. BAXTER: (Resuming)

21 Q Mr. Keaten, I am not sure we got your Dr. Jordan's
22 question. How does he diagnose the overcooling event from
23 the secondary side?

24 A (WITNESS KEATEN) Yes, I am sorry. I answered only
25 the first part of the question.

1 Once -- and again, I am talking about a significant
2 overcooling event, and let me define it for the moment as
3 one which results in automatic initiation of the emergency
4 core cooling system. Once he has assured himself that the
5 necessary immediate actions that must be taken, such as the
6 fact that the high-pressure injection pumps have started,
7 that he has the flow rate that he has required, that he has
8 manually tripped the reactor coolant pumps as the procedures
9 require him to, and has done those immediate actions
10 necessary to protect the core, then, as Mr. Ross said, the
11 procedures instruct him to then try to distinguish between
12 whether he has a LOCA or an overcooling event.

13 And he does this not by looking at the primary
14 system parameters, which will not help him, but by looking
15 at the secondary system parameters, the flow rate, the steam
16 generator level, and the steam pressure.

17 Q Continuing at the top of page 3 of Mr. Phillips'
18 supplementary testimony, he states that: "In both cases --
19 that is, an overcooling event or loss-of-coolant accident --
20 vessel level meter, if available, would provide coordinating
21 information to assist the operator in restoring the water
22 solid primary system (possibly using the upper head vent)
23 and the normal water level in the pressurizer."

24 Mr. Keaten, what coordinating information might be
25 provided, and how would the operator use it?

1 A (WITNESS KEATEN) We have not to date been able to
2 identify how this type of information could be used to help
3 the operator, even if it were available.

4 As Mr. Jones pointed out, the actions that the
5 operator needs to take under a normal loss-of-coolant
6 condition or an overcooling event are relatively simple and
7 are easily performed using the existing instrumentation.
8 Even in the case where an event develops which is beyond the
9 design basis, which is not a normal loss-of-coolant accident
10 but it is something else, B&W has developed the inadequate
11 core cooling guidelines which apply to this case. And the
12 operator is instructed to take action based upon the
13 readings of the in-core thermocouples, coupled with the
14 saturation meter and the other installed instrumentation.

15 As Mr. Jones also pointed out, even if there were a
16 reliable method of measuring the reactor vessel water level
17 and such instrumentation were installed, we have not been
18 able to find any use that the operator could make of that
19 information.

20 Frankly, our objection to installing such
21 instrumentation is based upon that fact. In the testimony
22 that you have been hearing on the previous Contention having
23 to do with the human-engineering review of the control room,
24 in carrying out that human-engineering review, one of the
25 guidelines which was suggested to us by our expert

1 consultants in human-factors engineering was that the
2 information which is presented to the operator should be
3 restricted to the information that he will use, and that if
4 used in general terms it is a violation of the
5 human-engineering principles to present him information that
6 he is not going to be able to use, because it tends to
7 overload him and it gets him thinking about things that he
8 is not going to use rather than thinking about those things
9 that he can use.

10 And so in a situation like this, where we have
11 information that somebody has suggested that might be of use
12 but where we cannot find any use for it, then we are very
13 reluctant to say that this is something that ought to be
14 installed in the control room and presented to the operator
15 in a fashion that may distract him from looking at the
16 things that he should be looking at and that he does know
17 how to use.

18 So our reluctance to install such instrumentation
19 even it were available, it is based on the fact that we want
20 our operators to concentrate on the things that they have to
21 do in responding to these events and to concentrate on the
22 instrumentation that we have taught them to use in order to
23 determine what actions need to be taken.

24 CHAIRMAN SMITH: Mr. Keaten, in that answer you
25 began by saying, as you concluded, that you did not know

1 what use could be made of the level meter. Then you
2 explained that the procedures in place do not rely upon it.
3 And then you came back to, again, you do not know what use
4 could be made of it and you do not want useless
5 information.

6 But I do not know if you made it clear that you
7 have looked at established procedures to see if they would
8 fit in or if you have begun a new -- a new conceptual look
9 at emergency procedures to see if a redesign of the
10 procedures could make use of the water level indicator.

11 MR. BAXTER: Mr. Smith, that was going to be one of
12 my questions. Let me ask it now, if I might.

13 CHAIRMAN SMITH: The reason I ask it now is I did
14 not understand if this question included that or didn't.
15 The emphasis seemed to be on established procedures, and
16 they do not fit in. But that is fine. Clarify it anyway.

17 BY MR. BAXTER: (Resuming)

18 Q At page 4 of his testimony Mr. Phillips make the
19 assertion that Licensee has not submitted any analyses or
20 evaluation addressing additional operator actions which
21 could be taken to prevent core uncovering for small-break
22 LOCAs, if information were available for prompt diagnosis of
23 the condition."

24 Would you review for us what analyses and
25 evaluation Licensee or B&W has submitted to the staff on

1 this issue? Mr Jones or Mr. Keaten?

2 A (WITNESS JONES) Let me start out first -- go back
3 to the original creation of the guidelines. Back around
4 last May, of 1979, the small-break guidelines were
5 developed. Various revisions were made to those guidelines
6 over the next several months to incorporate things like
7 reactor coolant pump trip and other items that developed as
8 we took a closer and closer look at these guidelines and
9 tailored them to be more plant-specific.

10 Around November of 1979 the inadequate core cooling
11 guidelines were developed based on existing instrumentation
12 as required by 0578. But there was also another part of
13 0578 which said to look for additional instrumentation that
14 could be utilized for the detection of inadequate core
15 cooling, et cetera.

16 A review was performed first of other concepts of
17 instrumentation to try to see if we could identify anything
18 which would be more useful than the core exit thermocouples,
19 the in-core thermocouples, and we could not find any.

20 DR. JORDAN: By "existing instrumentation," do you
21 mean the in-core thermocouples? Do you also include the
22 saturation meter and the hot leg exit thermocouples?

23 WITNESS JONES: Yes. The core exit thermocouple --
24 the in-core thermocouples, I probably used both terms as I
25 go through here. The hot leg RTDs, the t-sat meter, all of

1 those are --

2 DR. JORDAN: By "existing," you mean those things?

3 WITNESS JONES: Yes.

4 DR. JORDAN: All right.

5 WITNESS JONES: Now, we could not find any
6 instrument that would be worthwhile. But we had basically
7 been directed to look at use of core water level
8 instrumentation. And we examined that issue. We found,
9 first off, that we could not find any instrumentation that
10 was unambiguous or easy to interpret, which was one of the
11 guidelines for selection of an instrument.

12 CHAIRMAN SMITH: You mean available on the market?

13 WITNESS JONES: And even some of the concepts that
14 had come up over the last year. We still have not found
15 anything that has been proven to be worthwhile.

16 And additionally, we did take a look at the
17 existing guidelines to see how possibly could a core water
18 level indication modify those procedures? And we really
19 could not find anything that we would want to change or add
20 as a result of having core water level instrumentation
21 available.

22 And in fact, there was a lot of concern that
23 putting a core water level instrument in was unsafe. For
24 example, let's take the situation which is a break in the
25 primary system somewhere, say, in the top of the

1 pressurizer, similar to TMI. You get an indication that the
2 pressurizer fills up. Okay.

3 You then turn around and you look at your core
4 water level indication and remember the core is way down in
5 the system relative to the overall system arrangement. So
6 that level will not even change significantly for quite some
7 time until you essentially drain the entire primary system.

8 And what happens -- so the operator will see I have
9 my water level going up in the pressurizer, I have a
10 constant water level in the core, gee, maybe I ought to
11 gravel my HPI so I do not put water out on the floor through
12 the pressurizer relief valve because that is not a desirable
13 thing to do.

14 And if an operator would do that, that would lead
15 you exactly to a TMI-type scenario, because the HPI pumps
16 are not designed to function at -- here is the core starting
17 to uncover now and they will quickly recover the core. That
18 was never their design purpose.

19 The HPI works by providing an integrated makeup
20 flow to the primary system to help delay the drainage of
21 water from the primary coolant loops, such that the time
22 span that additional water delays the time to the water
23 levels dropping toward the top of the core to a time when
24 the HPI pump is now capable in and of itself to match up
25 with the core boil-off and initiate a refill of the reactor

1 coolant system and core.

2 And that does not occur for 30 or 40 minutes in
3 many of the small-break transients. In 30 to 40 minutes of
4 HPI flow, it is something on the order of 15,000 gallons of
5 water. That is a substantial amount of water, and the loss
6 of that water could mean the difference between the core
7 being covered and being adequately cooled to not being
8 adequately cooled.

9 DR. JORDAN: It seems to me that your definition
10 then of a level meter must be at variance with the staff's,
11 because you are saying the level meter should measure only
12 to the top of the core. And surely, in reading the staff's
13 testimony, I must conclude that their meter goes up into the
14 head, so that they could detect approach to a loss of
15 cooling before it happens.

16 That was one of the major advantages that they
17 saw. And are you saying that you have not thought about the
18 possibility of a meter that measures the level clear up to
19 the top of the head?

20 WITNESS JONES: No. I am considering either one
21 within the core region itself or one that spans the entire
22 span of the reactor vessel or even limited from the top of
23 the core to the head of the reactor vessel.

24 And to point out the problem I have, if you can
25 turn to page 4 of Mr. Phillips' supplementary testimony, at

1 the last -- actually, the whole second paragraph is dealing
2 with the St. Lucie event, and he goes on to finish up with
3 the last sentence, which was: "Additionally, vessel level
4 indication would provide a safe bases for manual shutoff of
5 HPI to avoid overflow to the containment."

6 Now, in looking at the St. Lucie event -- and I
7 assume in reading this he is talking about the St. Lucie
8 event being in the same paragraph -- you now have a
9 situation where you would have a bubble indication in the
10 primary system within the core, you have a void in the upper
11 head. You have pressurizer level rising, which is what
12 happened at St. Lucie, and this to me indicates using those
13 -- that type of instrumentation that maybe we could shut off
14 the HPI to avoid the overflow of liquid to the containment.
15 And that is exactly the wrong thing to do.

16 DR. JORDAN: Wouldn't the meters, if there was a
17 bubble up there, wouldn't it show that the level of the
18 water is only up to here and above that it is a bubble, not
19 water?

20 WITNESS JONES: But, again, taking this in context
21 with the St. Lucie event, which is what he is doing -- that
22 is the way I read that -- he has a bubble in the head. And
23 so what I am interpreting him to be saying is: I have a
24 bubble in the vessel head, and that while I am
25 depressurizing, you know, I am getting level swings in the

1 pressurizer, and that may be the way to prevent me from
2 overflowing the system and putting water on the floor is to
3 throttle back on the HPI, based on the fact that I know I
4 have a bubble in the head, but yet I have the core covered.

5 You see, my fear is not that you know you have a
6 bubble, my fear is now you know that the core is covered
7 because you measured the head region and there was water
8 there, or you measured the entire span of the reactor vessel
9 and it says there is water 17 feet in the air, which means
10 maybe you have five feet over the top of the core. So you
11 say, "Ah-hah, my core is covered, and so therefore I can
12 shut back on my HPI," when in fact you may lose that
13 accumulated benefit of HPI which is very important to you.

14 And taking those type of factors into account, I am
15 not even sure the use of vessel meter level is a safe thing
16 to do.

17 I would prefer the operator strictly rely upon the
18 primary system temperature indications, subcooled or
19 saturated, to determine whether or not to throttle HPI.

20 CHAIRMAN SMITH: Is that last conclusion a general
21 conclusion, or is it based upon the statement to avoid
22 overflow into the containment is not necessarily a desirable
23 goal?

24 WITNESS JONES: Well, I agree with the goal to
25 avoid overflowing water into the containment.

1 CHAIRMAN SMITH: Is that a safety goal or an
2 industrial goal?

3 WITNESS JONES: I would say it is more of an
4 industrial goal. My own personal feeling, from a safety
5 standpoint, I do not care; they can throw all the water
6 through the pressurizer relief valve they want to keep the
7 core covered, because that is the safe objective, to make
8 sure the core remains covered and does not become uncovered
9 and get damaged.

10 But obviously, from a commercial standpoint, you do
11 not really want to run your plant to where you start putting
12 water through the valves and putting water all over the
13 floor in the containment. That is not really a desirable
14 thing to do.

15 CHAIRMAN SMITH: My question was: Was your
16 conclusion that the level meter might be inconsistent with
17 safety? Was it based upon this particular analysis, or was
18 that a general conclusion, counting all of the factors you
19 have taken into account?

20 WITNESS JONES: I think taking all of the factors
21 into account, the fact that we have indicators should the
22 core become uncovered, which is the exit thermocouples of
23 the core, we have instrumentation that tells us that the
24 plant is in a configuration it should not be in, and that
25 you need to restore inventory -- that is, the saturation

1 meter or just the hot leg RTEs and pressure measurement to
2 tell if the fluid in the RCS is saturated -- and at that
3 point in time, that plant is not in a configuration it is
4 supposed to be in.

5 Your objective at that point in time is to restore
6 water and to inject all the water you can. You will get on
7 your safety systems and let them inject water and attempt to
8 return the system to a liquid solid condition. If you leave
9 the ECCS on, the emergency core cooling system, you will
10 keep the core covered throughout the event. If you leave
11 them on.

12 CHAIRMAN SMITH: Before we get too far away from
13 your earlier testimony, I have two clarifying questions. At
14 the very beginning of your most recent testimony, you have
15 indicated that you do not believe that the water level meter
16 would be better than the thermocouple -- in-core
17 thermocouples. And then you expand in-core thermocouples to
18 the other devices mentioned by Dr. Jordan.

19 Well, that to me is an ambiguous answer. I could
20 take it two ways. One is that we are not talking about
21 alternatives; we are not talking about water level meters
22 instead of thermocouples. Or you could be saying that if it
23 is not better than a thermocouple, then it is superfluous,
24 unnecessary, and it meets that standard that Mr. Keaten is
25 talking about, you don't want it, or whatever other

1 alternative.

2 But in any event, I believe it was ambiguous. You
3 said that one reason you do not favor water level meters is
4 that they are -- that in-core thermocouples are better.
5 That suggests that we are talking about either-or
6 alternatives. Or it could suggest that since they are not
7 better, they are superfluous and, therefore, undesirable
8 because of the reasons Mr. Keaten mentioned. Or it could be
9 an alternative I have not perceived. And I just wonder if
10 you could clarify.

11 WITNESS JONES: Well, actually, we believe, first,
12 it would be superfluous. And second -- and this is not in
13 order of priority -- we believe it is superfluous
14 information, and we do believe indeed that the in-core
15 thermocouples are better.

16 And just help illustrate at least the second
17 statement, let's say at I had a vessel water level
18 instrument that was there and it indicated the core was
19 uncovered. Now, the general types of instruments available
20 to -- available today is simply a DT instrument; that is, it
21 will essentially weigh the column of water in the system.
22 That is about all it can do. And you can infer from the
23 weight essentially where the collapsed or solid water level
24 is.

25 The problem with that is in the core you do not

1 have a solid water level, you have a two-phased mixture
2 within the core region. So in fact you may have a vessel
3 level indicator even when the transient is progressing
4 normally and safely that will say the core is partially
5 uncovered when, in fact, the two-phased mixture is indeed
6 above the top of the core and the core is being adequately
7 cooled.

8 That can be distinguished by thermocouple and not
9 the water level instrument. Additionally --

10 CHAIRMAN SMITH: I was not inquiring about the
11 basis for you believing that thermocouples are superior. I
12 was inquiring about the relevance of that comparison.

13 MR. BAXTER: Let me see if I understand. Is the
14 question, Mr. Smith: If in-core thermocouples and level
15 meters are equivalent alternatives and yet we say a level
16 meter is unneeded, then also we are thereby indicating that
17 perhaps the in-core thermocouples are unneeded?

18 CHAIRMAN SMITH: No. I am saying -- who has
19 suggested removing thermocouples? No one. What is the
20 relevance of the fact that thermocouples are better unless
21 they are superfluous and therefore mischievous?

22 WITNESS KEATEN: Let me give the answer. I think,
23 from all our viewpoints -- and Mr. Jones can talk about it
24 from the B&W standpoint -- I would also like to answer your
25 earlier question, Mr. Smith.

1 Certainly, in trying to evaluate whether water
2 level might be of use to us, we have not evaluated on the
3 assumption that if you put in a water level meter that you
4 would take out the in-core thermocouples or take out the
5 other instruments. But rather, we have tried to evaluate
6 how would we use it in addition to the instrumentation which
7 is already there.

8 In my earlier statement having to do with the fact
9 that we believe it is superfluous, I was not relying on the
10 fact that our present procedures do not call for water
11 level. Of course, they would not call for it, because we do
12 not have such a meter. But rather, I was referring not only
13 to the work which B&W has done, but to an evaluation which I
14 personally performed about a year ago, where I took the
15 scenarios of various small-break LOCAs and other events, as
16 developed by Babcock & Wilcox, and sat down myself and tried
17 to say if I had a water level meter in addition to the
18 things I already have, what would I tell the operator to do
19 different or to do in addition to what he is already doing?

20 And the answer I personally came up with is the
21 same one that B&W came up with. I could not figure out how
22 we would use it.

23 CHAIRMAN SMITH: The question I am asking now is
24 not to challenge the testimony, but only to clarify it,
25 because I think that one answer could have been ambiguous if

1 the record would be approached at that point. Which now
2 suggests my second question.

3 Mr. Jones indicated that the concept of water level
4 meters and those on the market are not particularly good or
5 they are not particularly useful. I think it might be
6 helpful if he were to explain what assumptions of the
7 capabilities of water level meters were used in determining
8 how they could have been used in the operating procedures.

9 BY MR. BAXTER: (Resuming)

10 Q Is this evaluation that you have been referring to,
11 Mr. Jones, of methods to detect inadequate core cooling
12 beyond those available with existing instrumentation
13 documented in a paper entitled "Evaluation of
14 Instrumentation to Detect Inadequate Core Cooling, Prepared
15 for the 177 Owners Group," dated August 15, 1980, and found
16 in Licensee's Restart Report, Exhibit 1, supplement 1, part
17 2, the answer to question 95?

18 A (WITNESS JONES) Yes, it is.

19 CHAIRMAN SMITH: If those are the assumptions, that
20 is fine.

21 WITNESS JONES: But even my own look at the
22 instrumentation would be -- let's assume I have an
23 instrument that was perfect, that functioned perfectly,
24 which is the way I looked at it myself, and I could still
25 find no use for it even if it could pick up the two-phase

1 water level, I could find no use for such an instrument
2 that, you know, does anything different than what we have
3 done based on the existing instrumentation.

4 DR. JORDAN: That raises several questions, and I
5 probably will not be able to remember them long enough to go
6 through them. But one of the things that bothers me is you
7 say you have done in this analysis -- looked at possible
8 meters that would augment the present meters. It seems to
9 me that if you have done this, that this would meet the
10 requirements for the January 1 which Mr. Rubin has -- no, I
11 guess it is not Mr. Rubin. No. Mr. Rubin goes further than
12 that. Mr. Rubin says you do not even have to have the
13 restart requirements, but they say you have not attempted
14 even to meet the January 1 requirements, which calls for an
15 analysis. And yet you say you have done an analysis and it
16 has been submitted. Now, where does the truth lie here?

17 WITNESS JONES: All --

18 DR. JORDAN: Should we save this for further --

19 MR. BAXTER: No.

20 WITNESS JONES: All I can say to that is that I do
21 not understand the basis for the staff's statement. We have
22 done our analysis and submitted it in August. They have
23 said -- they have apparently come back and said it is either
24 not an adequate analysis or -- what the staff really wants
25 is for us to put water level in. But yet they will not come

1 out and say it. I just do not know any other way to read
2 it.

3 DR. JORDAN: Okay, that is fine.

4 CHAIRMAN SMITH: Maybe we will find out today.

5 (Laughter.)

6 DR. JORDAN: I guess we possibly will.

7 WITNESS KEATEN: Excuse me. If I might, I would
8 like to also answer Mr. Smith's question. In the evaluation
9 which I did as far as the characteristics of the water level
10 meter, I considered two cases. I considered a water level
11 meter of the type that Mr. Jones described, that measures
12 the effective collapsed water level, such that if there was
13 a froth, the meter would think it was solid water at a lower
14 level.

15 And then I alternatively considered one that would
16 actually give the true indications of the top of the
17 two-phase mixture. And as in the case of the BEW analysis,
18 in neither case was I able to identify anything that I could
19 tell the operator to do different based upon that
20 information.

21 DR. JORDAN: I will come back. I have this
22 analysis in front of me, and I have not had time to read
23 it. I only learned last night that this was one of the
24 documents.

25 But in reading the short response, I am not sure --

1 it seems to me all it says is that -- when I read the
2 response, it says what we have is adequate, we do not need
3 to do anything more.

4 But we will certainly come back to that later, so
5 let's not dwell on it now.

6 DR. LITTLE: When you say he would do the same
7 thing, does this mean he would do it on the same time basis,
8 too? He could not do anything earlier if he had water level
9 instrumentation than he can do with the present
10 instrumentation?

11 WITNESS JONES: That is basically correct. And,
12 again, as I said, I have some personal fears that he would
13 use it the wrong way. He could actually use it to do things
14 that would be unsafe.

15 WITNESS KEATEN: Dr. Little, the problem we run
16 into here is that the operator has to be prepared to meet a
17 very wide spectrum of possible events, ranging from, for
18 example, a very small break to a very large break, depending
19 on which size break actually occurs. And where it occurs in
20 the system, the behavior of either the actual liquid level
21 or the two-phase liquid level varies enormously from one
22 transient to another transient.

23 And so whether the level is dropping rapidly or
24 slowly is not particularly useful information to the
25 operator, because that may be perfectly normal behavior for

1 the particular event that he has.

2 It is not a situation where he can look and say if
3 the level is dropping at one foot a minute I am all right,
4 my emergency core cooling systems will take care of it, but
5 if it is dropping two feet a minute I am not all right and I
6 need to do something different. That is not the situation,
7 because the two-feet-a-minute rate of drop may be perfectly
8 normal for a different break, which again the emergency core
9 cooling systems are perfectly capable of handling.

10 So that is why we ran into the problem of not
11 figuring out how to use the information.

12 DR. JORDAN: We surely have to get into today the
13 business of the overcooling event. I just do not understand
14 why you say that a level meter would not be useful. If I
15 found that there was an overcooling -- supposing we did have
16 an overcooling event, the level drops, and then it stops
17 dropping. Surely that is valuable information for the
18 operator to know.

19 WITNESS KEATEN: But, Dr. Jordan, that also occurs
20 for quite a spectrum of small-break LOCAs.

21 WITNESS JONES: That is correct. And there are --
22 hold on one second.

23 (Pause.)

24 WITNESS JONES: Just to help illustrate Mr.
25 Keaten's point, this is a figure extracted from a previous

1 exhibit, Licensee's Exhibit Number 4. It is not the whole
2 document, but this is just the figure.

3 (Extract from Licensee's Exhibit Number 4 follows.)

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

Layman 1/21
10/663

(2)

Docket No. 50-289


(Restart)

Licensee's Exhibit No. 4

Excerpt from

Letter dated July 18, 1978 from
J.H. Taylor, Babcock & Wilcox,
to S.A. Varga, NRC, attaching additional
ECCS small break analyses

FIGURE - A
 MIXTURE HEIGHT
 VS TIME
 2972 MWL
 177 - FA



1 WITNESS JONES: And to help show part of the
2 problem you get, this is a spectrum of small-break vessel
3 level response, basically two-phase liquid response for a
4 variety of break sizes.

5 And as you can see, characteristically, after an
6 initial -- initial drop which is coming down and putting the
7 two-phase mixture level at the internal vent valve, the
8 level will stabilize, basically just stay stabilized at
9 roughly that elevation, and dependent on the size, for quite
10 a prolonged period of time. And if you had a rapid
11 overcooling event which pulled a bubble in the overhead, you
12 would see something very similar to this.

13 And the other problem is this is just to a .04
14 square foot break, and if you used a smaller break, then the
15 .04 which is shown here, the actual initial level response
16 drop will be much, much slower, and you would not even see
17 an indication of drop in level for possibly several minutes.

18 CHAIRMAN SMITH: Before you get too far, I would
19 like to suggest that this be bound into the transcript at
20 the beginning of his explanation, right at the point that he
21 described it as being an excerpt from Licensee's Exhibit 4.

22 Is that possible, Mr. Reporter?

23 DR. LITTLE: You are implying water level
24 instrumentation may be more ambiguous than the information
25 you already have?

1 WITNESS JONES: That is correct, especially in
2 trying to figure out where the transient is going or the
3 initial response of the transient because of a wide variety
4 of conditions you can get for both an overcooling-type
5 accident or event or a small-break LOCA event, depending on
6 its size, location, et cetera. It becomes very difficult to
7 use it as a distinguisher.

8 DR. JORDAN: Could we start over again? I did not
9 hear the question.

10 DR. LITTLE: The question was: In the early part
11 of an event, the water level instrumentation may give more
12 ambiguous -- may be more ambiguous than what they would
13 ordinarily have.

14 DR. JORDAN: Than what you ordinarily have?

15 DR. LITTLE: With the existing means of --

16 DR. JORDAN: What?

17 MR. BAXTER: Existing instrumentation.

18 CHAIRMAN SMITH: This is the first examination
19 among Board members that I have ever had.

20 (Laughter.)

21 CHAIRMAN SMITH: Off the record for a moment.

22 (Discussion off the record.)

23 DR. JORDAN: Would you interpret what you think the
24 question is now and then repeat your answer?

25 WITNESS JONES: The way I understand the question

1 -- the question, I think, asked: Do you believe basically
2 that water level may in fact be an ambiguous signal early in
3 the transient? And I do agree with that, and especially
4 trying to diagnose between an overcooling and an
5 undercooling event. And, you know, it gets more
6 complicated, depending on the scenario, whether the pumps
7 are running or not, et cetera. If you are running with the
8 pumps on, you may really have a problem, because the level
9 indicator could say no water initially because of just the
10 pressure drop across the core. So you need to be very
11 careful.

12 DR. JORDAN: Do steam plants of a site gauge still
13 cold plants?

14 WITNESS JONES: I do not really know.

15 DR. JORDAN: Do they have water level indication in
16 a boiler? That is ambiguous information, I guess is what is
17 bothering me.

18 WITNESS JONES: A boiling water reactor --

19 DR. JORDAN: Not boiling water reactor. I am
20 talking about a cold plant.

21 WITNESS JONES: I really do not know about cold
22 plants.

23 DR. JORDAN: Okay.

24 CHAIRMAN SMITH: There would not be an equivalent
25 water level -- you have steam generator -- would the --

1 never mind. Strike that.

2 DR. JORDAN: There is a boiler. But, okay, go
3 ahead.

4 BY MR. BAXTER: (Resuming)

5 Q Let me, if I may, return to the issue raised some
6 time ago by Mr. Smith about what evaluation you have done of
7 additional operator actions or instrumentation, and complete
8 that subject. We were looking at page 4 of Mr. Phillips'
9 testimony. But in supplementation in answer to Licensee's
10 interrogatory number 1, he asserts that: "We specifically
11 have not addressed the desirability of various operator
12 actions to increase safety injection makeup flow when a slow
13 but continuous loss of coolant inventory is indicated."

14 And Mr. Phillips suggests that one such action may
15 be rapid OTSGD pressurization to 400 p.s.i.g. which would
16 make the accumulator coolant injection available.

17 Would you assess these criticisms, Mr. Jones?

18 DR. JORDAN: I can't find it.

19 MR. BAXTER: It is in the interrogatory responses,
20 interrogatory 1.

21 DR. JORDAN: Interrogatory 1.

22 MR. BAXTER: It is in connection -- I linked it to
23 the testimony -- it is connection with the criticism in that
24 interrogatory that we have not submitted analyses or
25 evaluations addressing additional actions.

1 DR. JORDAN: The last paragraph, which is page 1.
2 Answer to interrogatory 1, is that where we are?

3 MR. BAXTER: That's correct

4 DR. JORDAN: All right. Thanks.

5 WITNESS JONES: Well, I -- I am not so sure that we
6 have said to the staff we have done this little item, looked
7 at this little item, et cetera. But let me just address
8 what is there.

9 The question is that we have not looked at maybe
10 the use of water level indicator for -- where we know we
11 have or would be picking up indications where we are slowly
12 losing inventory in the system, and then go on and based on
13 that take some other actions in the plant, such as an OTSGD
14 pressurization.

15 We have, in fact, considered this, not so much from
16 the standpoint of where the level instrument -- but even the
17 initial creation of the inadequate core cooling guidelines,
18 since some of the small breaks utilize the steam generator
19 for heat removal, we recognize that if we drop the steam
20 generator pressure rapidly, we would hope to depressurize
21 the primary system and, hence, increase primary system flow,
22 makeup flow.

23 But there are problems associated with that, which
24 is one of the reasons why we did not suggest rapid
25 depressurizations within the normal small-break transient.

1 We do have -- to first describe what we have, we have within
2 the small-break transients, if he knows he has a small
3 break, which he should be able to determine very readily off
4 the existing instrumentation, the operator has been
5 instructed to initiate a 100-degree per hour cooldown of the
6 plant in a saturated -- even though the system may be
7 saturated.

8 So that in fact we do have actions within the
9 guidelines for these slow, continuous depressurization
10 transients where we are increasing safety injection makeup
11 by depressurizing the plant with the steam generator. That
12 is within the existing small-break guidelines.

13 Now, the reason we do not like a rapid OTSGD
14 pressurization are a couple. First off, we would like the
15 operator to really evaluate what is happening in the plant.
16 Do you want the operator to rapidly depressurize the steam
17 generator when maybe what he has is a combination tube
18 rupture event with a LOCA? That would not be a good thing
19 to do, because that would increase the leakage flow into the
20 generator and increase off-site dose. We would rather have
21 the operator evaluate secondary-side conditions.

22 The operator is in the middle of a severe
23 transient, a small-break LOCA. We do not want him to do --
24 we would like him to get the plant stable, make sure his
25 injection systems are on, et cetera, and then to take

1 control, flow control of the plant to initiate a rapid
2 depressurization in the steam generator, will impose another
3 transient on top of a transient, and we think that might
4 mask other things that are happening to the system. And it
5 is not desirable, therefore, to take a sudden action.

6 Rather, what we feel is better is for the operator
7 to continue a continuous slow cooldown of the plant by
8 depressurization of the secondary side in a controlled
9 fashion. And then, if something happens while in that
10 controlled fashion, he can evaluate it rather than taking a
11 rapid drop and then figuring out now is the primary system
12 doing this because I did it to the plant or is it doing it
13 as a consequence of the original event.

14 DR. JORDAN: When you say "continuous cooldown by
15 depressurization," you mean the cooling now is taking place
16 by the boiling of the water and the escape of the steam to
17 the break? Is that the cooling you are talking about?

18 WITNESS JONES: Well, what I am talking about --
19 when I am talking about the cooldown of the plant, what I am
20 talking about is essentially decreasing its pressure and
21 temperature by bringing down the steam generator pressure,
22 condensing steam within the primary system by that action,
23 and slowly depressurizing the primary system.

24 The core itself is being cooled by the two-phase
25 mixture and from the continuous HPI flow.

1 DR. JORDAN: You are talking about using the steam
2 generator then and the condensor for injecting -- rejecting
3 the heat.

4 WITNESS JONES: Or the atmospheric dump valves,
5 manual control of those sorts of items. But again, we would
6 rather the operator take a cautious look to evaluate all the
7 system conditions and take slow control rather than initiate
8 very rapid transients when they may not be necessary. And
9 they should not be necessary if the systems are functioning
10 properly.

11 BY MR. BAXTER: (Resuming)

12 Q Let's return to Mr. Phillips' supplementary
13 testimony at page 3.

14 DR. JORDAN: Which page?

15 MR. BAXTER: 3.

16 CHAIRMAN SMITH: We'll look for a time for a break
17 when it is convenient.

18 MR. BAXTER: This is fine, Mr. Chairman.

19 CHAIRMAN SMITH: All right, let's take our
20 midmorning break.

21 (Brief recess.)

22

23

24

25

1 CHAIRMAN SMITH: Did we figure out what to do with
2 that insertion in the transcript? It should be both pages.
3 I think we should amend it. It is an excerpt from
4 Licensee's Exhibit 4.

5 MR. BAXTER: That is correct. I think Mr. Jones
6 did refer to it as not the complete exhibit but an excerpt.

7 CHAIRMAN SMITH: Can we physically put the words
8 "excerpt from" and let that be the one that is physically
9 bound in?

10 MR. BAXTER: Mr. Chairman, I distributed over the
11 break to the Board and parties who are here testimony of
12 Solomon Levy in response to UCS Contention Number 13. That
13 document was served on everyone yesterday by mail, but this
14 is an extra copy.

15 BY MR. BAXTER:

16 Q Looking at page 3 of Mr. Phillips' supplementary
17 testimony, approximately the middle of the first full
18 paragraph.

19 DR. JORDAN: The one that begins "For a small
20 break LOCA"?

21 MR. BAXTER: Yes.

22 BY MR. BAXTER: (Resuming)

23 Q In the middle of that paragraph, "For some small
24 break LOCA conditions, the time interval from the instant of
25 primary system saturation conditions until the occurrence of

1 superheat indication on the core exit thermocouples or hot
2 leg RTDs is in excess of 30 minutes and possibly up to three
3 hours or more."

4 Mr. Jones, what are the implications of such time
5 intervals?

6 A (WITNESS JONES:) Well, I do not understand the
7 total implications that Mr. Phillips was trying to draw
8 there. I assume what he is trying to get at is that if you
9 have such a prolonged period of time, the operator could do
10 something to assist the transient or the water level
11 indicator.

12 Per ly, all it means to me is that you will be
13 then using your high pressure injection water for something
14 on the order -- in excess of 30 minutes and possibly up to
15 three hours after you saturate the system. That is again
16 going back to the primary design function of the HPI. If
17 you reach low pressure or saturation conditions and actuate
18 the HPI, you want to keep that HPI on until such time as you
19 have returned the system to a subcooled state.

20 DR. JORDAN: But isn't the staff saying that
21 during this period there is a continuous lowering of the
22 water level and it would be useful for the operator to know
23 this before he reaches inadequate core cooling conditions?
24 And are you saying there is just no need for him to know
25 that there is a lowering of the water level, that it does

1 not help him to know it?

2 WITNESS JONES: Well, in my opinion, yes. And if
3 you go back to that excerpt, the figure looking at the water
4 level, transient as a function of time, you in fact see that
5 although it may be three hours or 30 minutes before you
6 might reach the top of the core, for a substantial period of
7 time -- now, 30-minute-type timeframe. Let me just back up
8 a little.

9 A 30-minute time frame to expose the upper
10 portions of the core imply that you have a relatively small
11 size LOCA, okay, on the order of .05 square feet or less,
12 looking at this excerpt. And you see the water level
13 indication basically remains in a very tight band for a long
14 period of that time, so you would only even see the
15 indication of water level continuing to drop in the vessel
16 later on in that timeframe, and in fact you do not have this
17 up to three hours indication that he talks about.

18 You will only see it from a period of time that
19 the level drops from the vent valve location to the top of
20 the core, and that could be much shorter than three hours or
21 30 minutes, depending on the break size.

22 Additionally, as you can see from the excerpt,
23 there is a substantial difference in the rate of water level
24 drop between these cases, and as a break size gets smaller
25 and smaller or goes to the larger size, the range is going

1 to get even more spread out to where you will see very slow
2 drops in level, to where you will see rapid drops in water
3 level indication.

4 I do not know of any way to tell an operator how
5 to interpret what is the proper rate because that rate is
6 dependent on where the break is, how big it is, what the
7 previous power history is on the core, how much RPI may be
8 going into the system. There are so many parameters to
9 correlate that to try to use rate of water level drop as an
10 indicator becomes very difficult to do because, as you see,
11 even from these excerpts, the water level drops for maybe a
12 substantial period of time and then turns around.

13 I think that would possibly even alarm the
14 operator and make him take other actions. That, indeed, may
15 not be necessary nor desirable. One of the examples of this
16 is in the inadequate core cooling guidelines. One of the
17 actions we take is to restart the reactor coolant pumps.
18 Now we know that use of the reactor coolant pump has a
19 potential safety hazard associated with it, so you do not
20 want the operator to start the reactor coolant pumps when it
21 is not necessary.

22 But if you are in a condition where you have
23 indeed exposed the core beyond where you expect to have
24 been, at that point in time you really are trying to find
25 other ways to cool the core, and at that point the judgments

1 remain that the risk of a potential ultimate loss of the
2 pump later on in the transient is far outweighed by the
3 benefits associated with turning on the pump and getting a
4 slug of water into the core and helping to rapidly decrease
5 the temperature.

6 So, although there is time there for the operator
7 if he had such a level instrument, I have no idea how to
8 tell him to use it based on level drop.

9 BY MR. BAXTER: (Resuming)

10 Q In the last paragraph on page 3 of Mr. Phillips'
11 supplementary testimony, the first sentence in part, he
12 takes the position that the trend of level indication would
13 provide valuable diagnostic information on the nature of the
14 transient before the level drops into the core.

15 This position is amplified on in the staff's
16 response to Licensee's interrogatory number 4 and the part
17 of that answer that is on page 4 of that document, where Mr.
18 Phillips says that with respect to diagnostics, the primary
19 coolant inventory versus time data could be compared to
20 event scenarios considered in the safety analyses to infer
21 the type and location of the break or to provide evidence of
22 anomalous behavior which could otherwise be undetected.

23 I have two questions, then. Why would it be
24 necessary, if it is, to provide positive and direct
25 indication that a LOCA exists, as Mr. Phillips asserts

1 earlier in that answer to interrogatory number 4; and
2 second, is the suggestion of comparing inventory versus time
3 data with event scenarios a practical suggestion for an
4 operator in the control room?

5 A (WITNESS JONES:) Well, on the first question,
6 which is why is it necessary to provide a direct indication
7 that a LOCA exists, first of all, I do not believe a water
8 level instrument would do it. But I believe the existing
9 instrumentation already provides it to you. Additionally,
10 it really is not necessary, especially in the early portion
11 of the transient, to be able to tell whether it is a LOCA or
12 a non-LOCA event.

13 If you have a transient which leads to saturation,
14 you want to get the high pressure injection on to resupply
15 makeup fluid or water to the system, to assure that adequate
16 inventory will be maintained so that the core will remain
17 cool. So, in fact you do not need to be able to tell it
18 right away. You don't need to have a meter which flashes up
19 and a flag that says you have a LOCA. You do not need to
20 know that right away.

21 On saturation you need your HPI on, which will be
22 performed automatically. And secondly, you keep it on until
23 it is there and the operator has the time based on the
24 existing information and has sufficient information to
25 diagnose that he has a LOCA in the plant.

1 DR. JORDAN: Mr. Jones, whether or not a level
2 meter may be the best way, wouldn't it be useful to have
3 some indication of approach to inadequate core cooling, and
4 by approach I mean exactly what the staff has been saying,
5 well long before you reach the place where the core is
6 uncovered. Wouldn't it be helpful to have a device that
7 says we are losing inventory, we should be doing something
8 about it if we can?

9 WITNESS JONES: The problem with that is, as you
10 can see from that excerpt, you lose inventory for a
11 substantial period of time, depending on the size of the
12 break.

13 DR. JORDAN: Yes, but wouldn't it be helpful to
14 have this information?

15 WITNESS JONES: Let me just try to tell you what
16 the ICC guidelines really look like and the transition
17 between the small break LOCA guidelines -- I used an
18 anachronism -- ICC meaning inadequate core cooling, how you
19 make the transition from the small break guidelines to the
20 inadequate core cooling guidelines.

21 When we get to superheat conditions in the core,
22 they really do not tell the operator to do, at least
23 initially, anything different than what we had already told
24 him to do. It is basically verifying you have your HBI on,
25 verifying that you have cooling to the steam generator,

1 verifying that you are cooling down with the steam
2 generator, actions of that nature, and then to take some
3 actions to prepare him for potential steps later on, such as
4 verify that the core flood tank isolation valves are open,
5 because there are places in the small break procedures -- in
6 the guidelines, excuse me -- which would allow you to close
7 the isolation valve on the core flood tank, at least within
8 the guidelines.

9 So that is the alert stage for the operator. That
10 is his advanced warning, because we do have safety analysis
11 cases which do uncover the core somewhat.

12 DR. JORDAN: Which do what?

13 WITNESS JONES: We do have some of the safety
14 analyses cases which do uncover portions of the upper
15 regions of the core by about a foot. So we wanted him to be
16 ready at that stage, get into the procedure and be ready to
17 take the action, and then to perform the functions if the
18 system continues to degrade from there and to monitor the
19 in-core thermocouples to see whether he is continuing to
20 degrade or whether he has a small degradation and then
21 starts a recovery process.

22 Then he goes back when he recovers the core. He
23 goes back, transfers back into the normal small break
24 guidelines again, and we feel that is adequate advanced
25 warning to the operator for the potential onset of

1 inadequate core cooling conditions.

2 DR. JORDAN: Suppose I had a meter that read
3 reactor inventory. Would that be a helpful meter to have?

4 WITNESS JONES: From an analyst's standpoint, if
5 you had a reactor vessel water meter it would be useful to
6 me to go and later on look at the event and benchmark
7 computer codes, et cetera. From an operator's standpoint, I
8 do not really see that much of a benefit to be gained from
9 it.

10 And again, I might be -- personally, I just worry
11 a little bit about the operator confusion aspects. But, you
12 know, I cannot really testify exactly as to the type of
13 confusion it might give him. But certainly I feel that it
14 would tend to confuse him.

15 DR. JORDAN: Mr. Keaten or Mr. Ross?

16 WITNESS ROSS: I think on the subject of operator
17 confusion you must realize this meter would sit there
18 reading the same at all times during power operation. It
19 would read the same whether at 100 percent power, whether I
20 make a reduction to 50 percent power, whether to 15 percent
21 power. It would read the same if I had a normal reactor
22 trip, whereas the other indicators would move. The operator
23 would see them move. He would grow reliant on the other
24 indicators and know what they mean.

25 As far as value to the operator or directing his

1 actions on this indicator, I see little value in it.

2 DR. JORDAN: Okay.

3 WITNESS KEATEN: Dr. Jordan, let me see if I can
4 say the same thing in slightly different words. The problem
5 that we have found in trying to decide how we would use this
6 kind of level information if it were available, even
7 assuming that there were an ideal level meter or inventory
8 meter and so forth is that we have not been able to figure
9 out how to correlate between what we are seeing as a level
10 and whether or not there is, in fact, an approach to the
11 condition that we are referring to as inadequate core
12 cooling.

13 The important thing to recognize is that under
14 LOCA conditions, the emergency core cooling systems have
15 been designed to protect the core, and really, the role of
16 the operator is simply to see that those systems are working
17 the way that they are supposed to, and we really do not want
18 him to do something different.

19 The inadequate core cooling procedure or
20 guidelines and the procedures that we have developed from
21 that are directed at a situation that is basically a
22 nonmechanistic situation in which for some reason although
23 we have had a loss of coolant accident, things are not
24 proceeding the way that the analyses say that they will, and
25 so that we are getting into a new beyond-the-design-basis

1 type of event.

2 In this situation we are asking the operators to
3 take further and very unusual actions, actions which, as Mr.
4 Jones has pointed out, in fact have some possibility of being
5 detrimental. But we are willing to take them because we are
6 now in a hypothetical situation beyond the design basis.

7 In looking at how that could be related to reactor
8 vessel inventory or water level, we ran up against the snag
9 that for many of the LOCA events, as the figure shows, in
10 fact the water level drops down to the top of the core, and
11 in that situation we do not want the operator to do
12 anything.

13 We want him to continue to rely on his emergency
14 core cooling systems to recover that. And it is only if we
15 get some indication that the emergency core cooling systems
16 are not going to be capable of doing their job that we would
17 want the operator to do something different, and that cannot
18 be water level because they can be doing their job just fine
19 and you still see a drop in the water level.

20 What we have been able to identify, however, is
21 that if we see temperatures on the in-core thermocouples
22 that are sufficiently higher than we expect, that it
23 indicates that the cladding temperature is going above the
24 range predicted by the analysis.

25 Now we have an indication that things are not

1 going the way the analysis predicted. That is the reason we
2 were able to identify actions based on that and why we have
3 not been able to identify any actions based on water level.

4 DR. JORDAN: This recommendation, of course, came
5 out of the TMI-2 incident. But I guess most everyone has
6 the feeling that if there had been a meter that said the
7 inventory is disappearing, gentlemen, would those operators
8 then have turned off the ICS system deliberately? I guess
9 -- I am sure your feeling is now with the instrumentation
10 that you do have, that the operator will not take that
11 course. But he did have the in-core instrument. He did
12 have in-core thermocouples, and in spite of what those read,
13 he did turn it off.

14 So why wouldn't an inventory meter be helpful?

15 WITNESS KEATEN: Dr. Jordan, let me point out
16 first that we are not asking the operators to look at the
17 in-core thermocouples to decide whether or not to throttle
18 the high pressure injection. We are asking him to look at
19 his primary system temperature and pressure, or
20 alternatively, at the saturation meter. And it is true that
21 he did have primary system temperature and pressure. He did
22 not have a saturation meter such as we now have.

23 But the other thing he did not have is the very
24 extensive training and very clear procedures that are now
25 provided to him that really explain to him what he needs to

1 do, and this is why you have heard me say on previous
2 occasions that in my viewpoint the real lesson from the
3 accident is not that we need additional hardware, it is to
4 make sure we have the operators use correctly the hardware
5 that is there.

6 DR. JORDAN: I have heard you say that before, Mr.
7 Keaten. Thank you.

8 DR. JORDAN: Okay. I believe the second question
9 -- I will try to paraphrase it because it has been a while --
10 is can we use the primary coolant inventory versus time data
11 compared to the safety analysis predictions and therefore be
12 able to pick up an anomalous behavior?

13 Well, I find that very difficult to believe it
14 could be done because first off, as we have already stated,
15 the water level changes dramatically and differently
16 depending on the size and location of the break. But it is
17 not only that. Even if I could put it in and somehow could
18 correlate it to say system pressure, for example, there are
19 other things to recognize.

20 First off, it makes assumptions about certain
21 equipment status, so much feedwater flow to the generator,
22 so much HPI flow to the system, the generator pressure
23 control of safety valves instead of what would probably be
24 controlled out, which is the turbine bypass valves. When
25 you put all the various parameters that are in the analysis,

1 core decay heat that we have assumed versus what would
2 actually be there, when you put them all together you have
3 one jumbled mess. And to try to compare what is going on in
4 the plant, certainly I would find it very difficult myself
5 personally to sit there and look at the thing with my
6 experience and try to say yes, it is that break and that is
7 where it is and it is anomalous.

8 You would have to, at best, have to program it
9 into some computer and then have some parametric variations
10 on all the other parameters that could affect the analysis,
11 and it would be very difficult even to probably draw that
12 correlation and present it to the operator and say you have
13 got something wrong.

14 He could find out quicker by looking at the HPI
15 flow, comparing it to what he should have and saying, hey, I
16 do not have enough flow. I either better get that flow up
17 or be prepared to take further actions because this has a
18 potential of degrading. That is a better indicator of a
19 lead to inadequate core cooling than looking at the water
20 level drop because it is direct and simple.

21 BY MR. BAXTER: (Resuming)

22 Q Would you consider the use of vessel level
23 measurement for the kind of diagnostic exercise Mr. Phillips
24 has suggested to be an unambiguous and easy to interpret
25 indication?

1 A (WITNESS JONES:) No, sir.

2 CHAIRMAN SMITH: Could you with your t-sat meter
3 and in-core thermocouples and all of the other data that
4 would be available to you calculate the water level at a
5 given moment in a given event?

6 WITNESS JONES: It is possible from the in-core
7 thermocouples to predict the water level, the two-phase
8 mixture level in the core. You would have to have some sort
9 of a calculational routine to do it because you would have
10 to account for the power shape and the core decay heat that
11 was on in the plant at that time in order to make that
12 calculation. But such a calculation could be performed.

13 That's it.

14 BY MR. BAXTER: (Resuming)

15 Q What use might the operator make of that
16 calculation if he could get it?

17 A (WITNESS JONES:) Off-hand I know of no real use
18 to him because he would have to wait for first the
19 calculation to come up if he was going to use it to take an
20 action. The in-core thermocouples are responding at the
21 time and it is a faster thing, it is a faster indication
22 available to the operator than going through the
23 calculational routine, although that may take a small period
24 of time.

25 But you know, since you are backing it out of the

1 in-core, I do not see how it provides you anything really
2 additionally useful, more useful than what you already have
3 from the in-cores.

4 Q Looking at the same sentence in the last paragraph
5 on page 3 of Mr. Phillips' supplementary testimony and also
6 the interrogatory 4, he asserts that water level indication
7 would also provide indication when safety injection makeup
8 is adequate to prevent core uncovering and would provide
9 positive information when primary system inventory recovery
10 commenced.

11 Mr. Jones, what would the operator do with this
12 information?

13 A (WITNESS JONES:) Well first off, I do not see any
14 way, based on the level information as it changes during the
15 transient, the operator would be able to tell whether he had
16 adequate safety injection flow because even the analyses
17 which have been performed, assuming the flow is there, show
18 the water level dropping with time. So it is difficult to
19 assess that.

20 Certainly a level instrument could tell him when
21 primary inventory recovery is commencing, possibly; but
22 again, there is nothing that he would do with that because
23 his objective is still to restore the plant, ultimately, to
24 a liquid, full primary system loop condition. That is his
25 ultimate objective, to return the system to a subcooled

1 state.

2 Personally, all I see that positive information
3 about the recovery would tell, would do would be give me
4 maybe a slightly warm feeling in my stomach, is about it. I
5 cannot see an operator doing anything with it because the
6 rate of recovery, just like the uncovering of the core, is
7 dependent on break size and location. The rate of recovery
8 has the same parameters affecting it.

9 Q Mr. Jones, I take it from your earlier testimony
10 you have examined the NRC staff's report on the St. Lucy 1
11 natural circulation cooldown on June 11, 1980, which is
12 cited by Mr. Phillips on page 4 of his supplementary
13 testimony. Is that correct?

14 A (WITNESS JONES:) That is correct.

15 Q Both to help explain your earlier testimony and to
16 answer my next question, I think it would be appropriate to
17 very briefly summarize what that event was, if you would.

18 A (WITNESS JONES:) Well, basically what happened at
19 St. Lucy was they had a loss of component cooling water to
20 the reactor coolant pumps, which therefore they lost cooling
21 to the pump seals, and to prevent damage to the pump seals,
22 they tripped the reactor coolant pumps and then initiated a
23 plant cooldown on natural circulation.

24 At some time during this cooldown process, they
25 apparently pulled a void within the primary system.

1 Specifically, it is believe to have been located in the
2 upper head of the vessel. That was indicated to the
3 operators because the level swing occurring in the
4 pressurizer was rather large and could not be explained by
5 the fact that they were just changing the injection location
6 from the cold legs of the system to the pressurizer as a
7 repressurizer spray.

8 The significance of the St. Lucy event was
9 basically the fact that a bubble was drawn in the head.

10 Q Does St. Lucy 1 have a Babcock and Wilcox nuclear
11 steam supply system?

12 A (WITNESS JONES:) No. The St. Lucy plant is a
13 Combustion Engineering plant.

14 Q Would you assess, then, the contention by Mr.
15 Phillips on page 4 of his supplementary testimony that this
16 event at St. Lucy 1 somehow illustrates a need for water
17 level indication?

18 A (WITNESS JONES:) Well, I do not see the event
19 really showing the need for water level indication. In
20 fact, I think the event just tends to point out one of the
21 problems with using water level as a distinguisher between
22 overcooling and a small break LOCA, as I have discussed just
23 previously.

24 What the staff has stated in the report and is
25 stated in Mr. Phillips' testimony is that the operators

1 apparently did not initially recognize the fact that they
2 had drawn a bubble in the head of the reactor vessel, and
3 they have somehow concluded that possibly unsafe operator
4 actions could have been taken and that if they had vessel
5 level instrumentation they would have known about the bubble
6 in the head.

7 I have had trouble trying to figure out what
8 unsafe operator actions could have been taken because there
9 are no details in the report, but additionally the operators
10 were able to figure out they apparently had a bubble in the
11 vessel head because they controlled the plant, and certainly
12 it was easily recognizable by the level swings that were
13 occurring in the pressurizer, and it was a direct
14 indication, in fact, that they had a void in the primary
15 system.

16 Now, as far as possible unsafe operator actions,
17 the only action that I can conclude that might have been
18 taken, reasonably have been taken is that they continued to
19 cool down the vessel, cool down the plant, which allowed the
20 bubble in the vessel head to expand and some of the steam to
21 be drawn into the reactor coolant system loops.

22 That would not necessarily cause a safety problem
23 in the sense that you would now have hot steam coming in
24 contact with cold water and would condense, number one, and
25 additionally it would be easily recognizable on the

1 temperature and pressure indications for the plant because
2 if that happens, you would have had a rapid pressure
3 decrease as a result of the condensing of the steam, plus
4 you would have seen the temperature in those legs increase
5 as a result of the mixing of the hot water with the cold
6 water; and they ultimately would have lost their saturation
7 margin long before they would have -- I cannot say long
8 before, but certainly before they would have had a loss of
9 natural circulation in the loops because the fluid would
10 have gotten hotter in the hot leg, would have been
11 indicated, lost their 50 degree subcooled margin, would have
12 had to restore HPI, which would have been what they would
13 have had to do to maintain 50 degrees subcooled, was to
14 repressurize the plant.

15 Since St. Lucy, as Mr. Ross has already stated,
16 the St. Lucy event has been fed back into the operator
17 training to assure they understand the potential for void
18 formation during one of these events.

19 DR. JORDAN: Do they now recognize a St. Lucy
20 event by virtue of the fact of level oscillations? Is that
21 the tip-off now?

22 WITNESS JONES: That would be a primary way of
23 recognizing it, yes.

24 BY MR. BAXTER: (Resuming)

25 Q Mr. Jones, the staff report concludes with a list

1 of recommendations. Did the author of that report include
2 any recommendation that the vessel level indication should
3 be installed or imply anywhere in the report that it would
4 have been helpful?

5 A (WITNESS JONES:) No, it did not. Basically the
6 recommendations for the plant were along the lines of
7 procedural aspects and a few of the equipment problems
8 noticed during the St. Lucy event. There was no
9 recommendation to put in the water level indicator.

10 Q Beginning at the bottom of page 4 and moving on to
11 the top of page 5 of Mr. Phillips' supplementary testimony,
12 he asserts that "vessel level information is important and
13 possibly essential to proper emergency procedures relating
14 to use of the reactor vessel head vent required by the TMI
15 Action Plan."

16 Is B&W developing operator guidelines on the use
17 of these head vents in operating B&W plants, and will these
18 guidelines recommend any correlation or use of water level
19 in the reactor vessel?

20 A (WITNESS JONES:) We have developed or at least
21 have partially developed the set of guidelines for use of
22 the vents, and at this time we have not determined that
23 there is any need to have water level indication to assure
24 proper utilization of the head vents.

25 Q Both the original testimony filed by Mr. Phillips

1 and his supplementary testimony cite and rely in part as the
2 basis for the staff's position a letter of September 24,
3 1980 from Mr. Eisenhut of the staff to Mr. Arnold of
4 Metropolitan Edison Company, with the attached staff
5 evaluation of the Babcock and Wilcox position regarding
6 additional instrumentation for detection of inadequate core
7 cooling for B&W reactors.

8 IF there is anyone who needs a copy, I have extras.

9 DR. JORDAN: I have it but I have to find it.

10 (Pause.)

11 DR. JORDAN: If we could borrow a copy or two, we
12 have copies but --

13 CHAIRMAN SMITH: The more copies we have, the
14 greater our chances are of finding any given one.

15 (Laughter.)

16 BY MR. BAXTER: (Resuming)

17 Q On page 3 of the staff evaluation attached to the
18 letter I cited, near the bottom of item one, the staff
19 states that its review of available LOFT and semiscale data
20 during large and small break loss of coolant tests and
21 comparison to calculated values of measurable parameters
22 such as differential pressure lead the staff to believe that
23 correlation of measurable parameters to the advent of
24 inadequate core cooling is feasible.

25 Can you endorse this belief on the part of the

1 staff, Mr. Jones, on the basis they cite and why?

2 A (WITNESS JONES:) Well, what they are basically
3 saying is, or the way I interpret it is they are trying to
4 state that because we have been able to predict these
5 experiments, you should be able to predict what will happen
6 in the plant during one of these accidents.

7 There are numerous problems with taking this to a
8 plant. First off, these are controlled experiments, and
9 while I am not going to disagree with the statement that
10 they have been able to correlate in reasonable agreement the
11 calculated parameters, pre-test or even on a post-test
12 evaluation to the measured parameters, it is difficult to
13 see how you could use that in a plant because it is not a
14 test.

15 In performing these evaluations it is important to
16 note that they have been able to -- first, it is a well --
17 they try to control the test reasonably well, and they have
18 had some experience in calculating these experiments so they
19 have been able to so-call tune the model to make sure the
20 parameters in general match up, so when they change
21 something, they should be able to pick up that effect within
22 their calculations and it should match reasonable well with
23 the experiment.

24 The calculations which are done for a nuclear
25 plant have got to cover a wide range of conditions. These

1 are nice specific tests with specific input assumptions on
2 the system performance. For a nuclear plant you would,
3 again, as I tried to point out before -- you have such a
4 large degree of parameters to try to mark up that it would
5 be impossible, in my opinion, to really correlate it.

6 Just to point out some of the potential fallacies
7 or some of the effects of system interactions on predictions
8 to calculated values, I would like to note the recent L36
9 test that was done. L36 was a small break loss of coolant
10 accident where they kept the reactor coolant pumps running.
11 I think it was E, G & G in Idaho performed a pretest
12 prediction of this experiment with some assumed system
13 performance based on how the secondary system had performed
14 in previous experiments, and what they calculated was
15 following a tripping of the pumps there would be sufficient
16 inventory in the system that the core would not uncover.

17 When the experiment was run, one of the valves, or
18 at least the indications to date that I have seen say that
19 one of the valves which has historically had a problem of
20 not closing tightly closed tightly in this experiment and
21 the system depressurized slower, and when they tripped the
22 pumps, instead of having enough water to keep the core
23 covered, the core was way uncovered. It uncovered to a
24 substantial degree, and that is a systematic feedback that
25 can occur at a plant -- a valve sticks or it does not stick

1 or whatever -- that you have to account for.

2 That is why the safety analyses that are done rely
3 on certain values of safety valves and they do not take
4 credit for some of the equipment like the turbine bypass
5 valve. They do not take credit for the atmospheric dump
6 valves. They take credit for the safety valves on, say, the
7 steam generator, when in fact if you have an accident, it is
8 quite probable that you would have either the atmospheric
9 dump valve or the turbine bypass valves available to you,
10 and that already knocks your comparison right off. So you
11 cannot really correlate things directly.

12 DR. JORDAN: Mr. Jones, your statement about the
13 difficulty of applying the LOFT experiments and the codes
14 and so on that are developed there to a nuclear plant sound
15 exactly to me like the critics during the rulemaking
16 hearings on emergency core cooling, which claimed exactly
17 that: that it was impossible on these small-scale
18 experiments and these codes to predict what would happen in
19 a big plant.

20 WITNESS JONES: No.

21 DR. JORDAN: Are you agreeing?

22 WITNESS JONES: I am not saying that. What I am
23 saying is that what they have done is analyze the specific
24 tests. Okay, they are running the test and they analyze the
25 test, either in a pre- or post-test mode. They are also

1 doing best estimate calculations versus what I will call the
2 licensing or evaluation model-type calculation designed to
3 overpredict the normal consequences of the event.

4 DR. JORDAN: That is true.

5 WITNFSS JONES: They attempt to control the
6 experiment to verify that the codes indeed have proper
7 formulations of the equations so that it indeed can predict
8 system response and system behavior with the right set of
9 input conditions for the plant.

10 All I am pointing out with the LOFT test is that
11 here is a case where they made an assumption on a system
12 performance based on previous history. They were trying to
13 do a best estimate. They expect the valve will perform the
14 same way it always has, and suddenly the valve performs
15 actually the way it was designed to function, which was not
16 to leak, and they get two different answers.

17 So if you apply this to a nuclear plant, what you
18 get is should the valve perform differently than what is
19 assumed or the other equipment functions which we are not
20 allowed to take credit for, the comparison is no longer any
21 good from the standpoint of an actual prediction of how the
22 level changes with time.

23 The calculations are conservative from the
24 standpoint that they do not take credit for the equipment
25 which would help, such as a bypass valve or the atmospheric

1 dumps which keep the steam generator pressure down. Rather
2 we relied only on the safety system itself, which is the
3 steam safety valve, and we further assumed that they stayed
4 and functioned exactly right from the standpoint that they
5 did not stick open.

6 If they stuck open, the consequence of the
7 accident would be less severe than what we analyzed. So we
8 would mock up the systems in their design configuration,
9 take some assumed failures, not take credit for certain
10 systems that might be available to help you, and we make
11 assumptions on the core decay heat and various other things
12 that all together make the safety analyses really not very
13 good for telling you exactly where that plant is going to go.

14 But given all the inputs, I think we could do a
15 reasonable job of predicting where the level would go if we
16 knew all the inputs beforehand.

17 BY MR. BAXTER: (Resuming)

18 Q Turning to page 4 of this evaluation, item 4
19 states "The staff finds the position that additional
20 instrumentation is not needed because necessary operator
21 actions will be taken based on existing indicators to be
22 unacceptable. If all actions available to the operator had
23 been taken and the system is continuing to lose coolant due
24 to equipment malfunction or some unknown system condition,
25 the operator should be clearly informed of the situation.

1 "It is probable that additional actions such as
2 detection and correction of the unknown malfunction or
3 initiation of system depressurization to utilize low
4 pressure coolant injection sources could be taken by the
5 operator if circumstances warranted such action."

6 Mr. Jones, would you assess for us how vessel
7 level indication might aid the operator and be used to
8 detect and therefore correct an unknown malfunction?

9 A (WITNESS JONES:) Well, I don't really see a way
10 that the level indicator could be used to correct an unknown
11 malfunction or even detect it because, as I said, you have
12 such a wide spectrum of water level decreases with time that
13 you cannot really determine from rate of change or anything
14 like that what is happening, because if I took the smallest
15 break, say, that I have analyzed and take away the water
16 level or take away the high pressure injection flow, for
17 example, its range of change in level would look just like a
18 smaller break -- a slightly larger break, and I have no real
19 way to distinguish it.

20 The best way to address this type of an opinion
21 would be to say if I have inadequate HPI flow because I am
22 not getting the flow on the meter that I should be getting,
23 then either fix it or, if you know you cannot fix it, then
24 depressurize the plant rapidly. But you do it based on the
25 indications that I am not getting the flow I need rather

1 than the level drop.

2 That is a much better way to do it from a systems
3 standpoint of detecting malfunctions and what to do if you
4 have multiple system failures. That is a better approach
5 than looking at a water level approach and, in fact, in my
6 opinion is more direct than trying to infer it from water
7 level.

8 Q Continuing with that paragraph, the staff states
9 that "even if operator actions are not keyed directly to
10 level indication, the information derived from such an
11 indicator would be valuable in assisting the operator and
12 supporting emergency operations staff to assess the
13 situation and to prepare for those actions required upon
14 indication of the existence of inadequate core cooling."

15 Mr. Keaten, I have two questions for you on the
16 basis of that statement. One, what assistance might such
17 information provide supporting emergency operations staff;
18 and two, are you in favor or do you agree with the idea that
19 such instrumentation should be installed even if operator
20 actions are not keyed directly to it?

21 A (WITNESS KEATEN) In the process of trying to
22 evaluate whether or how such level instrumentation might be
23 used if it were available, as has been stated here earlier
24 this morning, we have not been able to figure out any method
25 of using it. We have a situation that if we get a small

1 break LOCA, we expect to see the level to drop.

2 And depending on whether it is a big or small
3 break LOCA or a smaller small break LOCA, it will drop
4 faster or slower. Many of these LOCAs we expect to see the
5 level drop down to about the top of the core. So if we had
6 a level indicator and we saw the level dropping and saw it
7 getting close to the top of the core, that still would not
8 tell us if there was anything unusual. It could be a
9 perfectly normal loss of coolant accident that the emergency
10 core cooling system was going to accommodate, so we would
11 not know what different to do than we are already doing.

12 It is not the situation were that kind of a level
13 drop can be identified as being abnormal or can be
14 identified as being a forerunner of the approach to
15 inadequate core cooling. It may be a perfectly normal
16 event, and therefore, you know, let's say we have a level
17 indicator but it was in the technical support center instead
18 of in the control room so the technical staff was evaluating
19 it. I don't know what they would do with the information.

20 Your second question is --

21 Q Before you move to that one, Mr. Keaten, I am not
22 sure whether the staff when they say emergency operations
23 staff are implying emergency planning personnel, but if that
24 were the implication, would the information be of use to
25 them?

1 A (WITNESS KEATEN) It is the same thing. If you
2 are talking about the initiation of the emergency plan, the
3 notification of the state and counties and so forth, TH1 has
4 developed a set of action levels that are used to identify
5 what classification of an event is in progress and to use
6 this to start the notification process. On a loss of
7 coolant accident as defined by either a high building
8 pressure and initiation of emergency core cooling or by loss
9 of saturation margin is an action level to trigger a site
10 emergency.

11 If we had level indication, I do not know what
12 else we would do in the way of notification. Again, if we
13 have a loss of coolant accident, we expect to see the level
14 drop, and it drops further or not as far and faster or
15 slower depending on what kind of a loss of coolant accident
16 is concerned. To my mind in terms of the relevance to the
17 emergency plan, once we knew that we had a loss of coolant
18 accident, I do not know what would be done additionally or
19 differently with the level instrumentation.

20 The next step beyond a site emergency and the
21 final severe level of declaration is a general emergency,
22 and for the most part, the declaration of general emergency
23 tends to be tied to actual radiation levels, releases of
24 radiation, and I do not see any way it would make technical
25 sense to me that one could use the level instrumentation if

1 it were available to decide whether or not you should go
2 from a site emergency to a general emergency.

3 As far as the second question you asked, do we
4 favor installing it even if it cannot be used, as I
5 explained earlier, we would like to restrict the information
6 available to the operators to that information which they
7 need and will take actions from, so that we increase our
8 assurance that they are looking at the right thing. And if
9 we overburden them with information, all we do is make their
10 job harder.

11 So, if we cannot identify how they are using this
12 instrumentation, then I for one am opposed to the idea that
13 it is something that should be presented to the operator.

14 (Board conferring)

15 BY MR. BAXTER: (Resuming)

16 Q To sort of sum up, I would like each member of the
17 panel to answer the question whether in your view reactor
18 vessel water level indication would provide an unambiguous,
19 easy to interpret indication of inadequate core cooling.
20 You may or may not choose to expand or repeat testimony you
21 have already given.

22 A (WITNESS JONES:) No, I do not believe it is; but
23 there is one other reason that had not been brought out
24 previously I would just like to quickly touch upon. A given
25 water level in the core, say ten foot water level in the

1 core, even if you could measure it exactly, still does not
2 tell you whether or not that core is being adequately cooled
3 or not because if the power shape is such that the power is
4 peaked to the bottom of the core, then you have very low
5 power in the upper portions of the fuel rod.

6 You do not have that heat to remove, and in fact
7 the steam cooling will keep that rod very cool and thus the
8 superheat temperatures being reached, say, on the in-core
9 thermocouples will reflect that fact. If, however, you are
10 at ten feet and you have a power shape skewed toward the top
11 of the core, then you could indeed -- I am not sure ten feet
12 would do it, but you would get very elevated temperatures if
13 you had a large peaking factor in the very top of the core
14 because you have a lot of energy removed and the in-core
15 thermocouples would pick up higher degrees of superheat
16 coming out of the top of the core for a given core water
17 level.

18 So, in fact, the water level does not even tell
19 you whether or not it is being adequately cooled without
20 knowing more facts about what is happening in that core, and
21 that you have to interpret even if you are down into the
22 core at that period of time. So I just totally disagree with
23 the fact that water level is an unambiguous or
24 easy-to-interpret indication of inadequate core cooling.

25 A (WITNESS KEATEN) Well, as I have said earlier, I

1 agree with Mr. Jones. I think the way I look at it is that
2 the configuration that we want the reactor coolant system to
3 be in is the configuration that it is designed for, and
4 since this is a pressurized water reactor, it is designed to
5 run water solid. In the instrumentation that is used to
6 measure such saturation margin, we have an indication, a
7 very clear indication of whether the system is subcooled or
8 whether it is, in fact, in saturated conditions.

9 If it is at saturated conditions, the real goal
10 and almost the only goal of the operating staff is to resort
11 to subcooled conditions, and the way that is done is to add
12 water. And the amount of water that is added is determined
13 by the design of the emergency core cooling system, and it
14 is designed to add adequate water for the total spectrum of
15 breaks that might occur, as well as for other types of
16 inventory loss accidents such as an overcooling accident.

17 So what the operators need to do in those cases is
18 make sure his emergency core cooling systems are functioning
19 as they were designed to, or if, for example, one pump does
20 not start even though that is within the design basis,
21 nevertheless he should try to start the second pump in order
22 to try to add more water.

23 His indication that he has successfully completed
24 that comes not from a water level indication because, as Mr.
25 Jones pointed out earlier, that might be in fact

1 misleading. It comes from the fact that he has
2 reestablished a subcooling so that he has returned the
3 reactor coolant system to the configuration appropriate for
4 a pressurized water reactor.

5 So given that as the design basis and the
6 operating basis of the plant, and given that we have not
7 been able to identify anything that he would do differently
8 or in addition to the things that he is already instructed
9 to do based upon the presently installed instrumentation, I
10 see no incentive for adding water level instrumentation, and
11 I see some disadvantages if that were to be done.

12 So I personally would recommend against it.

13 WITNESS ROSS: I guess I definitely see a
14 disadvantage to burden the operator with an instrument that
15 he does not use in his normal duties every day. He doesn't
16 respond or indicate nor does he take any actions based on
17 it, I might add, that are different than is already planned.

18 CHAIRMAN SMITH: No one has discussed whether the
19 physical presence of such a meter inside the reactor would
20 have an undesirable effect.

21 DR. JORDAN: He means a sensor.

22 CHAIRMAN SMITH: A sensor, yes.

23 WITNESS KEATEN: That's right, we have not, Mr.
24 Smith. One reason is that there are a wide variety of
25 different designs of instrumentation that have been and are

1 being considered for use in measuring water level or
2 something equivalent to water level, and they vary radically
3 in terms of whether they have anything inside the vessel or
4 not, and if they do have something, what it is. So it
5 really is impossible to address on a generic basis.

6 Some of the designs, at least in principle, are
7 thought might be able to work without anything inside the
8 vessel. There are others that rely on sensors. So that is
9 the type of consideration that has to be done on a
10 case-by-case basis depending on what particular design is
11 being considered.

12 DR. JORDAN: Could you tell us what is involved in
13 -- could you tell us what INPO and NSAC are doing about
14 this? Are they making any analyses, doing any experiments,
15 are they addressing the problem at all that you know of?

16 WITNESS KEATEN: I cannot address INPO and NSAC,
17 but I can tell you what EPRI is doing. In general EPRI has
18 been following work done by various organizations around the
19 country, and in addition they have done some limited work on
20 their own directed toward a couple of concepts.

21 To the extent that we are familiar with what is
22 done -- and we have made some attempt, at least, to stay
23 aware of what is going on around the country, realizing that
24 this is a topic that a lot of people have a great deal of
25 interest in -- we have not seen any convergence of opinion

1 toward what is a good or acceptable device for measuring
2 water level.

3 Now, one of the NRC staff witnesses at the recent
4 ACRS subcommittee meeting on TMI-1 restart indicated that he
5 believed that the staff was -- and I do not remember his
6 exact words -- but along the lines that the staff had
7 encouraging feelings with regard to two approaches, one
8 which measured the water level by the differential pressure
9 technique, and the other which used the heated thermocouple
10 technique.

11 I believe it is a true statement that both of
12 those are being evaluated as part of the LOFT program. On
13 the other hand, we have heard different evaluations of those
14 and in some cases conflicting evaluations from other
15 people. So, while there is work going on, it is at least my
16 personal opinion that at the moment there is not a method of
17 measuring water level that has uniform and universal
18 acceptability.

19 A part of the problem is a definition of the
20 conditions under which it is desirable to measure water
21 level. For example, if a determination were made that water
22 level measurements would be used only under circumstances
23 where the reactor coolant pumps were turned off, then a
24 measurement that used differential pressure would be much
25 more meaningful than would be an attempt to use that same

1 method when the reactor coolant pumps were running.

2 So, to sum up at least to the extent of my
3 knowledge, Dr. Jordan, I would have to characterize all of
4 these efforts as still being in the development stage.

5 DR. JORDAN: Supposing the NRC requirements were
6 pointed not at a measurement of water level but a
7 measurement of inventory level. What would be your answer
8 then? Would it be the same or would you say you just do not
9 see any way of doing it?

10 WITNESS KEATEN: I think my answer would be
11 similar. For example, if it was desired to measure the
12 inventory inside the reactor coolant vessel -- the reactor
13 vessel -- and if the only time that I wanted to do this was
14 when the pumps were turned off, which is the normal LOCA
15 scenario, at least to date it is, then it is conceivable to
16 me that a technique that used a differential pressure
17 measurement from the bottom to the top or some portion
18 thereof of the reactor vessel, properly temperature
19 compensated, might be used as an indication of the inventory
20 in the vessel.

21 DR. JORDAN: Isn't that what is used in the
22 pressurizer?

23 WITNESS KEATEN: Yes, sir, that is what is used in
24 the pressurizer; that is correct.

25 WITNESS JONES: But there is a big difference

1 between the pressurizer and the core during one of these
2 transients. The pressurizer is going to tend to be, if you
3 put the break in a nonpressurizer location -- that is, put
4 the break in the pipes -- the pressurizer water level is
5 just going to be a measure basically of where the water is
6 and the actual level in it, while in the core region you
7 have all the frothing --

8 DR. JORDAN: What?

9 WITNESS JONES: All the frothing mixture,
10 swelling.

11 DR. JORDAN: If you have a break.

12 WITNESS JONES: If you go -- yes, if you have a
13 break you will create steam, trap bubbles within the water,
14 and the only thing the DP cell will be able to pick up for
15 you is how much water is within this region, but it will
16 tell you nothing about where the actual level is. That
17 would be very dangerous to do anything with because, again,
18 you may have more than enough mixture to cover the core, and
19 the solid water level is down below the top of the core, and
20 that is not an unusual condition to be in during our
21 analyses.

22 DR. JORDAN: I guess I have some feeling that it
23 would be useful for the operator to be able to know
24 instantly whether he is dealing with a loss of coolant, say
25 a small break loss of coolant, or an overcooling event.

1 Now, you have told me that if there is a loss of level in
2 the pressurizer, than one of the things he does is to
3 immediately look at the secondary system.

4 I guess what I need to know is what happens in the
5 case of an overcooling event such as a steam line break, a
6 small or large, which produces a loss of level in the
7 pressurizer. What does the operator do about this? How
8 does he know it? How does he respond?

9 WITNESS JONES: Let me try to just generally
10 characterize all overcooling events rather than hit a
11 specific steam line break or feedwater overfill because the
12 basic dynamics of the transient is essentially the same.
13 There are details which are significantly different, but the
14 basic system dynamics are the same.

15 DR. JORDAN: All right.

16 WITNESS JONES: Both events -- any overcooling
17 event is a result of taking more power out of the primary
18 system than the core is producing basically. It is a
19 mismatch between what should be taken out of the secondary
20 side under normal circumstances and what you have here is
21 more coming out. What that does is it cools down the
22 primary system temperatures below what you would normally
23 expect the primary system temperatures to be at following a
24 reactor trip.

25 That means you have additional shrinkage or

1 compressing of the water because it is at a lower
2 temperature, and in order to replace the shrinkage occurring
3 in the primary system, the pressurizer level falls. And
4 because the pressurizer level falls, the system pressure
5 falls. And for most overcooling events of any significant
6 magnitude, and certainly steam line breaks, you will get a
7 high pressure injection signal or an emergency core cooling
8 system signal to actuate.

9 DR. JORDAN: One quick one. Would the operator
10 have turned off the coolant pumps?

11 WITNESS JONES: At that point in time he would
12 then go and turn off the cooling pumps.

13 DR. JORDAN: All right.

14 WITNESS JONES: Under the present instructions.

15 Now, depending on the severity of the overcooling
16 transient, it is possible that the pressurizer may drain and
17 become completely empty of water and indeed start passing
18 steam into the primary system where it would be condensed,
19 at least for some period of time, within the primary system
20 water.

21 If it is a very severe overcooling transient, such
22 as both steam lines breaking, for example, he might even
23 produce a void within the primary system, within the U bends
24 of the candy cane of the hot leg, and also possibly in the
25 reactor vessel upper head, and the system pressure for this

1 transient would be extremely low. It would drop to around
2 1000 psi or so. It could even go lower, depending on the
3 case that you are analyzing.

4 Now, the basic operator response during this
5 transient initially is to do nothing except verify that the
6 reactor has tripped -- trip the reactor coolant pumps, that
7 is an operator action, assure the HPI comes on when
8 actuated, and then to go and verify that he has secondary
9 side cooling and to evaluate for an overcooling transient.

10 Now, those three steps or four steps are the same
11 steps the operator takes initially for a LOCA. There is no
12 difference. Verify the reactor has tripped on the
13 appropriate signal, verify the ECCS works, trip the reactor
14 coolant pumps and assure secondary side cooling. So all
15 four steps are exactly the same.

16 Now, when he evaluates the secondary side
17 parameters -- is the level too high or the pressure too low,
18 indicative of an overcooling event depending on the nature
19 of the event -- the operator then has to terminate it. If
20 it is too much feedwater flow he throttles back a valve or
21 trips a pump. If it is a steamline break, he assures that
22 the steam line break detection system isolates that steam
23 line, isolates the broken generator and controls properly
24 the unbroken generator.

25 If it is a LOCA, he would look at those parameters

1 and assure they are being maintained at a proper value. So
2 just doing that confirmation step, he will automatically
3 pick up if it is an overcooling event.

4 Now, the subsequent actions of the operator are to
5 basically leave the HPI or the ECCS on until the system
6 returns to a subcooled state. At least that is the
7 significant one. There are for the LOCA procedure, of
8 course, many other steps the operator can take, such as cool
9 down the steam generator, et cetera.

10 But the most important thing is that he leaves the
11 HPI on, and that is the same whether it is an overcooling or
12 a LOCA situation until he has returned the system to a
13 subcooled state, has the pressurizer level rising, and at
14 that point in time he can throttle back on the HPI while
15 continually assuring he maintains adequate subcooling in the
16 system.

17 And then there are again some other actions which
18 then go forward from that, depending on what the nature of
19 the event was. So all of this period of time, as far as the
20 operation of the adding inventory to the system, they are
21 the same for all intents and purposes.

22 DR. JORDAN: Is there a difference in the case of
23 an overcooling event that the operator wants to try to make
24 sure that he does not somehow inject a slug of cold water
25 into the pressure vessel, thereby exceeding the pressure

1 temperature limits on the vessel? Is there something that
2 he should avoid doing in the case of an overcooling event
3 that is different from the case of a LOCA and therefore
4 additional information is needed in order to avoid slugging
5 the reactor vessel itself with a slug of cold water?

6 WITNESS JONES: Off-hand, the only difference
7 that I can come up with is that if he has an overcooling
8 event and he is returning the plant or allowing the plant to
9 heat back up following the original transient response for
10 an overcooling event, the operator is directed to open up
11 his letdown line and to control the steam -- if it is a
12 steam line break, the good steam generator, the broken one,
13 or control both steam generators to try to prevent the water
14 level rise in the pressurizer from filling it up during the
15 subsequent heatup process because he might have added a lot
16 of water from the high pressure injection system which then
17 just had to be removed from the system at this point in time
18 because now you are swelling again in the system and you
19 could potentially fill up the pressurizer.

20 So he is allowed to take those other functions.
21 But other than that, I do not know of any. As far as a cold
22 slug of fluid, when you turn on the HPI you are putting cold
23 water in the primary system. You are thermally shocking the
24 HPI nozzle. But that is not a real concern. That is part
25 of the design.

1 If it is a severe overcooling event, there will be
2 nothing you can do about it, possibly, by violating the
3 temperature and pressure limits of the vessel. You want to
4 try to get a handle on it before it happens. But if it is a
5 steam line break, you will violate the pressure, temperature
6 --

7 DR. JORDAN: There is nothing himself that the
8 operator can do.

9 WITNESS JONES: Not off-hand.

10 CHAIRMAN SMITH: Okay. This would be a good time
11 to break for lunch. Let's take --

12 MR. CUTCHIN: I wanted to ask, Mr. Chairman, if we
13 are approaching the end of Mr. Baxter's examination of these
14 witnesses. I would like to get a feel because there has
15 been a lot of testimony this morning and I believe we are
16 within striking distance of wrapping this issue up by the
17 end of the day.

18 I would like to have a little extra time at lunch
19 to go over with my people some of the things that have gone
20 on here this morning.

21 CHAIRMAN SMITH: Mr. Baxter.

22 MR. BAXTER: I only have three or four more
23 questions. I was going to move to a different subject,
24 though, so this would be a convenient breaking point, but I
25 can do it now if you would like.

1 MR. CUTCHIN: If you wanted to break now and we
2 could prepare on everything that has gone on, it probably
3 would not create a problem with the additional three or four
4 questions.

5 CHAIRMAN SMITH: How much time?

6 MR. CUTCHIN: Were you normally planning to come
7 back at 1:00? I would suggest maybe 1:30.

8 CHAIRMAN SMITH: All right, sure.

9 (Whereupon, at 12:07 p.m., the hearing was
10 recessed, to reconvene at 1:30 p.m. the same day.)

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

1 AFTERNOON SESSION

2 (1:32 p.m.)

3 Whereupon,

4 ROBERT W. KEATEN

5 MICHAEL J. ROSS

6 ROBERT C. JONES

7 recalled as a witnesses by counsel for the Licensee,
8 Metropolitan Edison Company, having previously been duly
9 sworn by the Chairman, were examined and testified further
10 as follows:

11 MR. BAXTER: Mr. Chairman, I have determined that
12 I have no additional rebuttal questions, so the witnesses
13 are available for cross examination.

14 BOARD EXAMINATION

15 BY DR. JORDAN:

16 Q I will probably have questions after the staff has
17 cross examined. But there was one thing I was curious
18 about. On September 26 last year the Commission came out
19 with a proposed rule on interim requirements related to
20 hydrogen control and certain degraded-core considerations.

21 Among the features of the proposed rule, the
22 requirements of the proposed rule, is the following: By
23 January 1, 1982, each boiling and pressurized light water
24 nuclear power reactor -- oh, yes, if you would like to read
25 that, it is on almost the end of the proposed rule, which is

1 page 33, according to my document, but yours will be
2 paginated differently.

3 Now, do you find at the end, do you find Chilk's
4 signature at the end of the proposed rule? All right, up
5 from that, the paragraph above that is G.

6 MR. BAXTER: It is F, isn't it, Dr. Jordan?

7 DR. JORDAN: I must be talking about -- there are
8 two proposed rules on degraded core cooling, and I suspect
9 we are talking about different ones.

10 CHAIRMAN SMITH: I think you probably came up with
11 the early one, which was not even a proposed rule but it was
12 -- well --

13 WITNESS KEATEN: This was taken from the Federal
14 Register on October 2. It's item G, labeled "Training to
15 Mitigate Degraded Core Accidents."

16 CHAIRMAN SMITH: No, that is the early --

17 DR. JORDAN: The last paragraph in mine is
18 "Training to Mitigate Degraded Core Accidents." That is
19 right. But just above that I have item 4 and item 3. Item
20 3 I was starting to read from. Do you see that?

21 WITNESS KEATEN: Yes.

22 BY DR. JORDAN:

23 Q It says -- and I will repeat: "By January 1,
24 1981, each boiling and pressurized light water nuclear power
25 reactor shall be provided with instrumentation such that a

1 reactor vessel water level indicator which supplies to the
2 control room a recorded unambiguous direct indication of
3 inadequate core cooling. The indication must cover the
4 complete range from normal operation to complete core
5 uncovering and give advanced warning of the approach of
6 inadequate core cooling."

7 Now, my first question, this proposed rule was put
8 out for comment and comments were due in before November 30
9 -- November 3, 1980. Did B&W or Met Ed comment on this?
10 And if so, what were their comments?

11 A (WITNESS JONES) I do not know from B&W's
12 standpoint.

13 Q I see. All right. Okay. I note that you would
14 then differ with the requirement to have a reactor vessel
15 level indicator.

16 Do you also disagree with the second sentence,
17 which states: "The indication must cover the complete range
18 from normal operation to complete core uncovering and give
19 advanced warning of the approach to inadequate core
20 cooling"?

21 Do you feel that such -- that there is a need for
22 such instrumentation which will give advanced warning of
23 inadequate core cooling and will cover the complete range
24 from normal operation to complete core uncovering?

25 A (WITNESS JONES) Well, it is the B&W position

1 right now, I believe, that the in-core thermocouples cover
2 the range from normal operation to accident conditions,
3 provide direct, unambiguous, direct indication of inadequate
4 core cooling, and also provides the approach to it. That is
5 the B&W position right now.

6 DR. JORDAN: All right. Fine.

7 (Board conferring.)

8 CHAIRMAN SMITH: Did you cover complete core
9 uncovering in your answer? Which was a part of the question,
10 is the only reason I raise it.

11 WITNESS JONES: I believe the in-cores would also
12 be satisfactory for complete core uncovering. The only
13 hesitancy I might have on that would be if you really have
14 the core totally uncovered for a prolonged period of time, I
15 am not sure that the thermocouples could withstand the
16 excess of temperatures which could result. That is my only
17 limit on that.

18 DR. JORDAN: Okay. That is all for the present.
19 Go ahead, Mr. Cutchin.

20 CHAIRMAN SMITH: How do you want to proceed, Mr.
21 Cutchin, Mr. Adler, is there a preference?

22 MR. CUTCHIN: I have no preference.

23 CHAIRMAN SMITH: You have a preference, Mr.
24 Adler?

25 MR. ADLER: Yes. Mr. Dornsife had prepared for

1 this, so I prefer Mr. Cutchin to go.

2 CHAIRMAN SMITH: All right.

3 CROSS EXAMINATION

4 BY MR. CUTCHIN:

5 Q Mr. Jones, I will be asking you several questions
6 to begin with, based on your written prefiled testimony. I
7 will be referring first to page 4 of that prefiled
8 testimony. In the middle of page 4, the second full
9 paragraph reads that, "Obviously, the goal of assuring
10 adequate core cooling is ongoing and is achieved by
11 maintaining subcooled conditions in the reactor coolant
12 system (RCS) or, in the absence of such conditions, by
13 providing sufficient reactor coolant inventory."

14 How do you propose that reactor coolant inventory
15 be measured after subcooling is lost?

16 (WITNESS JONES) Well, it is not really -- we are
17 not proposing to measure reactor coolant inventory. Rather,
18 what that statement is meant to mean is if you do not
19 maintain subcooled conditions in the reactor coolant system,
20 you should provide high-pressure injection to the system to
21 maintain sufficient inventory.

22 The calculations show that if you keep the HPI
23 pumps running, you would provide enough inventory to ensure
24 adequate core cooling.

25 Q Now, referring to page 5, the parenthetical

1 statement which begins at the end of the continued paragraph
2 at the top of the page, it says: "At IXI-2 saturated
3 conditions were indicated several minutes after the reactor
4 tripped and if sufficient injection flow had been
5 maintained, the core would have been adequately cooled and
6 not damaged."

7 Do you not believe that had an indication of
8 reactor water level been available, it might have aided the
9 operators in recognizing that sufficient injection flow was
10 not being maintained and thereby possibly enable them to
11 have prevented core uncovering?

12 A (WITNESS JONES) Well, first off, you have to
13 remember initially in the transient you have the reactor
14 coolant pumps running for something on the order of the
15 first 100 or 101 minutes, I believe it was. The reactor
16 coolant pumps remained continuously operative, at least two
17 of them. Under that situation, something that measures
18 water level would have been quite useless because of the
19 slow delta phi, et cetera.

20 I am not sure what kind of signal you would have
21 got. You would have got a pressure drop across the core
22 which would have had to somehow compensate out. And the
23 fact that it was a two-phase fluid would have also had to be
24 taken out. It would be difficult.

25 Now, after -- after the pumps were tripped, I am

1 not so sure I could really say what the operators would have
2 done. It might have been an aid, but, you know, the
3 operator would have been faced at that time with a full
4 pressurizer level, as he was, an indication that the core
5 was uncovered, if he had a vessel level meter.

6 Which one of those two the operator would have
7 then chosen to believe, I just cannot guess at. He might
8 have chose the vessel level. He might have chosen to still
9 believe the pressurizer level. So I really cannot give you
10 a good answer. Just that it might have been an aid.

11 Q Now, you have seemed in several instances during
12 your testimony today to base your measurement of core water
13 level primarily on DT cells. And I believe in the document
14 which was filed by Babcock & Wilcox, entitled "Evaluation of
15 Instrumentation to Detect Inadequate Core Cooling," prepared
16 for the 177 owners group, which was referred to this
17 morning, you list a number of methods which were examined by
18 B&W in their evaluation of instrumentation to detect core
19 water level or inadequate core cooling.

20 Did you in that evaluation consider use of heated
21 thermocouples?

22 DR. JORDAN: Was that heated thermocouples?

23 MR. BAXTER: Heated thermocouples.

24 WITNESS JONES: In the evaluation in the report
25 that we referenced earlier, we -- I do not believe we

1 examined -- looking at it, there is no statement as to that
2 heated thermocouples were evaluated. I know of the concept
3 of using heated thermocouples to detect water level in the
4 upper plenum. And I believe some of the vendors are looking
5 at this.

6 But, in general, it still comes down to the same
7 thing. I do not believe that any level measurement
8 technique offers any additional action or any additional
9 benefit.

10 BY MR. CUTCHIN:

11 Q It appears that you at least -- the position that
12 is being taken by the Licensee and B&W is that superheat
13 detection via the thermocouples, the in-core thermocouples,
14 is an adequate means of detecting inadequate core cooling.
15 However, again, on page 5 of your prefiled testimony, you
16 refer in the first full paragraph in the center of the page,
17 you make the statement that, "As explained below, this
18 indication -- meaning the superheated reactor conditions --
19 would allow time for corrective action before the limits of
20 10 CFR 50.46 would be exceeded."

21 You say, "Again, core water level instrumentation
22 would not provide a basis for any additional action." And
23 you point out that, "During the accident at TMI-2,
24 indications of superheating in the reactor coolant system
25 were available."

1 And I am asking the same question: Wouldn't it
2 have been of some use in helping the operators to believe
3 other indications that they had available to them but did
4 not use, if they had had an indication of core water level?

5 A (WITNESS JONES) As I said, it is just highly
6 speculative. I cannot really answer the question. It may
7 have. And again, he may not have believed it, because it
8 would have been an instrument that would have read off scale
9 for -- during normal operation continuously, and one that
10 may have moved around during the transient. I don't know
11 whether he would have believed it or not. I just do not
12 know.

13 Q Mr. Ross, as one responsible for operations, do
14 you have an opinion on that question?

15 A (WITNESS ROSS) You must remember that the
16 training evolutions we have gone through have been
17 significantly different since the accident. Thermocouples
18 were available, but they were not trained on the
19 thermocouples. Today they are.

20 I still feel with no training available, with the
21 vessel level displayed to them, the fact that it did not
22 move, did not respond when the plant did significant
23 changes, like a plant startup or a plant shutdown, the
24 operator would not have relied on that indication.

25 Q Mr. Keaten, just so you won't feel left out, this

1 morning in your testimony, I believe, you indicated that the
2 procedures for Three Mile Island Unit 1 have been modified
3 to aid the operators in recognizing TMI-2 type events and
4 the recent St. Lucie-type events.



5 Are you now comfortable with the belief that core
6 water level indications would not be helpful to the operator
7 in recognizing other types of anomalous situations that
8 might occur? You seemed pretty positive that they would not
9 aid him in recognizing those two. But are there others?

10 A (WITNESS KFATEN) It is, of course, very difficult
11 to give a positive answer to a question which says is there
12 some unknown thing out there. And so I think I can only
13 answer in terms of the work that has been done, which has
14 been to attempt to identify any use that we would make or,
15 more accurately, any use the operator would make, of such
16 information.





17 And as I said this morning, we have not been able
18 to identify any circumstance where we could identify any
19 action that he would take that is new or different compared
20 to the actions that he is already instructed to take based
21 upon the existing information.



22 I cannot sit here and swear that there is -- you
23 know, that we have all knowledge in the world. Obviously,
24 we do not have all knowledge.

25 My concern, though, is that I am reluctant to see







**IMAGE EVALUATION
TEST TARGET (MT-3)**





**IMAGE EVALUATION
TEST TARGET (MT-3)**



1 us install any instrumentation that we do not know how to
2 use it, when at the same time we are installing something
3 that we do know could be confusing to the operator and at
4 least has the potential for leading him to take the wrong
5 action.

6 MR. CUTCHIN: Thank you. I have no further
7 questions of these witnesses, Mr. Chairman.

8 CHAIRMAN SMITH: Mr. Dornsife.

9 MR. DORNSIFE: I just have to say, Mr. Chairman,
10 you paid me back this morning; you destroyed my
11 cross-examination plan.

12 CHAIRMAN SMITH: I am sorry, I did not hear Mr.
13 Dornsife.

14 MR. DORNSIFE: I said you paid me back this
15 morning; you destroyed my cross-examination plan.

16 CHAIRMAN SMITH: As a matter of fact, no. There
17 were questions that Dr. Jordan pointed out were on your
18 cross-examination plan. So we will complete it if you
19 wish.

20 MR. DORNSIFE: I still have questions.

21 (Laughter.)

22 MR. CUTCHIN: I have the same problem. The Board
23 saved me a lot of time as well, Mr. Chairman.

24 BY MR. DORNSIFE:

25 Q I have a general question to start off. Maybe Mr.

1 Keaten is best able to address this. Your scheme of things,
2 the way you envision now with the procedures and instruments
3 that are available, is it true that the t-sat meter is
4 relied upon to detect approached inadequate core cooling and
5 the thermocouples themselves are used to determine
6 inadequate core cooling is taking place? Is that basically
7 how the scheme works?

8 A (WITNESS KEATEN) It is along that line. But let
9 me be careful in the way that I use the terms. If we
10 define, as has been done in the testimony here, inadequate
11 core cooling to refer to that condition in which the fuel
12 temperatures exceed the limits of 10 CFR 50.46, then the
13 inadequate core cooling guidelines, as they appear in the
14 TMI procedures as taken from the B&W guidelines, are used as
15 an indication of the approach to inadequate core cooling.

16 They show conditions where the fuel temperature is
17 higher than would have been predicted from the LCCA analysis
18 but still below the limits imposed by 10 CFR 50.46. And the
19 actions that are called up in the inadequate core cooling
20 guidelines are designed to prevent the temperatures from
21 reaching or exceeding the limits of Part 46.

22 Still using the terms in the same way then, I
23 think it would be accurate to say that the t-sat meters are
24 used as an indication that there has been a substantial loss
25 of reactor coolant inventory either due to shrinkage or due

1 to a LOCA or whatever.

2 That requires the operator to add coolant to
3 restore the normal subcooled conditions in the reactor
4 coolant system. This may be done automatically by the
5 emergency core cooling system, or it might be done manually
6 by the operator, depending upon the particular event.

7 So, really, in summary then, I would view the
8 t-sat meters as the indication that when the subcooling
9 margin is lost, that inventory needs to be added and the
10 core thermocouples as an indication that for an unknown,
11 undefined reason that the ECCS system is not operating as
12 designed and that there is starting to be an approach in the
13 direction of inadequate core cooling.

14 Q Mr. Jones, are you generally familiar in detail
15 with the TMI-2 accident scenario? Thermohydraulically,
16 anyway?

17 A (WITNESS JONES) Yes.

18 Q Maybe it would help to have you describe when --
19 if these instruments were available during the TMI-2
20 accident, when they would have indicated that the condition
21 would have existed, like, for example, when the t-sat meter
22 would have first identified that you are approaching
23 saturation conditions and when if a water level instrument
24 were available, when that would have first indicated that
25 the core level was going down and when the thermocouples

1 first started going -- increasing in temperature, and the
2 whole -- all the instruments that are now available, how
3 would they have responded?

4 A (WITNESS JONES) Okay, let me take a crack at it.

5 Well, following the initial event, the primary
6 system remained subcooled for about five to 5-1/2 minutes,
7 something on that order. At that point in time, saturated
8 conditions were reached in the hot leg, indicative of
9 something that inventory needed to be restored.

10 Now, all during -- from the beginning of the
11 accident to about 100 minutes into the accident, the reactor
12 coolant pumps were operating. And with the reactor coolant
13 pumps operating, I do not believe any level detections came,
14 such as a water level based on the DT cell or something of
15 that order, or a heated thermocouple. I am not so sure
16 either of them would have picked up any core or loss of
17 coolant inventory in the system because the pumps were on.

18 Now, 100 minutes after they tripped the reactor
19 coolant pumps, at that point in time, I believe what you
20 would have seen if you had a level instrument, you would
21 have seen that you had a bundle somewhere within the reactor
22 vessel head, probably down near the hot leg nozzles, maybe
23 even a little lower. The hot leg thermocouples, or RTDs, at
24 that time were reading saturated -- the in-core
25 thermocouples, although there were no readings available,

1 were also going to be indicating saturated conditions at
2 that time.

3 Now, it is debatable as to exactly when the core
4 uncovered. So I cannot give you a good estimate on when the
5 various instruments would have indicated superheated
6 conditions. But I would estimate that certainly before 110
7 minutes; that is about 10 minutes after the reactor coolant
8 pump trip, the hot leg RTDs were indeed superheated.

9 Now, between 100 and 110 minutes, it is possible
10 that the in-core thermocouples would have read superheated
11 conditions. In the -- well, it would definitely have, and
12 it probably would have been earlier than the hot leg RTDs
13 due to the transport time differential to move from the core
14 up the hot leg to the hot leg RTD.

15 At that point in time, you would have had
16 superheated conditions, and the operator would be starting
17 to use the inadequate core cooling guidelines. As far as
18 thereafter how the instruments would have read, it is
19 difficult to say. But they would have passed the various
20 threshold sometime over that period.

21

22

23

24

25

1 Q Once the core heat-up began, how long did it take
2 before fuel damage started occurring from the time heat-up
3 first began? Do you have any idea?

4 A (WITNESS JONES) There are various estimates, but
5 I believe in general it would be about 40 minutes, somewhere
6 about 30 to 40 minutes after the core uncovered. You
7 probably have some fuel damage; that is, ruptures of the
8 cladding.

9 Q Was that the 1400 degrees you were talking about
10 basically?

11 A (WITNESS JONES) Basically around 1400 degrees,
12 something on that order.

13 Q It starts occurring at 1400 degrees, but it is not
14 -- it is not cladding reaction with water, is it?

15 A (WITNESS JONES) No. To try to define that, the
16 1400 is more of a ballpark number. What you have is you
17 have a stress built up across the fuel rod from the internal
18 pressure of the rod and the external pressure in the reactor
19 coolant system. If the temperature reaches a certain point,
20 the stress temperature combination reaches a certain point,
21 the cladding will rupture

22 Somewhat previous to that it will start to expand
23 and become caustic, and it will -- shortly thereafter it
24 will rupture if it continues to heat up.

25 Q I guess the obvious next question is why then is

1 the limit 2200 for ECCS analysis and not 1400 where damage
2 begins to occur? What is the differences? Why the higher
3 limit for ECCS?

4 A (WITNESS JONES) Well, the ECCS limits deal with
5 the ultimate structural integrity of the cladding. Okay.
6 The fact that the cladding ruptures and balloons and can
7 cause some core blockage is not necessarily an unsafe
8 condition. You can cool the core in a blocked condition,
9 and in fact you are required to analyze by Appendix K,
10 Cladding Ruptures and Subsequent Feedback on the Transient
11 and the Clad Heat-up; 10 CFR.46 limits that deal with
12 basically the structural integrity of the cladding are the
13 2200 degree temperature limit, in combination with the 17
14 percent local oxidation limit of the cladding.

15 What those two in combination mean is that if you
16 satisfy those two and thermally shock the cladding -- that
17 is, suddenly cover the cladding with cold water, below those
18 thresholds, the combined threshold, the cladding will remain
19 ductile and will not shatter, become embrittled.

20 Above that it has a potential for embrittlement.
21 At the time that was essentially an embrittlement limit
22 today -- based on knowledge today, they are a very
23 conservative set of limits, but that was the basis for the
24 limits at that time.

25 Q In your analysis of inadequate core cooling, did

1 you come across any potential scenarios where the margin to
2 saturation would not be an adequate indication of actual
3 conditions in the core? Is there any possible scenario
4 where that could give you a fleeting indication?

5 Like, for example, could pockets of hot air
6 trapped near the RTDs give you an accurate reading of the
7 actual conditions?

8 A (WITNESS JONES) Well, for the initial indication
9 of saturated conditions, no, I do not know of any situation
10 where you get high temperature readings locally, excessively
11 high temperature readings locally at the hot leg RTD that
12 would not be indicative of overall system saturation, or at
13 least a good portion of the system being saturated.

14 If you had gone through a complete accident and
15 had come through, uncovered the core, went through an
16 inadequate core cooling situation and then recovered the
17 core, it is quite possible at that time that the Haflich RTD
18 could be reaching superheated conditions due to a gas trap,
19 such as hydrogen generated from metal-water reaction, where
20 it would be reading, say, superheat while the core
21 exothermocouples would be reading saturated, and in fact,
22 the recovery process is more based on the getting the
23 transfer from the inadequate core cooling guidelines back to
24 the normal small break guidelines based on the recovery
25 indications from the in-core thermocouples, not the hot leg

1 RTD.

2 Q How about the other way around? Are there any
3 possibilities of the core being saturated, but the RTD's
4 seeing sub-cooled temperatures?

5 A (WITNESS JONES) It is possible that you could
6 have local regions in the core be in a saturated condition,
7 such as the hot rod being in somewhat saturated conditions
8 while you have subcooled indications on the hot leg RTDs.
9 But that does not mean it is not providing adequate cooling,
10 but that is a situation there that you could -- is possible.

11 I am not sure about ATWS, anticipated transients
12 without scram. It may be possible in those type of
13 transients where you could get into that type of situation,
14 voiding in the core while at the same time being subcooled
15 on Haflich RTDs.

16 I would expect that to be somewhat momentary.
17 There are probably other reactivity type control rod
18 withdrawal transients or control rod ejection type
19 transients, where again you may get the local boiling within
20 the core, yet still see subcooled conditions on the hot leg
21 RTDs, but for that case, like the other, that would still
22 provide adequate cooling of the core.

23 Q How about if noncondensable gases were saturated?
24 How would that affect the various -- especially the pre-fat
25 indication?

1 A (WITNESS JONES) Well, I think -- that is what I
2 was getting at before. If you went through an inadequate
3 core cooling situation and a generated hydrogen or you had
4 some other noncondensable gases in the system, it is
5 possible that that gas will form a block in the reactor
6 coolant system such that as the water level tries to rise,
7 it is sitting at the RTD and would be reading superheat.
8 Yet the core could indeed be covered with water.

9 Q Are any of you gentlemen familiar with some of the
10 interviews of the operators concerning why they did not
11 believe the hot leg temperature readings?

12 A (WITNESS KEATEN) Yes, I am.

13 Q Are you aware specifically of one of the
14 interviews with Leland Rogers, the BMW representative who
15 said the reason he did not believe the hot leg temperatures
16 is because he saw those temperatures higher than saturated
17 conditions of the previous time.

18 Do you recall any of that interview?

19 A (WITNESS KEATEN) I am not specifically familiar
20 with the interview with Lee Rogers. No, I am not. For the
21 benefit of the Board, he was a BMW representative at the
22 plant.

23 I have talked to some of the Met Ed operators.

24 Q Can you maybe give us some analysis of why they
25 did not believe it?

1 A (WITNESS KEATEN) Of the persons that I have
2 talked to, the majority of them have said that they were not
3 aware of the actual readings, although they were aware that
4 the computer printout was showing question marks.

5 Q I am talking about the hot leg temperatures.

6 A (WITNESS KEATEN) Oh, excuse me. I am on the
7 wrong topic. Pardon me.

8 Q Wasn't the range of the TMI to hot leg RTDs up to
9 about 800 degrees?

10 A (WITNESS KEATEN) There was one that went up that
11 high, but the normal range was not that high. It is 620.
12 Actually, the operators that I talked to that were in the
13 control during the critical portion early in the accident --
14 I have not had any of them tell me that they did not believe
15 the higher readings.

16 You have to realize that Mr. Jones has said for
17 the first 100 minutes when the coolant pumps were still
18 running, the coolant was in fact being cooled and the
19 temperatures were normal. When the operators turned off the
20 final pump in the A-loop in an attempt to establish natural
21 circulation, shortly thereafter the temperatures in the hot
22 leg RTDs started going up, and the operators did see this
23 and they did attempt to respond to it.

24 They tried to respond to it by attempting to
25 restart the reactor coolant pumps, recognizing that

1 something adverse had happened when they turned off the
2 pumps, and this is where they got into the situation where
3 they found they could get the pump to turn.

4 But they had no indication there was pumping
5 fluid, so they were in fact trying to respond to those
6 elevated readings.

7 The other thing is that the operators have
8 testified that in the timeframe where they turned off the
9 reactor cooling pumps -- and we do not have accurate data on
10 this -- that in this timeframe they did take action to
11 reinitiate the emergency core cooling flow.

12 Now, this is a portion of time where we are
13 missing some of alarm summary data, and so I do not know
14 times and intervals, but this is what the operators remember
15 that they had done.

16 So I think a reasonable conclusion is that they
17 did believe them, at least in the sense of recognizing that
18 they needed some actions that they were not taking.

19 Q The main problem, they were just not trained to do
20 the right things to respond to that.

21 A (WITNESS KEATEN) That is certainly a part of it.
22 I think the other part of it is that by this time sufficient
23 inventory had been lost that the actions were not as
24 clearcut as they would have been much earlier in the
25 transient.

1 Q Going to the t-stat meter itself, will this be a
2 safety grade instrument, and if not, what is lacking on
3 being a safety grade instrument?

4 A (WITNESS KEATEN) Let me double-check.

5 (Pause)

6 In general let me tell you that the instrument is
7 not fully safety grade, but it is sort of the category that
8 I might characterize as nearly safety grade.

9 The equipment will meet the environmental design
10 conditions. It is seismic.

11 DR. JORDAN: It is what?

12 WITNESS KEATEN: Seismically qualified. The
13 separate requirements are met.

14 DR. JORDAN: So it is redundant?

15 WITNESS KEATEN: It is redundant. There are two
16 t-stat meters, one for each of the hot legs.

17 BY MR. DORNSIFE:

18 Q Are there two separate readouts or just one?

19 A (WITNESS KEATEN) There are two separate
20 readouts. The equipment in the cabinets -- that is, the
21 electronics that drives the output and so forth is in fact
22 nuclear safety related and Class I-E, but I believe the
23 difference is in the indicators and perhaps the cabling from
24 the signal conditioning equipment to the indicators.

25 I do not believe that those are safety grade. But

1 they are very high quality equipment.

2 Q I guess that was my next question. These are
3 digital readout?

4 A (WITNESS KEATEN) These are digital readouts.

5 Q Are these the only digital indicators you have in
6 the control room?

7 A (WITNESS KEATEN) No, they are not, and certainly
8 new equipment that we are installing, there is more than one
9 digital.

10 Q I am wondering how a digital meter compares in
11 reliability, say, to another type of meter, that that is a
12 hard-wired type of device. Is there any difference in
13 reliability between those digital and any experience in
14 those types compared to a gauge, let's say, or something --
15 something on that order that is more familiar on control
16 room panels.

17 A (WITNESS KEATEN) I am not terribly knowledgeable
18 in this area, Mr. Dornsife, but it is my impression that the
19 model digital display meters that can be purchased now are
20 in fact a high reliability display unit, and they have a
21 tremendous advantage in terms of the precision with which
22 they can be read, and that is the reason that we are going
23 to digital indicators in several of the applications.

24 Q I assume from human engineering, too, they are
25 easier to read.

1 A (WITNESS KEATEN) Yes, that is true, particularly
2 where it is necessary to read them accurately.

3 Q Why was the 50 degrees subcooling chosen for the
4 limit for the procedures? What is the basis of the 50
5 degrees?

6 A (WITNESS JONES) I cannot remember the specific
7 numbers that went into coming up with this, something on the
8 order of 50 degrees, but basically what it was was we wanted
9 to assure an indicated or a real subcooled margin of at
10 least 10 or 20 degrees.

11 I cannot remember the exact number, but we wanted
12 to be several degrees away from the saturation line, and
13 then on top of that, what we placed was instrument errors
14 for the hot leg RTDs and the system pressure indication,
15 which translates back into a temperature -- potential
16 temperature error.

17 Those were utilized, and I do not remember how the
18 exact number came out, 40 or 45. It came out in that
19 ballpark for the instrument we were looking at -- using, so
20 we chose 50 to be a nice, round number ultimately.

21 Q You say in your testimony there is an alarm
22 associated with a t-stat meter. Is that alarm on the main
23 alarm panel, and is it going to be the one -- one of the
24 alarms that is especially coded?

25 A (WITNESS KEATEN) Mr. Dornsife, you are right at

1 the limit of our design. As a matter of fact I was on the
2 telephone on exactly that subject during the luncheon
3 break. It is my present anticipation that that probably
4 will be one of the ones that is color-coded. It will
5 certainly be enunciated in the control room, and we are
6 still in the process of debating just where it is.

7 Let me also take the opportunity to add to my
8 previous answer. In looking at the information I have with
9 me with regard to the extent that it is safety grade, I
10 believe that it is also true that at least in the
11 modifications that we are doing prior to restart, that the
12 centers that we are using for the saturation are perhaps not
13 safety grade sensors, although the new cabinets and signal
14 conditioning equipment that is being installed are safety
15 grade.

16 Q You say the sensors?

17 A (WITNESS KEATEN) Right.

18 Q RTDs?

19 A (WITNESS KEATEN) RTDs and/or the coolant
20 pressure. You understand the in the system there are both
21 safety grade and non-safety grade RTDs and pressure signals
22 and so forth. And I believe from what I can read in the STD
23 here that the sensors that are being used at the present
24 time for the t-stat meter are non-safety grade sensors.

25 Q So they are not the same -- the same sensors that

1 go to the safety system?

2 A (WITNESS KEATEN) That is correct.

3 Q Was there a problem with making the same sensors
4 as far as saturation? Is that why you chose non-safety
5 sensors? It would seem that this instrument has to be a
6 very reliable insurance because it is the basis basically
7 for the small break loss of coolant procedure, and it should
8 be a very important instrument.

9 I am wondering why you chose not to use
10 safety-related sensors.

11 A (WITNESS KEATEN) I think there are probably a
12 couple of answers to that. One is that as you can
13 understand, in tying into equipment which is presently going
14 to the protection of the system, it is necessary to be extra
15 careful and make sure nothing is done that would interfere
16 with the capability of the protection system to perform its
17 function.

18 Furthermore, in this particular case -- and maybe
19 others could answer clearer -- it is my impression that the
20 non-safety grade sensors and the 50 grade sensors are pretty
21 much the same thing, other than perhaps paperwork and so
22 forth.

23 It is certainly true that we want this to be a
24 highly reliable instrument, and we indeed to have it a
25 highly reliable instrument, but let me also point out that

1 if for some reason this meter or meters are not available,
2 the operator still does have available to him the safety
3 grade temperature instrument and the safety grade pressure
4 instrument, and he can himself calculate saturation margins
5 so there is a safety grade fallback position if this meter
6 were not available.

7 DR. JORDAN: Well, Mr. Keaten, in that connection
8 wouldn't it also -- isn't it also designed to have the
9 t-stat meter completely separated from the meters which tie
10 into the safety system in that the operator is controlling
11 from the t-stat meter and to have that tie in with the same
12 meter that are used in the safety equipment seems to me
13 would be a gross violation of the separation of safety
14 equipment from operating equipment.

15 WITNESS KEATEN: I think it is correct, Dr.
16 Jordan, that there are some advantages to having separate
17 instrumentation. It is my understanding of the regulations
18 that in fact it would be possible to have the t-stat meter
19 use the same sensor using appropriate isolation devices and
20 so forth in a way that would meet, for example, IEEE-279.

21 But personally I am just as happy to have it use a
22 different sensor.

23 DR. JORDAN: I guess you are right, because I
24 remember now complaining about the integrated control system
25 also getting information on power from the meters that also

1 provide for the scram, and to my mind I think that is a
2 violation of 279.

3 BY MR. DORNSIFE:

4 Q How about power supplies to these sensors? How
5 reliable are they?

6 A (WITNESS KEATEN) They are powered from either
7 onsite or offsite power, so loss of offsite does not lose
8 the function.

9 Q Are they used for anything else, these sensors?
10 Are they tied to the ICS or something?

11 A (WITNESS KEATEN) I think they probably are used
12 for normal indication. I am sorry. I just do not know
13 whether these are the same ones that feed the ICS or not.
14 They might be the same ones that go to the ICS.

15 Q About the backup capability of determining t-stat
16 on the computer, what sensors does that use? Do you know?
17 Are they the same, or are they the safety-grade sensors?

18 A (WITNESS KEATEN) I believe that our intent had
19 been to use the same sensors to feed the computer as is
20 feeding the t-stat meter, to independently calculate the
21 saturation margins so we would not use the output from the
22 saturation margin meter itself, but would use the same
23 temperature and pressure information to calculate the
24 saturation margin.

25 DR. JORDAN: Mr. Dornsife, I guess I do not know

1 how a t-stat meter works. know it works with indications
2 -- taking as input the pressures and temperatures, of
3 course. Is there a simple -- could you describe simply how
4 it works, because I notice, for example, in some of the --
5 either the questions that were asked somewhere or other,
6 there was a problem raised as to whether you were
7 approaching from the pressure side or the temperature side,
8 and it reminded me that I did not understand exactly how the
9 t-stat meter worked.

10 WITNESS KEATEN: The ones we are installing prior
11 to restart, Dr. Jordan, are meters which will indicate the
12 temperature saturation margin, and so basically the way the
13 meter works is to take the reactor coolant system pressure
14 and calculate the saturation temperature associated with
15 that pressure, and then subtract that from the actual
16 measured temperature.

17 DR. JORDAN: I see. Where is that calculation
18 done?

19 WITNESS KEATEN: It is done in a separate
20 electronic unit that goes with the equipment.

21 DR. JORDAN: I see. It has the steam tables built
22 into it.

23 WITNESS KEATEN: Yes, sir, and I'm not sure
24 whether it is a digital or analog calculation.

25 DR. JORDAN: Okay.

1 BY MR. DORNSIFE:

2 Q The next line of questioning I have involves the
3 core exit thermocouples. First of all, what -- what
4 typically is their range? What will be their range prior to
5 restart of the instruments? What is their accuracy?

6 A (WITNESS KEATEN) I believe to the best of my
7 memory that the computer software that we are using to
8 translate from mid-vals to degrees Fahrenheit goes to -- it
9 is on the order of 2200 degrees Fahrenheit. Maybe it is
10 23. I am not sure exactly, but it is of that kind of number.

11 Q Do you have any feel for their accuracy?

12 A (WITNESS KEATEN) These are standard type
13 K-chromel-alumel thermocouples, and my experience with them
14 has been that the accuracy is very good, assuming that the
15 thermocouple is working.

16 I am not sure I have a good number to give you,
17 frankly.

18 Q Is the only way to read them from a computer? Are
19 there any other ways of reading the temperatures besides the
20 computer?

21 A (WITNESS KEATEN) The only hard-wired method that
22 we have at the moment is to the computer. However, it is
23 possible for the operator to take a portable meter and go to
24 the terminal board, for example at the input of the computer
25 multiplexers and read the millivolts there, and convert that

1 using the table to temperature.

2 Frankly, we are right now in the act of evaluating
3 just how quickly and readily that could be done, and whether
4 or not there may not be another method.

5 Q That was my next line. I was wondering how much
6 you were going to pursue that considering that was a major
7 problem during the TMI 2 scenario, people believing those
8 readings and actually taking the volt meter readings from
9 the hard-wired portion and transferring them to numbers, and
10 making any sense out of them. I wonder how far you are
11 going to pursue that.

12 A (WITNESS KEATEN) We are going to pursue it. I
13 think there are two different reasons why we are going to
14 pursue it. One is our own incentive. I have, I think, in
15 earlier testimony told the Board that we tried not to be in
16 the situation in TMI where we relied on the computer as the
17 only method of getting information.

18 Here is a case where we are tapping on the
19 operators' being able to read the in-core thermocouples and
20 so, in line with our own philosophy, we are going to explore
21 how practical it is for him to do it with the portable
22 meter, or whether there might not be another method.

23 In addition to our own requirements, I might point
24 out that new reg 737 imposes requirements for a backup
25 method of being able to read at least a portion of the

1 thermocouples and also specified a time within which a
2 certain number of thermocouples must be able to be read.

3 And so we will also be addressing that requirement
4 in new reg 737.

5 Q That was my next question, since you brought it
6 up. Are you going to be meeting all the requirements on
7 Attachment A in new reg 0737? Are you committing to do that
8 for the in-core thermocouples?

9 A (WITNESS KEATEN) Honestly, Mr. Dornsife, we are
10 right now in the process of evaluating those requirements.
11 As you are aware, Attachment A has quite a few different
12 requirements. We certainly will have to address all of
13 those requirements.

14 There are a couple of them that I in my own mind
15 right now am not sure how to meet, so we are presently --
16 have already had dialog with the NRC staff on the subject of
17 those requirements, and the subject of the schedule on which
18 we would be meeting the requirements.

19 We are starting to address them.

20 Q Is it your position at this point that these
21 in-core thermocouples would be the principal way of
22 detecting inadequate core cooling?

23 A (WITNESS KEATEN) Yes. Yes, that is our position,
24 but let me also state again, as I am sure you recognize,
25 that inadequate core cooling scenario that we are talking

1 about is an event beyond the design basis of the plant, and
2 -- but in that case, yes, we have given instructions in the
3 procedures that the operators should monitor the in-core
4 thermocouples as a method of detecting that non-design basis
5 event.

6 Also, I would like to -- just to make sure the
7 record is clear -- as far as the problem that was faced by
8 the operators in using the in-core thermocouples during the
9 TMI 2 transient, the problem was the computer software which
10 had an algorithm that translated millivolts into temperature
11 readings only up to a temperature of 700 degrees Fahrenheit,
12 and that of course has been corrected at TMI 1.

13 Q So is that basically the only difference between
14 the thermocouple installation on TMI 2 and TMI 1, just the
15 fact that you extended the range on the computer? Are there
16 any differences besides that?

17 A (WITNESS KEATEN) In terms of changes that we have
18 made, I would say, no, not really. The situation is a
19 little bit different between the two units in that as you
20 may remember, the in-core thermocouples in unit 1 were not
21 connected up prior to the accident.

22 And so we had to go through the act of rewiring
23 them into the control room and connecting them to the
24 computer, which had been done at TMI 2 and not been done at
25 TMI 1. In the process of doing this, there were some

1 details that resulted in some differences in the
2 installation, the physical installation, particularly the
3 fact that the thermocouples at TMI unit 1 did not terminate
4 in a reference junction, as they had at -- or a cold box as
5 they had at TMI 2.

6 Therefore, for the installation at TMI unit 1, we
7 measure the temperature at the physical location where the
8 reference junction or the transition from chromel-alumel is
9 located, and then we analytically do the calculation to
10 correct for the temperature at that location, rather than
11 having a fixed reference junction, as TMI 2 had.

12 But these are the details of the installation. As
13 far as the readout in the control room, it is via the
14 computer as far as the reference readout is concerned.

15 Q As far as the reliability, are they capable of
16 being powered from onsite and offsite power supplies, and
17 generally a very reliable piece of instrumentation?

18 A (WITNESS KEATEN) The thermocouples themselves, in
19 my experience, are very reliable pieces of instrumentation.
20 They are among the most reliable pieces of instrumentation.

21 The power supply consideration really comes up in
22 association with the computer, and yes, it is capable of
23 being powered from either onsite or offsite powers.

24 Q Thermocouples themselves have no requirement for
25 power. They are self-powered devices.

1 A (WITNESS KEATEN) That is right. They do generate
2 the millivoltage themselves. My only uncertainty in that is
3 I am not exactly sure what we are using to measure the
4 temperature at the position of the reference junction, and
5 if that is an RTD it would require power.

6 Q Do you have any idea what the design, the maximum
7 design temperature gives when they would start melting and
8 no longer be giving useful information?

9 A (WITNESS KEATEN) It is my understanding -- in
10 fact, it is my experience that type K thermocouples have
11 been used usually inadvertently to measure temperatures as
12 high as 1,500 degrees Fahrenheit, although that is certainly
13 well above the normal high range of such thermocouples.

14 My memory is that something around maybe 1800
15 degrees is considered the normal upper limit. Even that is
16 pretty hot.

17 Q The last instrument you identified then as being
18 an additional way of determining inadequate core cooling is
19 the expanded range, RCS hot leg temperature. Is this
20 instrument separate from the p-sat hot let temperature
21 instrument?

22 A (WITNESS KEATEN) It is certainly a separate
23 instrument, and neither myself nor Mr. Ross are 100 percent
24 certain whether it uses a different sensor or not. I do
25 know that it is not one of the safety grade key hot sensors.

1 Q It is -- its range, I believe, was 620. Is that
2 not correct?

3 A (WITNESS KEATEN) Yes, that is the range as it
4 was, right.

5 Q On page nine of your testimony, the second full
6 paragraph, right near the end, you kind of summarize what
7 you said previously, and you say that all these instruments
8 are useful -- I am paraphrasing now -- are useful for
9 identifying when inadequate core cooling is approaching, and
10 specify the operator action necessary to properly enhance
11 core cooling.

12 Specifically, I am looking at the ways of properly
13 enhancing core cooling. Are there any safety grade systems
14 or components that are called out in the procedures to
15 enhance core cooling when you get into this situation? Are
16 they all on safety systems?

17 A (WITNESS JONES) Well, the objective of most of
18 the actions which are being taken to bring the -- bring the
19 system pressure down to allow other safety systems to
20 actuate, but in general we are relying on non-safety pieces
21 of -- non-safety grade pieces of equipment, although like
22 the emergency feedwater system which is a safety grade
23 system from the standpoint of a LOCA.

24 Q But that by itself would not -- you would need
25 things like the atmospheric dump valves and the condenser

1 bypass valves.

2 A (WITNESS JONES) That is correct. What I'm saying
3 is although we are using non-safety grade pieces of
4 equipment, some of the support equipment can be safety
5 grade, but in general we are relying on non-safety grade
6 equipment in that period of time.

7 Q On that same page of your testimony you indicate
8 three -- four ways of determining or four actions that are
9 necessary for inadequate core cooling and I am wondering are
10 procedures -- are these actions alternatives, or are they
11 all in sequential steps?

12 MR. BAXTER: Excuse me. I think Mr. Dornsife said
13 these are actions for inadequate core cooling. I think the
14 testimony is they are actions taken during an approach to
15 attempt to avoid it.

16 WITNESS KEATEN: Yes, and let me expand on that,
17 but first to answer your direct question, no; the initiation
18 of high pressure injection, the maintenance of the correct
19 generator level, the tripping of the reactor coolant pumps
20 -- if there is an engineered safety feature actuation and
21 monitoring the exit core thermocouples are actions which all
22 need to be taken. It is not one of them but all of them.

23 Let me also then call your attention to the final
24 sentence, which is that no further action is required for
25 design basis accidents. In other words, this is not really

1 addressing the approach to inadequate core cooling that
2 would go beyond the normal LOCA analysis, for which we would
3 be taking the actions Mr. Jones was describing, such as the
4 pressurizing of the steam generator.

5 These are the acts associated with a LOCA which is
6 within the design basis.

7 BY MR. DORN SIFE:

8 Q The next page, the bottom of page 10 and the top
9 of page 11, these are in fact steps for inadequate core
10 cooling. Is that not correct?

11 A (WITNESS JONES) Yes.

12 Q The same question. I would like to ask the same
13 question. Are these alternatives or are they sequential? Is
14 the operator first instructed through the first step and
15 then to proceed through the rest of the steps? Or if the
16 one were to be stopped at that particular step?

17 A (WITNESS JONES) No. These have been constructed
18 for the operator to do them all basically. The order is
19 really not that important in my mind, with the exception of
20 like, on page 10 I list four items, but most important are
21 one and two, and I am not really -- it does not really
22 bother me if they are done in a different order.

23 The opening of the PORV, it is listed as an
24 as-necessary step, so I would not want to open to the PORV
25 to depressurize the plant. I would rather use the steam

1 generator first, and then the cooldown with the steam
2 generator after you continue the initial action, but the
3 first two could be interchanged.

4 Q Based on the analysis that you did following the
5 TMI 2 accident, what in your opinion is the reason the plant
6 could not be depressurized using the PORV? Was it because
7 the non-condensable gases primarily that were generated?

8 A (WITNESS JONES) Could you reference me to a time
9 period?

10 Q When the operator is following what is assumed to
11 be initial core recovery and then attempts to go to a decay
12 heat removal recirculation cooling? When they tried to
13 reduce pressure by opening PORV, why couldn't they achieve
14 the conditions necessary to activate that system?

15 A (WITNESS JONES) Okay. I would not necessarily
16 believe it is the non-condensable gases. I just think
17 simply what you reached at that point in time was a matter
18 of -- as the system pressure decayed, you get less and less
19 energy removal or steam or non-condensable gas removal out
20 of the valve while you still are creating steam in the
21 system.

22 And then you reach the balance pressure, at which
23 flowout and steam generation more or less equalize.

24 Q So that is a reason why one of those steps
25 previously is not sufficient. You would need more than one

1 because a PORV itself would not necessarily be adequate to
2 do that.

3 A (WITNESS JONES) Correct.

4 Q I have some questions now on potential vessel
5 level indications and type of indications. Mr. Jones, are
6 you -- are the positions of the licensees at the BMW plants
7 similar to Met Ed's in that they feel that the t-stat meter
8 is totally adequate; they do not need to add any additional
9 instrumentation?

10 A (WITNESS JONES) As far as I know, right now the
11 position of all of the BMW operating plants is not to add
12 additional instrumentation?

13 Q How about other meters?

14 A (WITNESS JONES) I am not really that familiar
15 with what other vendors or what other plants are utilizing.
16 I have heard that Combustion Engineering -- and they have
17 recommended to some of its operating units that they put on
18 heated junction thermocouples, but that some of the units
19 are rejecting them because they just do not see a use, and
20 they do not think they really work.

21 They had questions about whether they were a good
22 instrument or not, so I do not think there is a clear
23 picture. I don't have a real good picture as to what all
24 Combustion Engineering plants are doing.

25 Q Mr. Keaten, you had described the two ways you are

1 familiar with that people are looking at are the heated
2 thermocouple that Mr. Jones just described at a differential
3 pressure measurement.

4 A (WITNESS KEATEN) Excuse me. I believe my
5 reference, or at least what I intended to have said at the
6 time was that those were the two methods that one of the NRC
7 staff members had described to the ACRS as being the method
8 that the staff thought might be the near term candidate for
9 being qualified in the eyes of the staff.

10 We have also looked at some other approaches, such
11 as the use of neutron detectors, for example. We have
12 considered the possibility of sonar type devices, but we
13 have not found any that appeared to us to meet the
14 reasonable criteria of being reliable and unambiguous.

15 CHAIRMAN SMITH: What is the principle of the
16 heated thermocouple?

17 MR. KEATEN: The idea, Mr. Smith, is that if a
18 thermocouple is provided with a current that is flowing
19 through the junction, as long as it is covered with water
20 the water will keep it cool, and so it will read the normal
21 temperature of the water.

22 If the water is then gone, the thermocouple will
23 start heating up, indicating a loss of water.

24

25

1 DR. JORDAN: What happens if it is in two-phase
2 fluid?

3 WITNESS KEATEN: Dr. Jordan, I think that is the
4 sixty-four dollar question. My interpretation of one brief
5 sentence that appeared in the report of the most recent LOFT
6 tests, in which they had heated thermocouples in the upper
7 region --

8 DR. JORDAN: Which report?

9 WITNESS KEATEN: This is a report on the most
10 recent LOFT test.

11 DR. JORDAN: LOFT. Thank you.

12 WITNESS KEATEN: It was that -- as I say, my
13 interpretation of this brief sentence was that the heated
14 thermocouples did not work to indicate level or equivalent
15 level in the two-phased mixture that existed while the
16 reactor coolant pumps were in operation during the test, and
17 it was only after the pumps were turned off that the heated
18 thermocouples gave a good indication.

19 But I emphasize for the third time that that is
20 one sentence that I saw. I am certainly not prepared to
21 support that in any depth.

22 DR. JORDAN: One would think that a heated
23 thermocouple would almost be the ideal instrument because it
24 essentially simulates the situation in the core. You have
25 heat being generated, heat being removed, and if you put a

1 heated thermocouple in the same medium, then it ought to
2 respond very similarly.

3 WITNESS KEATEN: I think there may be a problem,
4 Dr. Jordan, with respect to the relative heat fluxes. In the
5 case of a heated thermocouple you have a low current and
6 therefore a relatively low heat flux, whereas -- I am
7 thinking of heat flux in terms of transfer to the
8 surrounding medium -- whereas in the case of the fuel rods I
9 would expect that the heat flux would be considerably higher.

10 DR. JORDAN: I would have thought that rather than
11 -- well, if you are speaking of flux as kilowatts per square
12 centimeter, wouldn't they be somewhat similar because the
13 thermocouple is such a small --

14 WITNESS KEATEN: My understanding is -- I would
15 not have thought so. Maybe I really better say I do not
16 know.

17 DR. JORDAN: All right. Of course.

18 WITNESS JONES: There has been some further work
19 -- I have seen some of the work that has been done on the
20 heated junction thermocouples, and they have found some
21 problems with them to date, especially at high pressures
22 where the steam and water density were close at high
23 pressures. They have trouble in telling when it is steam or
24 water. The type of changes that they see are very small,
25 and they get some noise with these heated junction

1 thermocouples because you do have some spattering of water
2 here or there and it is somewhat indistinguishable from the
3 noise.

4 DR. JORDAN: It becomes more and more difficult.

5 WITNESS JONES: Yes. This was my information. It
6 is something on the order of two or three months old, but
7 what they showed was that under certain conditions they
8 seemed to be pretty good, but as the pressure got up they
9 became more and more questionable. The last I heard, it was
10 still under development. They were still being examined.

11 BY MR. DORNSIFE:

12 Q This proposed device, would it be a thermocouple
13 on both levels? Is that the principle?

14 A (WITNESS KEATEN) If the idea is to use it to
15 measure level, then that is how it would have to be done;
16 that is correct.

17 Q So you probably need a large number of these
18 thermocouples to get a fairly good range of levels.

19 A (WITNESS KEATEN) There is a trade-off between the
20 range, the number of thermocouples and the resolution. If
21 you are happy with one every foot, well, then you measure 20
22 feet with 20 thermocouples.

23 Q Other than the R&D work, are there any
24 applications that you are aware of that actually use these
25 devices or any other devices for level measurement in this

1 type of an environment where you have a large density
2 difference, possibly, heat source, that type of thing?

3 I guess my question is: is the state of the art
4 still really a differential pressure meter? Is that really
5 the state of the art right now in the industry or all
6 industries that you're aware of?

7 A (WITNESS KEATEN) In the kinds of environment that
8 we are talking about in a pressurized water reactor, I am
9 not aware of anything different from a differential pressure
10 meter which has been used in a production reactor. In other
11 types of environments, of course, other things have been
12 used, but I am not aware of any in a nuclear environment.

13 Q If you were to install a differential pressure
14 device on the reactor vessel, would it require additional
15 penetrations in the reactor vessel?

16 A (WITNESS KEATEN) I am not sure I have a
17 completely unequivocal answer to the question. It is my
18 impression, Mr. Dornsife, based upon some early work that
19 was done, I think partly by B&W and partly by ourselves,
20 that some type of differential pressure indicator probably
21 could be installed using existing penetrations. What I am
22 not sure about is just which range it would cover.

23 Q I guess, for example, there is probably drain
24 devices on the bottom of the vessel that could be used if
25 you wanted a full indication. Is that correct?

1 A (WITNESS ROSS) By design the vessel is designed
2 to be undrainable and there are no drain connections on the
3 bottom. There are other connections that could possibly be
4 used, like in-core thermocouple connections.

5 A (WITNESS JONES:) Well let me, just to bring maybe
6 a little more closure to this, when we looked at the use of
7 differential pressure transmitters in that August 15 report,
8 it states directly there that if you put a total reactor
9 vessel differential pressure measurement device, you would
10 require new penetrations in an in-core nozzle and one at the
11 top of one of the control rod drive mechanisms. You would
12 have to make some new penetrations.

13 Q Would that cause any safety problems, in your
14 opinion, having that type of an open penetration? For
15 example, let me give you a scenario. Let's say you had a
16 differential pressure device having a small instrument tube
17 on it and that tube were to rupture and you had a leak at
18 the bottom of the pressure vessel. Would that be, although
19 small, an accident or a leak that could cause problems
20 beyond the design basis?

21 In other words, if you wanted to refuel to get a
22 stable condition, you would have to flood the containment up
23 to the top of the fuel.

24 A (WITNESS JONES:) If you got a break, if had that
25 pipe break and the size of the break was one in-core nozzle,

1 that would be capable of being handled by the makeup system
2 and retain the system in a solid configuration. You would
3 ultimately to refuel probably have to fill the cavity, as
4 you state. If it was several in-core nozzles, I am not sure
5 what kind of problems that would cause.

6 Q But wouldn't, though, based on the current
7 configuration of the in-core thermocouples, wouldn't having
8 a pressure sensor be a different configuration whereby you
9 would have pressurized water outside the vessel compared to
10 just the tube, the nonpressurized tube, so it would present
11 some special problems that -- it is not a pressurized
12 instrument outside the vessel, is that correct?

13 A (WITNESS ROSS) The in-core itself is a
14 pressurized vessel and the pressure boundary is located
15 outside of the reactor vessel, that is correct.

16 Q So it would have the same potential problems for a
17 break.

18 A (WITNESS ROSS) I could not say it would have the
19 same potential. I said the potential would exist.

20 A (WITNESS JONES:) Now, let me just make one
21 comment. I get the impression from your question that use of
22 these in-core thermocouples are heated junction type
23 thermocouples. If you are trying to get at those as not
24 requiring additional penetrations, you know, a unique
25 feature of the B&W design -- you know, like we have our

1 instrument tubes come from the bottom of the vessel up,
2 while the Combustion Engineering design, their instrument
3 tubes come from the top down, and it is one of the reasons
4 why they are able to recommend such an item, because they
5 already have the existing instrument tubes and penetrations
6 available.

7 But something like a heated junction thermocouple
8 installation would cause problems in that it would require
9 potentially additional vessel penetrations for us.

10 Q Mr. Jones, didn't you say you could potentially
11 use one of the thermocouple nozzles for a differential
12 pressure meter? That is where I was getting at, not the --

13 A (WITNESS KEATEN) Yes, potentially you could. It
14 is at the bottom of the vessel. I think the point is that
15, while you could use that one for a DP-type indicator, since
16 it terminates basically at or just above the type of the
17 core, you could not use it for a heated thermocouple that
18 was up higher.

19 Q You also could not use that for an indication at
20 the bottom of the core; is that also true? There is no way
21 you could use that thermocouple without removing some of the
22 internals as an indication of the full range of the vessel.
23 You would have to have an additional penetration then for
24 that type of an instrument.

25 A (WITNESS KEATEN) I think that it would require

1 some significant changes in order to use that type of an
2 instrument over the full range. I am not sure we know
3 exactly what those changes are. But certainly the reactor
4 was not designed with that in mind.

5 A (WITNESS JONES:) If we used in-core thermocouples
6 inside the core, you know, by somehow putting them in the
7 instrument guide tubes, they would not have to be heated
8 junction thermocouples because they would see directly the
9 hot steam because the core is getting hotter as you are
10 progressively going up from the two-phase mixture if you are
11 in this type of situation, while what the present
12 utilization concepts of the heated junction thermocouple is
13 to try to tell where the water level is from the top of the
14 core to the top of the vessel head, where is it steam and
15 where is it water; and again, for us that would require at
16 least additional penetrations.

17 Q Are you familiar with the way the BWR measures
18 vessel level, any of you?

19 A (WITNESS KEATEN) Yes, I am.

20 Q Is it a direct measure of the core level or an
21 indirect measure of the core level?

22 DR. JORDAN: Did you say BWR?

23 MR. DORNSIFE: Yes, boiling water reactor.

24 WITNESS KEATEN: I am going to give my answer in
25 the context of Oyster Creek, which is a specific BWR that I

1 am familiar with, and actually there is more than one level
2 measurement. The ones which are used during normal
3 operation and for most of the safety system actuation
4 actions are a differential pressure type of device but they
5 do not measure the water level in the core. They measure
6 the water level in the downcomer, which is expected to be
7 related to the water level in the core.

8 The reason that that is done is that trying to
9 measure the water level in the core and during normal
10 operation of a BWR with all the frothing and so on is a
11 very, very noisy signal, and so the normal control -- and
12 the early protective actions are based on the water level in
13 the downcomer.

14 Now, there is a measure of the water level in the
15 core which does come into play in certain safety circuits,
16 but these are actuation signals that would be expected to
17 come into play only with the reactor shut down. And that
18 was at the time that Oyster Creek was licensed and built,
19 that particular signal was felt to be of such little use
20 that in fact it was not read out in the control room.

21 Q Was it also a differential pressure device?

22 A (WITNESS KEATEN) Yes.

23 Q If you could conceivably measure the level in the
24 downcomer -- you could do that in this vessel, is that not
25 true, although it would not give you indications at the top

1 of the vessel? It would give you some indirect
2 measurement. I am wondering how, in your opinion, how
3 accurate would that be during accident scenarios? Would
4 that give you a fairly decent representation of the level in
5 the core?

6 A (WITNESS JONES:) Well, conceivably I guess you
7 could say you could measure it. It certainly would be
8 difficult from trying to get the instrument in. But if you
9 had a stagnant loop situation, that is, the pump is off and
10 you measure the water level in the downcomer, it would be in
11 reasonable agreement with the cold water level probably from
12 a solid liquid standpoint now. Probably it would be high by
13 about a foot to two feet. You could probably measure
14 downcomer water level and get an inference.

15 Now, I am saying that is if you could somehow
16 figure out how to get the instrument in, but you could do
17 it. You know, you could get useful -- I will not say useful
18 because I do not think it is useful information, but you
19 could get information relative to the water level in the
20 core.

21 Q Based on the problems with frothing in the core,
22 wouldn't it conceivably be just as useful as a direct core
23 level measurement?

24 A (WITNESS JONES:) Yes. Yes, it would be. If you
25 took a DP across the downcomer or took a DP across the core,

1 both of them would both suffer from the same problems that I
2 testified to earlier.

3 Q Mr. Ross, in your portion of the testimony on page
4 15, you state that 16 hours are spent on heat transfer and
5 fluid dynamics.

6 DR. JORDAN: Just a minute. Let me find it.

7 BY MR. DORNSIFF: (Resuming)

8 Q Does that include any theory concerning the
9 effects of noncondensable gases in the system, how they may
10 alter some of the instruments or they may affect some of the
11 instruments?

12 A (WITNESS ROSS) That particular portion did not.
13 It was theory of heat transfer. We had covered that under
14 different lecture series. Not included was the Unit 2
15 accident analysis.

16 Q You have covered the effects of noncondensable
17 gases on instruments.

18 A (WITNESS ROSS) That is correct.

19 Q The possible effects it might have.

20 A (WITNESS ROSS) That is correct.

21 Q Figure 1 of your testimony, just kind of looking
22 at it in detail, I am kind of curious. First of all, did
23 those curves, the 1400 curve and the 1600 curve, if you are
24 right on that curve, does that mean the cladding is at 1400
25 or 1600 degrees?

1 A (WITNESS JONES:) Well, first off, the top curve
2 is a bad reproduction of the number. That is 1800, not 1600.

3 Q That answers my question, then, because there was
4 a 200 degree difference between that and a 300 degree
5 difference between that and an in-core thermocouple reading.

6 A (WITNESS JONES:) That is 1400 and 1800 degree
7 curve.

8 CHAIRMAN SMITH: Go ahead, Mr. Baxter.

9 MR. BAXTER: You are amending the testimony or
10 correcting it, then, to make 1600 1800?

11 WITNESS JONES: I can only see the 1800. I am so
12 used to seeing this copy of the figure that I read it as
13 1800. I am sorry. It is an old habit, I guess, looking at
14 that number, because it always seems to get wiped out every
15 time I make a copy of it, and I instinctively read it as
16 1800.

17 CHAIRMAN SMITH: It is correct as presented.

18 WITNESS JONES: As 300. I think the figure it
19 was made from said 1800. It just did not reproduce well.

20 MR. BAXTER: The 1600 that is below curve two, it
21 says less 1600 degrees F. It should read less than 1800
22 degrees F.

23 CHAIRMAN SMITH: That is what we understood. It
24 seems to be quite clearly a "6."

25 MR. BAXTER: It does to me, too, but the history I

1 do not think is all that relevant as long as we get it right.

2 CHAIRMAN SMITH: "I am amending the -- whatever,
3 you are amending figure 1 to show 1600 degrees Fahrenheit.

4 WITNESS JONES: Yes.

5 DR. JORDAN: He is making it clear.

6 MR. CUTCHIN: Mr. Chairman, perhaps if the
7 reporter, not having bound that yet, could make that
8 correction in the copy before it gets bound in, it might be
9 more useful than being hidden away in the transcript.

10 DR. JORDAN: He anticipated you.

11 BY MR. DORNSIFE: (Resuming)

12 Q In NRC's supplemental testimony from Mr. Phillips,
13 the one filed supplemental to testimony filed December 1, on
14 page 3 of that testimony, the last paragraph, the second
15 sentence, it says, "The level indication would also provide
16 evidence that the core is covered during recovery from a
17 TMI-2 type flow block condition, even though superheat may
18 persist at the core exit thermocouples."

19 Could your present instrumentation do that,
20 perform that same function? Is that something that only the
21 level instrumentation could uniquely perform as stated there?

22 A (WITNESS JONES:) No, I think the level -- I think
23 the core exit thermocouples will provide you information
24 that would tell you that the core was indeed covered because
25 even during the TMI accident, after they recovered the core

1 you had many of the thermocouples along the outside of the
2 core indicating very cold temperatures, and had this zone of
3 superheat conditions reading out for the hot portions of the
4 blocked portions or apparently blocked portions of the core.

5 So, in fact I think the instrumentation available
6 tells you where you are relative to the core. But
7 additionally I would like to point out that even if this
8 happens, even if you had a level instrument that told you
9 that the core was recovered, your actions still do not
10 change. Your attempt is to continue to fill that primary
11 system and return it to a totally subcooled state; and that
12 although if you had a level instrument that told you this,
13 that you had blockage in, say, the center of the core, it
14 does not help you any or you do not change things because
15 you still want to fill the system back up and return it to
16 its normal configuration.

17 Q On the next page of the testimony, page 4, the
18 paragraph about the St. Lucy event, and from reading the
19 scenario that is attached to the answers to discovery, in
20 your opinion -- are you familiar with that transient?

21 A (WITNESS JONES:) In a general sense, yes.

22 Q Is it your opinion that the primary reason that
23 that void occurred in the reactor vessel head was due to the
24 fact that the plant was depressurized -- went through a
25 rapid depressurization to try to get it down to a cold

1 condition? Was that one of the main reasons?

2 A (WITNESS JONES:) That is my understanding, that
3 basically the operating staff at the plant tried to rapidly
4 depressurize the plant and the metal heated up or kept the
5 hot water in a more or less stagnant region of the upper
6 head, warm, and they did not give it enough time to lose
7 some of its heat through the metal and out to the
8 containment itself; that it ultimately flashed when the
9 pressure got down low enough.

10 Q And the way they reduced the pressure was by using
11 a system that is unique -- well, unique to -- not
12 necessarily to that system but a CE system where you can use
13 auxiliary spray from a charging pump to reduce the pressure
14 in the pressurizer. Is that how they reduced pressure?

15 My question -- well, assuming that was the way
16 they did it, does that capability exist on TMI-1 and could
17 that transient have occurred on TMI-1?

18 A (WITNESS JONES:) I do not believe that capability
19 exists at TMI-1, and I think you are correct that they -- I
20 know at least during certain portions of the transient they
21 were using spray into the pressurizer. I was just trying to
22 check whether it was all the time. Since you are
23 stipulating it for the question, I will say that we cannot
24 get in under that assumption.

25 Q My question was: without the capability of

1 spraying, other than using the differential pressure across
2 the reactor coolant pump, could you have gotten into that
3 situation on TMI-1?

4 A (WITNESS JONES:) Well, not directly, but if you
5 initiated -- no, you could not get there unless you were
6 using the DORV to depressurize the system because they did
7 not have any reactor coolant pumps. You could not have
8 gotten this transient.

9 CHAIRMAN SMITH: Mr. Dornsife, when there is a
10 convenient place in your cross examination, we can take our
11 afternoon break.

12 MR. DORNSIFE: I am very near the end, so could we
13 continue for a couple more minutes?

14 DR. JORDAN: I guess before we do that, I am
15 failing to understand something. The B&W reactor can reduce
16 the pressure by its spraying into the pressurizer.

17 WITNESS JONES: Yes, it can. But the specifics
18 of the St. Lucy event, the one where they have tripped all
19 the reactor coolant pumps, which is your source of your
20 spray injection to the pressurizer --

21 DR. JORDAN: In the case of St. Lucy it was not;
22 in the case of B&W it is? Is that what you are saying?

23 WITNESS JONES: I think they probably have both.
24 I am not sure about all of the reactor coolant pumps. But
25 generally speaking that is the normal situation, but they

1 have the additional capability of spraying using the
2 charging pump through the pressurizer spray line or an
3 auxiliary spray line of some sort.

4 DR. JORDAN: I see. I guess I got the impression
5 that the boiling occurred as a consequence of the cooling.
6 Yes, and then of course the consequence was a reduction of
7 pressure that went along with the natural convection
8 cooling. And they arrived at a condition as a consequence
9 of cooling and reducing the pressure whereby they got --

10 WITNESS JONES: Yes, generally what it was was by
11 depressuring the plant in a rapid fashion, the hot pocket of
12 fluid located in the upper head just turned to steam when it
13 dropped below the saturation pressure.

14 BY MR. DORNSIFE: (Resuming)

15 Q Again on page 4 of that testimony at the bottom
16 where it talks about vessel level information possibly
17 necessary or essential for using the reactor vessel vent
18 valves, you had said that BEW was currently in the process
19 of developing guidelines for using that valve. I am just
20 curious of what kind of guidelines you are planning on
21 giving for using that valve without relying on vessel level.

22 WITNESS JONES: Well, to give you an example of
23 how we will use the head vent, let's say we have something
24 like a St. Lucy event, for example. Now, it is quite clear
25 from looking at the fact that the pressurizer level goes off

1 scale or has rapid changes while they are switching the
2 location of the charging pump that there is a void in the
3 head and they can open the vessel head, use the high
4 pressure injection system to maintain system pressure and
5 pressurizer level. While the head is continuing, the gases
6 or steam in the head is being discharged through the vent.

7 When you would fill the level or fill up the
8 reactor vessel, you will get a change in the flow quality
9 from steam to water, and you will get an increase in the
10 pressurizer level according to that because the volumetric
11 flow change from steam to water is quite dramatic. You
12 might only be putting out, say, four or five pounds of steam
13 but in fact be putting out an equivalent volume associated
14 with the replacement liquid of, say, 100 gallons per
15 minute. These numbers are just not even real numbers but
16 just to try to point out an example.

17 Now, when you change to a water flow from a steam
18 flow, say four pounds per second, and it is now up to, say,
19 ten pounds per second or whatever, you will get an increase
20 in the flow rate. But that may be associated with 50
21 gallons per minute. So now suddenly you are putting in 100
22 gallons per minute, you are only discharging 50, and so the
23 pressurizer level will increase at the rate of 50 gallons
24 per minute.

25 So when it makes the transition from steam to

1 water, the pressurizer level will start to increase. At
2 that point in time you can close the vent and continue to
3 cool down, and if a bubble reappears, you just take the
4 action again.

5 Q What if there are voids in the other parts of the
6 system?

7 WITNESS JONES: I was just trying to give an
8 example of it. There are two ways -- we are going to be
9 installing on the B&W plants -- GPU is installing both the
10 vents on top of the hot legs and a vent on top of the
11 reactor vessel head. AT least I believe they are installing
12 them; let me put it that way.

13 You can use the hot leg vents to vent the rest of
14 the system, and the general way of using the vents is to
15 vent the hot legs first in order to aid in the refilling
16 process of the primary system, and you can tell when you had
17 filled up the hot leg by the hot leg RTD measurement. That
18 is, you will return to a subcooled situation and get
19 indications of natural circulation flow if you fill it up,
20 if you fill up the system.

21 At that point in time you then go and use the heat
22 vent in a similar fashion to what I just described.

23 Q And on the last page of that testimony, page 5,
24 there is a sentence, the last sentence of the first
25 paragraph at the top, "The staff is aware of at least one

1 vent design for which the designer insists on the coupling
2 of level information to the vent."

3 Are you aware of that, details of that, why they
4 feel that is a better way of doing it than, let's say, your
5 proposed method?

6 A (WITNESS JONES:) While I do not know the details
7 of why they chose it, again, when we were developing the
8 guidelines we were looking at, you know, what the existing
9 instrumentation was, and then, you know, what the objective
10 was. If we felt we needed level information to really use
11 the vents properly, we were to identify it, and we found we
12 just did not need it.

13 I cannot find the information that I was given. I
14 believe the other vendor is Westinghouse, but I do not think
15 the staff provided us with details as to the why.

16 MR. DORNSIFE: I would like to explore that with
17 the staff.

18 WITNESS JONES: They give us some supporting
19 information to one of our interrogatories concerning use of
20 the head vent for another vendor, and it said -- all I have
21 here, and I quote, "The designer is Westinghouse. They have
22 stated that vent operating procedures will permit the vent
23 to be open only when a steam level in the head is indicated
24 by the reactor water level instrument, and the vent is to be
25 closed when the steam bubble has been vented."

1 That is the only details I have.

2 BY MR. DORNSIFE: (Resuming)

3 Q One of the recommendations of the St. Lucy
4 accident concerned specifically the B&W design, and it read
5 that consideration should be given to the potential for the
6 formation or accumulation of vapor in the candy cane of B&W
7 reactors, particularly in the inactive loop, when natural
8 circulation cooldown was being accomplished with a single
9 steam generator.

10 My question is: even if you had void formation in
11 the candy cane, could you still not remove enough decay heat
12 using two-phase natural circulation?

13 A (WITNESS JONES:) Well, that would depend on the
14 size of the bubble if there was one in the candy cane. If
15 the bubble was large enough it could block the circulation
16 path and yet small enough not to have a condensing surface
17 exposed in the generator, you could have an interruption of
18 circulation.

19 Now, you should not be able to form that bubble if
20 you went into a situation like St. Lucy where you had a
21 bubble in the system, depressurized and the bubble tried to
22 transport itself into the hot legs. Just the fact that you
23 are trying to maintain 50 degrees subcooled in the loop
24 during this process, the hot steam or gases escaping into
25 the hot leg will mix, will show up on the hot leg RTD as a

1 loss of the 50 degree subcooling, and you could just
2 reinitiate HPI, and really what you would do is hold the
3 pressure for a while.

4 Additionally there will be ultimately vents at the
5 top of the candy canes so that if you got a local bubble
6 trapped up here, it could be vented off. In fact, this is
7 an advantage for the B&W system as opposed to the
8 Westinghouse system or the Combustion Engineering, and they
9 have 15,000 U tubes that are impossible to vent should a big
10 gas bubble accumulate up there, while we can vent the gases
11 off through the hot leg vent.

12 Q I guess, going back to the first part of your
13 answer, you said that if the steam bubble was not big
14 enough, that you could not get a condensing surface. I was
15 under the impression that as long as you had exposed surface
16 in the steam generator tube of cold water, with a steam
17 bubble in there you could have nothing but vapor in the loop
18 and still have two-phase natural circulation.

19 A (WITNESS JONES:) Yes, yes, that is correct. But
20 what I am saying is if you go and look at the 180 degree
21 bend at the top of the hot leg, if a bubble forms right
22 across that bend, right at the bottom part of the elbow, you
23 form a bubble there and there would be no way to transport
24 liquid from one side to the other. Okay.

25 Now, until you drain down -- I don't know the

1 exact distance, but probably about 10 feet -- you have not
2 hit the top -- the coil surface of the steam generator tubes
3 yet. So a bubble of that order of magnitude is the size
4 bubble that could block or interrupt a circulation pattern
5 for a period of time.

6 This was discussed in the small break LOCA
7 testimony where you could have this interruption after
8 forming the small bubble, waiting for it to grow forming
9 the condensing surface, yet during that entire period of
10 time the core is being adequately cooled because it has
11 water over it.

12 Q I just have one more question. You had mentioned
13 briefly the LOFT experiment. You mentioned some familiarity
14 with some of the details, and one of the things that
15 interested me was you indicated that they have different
16 types of level instrumentation on that particular level.
17 You mentioned they ran some experiments using the heated
18 thermocouples.

19 Are there other types of level devices, and what
20 has their experience generally been as far as reliability,
21 and whether they work or --

22 A (WITNESS KEATEN) It is my understanding that they
23 have normally used a DP type of level indicator as well as
24 the heated thermocouples, but I am not really familiar in
25 detail with that, Mr. Dornsife. I have just seen this

1 recent report that came out and it crossed my eye that they
2 were describing the difficulty or appeared to be describing
3 the difficulty that they had had with the heated
4 thermocouple until they had turned off the pump.

5 A (WITNESS JONES:) They do have a DP cell. I think
6 the heated junction thermocouples were a special test they
7 were running. The normal type of level instrument that they
8 use, I believe, is a conductivity probe. That is the normal
9 type of level instrumentation they use. I would not call it
10 instrumentation unambiguous by no means in that I have seen
11 times where they indicate, say, five feet of liquid or
12 two-phase mixture, a gap of no reading indicative of steam,
13 and then a spurious couple of marks here and there
14 indicating maybe two-phase up in that region, which I usually
15 consider to be spurious.

16 Whenever they have tried, or in general most of
17 the times I have seen them give you inventories in the
18 system, they have always done them on a mass flow balance
19 rather than by use of any of their level instruments. It
20 has usually been mass -- an integrated leak flowout, that
21 sort of stuff.

22 Q So your testimony is basically even on the LOFT
23 test there is no unambiguous way of determining the level of
24 the vessel.

25 A (WITNESS JONES:) In general if you could plot and

1 get used to the conductivity probes and their response, you
2 can learn to ignore them or throw over the fliers or
3 recognize if you have five feet of liquid, a two-phase
4 mixture and then a couple of points where it is steam and
5 then another ten feet of water, it means there is probably
6 water or two-phase in between there.

7 When you get used to that you can plot some trend
8 information which may be useful for them out in Idaho, but
9 to give that to an operator unprepared for it, I would be
10 very hesitant.

11 Q I guess that was kind of my next question, the
12 last question. Do you know whether the operators use that
13 information for their procedures at LOFT?

14 A (WITNESS JONES:) No, I do not. And they have --
15 all I have heard are some second-hand remarks, which is they
16 have been -- the capability of putting up their predictions
17 on a screen and comparing it to some of the actual plant
18 data, and so they could tell where it is going. Now, this
19 is, as I said, second hand, and I would not put much -- you
20 know, that is to the best of my knowledge.

21 Additionally, they have some override capability
22 that if they do not like the way the transient looks, they
23 are capable of pressing a button and bringing on additional
24 safety systems if the thing looks to squirrely for them.

25 MR. DORNSIFE: I have no further questions. Thank

1 you.

2 CHAIRMAN SMITH: Let's take a 15-minute break,
3 please.

4 (Recess.)

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

1 CHAIRMAN SMITH: I think we are ready for the
2 redirect.

3 REDIRECT EXAMINATION

4 BY MR. BAXTER:

5 Q Do you have a correction, Mr. Keaten, that you
6 would like to make to your testimony?

7 A (WITNESS KEATEN) Yes, I do. During the break,
8 Mr. Phillips pointed out to us my reading of the document on
9 the most recent LOFT test had misled me. He is much more
10 familiar with the details of LOFT than I am. I had read
11 what was in this document as referring to a heated
12 thermocouple level probe. And he points up that, strictly
13 speaking, those thermocouples they have in there are not
14 heated thermocouples in the normal sense we use the term
15 "heated thermocouples." I guess they receive some heat from
16 the energy stored in the vessel rather than being heated on
17 electric current.

18 And so the results here may not be particularly
19 representative of what a more carefully designed heated
20 thermocouple might do. I indicated earlier I was drawing
21 conclusions based on one sentence, and apparently I was a
22 little bit misled by what that sentence said.

23 MR. BAXTER: I have no further redirect
24 examination.

25 CHAIRMAN SMITH: Any further cross examination?

1 MR. CUTCHIN: None by staff, sir.

2 BOARD EXAMINATION

3 BY DR. JORDAN:

4 Q I am going to refer you to staff testimony by Mr.
5 Rubin.

6 MR. CUTCHIN: Mr. Chairman, if it might help the
7 Board, the staff has now decided that we will not be
8 offering Mr. Rubin's testimony. You may still have the same
9 questions, but we will not be offering that testimony.

10 DR. JORDAN: Yes. This does --

11 MR. CUTCHIN: I might tell you why.

12 DR. JORDAN: Yes. I guess I better find out why.
13 Is it because Mr. Rubin is no longer of the opinion?

14 MR. CUTCHIN: There are several reasons. If you
15 look at the purpose for which that testimony was originally
16 filed, it was to describe the status of the inadequate core
17 cooling procedure review at the time the testimony was
18 filed, which was December 1.

19 If you will turn to the last page, which is page
20 3, the question is: "What action does the staff plan to
21 resolve the remaining concerns?"

22 And the staff is stating that it will require
23 prior to startup that there be inadequate core cooling
24 emergency procedures which are adequate to allow operation,
25 and the staff will ensure that this comes about either

1 through revision of existing procedures or putting into
2 place of the ATOG, meaning "abnormal transient operational
3 guideline," procedures.

4 The status between staff and Licensee is that
5 these procedures are still not resolved, and we are working
6 on them. There is in process a letter from staff to
7 Licensee setting forth the results of the staff latest
8 review and some interchanges between Licensee and staff.
9 And, of course, the Board and all the parties will be served
10 with that, hopefully, within the next week or so.

11 So there was really nothing other than to update
12 that status, and it does not really help the record as far
13 as substance is concerned.

14 BY DR. JORDAN:

15 Q I guess then the only question I have either of
16 you or of these witnesses is: Has the -- will the
17 requirements of NUREG-0758 -- and I believe it is section --
18 what is it -- 2.13? Is that it? Is that the section we are
19 talking about with respect to the Lessons Learned, which has
20 two parts to it?

21 One of the parts is the short-term requirement
22 that there be a meter for measuring inadequate core cooling
23 or for measuring approach to saturation. And I guess the
24 question is whether that first section either has been or
25 will be complied with completely prior to restart.

1 (WITNESS JONES) Dr. Jordan, you stated 0758. Do
2 you mean 0578?

3 Q 0578. I mispronounced it -- I misspoke.

4 A (WITNESS JONES) I believe you are talking about
5 2.13 part B.

6 Q Part B. And then there is a B1 and B2.

7 A (WITNESS JONES) This one is not broken up. The
8 copy I have is not broken up into B1 and B2. Though it does
9 call for two distinct action levels.

10 Q All right. Now, the first part is something, I
11 believe, an action required prior to restart. Well, let me
12 find it.

13 (Pause.)

14 MR. CUTCHIN: Dr. Jordan, that matter is addressed
15 in the staff's safety evaluation report, starting at pages
16 C8-14. And it is my understanding that the procedures that
17 I was just referring to as having been the subject of Mr.
18 Rubin's testimony are the very procedures that are based
19 upon existing instrumentation.

20 DR. JORDAN: Right.

21 MR. CUTCHIN: And the saturation meter. And those
22 are still under development, and we will require that they
23 be in adequate shape prior to our saying it is okay to
24 restart.

25 DR. JORDAN: I guess also the staff is requiring

1 that there be a level meter, too. And I suspected you were
2 going to have the same success with respect to the short
3 term as you were with the long term.

4 MR. CUTCHIN: I do not believe that staff is
5 requiring a level meter short term.

6 DR. JORDAN: No, but long term they are. And it
7 sounds to me as though you are going to have a very
8 difficult time getting the licensee to agree that there is
9 such a meter. Are you also going to have the same problem
10 in getting the licensee to agree with the short term? You
11 say you are going to require it -- what if they do not? Are
12 they going to do it? I would like to hear them say that
13 they are.

14 MR. CUTCHIN: I thought you were saying either
15 they or us. I was trying to clarify the situation. I was
16 not trying to cut off your question.

17 BY DR. JORDAN:

18 Q Do you see my problem?

19 A (WITNESS KEATEN) As far as the short-term
20 hardware aspects are concerned, we have already committed to
21 do those things that are called for, the saturation meter,
22 the connecting of the in-core thermocouples, the expanded
23 range hot leg temperature indication. We have committed to
24 those. We presently have that work under way. And it will
25 be installed prior to restart.

1 Q That was my impression, precisely, but I was --
2 having read Mr. Rubin's testimony, I have some questions.

3 A (WITNESS KEATEN) Where Mr. Rubin's question is
4 concerned, as Mr. Cutchin has indicated, this has not been a
5 disagreement on hardware but a disagreement on the wording
6 of some of the procedures.

7 Q I see.

8 A (WITNESS KEATEN) We have received Mr. Rubin's
9 comments. Some of those comments have been incorporated.
10 For example, the inadequate core cooling procedure 1202-39
11 has very recently been revised and, I believe, does
12 incorporate some of Mr. Rubin's comments.

13 We intend to continue to interact with the NRC
14 staff until we have a procedure that we all believe are
15 acceptable.

16 DR. JORDAN: Very well, we shall leave it at
17 that. If there is any problem, we would want to hear about
18 it.

19 (Pause.)

20 BY DR. JORDAN:

21 Q The testimony of Mr. Pollard in this Contention
22 UCS 7 has been withdrawn. However, he does raise one or two
23 questions which I would like to get your opinions on.

24 On page -- do you have his testimony -- page
25 7-11. Item 3 on that page, the last sentence reads:

1 "Furthermore, the measurement of temperature in the hot legs
2 is of no use during the bleed-and-feed mode of core cooling,
3 because it is not in the cooling water flow path."

4 Is this true?

5 A (WITNESS JONES) That is true. That the hot leg
6 temperature indicators, if you are in a feed-and-bleed mode
7 of cooling without the steam generators, will not be
8 necessarily in the direct path of the fluid flow. What
9 would be used in this mode of cooling would be the core exit
10 thermocouples for providing HPI throttling guidance from the
11 standpoint of prevention of thermal shock, brittle fracture
12 concern of the reactor vessel, which has previously been
13 discussed.

14 When or if the steam generator is restored as a
15 heat sink, then the hot leg thermocouples would become the
16 primary means. Again, the objective is still always to try
17 to return the primary system to a liquid solid
18 configuration. Now, if you are in the bleed-and-feed mode,
19 it may not be possible to do that, depending on where the
20 break is in the system. But you can use the in-core
21 thermocouples to provide guidance on throttling; that is, if
22 they get adequately subcooled, so subcooled that you have to
23 worry about potential for brittle fracture of the vessel,
24 then you would throttle the HPI flow so as to depressurize
25 and prevent that concern, prevent a potential brittle

1 fracture of the vessel.

2 But if you restore the heat sink, you would still
3 monitor the in-core thermocouples from that standpoint for
4 brittle fracture measurement or as to provide indications to
5 help you prevent it. But you continue on HPI until you get
6 that system returned to a subcooled state.

7 Q Well, the t-sat meter would not be useful then
8 during this period of time; is that right?

9 A (WITNESS JONES) That is correct. Well, let me --
10 I am having trouble with the word "useful," whatever. If it
11 is reading saturated or superheat, even though it is not in
12 the flow path, it is an indication that you have an
13 off-normal situation in the primary system, and the
14 instruction based on the instrument is to continue to
15 provide HPI flow. And then if the in-cores start to
16 indicate excessive subcooling to the point where brittle
17 fracture of the vessel starts to become a concern, then you
18 can throttle your HPI while maintaining subcooled conditions
19 within the reactor vessel itself.

20 Q Well, the question is whether or not -- would not,
21 under those circumstances of bleed-and-feed, would a level
22 meter be of value to the operator during that operation?

23 A (WITNESS JONES) I would say "No," from the
24 standpoint that if he had a level meter and he is in this
25 mode of operation, again the only time you would want to

1 throttle HPI is to prevent the brittle fracture concern for
2 the reactor vessel, which implies a subcooling condition
3 within the vessel.

4 And a level meter would not be able to tell you
5 how much that vessel is subcooled. The thermocouples are
6 much better equipped for that, and you want to maintain the
7 subcooling in the vessel such that you do not even get near
8 boiling, you know, a minimum of 50 degrees subcooled but
9 less than whatever the value is on the specific limit curve
10 for brittle fracture of the vessel between those two
11 limits.

12 And under those conditions, the level instrument
13 should be reading a flat value. It would not be able to
14 tell you the difference.

15 Q I see. Okay. Well, on page 12, the next page, he
16 refers to the item that I now remember where I saw; namely,
17 that the meter can display either temperature or pressure
18 margin, that you say in your case you display temperature
19 margin.

20 A (WITNESS KEATEN) As far as the meter being
21 installed prior to restart, which is the continuous
22 indication to the operator, that is correct.

23 On the other hand, the readout via the computer
24 will be able to read in either temperature or pressure.

25 BY CHAIRMAN SMITH:

1 Q Does that mean that the computer will tell you how
2 close to saturation you are in terms of pressure, too?

3 A (WITNESS KEATEN) Yes, sir. It will do it with
4 either temperature or pressure.

5 BY DR. JORDAN:

6 Q He says that if the operator makes the simple
7 mistake of thinking that the temperature margin is displayed
8 when in fact the pressure margin is displayed, he can well
9 fail to maintain an adequate margin to boiling. Is that
10 true?

11 A (WITNESS KEATEN) I am not exactly sure of the
12 condition that Mr. Pollard was referring to there. But in
13 our case, since he does not have that option with the
14 hard-wired instrument, it always displays the temperature
15 margin. So there is no danger of confusion there.

16 As far as the output from the computer is
17 concerned, our computer output, as you are well aware, is
18 labeled as to what it is. And so it would say "temperature
19 margin" or "pressure margin." So I really do not think that
20 that mistake is likely to occur.

21 Q The next item had to do with the nature of whether
22 safety grade or not, but I think we have already covered
23 that item today.

24 Those are the only questions I have concerning Mr.
25 Pollard's testimony.

1 (Pause.)

2 Dr. Little points up on page 7-14, the middle of
3 the page, Mr. Pollard says as follows: "Therefore, I
4 conclude that instrumentation provided to directly measure
5 reactor water level should be used to automatically initiate
6 any necessary protective actions." I believe I also have
7 that one sentence underlined in my testimony, too -- in my
8 reading of Mr. Pollard's testimony also.

9 Would you care to address that statement?

10 A (WITNESS JONES) Yes. I will take a crack on it.

11 First off, the normal protective systems or
12 emergency systems utilized for a normal small-break
13 scenario, the emergency core cooling systems and the reactor
14 protection systems for just tripping the reactor out, now,
15 there is no way that I know of that you could get to a
16 low-water condition within the reactor core without having
17 already reached one of the various reactor protection system
18 inputs; that is, either low pressure or high temperature or
19 low flow.

20 There is no way that I know of that you could get
21 to low water level in the core without having at least
22 reached the reactor trip signal.

23 Q Which would start the high-pressure injection
24 system?

25 A (WITNESS JONES) No, that would just trip the

1 reactor.

2 Q I see. All right.

3 A (WITNESS JONES) From the high-pressure injection
4 system standpoint, under the typical licensing calculation
5 assumptions made with the emergency feedwater system
6 operable, you will get actuation of the emergency core
7 cooling system prior to even reaching saturated conditions
8 in the primary system loops.

9 That is, you would actuate your HPI prior to
10 losing all subcooling in the primary -- in the hot legs or
11 in the reactor coolant system.

12 Q I see. You expect the ECCS to be triggered prior
13 to the 50-degree margin?

14 A (WITNESS JONES) I am not so sure about the 50
15 degrees, because that is a combination including all the
16 various instrument errors. From a real-world situation,
17 what you would expect the actual fluid conditions to be, you
18 would have actuated the ECCS prior to actually losing
19 subcooling. So that you should have all of your emergency
20 systems on long before this.

21 If you do not have the steam generator, again the
22 key indicator that we would utilize is saturation for the
23 operator to manually initiate HPI for certain small-break
24 scenarios, where you have a very small break with normal
25 steam generator cooling. The operator is instructed to

1 actuate the HPI based on saturated conditions.

2 that also occurs long before you get to the core
3 water level uncovering. So that from the normal safety
4 systems that are designed to protect the plant from ever
5 uncovering the core, those functions are already taken and
6 will be done long before the water level is reached.

7 Now, as far as automatic re-actuating, protective
8 actions based on a water level signal for an inadequate core
9 cooling scenario, unless that water level instrument could
10 be designed to be highly reliable, to be very accurate, I
11 certainly would not advocate use of it to take some of the
12 additional operator actions we are contemplating, because
13 they can have unsafe ramifications if they trigger and come
14 on earlier than they are supposed to, such as the reactor
15 coolant -- start of the reactor coolant pumps in the middle
16 of a small-break LOCA does have a negative benefit, and if
17 it is not necessary to take that step, you should not.

18 So I disagree with his statement.

19

20

21

22

23

24

25

1 (Pause)

2 Q On page 14 of your testimony, the short paragraph
3 near the top of the page beginning, "We disagree," the
4 second sentence says, quote, "We also disagree with UTS and
5 ECNT that vessel water level indication should be installed
6 at TMI 1."

7 Was that ECNT that you meant there, or was it
8 NGREE?

9 MR. BAXTER: You are right.

10 CHAIRMAN SMITH: I think that is a better question
11 to Mr. Baxter, perhaps.

12 MR. BAXTER: Mr. Keaten and Mr. Jones, do you have
13 a correction to make on page 14, the penultimate part of
14 your testimony there where it says ECNT. Should that read
15 NGREE?

16 WITNESS KEATEN: I believe it should be NGREE
17 rather than ECNT. I would like to see the correction made.

18 DR. JORDAN: All right. I do not believe I have
19 further questions. I have asked quite a good number of
20 them, and most of them it seems to me have been covered. So
21 that is all I have.

22 CHAIRMAN SMITH: All right. Is there anything
23 further of the panel?

24 MR. CUTCHIN: No.

25 CHAIRMAN SMITH: Mr. Dornsife?

1 MR. DORNSIFE: Yes, I have two short questions
2 concerning Dr. Jordan's questions.

3 CROSS EXAMINATION ON BOARD

4 BY MR. DORNSIFE:

5 Q Mr. Pollard's concern about the thermocouples not
6 being in the circuit for feed and bleed, in the case of feed
7 and bleed aren't there, temperature instrumentations
8 available on the pressurizer that could indicate the same as
9 the hot leg RTDs and perform the same purpose.

10 A (WITNESS ROSS) Assuming the flow path is followed
11 all the way up through there, you do have two temperature
12 indicators located in the pressurizer itself, and they would
13 indicate the water temperature coming into the pressurizer.

14 Q Do you know physically where the hot leg RTDs are
15 located? Are they right on the vertical part of the hot
16 leg, or are they on the candy cane, or where physically are
17 they?

18 A (WITNESS JONES) They are located on the riser
19 section, the long vertical section on the hot leg,
20 approximately five to ten feet from the bottom of a 180
21 degree bend, right where it makes the turnover towards the
22 same generator.

23 It is somewhere in the five -- it is closer to the
24 five-foot - I believe away from that.

25 Q Is it conceivable under certain circumstances that

1 the one t-stat meter could be reading different than the
2 other one?

3 A (WITNESS JONES) Yes.

4 Q What would be the operator guidance if that were
5 the case?

6 A (WITNESS ROSS) I think the operator guidance
7 would be consistent with what we are telling him in all
8 cases that we give him guidance on, verify your parameters
9 by redundant indications; make decisions based on redundant
10 indicators and indicators that you feel are functional,
11 where you end up in a tie, where you believe your worst
12 indication, and take action accordingly.

13 Q So you are saying that -- let's say, an example
14 that a void started forming in the inactive loop, and you
15 had natural circulation in the other, and the t-stat meter
16 in the inactive loop approached such a region, and the other
17 indicated subcoolingd, that the operators would then only
18 look at the one in the inactive loop and not terminate high
19 pressure injection based on the reading in the inactive loop.

20 Is that what you are saying?

21 A (WITNESS ROSS) See in this case to look at other
22 indicators, in-core thermocouples -- he would select and
23 isolate temperatures. He would then look at the other leg.
24 At that point if he had TH subcooled on one look, if he had
25 thermocouples subcooled on one loop, he had all indications

1 that the core was in good shape, he would then have met his
2 prottling criteria.

3 He would say it was an out-of-service instrument.
4 He would have made the decision based on redundant
5 indicators and functional indicators and said it is out of
6 service. I have met my prottling criteria on the
7 instruments that are operable, those being instruments that
8 redundantly indicate the core is in a safe condition.

9 Q Do you feel this is clearly indicated in the
10 procedures?

11 A (WITNESS ROSS) To put every conceivable
12 combination in the procedure, of course you cannot do that.
13 I feel it is clearly indicated in his operator training that
14 he is to use redundant indicators, and I think it has been
15 clearly stressed in the OARP training we have done.

16 OARP is an abbreviation for operator accelerated
17 retraining program.

18 MR. DORNIFE: I have nothing further.

19 CHAIRMAN SMITH: All right. Gentlemen, you may
20 step down. Thank you.

21 (The witnesses were excused.)

22 CHAIRMAN SMITH: We are changing witnesses, and
23 Dr. Little has pointed out an area of completion about the
24 scheduling. You had indicated, Mr. Baxter, in your letter
25 of October 30 that you would present the testimony of Mr.

1 Groton in response to Board question number 11 at about this
2 time, I guess.

3 Now, you have it following this.

4 MR. BAXTER: No. We were going to try and do it.
5 Mr. Groton would have been available today, and he will be
6 available Friday. He will not be available tomorrow,
7 unfortunately. I have discussed it with Mr. Ketchen, and we
8 think it would be advantageous to have his witness and mine
9 appear roughly the same time.

10 We do not think that the hearing on this issue is
11 going to go past maybe mid-morning tomorrow, and I did not
12 think you would want to wait until Friday to hear Mr. Groton.

13 So what we thought we would do, unless you do want
14 to stay over to Friday for that would be to schedule Mr.
15 Groton and Mr. Jensen on Board question 11 as the very first
16 item on Tuesday the 27th. We do not think it will take a
17 long time, and then go into Class 9 accidents.

18 It would still follow this issue in the record,
19 but we are going to have some days off again.

20 CHAIRMAN SMITH: All right.

21 (Board conferring.)

22 MR. BAXTER: I did want to advise the Board that I
23 served Mr. Groton's testimony on Board question number 11 by
24 mail on October 30, so you might check to see if you have
25 it, and if you do not I will give you a copy before you

1 leave.

2 CHAIRMAN SMITH: That is not the problem with that
3 much lag. It is when we receive it -- it is when we are
4 here and it is delivered up there. A week does not make any
5 difference.

6 All right. With that arrangement then, the Board
7 would prefer the arrangement of beginning the first thing on
8 the 27th instead of staying over for Friday.

9 MR. CUTCHIN: I have no preference. I apologize.
10 I was not paying attention at the moment. Could someone
11 repeat the question?

12 DR. LITTLE: We just arrived at a decision, if it
13 is okay with you, to have the Board question 11 the first
14 thing on January 27.

15 MR. CUTCHIN: Yes, ma'am. I had understood that
16 to be the case a moment ago. Mr. Baxter and I had agreed
17 that that would be the preferred thing to do unless the
18 Board had a different preference.

19 CHAIRMAN SMITH: Now, the Board got into it. We
20 prefer that approach.

21 MR. CUTCHIN: That is fine with the staff.

22 CHAIRMAN SMITH: Okay. We have Mr. Phillips.
23 Whereupon,

24 LAURENCE E. PHILLIPS
25 was called as a witness, and after having been duly sworn,

1 was examined and testified as follows:

2 DIRECT EXAMINATION

3 BY MR. CUTCHIN:

4 Q Mr. Phillips, do you have before you two
5 documents, both bearing the caption of this proceeding, the
6 first being entitled, NRC Staff Testimony of Laurence E.
7 Phillips Regarding Reactor Water Level Instrumentation (UCS
8 Contention 7, Sholley Contention 6B, and NGRREE contention
9 5B)?

10 A Yes, I do.

11 Q Did you also prepare a copy of your professional
12 qualifications which I have now given copies of to the
13 Board, and which I have attached to that original testimony?

14 A Yes, I did.

15 Q Do you have any corrections to make to this first
16 document?

17 A Yes, I have some corrections.

18 Q Would you identify them, please?

19 A On page four in the last two lines of the answer
20 to Q-8, if you would inject the phrase -- now ends in
21 saying, the core is uncovered, exists, and that should read,
22 when the core is uncovered and although provide indication
23 that the core is covered when no superheat exists.

24 MR. BAXTER: I am sorry, Mr. Cutchin. I need to
25 ask to have that again. I just did not get it.

1 MR. CUTCHIN: To insert between the words,
2 uncovered, and exists, quote, and also provide indications
3 that the core is uncovered when no superheat, end quote.
4 "Exists" is the word that was still there. Corrections have
5 been made in the reporter's copy.

6 WITNESS PHILLIPS: On page five, the second
7 paragraph, the second line, water. The w should be lower
8 case where it say, water level instrument.

9 On the same page, the answer to question Q-10, the
10 fourth line, insert between the words, sensors and cold leg,
11 the word, and. It should read, sensors, comma, and cold leg
12 and hot leg.

13 On page six the answer to Q-11 at the end of the
14 third line, it reads, reactor coolant system temperature.
15 It should read, insert between system and temperature the
16 words, pressure, comma, reactor vessel outlet, temperature,
17 comma.

18 That is all the corrections I have.

19 BY MR. CUTCHIN:

20 Q Did you also prepare a document bearing the
21 caption of this proceeding entitled, NRC Staff Testimony of
22 Laurence E. Phillips, supplementary testimony to that of
23 Laurence E. Phillips filed December 1, 1980, regarding
24 reactor water level instrumentation (UCS Contention 7,
25 Sholley Contention 6B and NGRRE Contention 5B)?

1 A Yes.

2 Q Are there any corrections to be made to this
3 document?

4 A None.

5 Q As modified, are these documents true and correct
6 to the best of your knowledge and belief?

7 A Yes.

8 Q Do you adopt them as your testimony in this
9 proceeding?

10 A I do.

11 MR. CUTCHIN: Mr. Chairman, I offered the
12 documents just identified, which include the two pieces of
13 direct testimony plus one copy of Mr. Phillips' professional
14 qualifications be received into evidence and bound into the
15 transcript at this point as it is read.

16 CHAIRMAN SMITH: If there are no objections, the
17 testimony is received.

18 (The documents referred to above were received in
19 evidence.)

20

21

22

23

24

25

corrected copy

1/21/81
Layman 1/21

UNITED STATES NUCLEAR REGULATORY COMMISSION

In the Matter of)
Metropolitan Edison Company) Docket No. 50-289
(Three Mile Island Nuclear)
Station, Unit 1 Restart))

NRC STAFF TESTIMONY OF LAURENCE E. PHILLIPS
REGARDING REACTOR WATER LEVEL INSTRUMENTATION
(UCS Contention 7, Sholly Contention 6(b) and
ANGRY Contention 5(b))

- Q.1. Please state your name and position with the NRC.
- A. My name is Laurence E. Phillips. My position is Section Leader, of the Thermal-Hydraulics Section, Core Performance Branch, Division of Systems Integration, Office of Nuclear Reactor Regulatory.
- Q.2. Have you prepared a statement of professional qualifications?
- A. Yes, a copy of this statement is attached to this testimony.
- Q.3. Please state the nature of the responsibilities that you have with respect to the Three Mile Island Nuclear Station, Unit 1.
- A. I am responsible for managing the review of licensee responses to the requirements of TMI Task Action Plan, II.F.2 in particular and Inadequate Core Cooling requirements in general.
- Q.4. What is the purpose of your testimony?
- A. The purpose of this testimony is to respond to three similar contentions; UCS contention 7, Sholly Contention 6(b), and Angry Contention 5(b)

UCS Contention 7 reads as follows:

"NRC regulations require instrumentation to monitor variables as appropriate to ensure adequate safety (GDC 13) and that the instrumentation shall directly measure the desired variable.

IEEE 279, 4.8, as incorporated in 10 CFR 50.55a(h), states that:

To the extent feasible and practical protection system inputs shall be derived from signals which are direct measures of the desired variables.

TMI-1 has no capability to directly measure the water level in the fuel assemblies. The absence of such instrumentation delayed recognition of a low water level condition in the reactor for a long period of time. Nothing proposed by the staff would require a direct measure of water level or provide an equivalent level of protection. The absence of such instrumentation poses a threat to public health and safety."

Sholly Contention 6(b) reads as follows:

"The Commission's Order and Notice of Hearing dated 9 August 1979 are insufficient to provide the requisite reasonable assurance of operation without endangering public health and safety because these short-term actions do not include the following items:

- b. Completion of installation of instrumentation for detection of inadequate core cooling:"

Angry Contention 5(b) reads as follows:

"The NRC Order fails to require as conditions for restart the following modifications in the design of the TMI-1 reactor

without which there can be no reasonable assurance that TMI-1 can be operated without endangering the public health and safety:

- (b) Installation of instrumentation providing reactor operators direct information as to the level of primary coolant in the reactor core."

Q.5. What may cause inadequate core cooling?

A. An example is a small break LOCA. However, our objective is to detect the symptoms of inadequate core cooling and to initiate and monitor the progress of corrective action independent of the cause of the condition and of other preceding actions which should have precluded the ICC condition.

These contentions allege that until the instrumentation to detect inadequate core cooling includes a means for direct measurement of core water level, it will not be safe to allow TMI-1 to restart.

Q.6. What is the relationship between the reactor water level and the inadequate core cooling?

A. As long as the reactor is shut down and the two phase froth level (the swollen water level due to the presence of steam voids) is above the top of the core, cooling is adequate. When the two-phase froth level begins to drop below the top of the core, the exposed fuel begins to heat up and will ultimately reach temperatures at which fuel damage occurs. This is inadequate core cooling.

Q.7. What conditions must be monitored to provide a direct indication of inadequate core cooling?

A. The most direct indication is an increase in fuel temperature or surface temperature of the fuel cladding. In addition, the two phase froth level without pumped flow or the coolant quality with pumped flow provides indication of conditions associated with inadequate core cooling.

Q.8. Why isn't instrumentation to directly measure these parameters required?

A. There are serious problems concerning the feasibility and reliability of the design of a commercial PWR core to incorporate thermocouples attached directly to the fuel cladding surface. Such a design would greatly complicate the installation and replacement of fuel assemblies. In addition to the coolant level and quality measurements, there are indirect indicators (e.g., core exit thermocouples) of inadequate core cooling and of conditions which could lead to inadequate core cooling (e.g., saturation meters) which can be monitored more reliably and can provide equivalent information to the operator if properly processed for display and incorporation into emergency procedures. Core exit thermocouples provide an indication of the magnitude of steam superheat when the core is uncovered ^{and also provide} ~~exists~~ indication that the core is covered when no superheat exists.

Q.9. Does the absence of direct water level measurement instrumentation conflict with GDC 13 and 10 CFR 50.55a(h) of NRC regulations as inferred by UCS Contention 7?

A. GDC 13 states: "Instrumentation shall be provided to monitor variables and systems over their anticipated ranges for normal operation, for anticipated operational occurrences, and for accident conditions as appropriate to assure adequate safety, including those variables and systems that can affect the fission process, the integrity of the reactor core, the reactor coolant pressure boundary, and the containment and its associated systems. Appropriate controls shall be provided to maintain these variables and systems within prescribed operating ranges."

For TMI-1 and other PWRs, the normal water level range in the reactor coolant system is within the pressurizer and is maintained by the pressurizer level control system. For transient and accident conditions resulting in low coolant inventory, the high pressure and low pressure safety injection systems are initiated on low pressure signal to reflood the primary system. Reactor vessel water level is not an appropriate input to the safety injection system since the corrective action is initiated by a low pressure signal well in advance of core uncover.

Regulation 10 CFR 55 a(h) applies only to protection systems. Reactor water level instrumentation, if installed, will be used for monitoring and operator actions only and will not provide input to protection systems. Additionally, regulation 10 CFR 55a(h) is applicable only to construction permits issued after January 1, 1971. The TMI-1 construction permit was issued in 1968.

Q.10. What instrumentation is currently available at TMI-1 to indicate inadequate core cooling?

A. The instrumentation available at TMI-1 that could indicate inadequate core cooling includes core exit thermocouples which indicate coolant superheat associated with excessive fuel cladding temperature, reactor coolant pressure sensors, ^{and} cold leg and hot leg resistance temperature detectors (RTDs) which provide inputs to compute the margin to coolant saturation conditions, subcooling meters which will display the margin to saturation, and reactor coolant pump current which provides indication of increasing coolant quality while the pumps are running.

Q.11. Have emergency procedures for response to inadequate core cooling in TMI-1 using existing instrumentation systems been approved by the staff?

A. The licensee has proposed emergency procedures for inadequate core cooling (EP 1202-39 and 1202-6B), which rely on the information available from the core exit thermocouples, reactor coolant system *pressure,* *reactor vessel outlet* temperature, and the new saturation (subcooling) meters to identify the approach and existence of inadequate core cooling and to specify the operator actions required to prevent or recover from inadequate core cooling. These procedures are under review by the staff and revised submittals have been requested from the licensee. Although we have not completed our review at this time, we are confident that procedures acceptable for TMI-1 restart without reliance on water level measurement can be developed. The staff has found ICC emergency procedures based on instrumentation similar to that which will be provided prior to TMI-1 restart to be acceptable for other PWRs while a level measurement system to further enhance the operational safety is being developed. We will keep the Board apprised of our progress in the development of acceptable procedures for TMI-1 restart.

Q.12. How are the existing instrumentation systems at TMI-1 being upgraded to accomplish the inadequate core cooling response objectives?

A. Prior to restart of TMI-1, we will require an upgrading of those existing instrumentation systems, information displays, and operating procedures which relate to the detection of and response to inadequate core cooling conditions. These modifications in conjunction with improved operator training will substantially enhance the capability of the operator

to recognize and respond to conditions of inadequate core cooling.

The licensee has committed to install a primary coolant saturation meter, and has also described two short-term modifications to existing instruments to satisfy the requirements of NUREG-0578 (TMI-2 Lessons Learned Task Force Status Report and Short-Term Recommendations, July 1979).

These changes involve routing the in-core thermocouple signals outside of containment and connecting the 52 in-core thermocouples to the plant computer (for display purposes), and providing an extended range for reactor outlet (T_H) temperature measurement (from 520° -620° F to 120° -920° F). This modification will be made to four T_H channels, two in each reactor coolant loop. In addition, it is intended to isolate the new wide range T_H signal from the existing control signals.

These signals will then be seismic Category I and separated for use as redundant signals. It is anticipated that all modifications required for existing instrumentation will be implemented prior to TMI-1 restart.

- Q.13. What are the design criteria for instrumentation for detection of inadequate core cooling? Will the TMI-1 instrumentation meet these criteria prior to restart?
- A. All instrumentation in the final inadequate core cooling monitoring system must be evaluated for conformance to TMI Task Action Plan II.F.2 as clarified in NUREG-0737, November 1980, including Attachment 1 (In-core Thermocouple criteria) and Appendix B, "Design and Qualification Criteria for Accident

Monitoring Instrumentation," of the cited document. Such an evaluation will be required prior to restart and deviations must be justified.

Q.14. What additional instrumentation, if any, will be required for detection of inadequate core cooling for TMI-1. Will any additional instrumentation be installed prior to restart?

A. The staff requirements for additional instrumentation to detect inadequate core cooling are presented in NUREG-0578 and supporting documents (D. Eisenhut (NRC) letter to All Operating Nuclear Power Plants On "Followup Actions Resulting from the NRC Staff Reviews Regarding the Three Mile Island Unit 2 Accident," dated September 13, 1979; H. Denton (NRC) letter to All Operating Nuclear Power Plants on "Discussion of Lessons Learned Short-Term Requirements," dated October 30, 1979) and are further clarified in NUREG-0737. These documents state that the licensee shall provide a description of any additional instrumentation or controls proposed for the plant to supplement those devices cited in the preceding section of the requirement (2.1.3.b) which give an unambiguous, easy-to-interpret indication of inadequate core cooling.

The clarification provided with the Denton letter to operating nuclear power plants specifically states that "The evaluation is to include reactor water level indication." The purpose of the evaluation is to determine the feasibility and practicality of direct water level measurement in the core and to allow the licensee to select the best of several instrumentation concepts and/or data processing schemes, for obtaining a clear indication of inadequate core cooling conditions.

Metropolitan Edison and Babcock & Wilcox have proposed the use of existing instruments (that is, no additional instrumentation) to provide an indication of inadequate core cooling. The basis for this proposal is that there is no need for additional instrumentation, particularly a reactor vessel water level measurement, to determine inadequate core cooling. We have reviewed the justification for no additional instrumentation and have found it unacceptable (D. Eisenhut (NRC) letter to R. Arnold (Met. Ed. Co.) on "Lessons Learned Short-Term Requirements 2.1.3.b Instrumentation For Detection of Inadequate Core Cooling - Additional Information," dated September 24, 1980).

We will require that Metropolitan Edison provide an acceptable response to the Inadequate Core Cooling requirements, as detailed in our clarification for TMI-2 Task Action Plan II.F.2 (NUREG-0737), by January 1, 1981. Identification of new instrumentation to be installed and the schedule for installation cannot be provided until we review the submittal. Based on the current status of our review, it is likely that a water level measurement system will be required, but not necessarily prior to restart. In the absence of such a system, the NRC staff will assure that the instrumentation and procedures provided for detection and response to inadequate core cooling conditions are adequate for safe operation.

Laurence E. Phillips

CORE PERFORMANCE BRANCH
DIVISION OF SYSTEMS INTEGRATION
U. S. NUCLEAR REGULATORY COMMISSION

PROFESSIONAL QUALIFICATIONS

I am employed as a Section Leader of the Thermal-Hydraulics Section in the Core Performance Branch of DSI.

I graduated from the University of Cincinnati with a Chemical Engineering degree in 1954. After serving two years as an officer in the United States Army, I have been continuously employed in the nuclear engineering profession since January, 1957. I received a M.S. degree with nuclear physics major from Union College of Schenectady, N. Y., in 1961. I am a registered Professional Engineer, Certificate #E-026547, in the state of Ohio.

In my present work assignment at the NRC, I have supervisory responsibility for the review of the reactor core thermal-hydraulic design submitted in all reactor construction permit and operating license applications. In addition, my section participates in the review of analytical models used in the licensing evaluation of the core thermal-hydraulic behavior under various operating and postulated accident transient conditions. The latter responsibility includes technical review of the functional requirements for core monitoring systems to provide capability for detection and response to inadequate core cooling conditions.

Prior to joining the NRC staff in December, 1974, I was employed by NAI Corporation as a Senior Associate. In this capacity, I was responsible for the development and application of computer codes for analysis of nuclear reactor cores. I acted as a consultant to nuclear operating utilities in the use of these codes for analysis of their operation, and in the solution of general nuclear engineering problems. My tenure at NAI was from 1967 through 1974.

From 1962 to 1967, I was employed by Allis Chalmers Mfg. Co. My assignments during that period included supervisory responsibility for the safety analyses and licensing of the LaCrosse Boiling Water Reactor.

From 1958 to 1962, I was employed by Alco Products where I was project manager for the design, development, and fabrication of heat exchange equipment for nuclear liquid metal projects. Prior to that I was with the Nuclear Division of the Martin Company.

UNITED STATES NUCLEAR REGULATORY COMMISSION
BEFORE THE ATOMIC SAFETY AND LICENSING BOARD

In the Matter of)
Metropolitan Edison Company) Docket No. 50-289
(Three Mile Island Nuclear)
Station, Unit 1 Restart))

NRC STAFF TESTIMONY OF LAURENCE E. PHILLIPS
SUPPLEMENTARY TESTIMONY TO THAT OF LAURENCE E. PHILLIPS

FILED DECEMBER 1, 1980

REGARDING REACTOR WATER LEVEL INSTRUMENTATION
(UCS Contention 7, Sholly Contention 6(b) and
ANGRY Contention 5(b))

- Q.1s Metropolitan Edison in their October 2, 1980 letter (TLL 500) to the NRC takes the position that no additional instruments are necessary or desirable since the NRC has not identified any needed improvements in the inadequate core cooling guidelines. Has the staff responded to this position to make clear that additional instrumentation will be required?
- A. The position stated in the reference correspondence is no different than the position previously taken and addressed by the staff in the TMI-1 Restart Evaluation, NUREG-0680, June, 1980, pp. C8-20 and 21. Additionally, the present staff position, including rejection of the cited position of the licensee, is clearly stated in the September 24, 1980 letter and SER from D. Eisenhut to R. C. Arnold of Metropolitan Edison. The staff requirements for Metropolitan Edison and all other licensees are further reinforced by the issuance of NUREG-0737 in

November, 1980. Metropolitan Edison, in their letter of November 20, 1980 (TLL 591), did acknowledge the staff requirements and promised to provide a response by January, 1981. The staff has provided no comment on the October 2 letter and will have nothing to add to the discussion and staff position already provided until we complete our review of the January submittal.

Q.2s Since the staff has not identified differences in operator actions if level information were available versus the actions that are prescribed by the existing Inadequate Core Cooling guidelines, what is the need for reactor vessel level indication?

A. The Met Ed/B&W procedures for detection of Inadequate Core Cooling rely primarily on the saturation meter and core exit thermocouples. The saturation meter, while providing a basis for initial actions, does not distinguish between anomalous transients which can drain the pressurizer and cause primary loop saturation due to cooling and shrinkage of primary coolant versus loss of coolant inventory which could lead to inadequate core cooling if it continues.

TMI-1 Emergency Procedure 1202-6B describes the different operator responses to small break LOCA versus overcooling events which cause automatic high pressure injection. These procedures now require the operator to distinguish between the transients based on indirect indicators from existing instrumentation. Vessel level instrumentation, if available, would permit a much quicker and more reliable diagnosis of the conditions. For small break LOCA, an orderly cool-

down is required, but not necessarily for an overcooling transient. In both cases, a vessel level meter if available, would provide coordinating information to assist the operator in restoring the water solid primary system (possibly using the upper head vent) and the normal water level in the pressurizer.

For a small break LOCA, the primary system will continue to lose coolant inventory, at a rate and duration dependent on the size and location of the break, until the safety injection make-up flow exceeds the rate of coolant loss. For some conditions, the time interval from the instant of primary system saturation conditions until the occurrence of superheat indication on the core exit thermocouples or hot leg RTDs is in excess of 30 minutes, and possibly up to three hours or more. The superheat condition does not occur until the core is partially uncovered and fuel heat up has begun.

If level instrumentation were available, the effectiveness of HPI in recovering the system and the trend of level indication (continuing to lose coolant or refilling the system) would provide valuable diagnostic information on the nature of the transient before the level drops into the core. The level indication would also provide evidence that the core is covered during recovery from a TMI-2 type flow blockage condition, even though superheat may persist at the core exit thermocouples. None of the process parameters monitored by existing instrumentation provide equivalent information on a continuous basis.

The NRC staff has not evaluated the possible actions the operator would take based on core level instrumentation but has required that the licensees describe how emergency procedures should be modified after level instrumentation is incorporated (Item (7) and (8) of Documentation Required in II.F.2 of NUREG-0737). Met Ed has not yet submitted any analyses or evaluation addressing additional operator actions which could be taken to prevent core uncovering for small break LOCAs if level information were available for prompt diagnosis of the condition.

A recent event at St. Lucie (June 11, 1980) provides a classic example of an anomalous event leading to steam bubble formation in the reactor vessel head. The condition was not recognized by plant operators since instrumentation was not available to detect the low-level condition. The post-event evaluation concluded that unsafe operator actions could have been taken. ("Report on the St. Lucie I Natural Circulation Cooldown on June 11, 1980," by E. V. Imbro, Office for Analysis and Evaluation of Operational Data, USNRC.) Vessel level information would have indicated the void formation in the upper head and thus prevented operator confusion which contributes to the likelihood of unsafe actions. Additionally, vessel level indication would provide a safe basis for manual shut off of HPI to avoid overflow to containment.

Finally, vessel level information is important and possibly essential to proper emergency procedures relating to use of the reactor vessel

head vent required by the TMI Action Plan. Vessel level information would indicate the existence of a void in the upper head so that the need for vessel venting could be evaluated. The NRC staff has not evaluated the conditions for which the head vent should be opened and has requested that procedures for use of the vent be provided by the licensee. However, the staff is aware of at least one vent design for which the designer insists on the coupling of level information to the safe operation of the vent.

In summary, the staff believes that reactor vessel level information will enhance the operating safety of PWRs.

1 CHAIRMAN SMITH: We will take a break for just a
2 moment.

3 (Board conferring.)

4 CHAIRMAN SMITH: We are just addressing our travel
5 schedule here while there is still opportunity. We will be
6 checking tomorrow and concluding tomorrow by noon.

7 MR. CUTCHIN: I have only a couple of rebuttal
8 questions, so how long it takes will depend upon how much
9 cross examination and how many Board questions there are.

10 CHAIRMAN SMITH: Okay. Mr. Dornsife, do you think
11 that is reasonable that we will be --

12 MR. DORNSIFE: Yes.

13 CHAIRMAN SMITH: Also, before you begin, may we
14 throw away Mr. Rubin's testimony?

15 MR. CUTCHIN: Yes, you may.

16 BY MR. CUTCHIN:

17 Q Mr. Phillips, the licensee's witnesses, which
18 consisted of both representatives of Met Ed and the reactor
19 vendor, BMW, have testified that instrumentation to measure
20 reactor vessel water level is unnecessary.

21 Can you identify whether the position taken by the
22 licensee and BMW is consistent with that taken by other TWR
23 vendors?

24 A It is not consistent with that taken by other
25 vendors.

1 Q Would you explain, please?

2 A Other vendors -- by other vendors I am speaking of
3 the PWR vendors, Westinghouse and Combustion Engineering.
4 They have proposed water level measurement systems which
5 they are recommending to their -- to their customers.

6 Westinghouse has proposed a Delta-T measurement
7 system. Combustion Engineering has proposed the heated
8 junction thermocouple system. The heated junction
9 thermocouple system, to expand a little bit on the principle
10 of it, is basically one heated junction thermocouple and one
11 regular thermocouple with a reference which is used as a
12 reference temperature.

13 When the thermocouples are immersed in fluid, the
14 output -- the amount of cooling of the heated junction, the
15 difference between the two temperatures is proportional to
16 the voiding in that particular region. So it is really a
17 direct measure of the cooling in the area of the
18 thermocouple.

19 These thermocouples are inserted in the top of the
20 reactor vessel and extended down to the top of the core.
21 They will have to be supplemented by other means to measure
22 to the bottom of the core.

23 Other means would likely for the most part be
24 regular thermocouples inserted in instrument tubes, and the
25 Delta-T measurement system, as proposed by Westinghouse,

1 basically consists of three taps; one in a vessel head; one
2 at the bottom of the vessel; one at the hot leg.

3 They have done rather extensive analyses of what
4 the response would be to various situations, and they
5 interpret the measurement in terms of measuring mass while
6 the pumps are running.

7 This is based primarily on the two phase pressure
8 drop, the change in two-phase pressure drop with voiding,
9 and a direct measure of level when the pumps are cut off and
10 not running. So it is a measurement of coolant inventory.

11 The heated junction thermocouples have been tested
12 at Oak Ridge to a good deal, and Combustion Engineering is
13 running their own test. The staff feels that both of these
14 concepts show high promise and would appear to certainly be
15 a valuable additional instrument to those which are already
16 employed.

17 Our interpretation of much of the testimony this
18 morning seems to be weighing the level instrumentation as
19 opposed to the other instruments. The staff is looking at
20 this as a complete -- a system of inadequate core cooling
21 instrumentation, and are looking at the interpretation of
22 all the instruments together.

23 And if sufficient analyses have been performed,
24 say, to identify certain anomalous situations for one
25 instrument which may exist for a short period of time, if

1 that is combined with the output from other instruments
2 which will allow recognition of the anomalous situation, we
3 feel that the likelihood is very high indeed of an
4 acceptable system can be developed.

5 We feel that the processing of the data and the
6 display to the operators is a very important part of that
7 system, and as such, until the systems are installed, and
8 the operating methods have been identified and the
9 calibration and test data is available and the staff is
10 certain that these systems are indeed a plus as far as
11 safety goes and are not providing information which would
12 lead to unsafe actions, we cannot say in advance a system is
13 acceptable.

14 That is essentially where we stand.

15 DR. JORDAN: I do not quite understand now. Are
16 you saying this is a diverse method of measuring inadequate
17 core cooling, that the thermocouples or whatever provide a
18 complete system which tells you -- gives you an approach to
19 inadequate cooling quite apart from all the other systems?
20 Is that what you meant? Is that what you were saying? I
21 did not quite really understand.

22 WITNESS PHILLIPS: I am saying that when we --
23 let's say if there is a leak in the reactor vessel head and
24 we have a Delta-t measurement system as an example, analyses
25 have identified that there is a situation where for a brief

1 period of time under that situation you can get a false
2 indication on levels.

3 Using other instruments, other data which are
4 available, you can identify these situations and negate the
5 indication during that period as far as the operator is
6 concerned, during the period when an ambiguity may exist.

7 So there is a matter of interpretation of data in
8 the design of the system, as well as just putting in the
9 system itself. When we look at the system we look at the
10 core exit thermocouples. Certainly they are a valuable
11 indicator, and we have never proposed that levels should
12 replace them. They should be another confirmatory source of
13 information, and we just cannot believe that if a good
14 source of level measurement is available, that the operator
15 will be told to ignore that information.

16 DR. JORDAN: Then I think I did misunderstand. I
17 think I got it backwards. In fact, what you are saying is
18 that the core level instrumentation supplements all the
19 other information. It is not adequate in itself. It does
20 not do the job all by itself.

21 WITNESS PHILLIPS: That is correct.

22 DR. JORDAN: Okay. Then I just misunderstood, and
23 I wanted to get that straightened out. You go ahead.

24 BY MR. CUTCHIN:

25 Q Mr. Phillips, I believe you may have answered part

1 of this, but for clarity in the record, licensee's witnesses
2 also testified that reactor vessel water level information
3 in accident or transient situations may in their view tend
4 to confuse the operator.

5 Would you comment on that?

6 A I believe I did perhaps jump the gun in answer to
7 that. This would be a situation which has been identified
8 beforehand by rather extensive analyses, situations where a
9 false indication may be available for a short period of
10 time, and if other indicators are used in the interpretation
11 of the information, that can be processed either
12 automatically in a data processing system or, depending on
13 the complexity, by instructions such that such confusing
14 interpretation need not exist.

15 MR. CUTCHIN: Mr. Chairman, these are all of my
16 rebuttal questions. However, in light of the hour and the
17 fact that we have an outstanding question which Dr. Little
18 had which appeared on page 7488 and 7489 of the transcript
19 and had to do with her expression of some confusion in
20 interpreting page 3-113 of new reg 0737, I thought that
21 perhaps since it looks like we won't get into cross
22 examination today, it may be appropriate to go ahead and
23 have Mr. Phillips, who is the person managing the review of
24 the requirements of that past action plan, try to remove, if
25 he can, some of Dr. Little's confusion.

1 CHAIRMAN SMITH: Any objections to that?

2 (No response.)

3 CHAIRMAN SMITH: Let's review what the question is.

4 MR. CUTCHIN: I have the transcript pages that I
5 would be happy to try to identify the question. The pages,
6 I said, again are page 7488 and 7489.

7 Dr. Little said on 7488, I have been confused for
8 some time now because I have read the section in new reg
9 0737 on instrumentation for protection of inadequate core
10 cooling, and the new requirements for in-core thermocouples,
11 and when I read that first page there it looks to me as
12 though CRT and computer capability for reading those is
13 being encouraged rather than discouraged.

14 Later on she says, let me tell you the page that
15 is confusing me. If somebody has a chance to read it and
16 come back sometime later in the hearing and explain it, I
17 would be interested in hearing it. It is page 3-113 and is
18 of new reg 0737, dealing with Roman numeral II.F.2.

19 WITNESS PHILLIPS: Yes. Could you be more
20 specific please?

21 DR. LITTLE: Let me review it quickly.

22 (Pause.)

23 MR. CUTCHIN: I am sorry I caught you somewhat by
24 surprise, but I thought with the short time left it might be
25 a good time to take it up.

1 DR. LITTLE: I did have the page already opened
2 there.

3 CHAIRMAN SMITH: I think you may have the witness
4 by surprise.

5 MR. CUTCHIN: I hope not because we discussed it
6 over the noon hour.

7 (Pause.)

8 WITNESS PHILLIPS: The statement to be read
9 concerning our emerging computer system is a correct
10 interpretation. That was an objective, and we feel that
11 that will aid in the processing of a number of signals -- a
12 number of indicators in interpreting and displaying to the
13 operator such that he sees what he needs to know and doesn't
14 have to interpret it on his own.

15 DR. LITTLE: I believe discussion arose when we
16 were talking about use of CRT and the fact that totally
17 qualified CRT displays were not available, but that the
18 indication that was given in the section was that
19 nevertheless, these would be encouraged -- CRT displays of
20 in-core conditions would be encouraged, and that it felt
21 that it was warranted because -- while this relaxation can
22 be accomplished without compromise of ICC monitoring
23 reliability by requiring 99 percent availability for the
24 display systems.

25 That was the main thing, and by relying on diverse

1 methods of ICC monitoring that include completely qualified
2 display systems.

3 WITNESS PHILLIPS: Yes. That is referring to
4 having a backup system available which is hard-wired. Let's
5 see. I believe this is -- this is referring to the in-core
6 thermocouple system here, and if you need the -- if you go
7 over all of the requirements, you will find that where the
8 CRT display is the primary system and the CRT is not
9 seismically qualified, there is in all cases a hard-wired
10 backup system which can be used to provide these same
11 information in not such a good fashion, you might say.

12 But that is available in qualified systems.

13 DR. LITTLE: This leads us to the question of
14 whether the operator is relying on something less reliable
15 than what he has available already.

16 WITNESS PHILLIPS: No. He will still have
17 available what he has available already. He is relying on a
18 system which more completely processes the information
19 available and displays it to him in a fashion which is much
20 easier to understand, and it is a highly reliable system.

21 It is just that it does not meet seismic criteria,
22 and some of the more stringent design criteria which would
23 make, number one, a huge procurement problem in obtaining it
24 on any sort of a reasonable schedule, if it could be
25 obtained at all.

1 But in all cases we have looked at the information
2 that is required, and in all cases we are requiring a backup
3 hard-wired system which does meet seismic criteria which he
4 would be able to make do on in the unlikely event that he
5 has an earthquake, as he is making do on now without the
6 additional instrumentation in the system.

7 For instance, the facts are determined to some
8 degree; we agree with the licensee it is possible on the
9 instrumentation that they have now to manage to detect
10 inadequate core cooling.

11 What the staff and the Commission has determined
12 is that an additional margin of safety can be obtained, and
13 the techniques can be enhanced by providing additional
14 instrumentation.

15 If we felt that what now exists, that there was
16 not a way to do the job operating, say, somewhat in the
17 dark, we would have recommended closing down all the
18 plants. We do not think that is the case. We do think that
19 the system can be improved, and we would look on the CRT
20 system as an improvement.

21 This will not take away anything that already
22 exists. It will still be there.

23 DR. LITTLE: I would assume then that the CRT
24 display would be something that would, if in the unlikely
25 event that there were seismic problems, that the CRT would

1 not give information, rather than to continue to give
2 information, but inaccurate information.

3 WITNESS PHILLIPS: I would say it would either
4 give -- it is likely it would either give adequate
5 information or it would not give it at all.

6 DR. LITTLE: So the operator would know
7 immediately that he should use the backup. He would not be
8 misled by getting inaccurate information over the CRT.

9 WITNESS PHILLIPS: Yes. I would say that that
10 certainly should be a design consideration and would be
11 something that would be looked at as part of the design.

12 DR. LITTLE: Could you elaborate a little on this
13 sentence earlier in that paragraph, speaking to the
14 feasibility of use of CRT displays for proper interpretation
15 of reactor water level systems under development?

16 WITNESS PHILLIPS: I am sorry. I am having
17 trouble finding that.

18 DR. LITTLE: It is about the section we are
19 talking about. It is about six or seven lines above the
20 bottom of the page, 3-113.

21 WITNESS PHILLIPS: Where it says, and make
22 feasible the use?

23 DR. LITTLE: Of CRT displays that may be needed
24 for proper interpretation of some reactor water level
25 systems under development.

1 WITNESS PHILLIPS: Yes. That gets at the
2 situation I was talking about earlier where if you have an
3 anomalous situation which may occur on one indicator. If
4 that indicator were looked at alone, it could be an
5 ambiguous interpretation.

6 You may want to feed in additional figures which
7 would allow automatic interpretation, and either make a
8 signal as far as the operator was concerned at the time that
9 it is unreliable, or process it in a manner that properly
10 interprets it for feed display to the operator.

11 DR. LITTLE: So you are going to have some program
12 that will tell which of the signals coming in is anomalous
13 and which is not?

14 WITNESS PHILLIPS: Yes.

15 DR. LITTLE: I guess I would like to hear Mr.
16 Jones and Mr. Keaten's opinion some time before we finish,
17 the feasibility of doing that.

18 MR. CUTCHIN: I would like to point out, just for
19 additional information in the record at this point, Dr.
20 Jordan had some questions yesterday on this same general
21 area in connection with one of the areas of this agreement
22 between staff and licensee on human factors engineering.

23 That appeared start on page 10,523.

24 DR. JORDAN: Before you get to that, stay with the
25 same page that you are on. It is just a matter strictly of

1 clarification.

2 Two or three sentences above where you were
3 talking about, you say, the pertinent portions of draft
4 regulatory guide 1.97 have now been included as Appendix A.
5 What is Appendix A?

6 WITNESS PHILLIPS: That is an error. It should
7 have been Appendix B. It was Appendix A at the time this
8 appeared. It later became Appendix B.

9 Appendix E is an extract from regulatory guide
10 1.97 in the draft form. We did not want to refer to a draft
11 regulatory guide as a basis for the design of the systems.

12 DR. JORDAN: Appendix E to what?

13 WITNESS PHILLIPS: This document.

14 MR. CUTCHIN: New reg 0737.

15 DR. JORDAN: That will help. I looked at Appendix
16 A and did not find it. Now if I look to Appendix B, I will
17 find something.

18 WITNESS PHILLIPS: Right, I hope.

19 DR. JORDAN: That is all I needed to know, was
20 where to look. I have not read it yet. I don't know what
21 it says.

22 WITNESS PHILLIPS: It has the seismic defined
23 criteria and all that other good stuff in it.

24 DR. JORDAN: Yes, all that other good stuff. I
25 understand.

1 MR. CUTCHIN: That was all I had. I just wanted
2 to tie the two pieces of the transcript together by citing
3 the other page number. The discussion of the backup display
4 for in-core thermocouples independent of the process
5 computer took place yesterday at page -- starting at page,
6 transcript 10,523.

7 I just wanted it to appear here for a reference
8 back.

9 DR. JORDAN: All right. I see.

10 DR. LITTLE: Do you know of any vendor or
11 operating plant or any entity which is close to having a
12 program of the type which you just described which would
13 display on the CRT how do you determine which of the
14 readings is correct and which is not?

15 WITNESS PHILLIPS: We have some systems. This
16 required some design descriptions of the system on January
17 1, 1981 recently, so those documents are just coming into
18 the house, and as yet we have not -- by the house, I mean
19 NRC.

20 DR. JORDAN: These are Westinghouse?

21 WITNESS PHILLIPS: Westinghouse documents.

22 DR. JORDAN: We will get into those tomorrow.

23 WITNESS PHILLIPS: And we have not actually
24 commenced our review of them, but they have -- I would say
25 that the Westinghouse generic documents have three different

1 levels of data processing on the systems.

2 We have not looked at them. I do not know what
3 they are, but they are the -- the more sophisticated one
4 would incorporate, I am sure, quite a bit of assessing data
5 processing.

6 DR. LITTLE: What is your opinion about in the
7 instrumentation for measuring water level without having a
8 CRT display with the appropriate program?

9 WITNESS PHILLIPS: I am sorry. I did not catch
10 that.

11 DR. LITTLE: I am asking you what your opinion is
12 about having the instrumentation for measuring the reactor
13 water level, but not having an accompanying program to
14 interpret its significance.

15 WITNESS PHILLIPS: It would depend on the system and
16 whether there -- how complicated the interpretation is and
17 where ambiguous connotations might occur.

18 So we would have to look at the analyses of how
19 the system would perform under various circumstances. We
20 would have to consider when and error might exist and what
21 danger there is of that error contributing to operator
22 confusion; whether just by simple training procedures and in
23 the recognition and interpretation that he could operate
24 satisfactorily in the manner that the information is
25 displayed.

1 So I would say we are not in a position to say --
2 it would depend very much on our review of the specific
3 system. It is quite possible that a system can be proposed
4 and will be proposed without complicated data processing,
5 which we may very well find acceptable.

6 DR. LITTLE: Would you care to make sort of a
7 broad time range estimate of how long it would take to do a
8 review of this type?

9 WITNESS PHILLIPS: Yes.

10 DR. LITTLE: Days, month, years, whatever.

11 WITNESS PHILLIPS: If you will bear with me until
12 I find the right piece of paper.

13 (Pause.)

14 We have established a review schedule based on
15 licensee submittals on January 1, 1981. We have a national
16 lab contact to assist us in these reviews. We are currently
17 in the process of developing generic positions and criteria
18 for acceptance of the individual systems, and we expect that
19 to be complete about April 1.

20 We accept that our questions and positions on the
21 generic systems will be transmitted to the licensees
22 adopting those particular systems on July 1. The licensee
23 submittals and in responses to our questions and positions
24 would expect on September 1. We would expect to have
25 generic SER's and model tech specs issued on September 1,

1 1981.

2 The installation is scheduled for January 1,
3 1982. We expect that that will vary from plant to plant.
4 It is not likely a shutdown will be required to put it in at
5 that time. It will depend on their normal fueling outage,
6 and it would be next to impossible to do all of these at once
7 anyway.

8 The licensee submittal would then have to make
9 another submittal after installation giving the details of
10 his installed system and the calibration and the tested
11 data, and we would expect that about March 1, predicated on
12 a January 1 installation.

13 We would then issue tech specs and planned
14 specific approvals for implementation on May 1, 1982. The
15 tech specs and plant-specific approvals indicating that
16 these are -- the staff has accepted the systems and the way
17 they operate for a specific plant would be required before
18 they were actually implemented into the operating
19 procedures, into the emergency procedures.

20 So our review would be complete, and the
21 plant-specific SER's issued by July 1, 1982. That is our
22 current review schedule.

23 If I may just highlight that for you, I think the
24 key is that generic SER's and model tech specs which approve
25 systems and in principle we would expect to be towards the

1 end of the year, around December 1, just about the time the
2 installations of the systems are starting; then based on the
3 test data and the calibration of individual systems, we
4 would approve the plant-specific approvals and that would be
5 going on until about mid-1982.

6 (Board conferring.)

7 DR. LITTLE: Sometime tomorrow morning I would
8 like to hear from the licensee as to whether or not having a
9 program in place which would help interpret the information
10 from the reactor level instrumentation would alleviate some
11 of their concerns they expressed today.

12 MR. BAXTER: Both Mr. Jones and Mr. Keaten will be
13 here tomorrow.

14 CHAIRMAN SMITH: Mr. Cutchin?

15 MR. CUTCHIN: Nothing further. As far as I am
16 concerned, the witness will be available for cross as soon
17 as you need him in the morning.

18 CHAIRMAN SMITH: Are there any questions on the
19 special question that cannot be dealt with tomorrow? We
20 will be here. Everyone will be here.

21 All right. Shall we meet at 9:00 o'clock?

22 (Whereupon, at 5:06 p.m., the hearing was
23 adjourned, to reconvene at 9:00 a.m. on Thursday, January
24 22, 1980.)

25

NUCLEAR REGULATORY COMMISSION

This is to certify that the attached proceedings before the

in the matter of: METROPOLITAN EDISON COMPANY (TMI Unit 1)

Date of Proceeding: January 21, 1981

Docket Number: 50-289 (Restart)

Place of Proceeding: Harrisburg, Pa.

were held as herein appears, and that this is the original transcript thereof for the file of the Commission.

David S. Parker

Official Reporter (Typed)



(SIGNATURE OF REPORTER)