

General Offices: 212 West Michigan Avenue, Jackson, Michigan 49201 • Area Code 734 788-0550

April 23, 1978

Mr James G Keppler
Office of Inspection and Enforcement
Region III
US Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, IL 60137

DOCKET 50-155 - LICENSE DPR-6 -
BIG ROCK POINT PLANT - UPDATE
TO IE REPORT 50-155,78-01

By letter dated March 17, 1978 Consumers Power Company committed to submitting an evaluation of the performance of the Big Rock Point radwaste effluent monitor during periods of no release. To this extent, the monitor has been on service at all times to detect leakage between the normally locked closed valves and the air-operated discharge valves. The monitor alarm is set to warn the operator when concentrations are present that exceed those values listed in Column II, Table II, Appendix B of 10 CFR 20; plant procedures have been revised accordingly and will be put into effect upon review completion.

These changes have proven to be acceptable.

William S Skibitsky
Senior Licensing Engineer

CC: Director, Office of Nuclear Reactor Regulation
Director, Office of Inspection and Enforcement

MAY 1 1978

8101270981