

AP 1001

Three Mile Island Nuclear Station
Special Operating Procedure

SIDE 1

Figure 1001-8

SOP NO. 1-80-29A
(From SOP Log Index)NOTE: Instructions and guidelines in AP 1001
must be followed when completing this
form.This SOP incorporates
and supercedes SOP-80-29Unit No. 1Date 5/30/80

1. Title DRAIN DOWN AND MAINTAIN RCS LEVEL BETWEEN 314" 10" and 315" 3" ELEVATION
2. Purpose (Include purpose of SOP)

To prepare RCS For HPI Tie-in and Valve Inspection.

This new revision does not alter safety evaluation of SOP-1-80-29.

3. Attach procedure to this form written according to the following format.

A. Limitations and Precautions

1. Nuclear Safety
2. Environmental Safety
3. Personnel Safety
4. Equipment Protection

B. Prerequisites

C. Procedure

see Attached

4. Generated by HBSherman Date 5/30/80

5. Duration of SOP - Shall be no longer than 90 days from the effective date of the SOP of (a) or (b) below - whichever occurs first.

(a) SOP will be cancelled by incorporation into existing or new permanent
procedure submitted by _____ ☐(b) SOP is not valid after 90 ☒
(fill in circumstances which will result in SOP being cancelled)

6. (a) Is the procedure Nuclear Safety Related? Yes ☒ No ☐
If "yes", complete Nuclear Safety Evaluation. (Side 2 of this Form)
- (b) Does the procedure affect Environmental Protection? Yes ☐ No ☒
If "yes", complete Environmental Evaluation. (Side 2 of this Form)
- (c) Does the procedure affect radiation exposure to personnel? Yes ☒ No ☐

NOTE: If all answers are "no", the change may be approved by the Shift Supervisor. If any questions
are answered "yes", the change must be approved by the Unit Superintendent.

7. Review and Approval

Approved - Shift Supervisor [Signature] 5/30/80Reviewed - List members of PORC contacted [Signature] 5/30/80[Signature] 5-30-80[Signature] 5/30/80[Signature] 5/30/80Approved - Unit Superintendent [Signature] 5-30-80Reviewed - Sup. Quality Control (if required) _____ 5-30-80

SOP is Cancelled

Shift Supervisor/Shift Foreman

8-5-80

Date

THIS DOCUMENT CONTAINS
POOR QUALITY PAGES

8101230

737

"EVALUATION"

AP-1001
Figure 1001-8

Three Mile Island Nuclear Station
Nuclear Safety/Environmental Impact Evaluation

SIDE 2
SOP No. _____

1. Title Drain Down & Maintain RCS Level Between 314' 10" and 315' 3"

2. Nuclear Safety Evaluation

Does this SOP:

- (a) increase the probability of occurrence or the consequences of an accident or malfunction of equipment important to safety? yes ☐ no ☒
- (b) create the possibility for an accident or malfunction of a different type than any evaluated previously in the safety analysis report? yes ☐ no ☒
- (c) reduce the margin of safety as defined in the basis for any technical specification? yes ☐ no ☒

Details of Evaluation (Explain why answers to above questions are "no". Attach additional pages if required.)

Reducing RCS level to the elevations described in the procedure has been evaluated and tested to ensure adequate core cooling can be maintained, therefore nuclear safety and the safety of the public is not adversely affected.

(see additional evaluation on attached page)

Evaluation By AR Shigman

Date 5/30/80

3. Environmental Impact Evaluation

Does this SOP:

- (a) possibly involve a significant environmental impact? yes ☐ no ☐
- (b) have a significant adverse effect on the environment? yes ☐ no ☐
- (c) involve a significant environmental matter or question not previously reviewed and evaluated by the N.R.C. yes ☐ no ☐

Details of Evaluation

Evaluation By _____ Date _____

* NOTE: If these questions are "yes", the change must receive N.R.C. approval.

4. Unit Superintendent requests PO RC review ☐ Check if YES.

5. Approval

Station Superintendent/Unit Superintendent

Date

1-3

DRAIN DOWN & MAINTAIN RCS LEVEL
BETWEEN 314' 10" and 315' 3"

Safety Evaluation (cont'd)

While in the drained down condition, the BWST shall be maintained as the emergency source of borated water. Should an unexpected loss of Decay Heat Removal occur, the operator would follow the guidance of E.P.1202-15 "Loss of Decay Heat Removal" and flood the RCS from the BWST. Because of the RCS openings, the Reactor Coolant would spill over to the Rx Bldg. Sump, and long term recirculation cooling from the sump to the Rx Vessel would be initiated. This mode of cooling has previously been reviewed in Chapter 6 and 14 of the FSAR.

APPROVED

SOP 1-80-29

Rg Toole
Manager Unit I

5-23-80

Date

SOP 1-80-29A

Rg Toole
Manager Unit I

5-30-80

DATE

DRAIN DOWN AND MAINTAIN RCS LEVEL
BETWEEN 314' 10" & 315' 3" ELEVATION

A. LIMITS AND PRECAUTIONS

1. Nuclear Safety - core cooling shall be thru normal Decay Heat Removal System, taking precautions to prevent vortex formation in Reactor vessel or Decay Heat Drop Line. Should vortex formation occur, as detected by the incore thermocouples, and/or DH-P-1A/B cavitation several RCS inventory schemes are available in order to eliminate the vortex and provide adequate core cooling.
~~a) The boron concentration shall be maintained at greater than or equal to 2200 ppm boron. HBS~~
2. Environmental Safety - N/A
3. Personnel Safety - An RWP shall be provided to permit 24 hour surveillance. The location of the level monitor shall be coordinated with HP such that radiation exposure is minimized and need for respirators is minimized.
4. a. Equipment Protection - If DHR pump cavitates and/or the low flow alarm is activated, secure pump and refill RCS. (See Procedure step 18).
b. With the RCS drained to the repair level, ensure the RCS system remains vented to atmosphere to ensure the tygon tubing levels are accurate.

B. PREREQUISITES

1. While the RCS is drained below 45 inches in the Pressurizer and the RCS boundary is open at the ~ 315' elevation, the following criteria shall be in force:
a. The boron concentration shall be maintained at ~~not less than that required for refueling shutdown.~~ ≥ 2200 ppm boron. HBS
2. Incore thermocouples (all 52 if available, a minimum of 1 in each quadrant, plus the center T/C) shall be monitored on the computer (or other available read out device) and the average compared (plotted on graph at least once per hour) with DH-6-TE 1 or 2. The DH-6-TE 1 or 2 and average incore thermocouples temperatures shall be plotted and analyzed for indication of vortex formation/ inadequate core cooling trend. If an anomaly of 5-10°F develops between DH-6-TE-1 or 2 and the selected incore thermocouples, notify the Shift Supervisor.

- 5-
3. Continuous communications between the CRO and the tygon tube level monitor in the containment building shall be established whenever the RCS is drained below 45 inches in the pressurizer. The requirement to maintain an operator at the tygon tube after draindown may be WAIVERED by Supervisor of Operations if accurate reliable remote indication is available.
NOTE: The above waiver does ^{not} extend beyond having the tygon tube level compared to the remote indicator if either level indicator is in question or routinely comparing the indicators at least once per shift.
 4. Pipe plugs and/or soft patches available in the Shift Supervisors' Office.
 5. Both Decay Heat Removal trains operable prior to draining RCS. With less than two Decay Heat Removal trains operable while RCS is drained below 45 inches in pressurizer, notify Supervisor of Operations. It is recommended that the "B" DHR loop be inservice, using the cross connects when auxiliary pressurizer spray is required.
 6. BWST contains a minimum of 30 feet of water borated to ≥ 2270 ppm.
 7. Decay removal flow throttled and maintained between 800-1000 gpm.
 8. Tygon level monitoring rig (See attached Dwg.) installed at PX-462 and PX-464.
Do not open the isolation valves for the tygon level indicators until the RCS is vented to the Rx building. Tygon tubing should extend to top of D-Ring.
Do not valve in level transmitter until RCS level is within 60" of level transmitter.
 9. RCS on the Vent Header with hot leg water level equalized with pressurizer level.
 10. Pressurizer temperature $< 150^{\circ}\text{F}$. RCS temperature between 95° and 120°F .
 11. During initial draining below 45" in pressurizer, station man in operating DH vault to monitor for pump cavitation.
 12. CF-V-1A/1B closed.
 13. Decay Heat Removal Lo flow alarm shall be set for 700 gpm.

14. Low pressure containment integrity shall be capable of being established.

(i.e., Equipment Hatch on, no new bldg. penetrations left open, etc).

15. Verify Rx Bldg. Sump Recirculation path i.e. flange not installed, DH-V-6A/B operable.

C. PROCEDURE

___ 1. Perform valve line up per enclosure I. Select Bleed Tank to be filled (assure adequate capacity).

___ 2. Verify the following additional prerequisites.

___ a. Reactor Coolant System shutdown and cooldown as per OP 1102-10 and 1102-11.

___ b. Decay Heat System in operation maintaining RCS temperature between 95°F and 120°F.

___ c. Makeup and Purification System shutdown as per OP 1104-2.

___ d. OTSG secondary side in layup in accordance with OP 1106-16.

___ e. Nitrogen is available for RC blanketing through the Waste Gas System to the RC Drain Tank using makeup N₂ or recycled N₂ from Waste Gas Decay Tanks depending on gas quality.

___ f. Feed tank select switch is in the off position or selected for a Bleed Tank other than the one to be filled.

___ g. RC Drain Pump WDL-P16 tested, as necessary by using reclaimed water as follows:

a. Open inlet valve (WDL-V17, 18 or 19) for PCBT to be filled.

b. Open WDL-V303, 304, 161 and CA-V208.

c. Assure WDL-V52, 45, 46, 47, 48, 55 and 56 are closed.

d. Start the RC drain pump and check to assure no seal leakage

e. Pump for about 2 minutes and stop pump.

f. Close valves opened in (a) and (b) above.

- ___ 3. Allow N₂ from the Vent Header to bleed thru the RC Drain Tank into the RCS as the system is drained.
- ___ 4. Open RC-V-20 and RC-V-21.
- ___ 5. Open inlet to the RC Bleed Tank to be filled.
WDL-V-17 - A Bleed Tank
(or) WDL-V-18 - B Bleed Tank
(or) WDL-V-19 - C Bleed Tank
- ___ 6. Start RC Drain pump WDL-P-16 and reduce pressurizer level to less than 184". Then stop WDL-P-16.
- ___ 7. Reduce vent header pressure to zero and Red Tag and close WDG-V-3 and WDG-V-4.
- ___ 8. Open, and remove vent plugs of three highest CRD tubes. With N₂ spool pieces removed, open hot leg vents to Bldg. atmosphere through RC-V15-A/B and RC-V-16A/B. With N₂ spool piece removed, vent pressurizer to the Bldg. atmosphere through RC-V-17 and RC-V-19.
- ___ 9. Open isolation valves for tygon level indicators and verify correlation with pressurizer level indication. Do not valve in temporary RCS level transmitter at this time.
- ___ 10. Start RC Drain Pump WDL-P-16 and reduce pressurizer level to approximately 60", verifying correlation with temporary tygon level indication as level is decreased.
- ___ 11. Open RC-V-4 and DH-V-64 and continue to decrease pressurizer level to an indicated 45 inches in the pressurizer. Verify correlation with temporary tygon indication. Stop WDL-P-16 as necessary if not prepared to proceed.
NOTE: Due to surge line loop seal, pressurizer level will stabilize at ~ 42 inches. Monitor tygon tube level and I/C's per prereq. #2
From this point on.

- ___12. Establish continuous communications between CRO and tygon level monitor in the containment building. See prerequisite #3 for waiver requirements.
- ___13. Reduce or verify DH removal flow 800-1000 gpm by throttling DH-V-19A/B. CAUTION: RCS level must be maintained $\geq$ 10 inches indicated level.
- ___14. Carefully reduce RCS level to an indicated + 10 to + 15 inches on temporary tygon level indicator. This corresponds to + 10 + + 15 inches above center line of 28" pipe. When level is $\sim$ 60" above level transmitter, valve in temporary level transmitter.

CAUTION: Station operator in the vault of the operating DH pump to monitor for pump cavitation, (i.e. pressure oscillation, noise). The Shift Supervisor shall personally brief the selected operators to insure their recognition of pump cavitation. If cavitation occurs, stop draining and refill per step 17 until cavitation stops, then notify Supervisor of Operations.

- ___15. Stop WDL-P-16, close RC-V-4 and DH-V-64 and close inlet to Bleed Tank.
NOTE: Any change in level indication shall be reported to Shift Supervisor.

- ___16. Plot incore T/C and DH-6-TE 1 or 2 as per prerequisite #2 every hour. Log tygon level or equivalent (if approved) every hour on attachment 1.

NOTE: Should an unexpected loss of Decay Heat Removal occur the volume of water in the vessels is predicted to heat up at a rate of 13⁰F/hr. Therefore at least 7 hours is available before boiling would occur. This time would be available to first attempt to correct the problem, then to swap DHR loops, and as a last resort gravity drain the BWST into the RCS by opening DH-V-5A/B. Refer to EP 1202-35 "Loss of Decay Heat Removal" if adequate core cooling cannot be established by the above means.

1. When RCS level control has been established and the 'B' OTSG COLD LEGS needs to be drained for 'B' OTSG lower MANWAY Removal, perform the following:
- _____ Insure tygon tubing for B OTSG is valved in and RC-V-7C and RC-V-7D are closed.

- _____ A. Insure WDL-P-16 is secured
- _____ B. Close RC-V-20 and RC-V-21
- _____ C. Open RC-V-29B and RC-V-30B and WDL-V-18
- _____ D. Start WDL-P-16 and pump the 'B' OTSG COLD legs down to 24" on the tygon tubing associated with the 'B' OTSG, then stop WDL-P-16.

SEE ADDENDUM II

- _____ E. Station operator at WDL-P-16 in communication with control room. start WDL-P-16 to pump down remaining 24" and stop the pump when the operator indicates the pump has lost suction.
- _____ F. Close RC-V-29B and RC-V-30B and WDL-V-18
- _____ G. Re-open RC-V-20 and RC-V-21
- _____ H. Drain remaining coolant in cold leg loop (Bottom) to floor drain by opening RC-V-6D and RC-V-1033. Insure RC-V-7D remains closed.

PORC Reviewed:

AB Shuman 5/30/80

MT Ross 5/30/80

RO. Barley telecon 2035 5/30/80 HBS

R.W. Dubiel telecon 2040 5/30/80 HBS

unman V.P. Orlando telecon 2100 5/30/80 HBS

Duty Superintendent: G.P. Miller telecon 215 5/30/80 HBS

Shift Supervisor

HR 10/15

POOR ORIGINAL

1-10

ADDENDUM II TO SOP-180-291

- ① IF INADEQUATE SUCTION TO WDL-P16 IS NOTED BY NO INCREASE IN RGAT OR LEVEL DECREASE IN TYCON TUBE STOP WDL-P16.
- ② CLOSE RC-V 29B & 30B.
- ③ OPEN RC-V 6/7(D) & RE-START WDL-P16
- ④ WHEN LEVEL IN TYCON REACHES 24" STATION AN OPERATOR IN RC DRAIN TR ROOM. WHEN PUMP STARTS TO LOSE SUCTION STOP WDL-P16.
- ⑤ CLOSE RC-V 6/7(D), ~~WDL-P16~~ GAH
- ⑥ RE-OPEN RC-V 20 AND RC-V 21.

PORC Reviewed

H.B. SHIPMAN	5/31/80	2025	GAH
M.J. ROSS	5/31/80	2027	GAH
U.P. ORLANDI	5/31/80	2035	GAH
ED FUHRER	5/31/80	2040	GAH
JOHN PEARCE	5/31/80	2110	GAH
SUPER: G.P. MILLER	5/31/80	2045	GAH

S/S *[Signature]*

- ___17. Control of level at 10 to 15 inches on tygon level indicator shall be by carefully (manually) opening DH-V-5A(h) to make up for any small losses from the system. (See Attached Dwg.) To reduce level repeat steps 10 thru 15.
- ___17A. **SEE ADDENDUM I TO PUMP DOWN 'B' OTSG GOLD LEGS**
- ___18. If DHR low flow alarm is received verify alarm and trip running DHR pump, and establish proper level indication (i.e. 10 to 15 inches per step 17).
CAUTION: Monitor RCS level while venting DHR pump to prevent overflow by gravity flow. Vent DHR pump and system high points, DH-V-48A/B. Then restart a DHR pump. If flow of 800-1000 gpm cannot be maintained temporarily plug RCS openings at the ~ 315' elevation and fill RCS until adequate decay heat removal can be maintained.
- ___19. Attachment 2 provides the procedure sequence of work associated with the HPI Tie-ins.
- ___20. Exclusion requirements of AP 1030 shall be satisfied.
- ___21. As the check valves (HPI) are opened for inspection, install temporary pipe plug on vessel side.
- ___22. Remove temporary pipe plugs prior to closing up check valves.
- ___23. When conditions permit refilling, refer to OP 1103-2 insure CRDM vent plugs have been re-installed.
- ___24. When RCS has been returned to normal refueling shutdown status, return DHR low flow alarm to previous setting, 1500 gpm.

ENCLOSURE I
VALVE CHECKLIST

<u>Valve No.</u>	<u>Valve Description</u>	<u>Position</u>
RC-V14A	R. C. Vent Valve	Open _____
RC-V14B	R.C. Vent Valve	Open _____
RC-V15A	R.C. Vent Valve	Open _____
RC-V15B	R.C. Vent Valve	Open _____
RC-V16A	Nitrogen Connection to R.C. System	Closed _____
RC-V16B	Nitrogen Connection to R.C. System	Closed _____
RC-V17	Pressurizer Isolation to Vent & Nitrogen	Open _____
RC-V18	Pressurizer Vent Valve	Closed _____
RC-V19	Nitrogen Connection to Pressurizer	Closed _____
RC-V4	D.E. Spray Line Isolation Valve	Closed _____
RC-V20	Pressurizer Drain Valve	Closed _____
RC-V21	Pressurizer Drain Valve	Closed _____
RC-V6A	R.C. Drain Valve	Closed _____
RC-V6B	R.C. Drain Valve	Closed _____
RC-V6C	R.C. Drain Valve	Closed _____
RC-V6D	R.C. Drain Valve	Closed _____
RC-V7A	R.C. Drain Valve	Closed _____
RC-V7B	R.C. Drain Valve	Closed _____
RC-V7C	R.C. Drain Valve	Closed _____
RC-V7D	R.C. Drain Valve	Closed _____
RC-V28	Pressurizer Vent Valve	Open _____

ENCLOSURE I
VALVE CHECKLIST

<u>Valve No.</u>	<u>Valve Description</u>	<u>Position</u>	
WDL-V161	Feed valve to R.C. Bleed Tks. from WDL-P16 or P3	Open	_____
WDL-V300	Inlet to R.C. Drain Tank HX (CG-1)	Open	_____
WDL-V301	Outlet from R.C. Drain Tank HX (CG-1)	Open	_____
WDL-V302	Outlet from R.C. Drain Tank Pump (PG-3) to R.C. Drain Tank (T-3)	Closed	_____
WDL-V303	Outlet from Reactor Drain Pump (P-16) to R.C. Bleed Tanks	Open	_____
WDL-V304	Outlet from Reactor Drain Pump (P-16) to R.C. Bleed Tanks	Open	_____
WDL-V305	Outlet from R.C. Tank Pump (P-8) to R.C. Bleed Tanks	^{Open} Closed	_____
WDL-V307	R.C. Drain Pump (P-16) Suction Valve	Open	_____
WDL-V374	R.C. Drain Pump (P-16) Discharge Valve	Open	_____
WDL-V375	Isol Test and Drain Valve	Closed	_____
WDL-V376	Isol. Test and Drain Valve	Closed	_____
WDL-V306	R.B. Sump Isolation Valve	Closed	_____
WDL-V55	Aux. Building Drain Header Isol. Valve	Closed	_____
WDL-V56	Aux. Building Drain Header Isol. Valve	Closed	_____
WDG-V2	R.C. Drain Tank Vent Valve	Open	_____
WDG-V3	R.B. Vent Header Interior Isol. Valve	Open	_____
WDG-V4	R.B. Vent Header Exterior Isol. Valve	Open	_____
WDG-V60	Isol. Test Valve, Penetration 330, Inside R.B.	Closed	_____
WDL-V45	Precoat Filter Outlet (A)	Closed	_____
WDL-V46	Precoat Filter Outlet (B)	Closed	_____

ENCLOSURE I
VALVE CHECKLIST

<u>Valve No.</u>	<u>Valve Description</u>	<u>Position</u>
WDL-V47	Cation A Outlet	Closed _____
WDL-V48	Cation B Outlet	Closed _____
WDL-V52	Inlet to Precoat Filter Inlet	Closed _____
WDL-V62	Boric Acid to R.C. Bleed Tanks	Closed _____
<u>Valve positions if A RCBT is selected for fill:</u>		
WDL-V3	A RCBT Inlet	Closed _____
WDL-V14	A RCBT Inlet	Closed _____
WDL-V17	A RCBT Inlet	Closed _____
WDL-V18	B RCBT Inlet	Closed _____
WDL-V19	C RCBT Inlet	Closed _____
<u>Valve positions if B RCBT is selected for fill:</u>		
WDL-V4	B RCBT Inlet	Closed _____
WDL-V15	B RCBT Inlet	Closed _____
WDL-V18	B RCBT Inlet	Closed _____
WDL-V17	A RCBT Inlet	Closed _____
WDL-V19	C RCBT Inlet	Closed _____
<u>Valve positions if C RCBT is selected for fill:</u>		
WDL-V5	C RCBT Inlet	Closed _____
WDL-V16	C RCBT Inlet	Closed _____
WDL-V19	C RCBT Inlet	Closed _____
WDL-V17	A RCBT Inlet	Closed _____
WDL-V18	B RCBT Inlet	Closed _____

Performed By _____
Signature

Date _____

Reviewed By SRO
or RO License _____

Date _____

ATTACHMENT I

(Date)	Temporary RCS level by Tygon tubing at PX 462 and 464.							
0100								
0200								
0300								
0400								
0500								
0600								
0700								
0800								
0900								
1000								
1100								
1200								
1300								
1400								
1500								
1600								
1700								
1800								
1900								
2000								
2100								
2200								
2300								
2400								
(DATE)	(DATE)	(DATE)	(DATE)	(DATE)	(DATE)	(DATE)	(DATE)	(DATE)

1-66

ATTACHMENT 2

Procedure Sequence for HPT Wa-Ins

Prerequisites


1. Switching and Tagging per AP1002
2. RWP's shall be initiated.
3. Weld histories approved
4. Work crews briefed as to the RCS condition and their response to unexpected emergencies (ie: Loss of Decay Heat Removal and/or system overfill).

Work Sequence

1. Work will be performed using two shifts
 - 1st shift work B & D Loops
 - 2nd shift work A & C Loops
2. Make cuts and prepare pipe end as per the weld histories.
3. Weld Root and Hot pass
4. RT joints and repair as necessary
5. Weld out joints
6. Perform final RT.

TEMPERATURE, LEVEL, INDICATION

DURING INSPECTION/REPAIRS TO DH-V22 A/B,
MU-V86A/B, MU-V107 A/B/C/D, MU-V94 A/B,
MU-V25.



POOR ORIGINAL

ENGINEERING CHANGE MEMO

DESIGN ORGANIZATION

SECM NO. 007

REV. 5

TMI UNIT NO. 1

X GAI

GPUSC

OTHER

DISCIPLINE Mechanical

SUBJECT: HPI Modifications

TASK NO. RM-14

CHANGE

A. Valve MU-V217 has been installed as a part of previous modifications but requires a support. This revision of SECM-007 includes a support design.

B. Pipe support MK No. -MUE-19 is installed but requires modification

C. All installation fabrication, and welding shall be in accordance with approved GPU procedures or catalytic procedure.

The Nuclear Safety/Environmental Evaluation, Safety Evaluation, and Fire Hazards Analysis (pg 2, 334) ARE NOT AFFECTED BY THIS CHANGE.

REASON FOR CHANGE

A. As a result of make-up pipe rerouting, MU-V217 was installed, but not according to manufacturer's instructions. To ensure proper operation, a support for the valve is require. RESOLVES FQ R185

B. Support MK No. MUE-19 was installed, but not according to Basic Engineering Dwg. 3563-MU Sheet MU-296. The as-built condition is not acceptable and requires modification for acceptance. RESOLVES FQ R247

C. This revision to the ECM does not affect the restart report.

REMARKS

None.

NOTE: ATTACHMENT #94, DWG. S-317-816 REV 1A-C, HILTI QUICK BOLTS, ITEM #2 ARE NOT TO BE INSTALLED. ECM S-007 REV. 5A WILL CORRECT THIS.

M. E. Sturges
ORIG. ENGINEER

8/13/80
DATE

J. Schellinger
SUPERVISOR

REVISE SPEC. N/A

REVISE DWG. Attachments 98, 99

FOR APPROVAL REQUIRED

FOR INSTALLATION

SAFETY CLASSIFICATION
☒ NUCLEAR SAFETY RELATED
☐ IMPORTANT TO SAFETY
☐ NOT IMPORTANT TO SAFETY
QC CLASSIFICATION

☒ QC YES
☐ QC NO

GAI QA APPROVAL (AS REQUIRED)

GPUSC QA APPROVAL (AS REQUIRED)

REV. _____ APPROVED FOR ISSUE
AND CONSTRUCTION:

N/A TO UNIT - J. Waul
GPUSC CONST. SITE MANAGER DATE 10/30/80

ACKNOWLEDGEMENT

MLM 10/13/80 MLM

GPUSC
James Kondra
DOCC/DATE

NOV 04 1980

Service

ECM SECM-007 Rev 5

TASK RM-14

TITLE HP1 Modifications

PAGE 1 OF 6
SHEET 1 OF 2

REV

SUMMARY OF CHANGE

APPROVAL

DATE

4 THE IMPACT EVALUATION, SAFETY EVALUATION AND FHA HAVE NOT BEEN AFFECTED BY THIS REVISION. HOWEVER, THE LIST OF ATTACHMENTS AND THE LIST OF REFERENCES HAVE BEEN REVISED AND ATTACHED.

5 The impact evaluation, safety evaluation, and fire hazards analysis have been unaffected by this revision. The list of attachments and list of references has been revised and attached.

G. B. Trigen for
A. P. Rochus 10/7/90

FOR INFORMATION ONLY

GPU Service

ENGINEERING CHANGE MEMO

NUCLEAR SAFETY RELATED

STATION TMI-1

DESIGN ORGANIZATION

X

GPUSC
Site Liaison

OTHER

SECM 007 REV 5APAGE 1 OF 8SHEET 1 OF 1TASK RM-14TITLE HPI Modification

CHANGE

1. Install disc skirt in MU-V217 in accordance with Attachments FA-1 and FA-2. Prior to re-assembly ensure valve stem is not bent.
2. Install MU-V217 motor operator support in accordance with the modified requirements of Attachment FA-3.
3. Prepare, if necessary, welds identified in Attachment FA-4 for ultrasonic examination in accordance with the procedure of Attachment FA-5. Perform baseline inservice Examination of welds identified in Attachment FA-4.

The Nuclear Safety/Environmental Evaluation, Safety Evaluation, and Fire Hazards Analysis are not affected by this change.

REASON FOR CHANGE

1. To upgrade MU-V217 for operations with the operator in the horizontal position. This change resolves/closes out EQ-R-185 Rev 1.
2. To correct the design for MU-V217 motor operator support to reflect the correct orientation of the installed valve and to specify an approved type anchor bolt.
3. To incorporate/define the requirements for inservice base line inspections.

J. F. Freyzer
Responsible Engineer10/20/80
DateS. Capodanno
SupervisorJ. F. Freyzer 10/28/80
Project Engineering Manager/Date

SAFETY CLASSIFICATION

- ☒ Nuclear Safety Related
☐ Important to Safety
☐ Not Important to Safety
- QC CLASSIFICATION
☒ QC Yes ☐ QC No

GPU Section Mgr Sign/Date

S. Capodanno 10-23-80
Released Date

Conditional Release (No turn over until verification is completed)

DCN DT 0028

ACKNOWLEDGEMENT

MLM MLMJames Kondras

DDCC/Date

AES Approval (AS Required)

L. B. Bahr
GPUSC QA Approval (AS Required)
10/28/80

MA TO UNIT NO. 1

GPUSC Const Site Manager/Date

J. B. Bahr
11/4/80

Service NUCLEAR SAFETY RELATED

ENGINEERING CHANGE MEMO

STATION TMI-1

DESIGN ORGANIZATION

☒ GPUSC SITE
LIAISON

☐ OTHER
ECM 5-007 REV 5BPAGE 1 OF 8SHEET 1 OF 1TASK RM-14TITLE HPI CROSS CONNECT FLOW INDICATION

CHANGE Show actual controlotron terminations on the drawings as actually on physical equipment. Revise term. sheets for actual termination information.

THE NUCLEAR/ENVIRONMENTAL IMPACT EVALUATION, SAFETY EVALUATION AND FIRE HAZARD ANALYSIS REMAIN UNCHANGED.

REASON FOR CHANGE

the dwg's did not show actual terminations on the equipment for control & instrumentation wiring.

this SECM resolve FQ-R020

DEC 4 1980

Responsible Engineer

Date

Supervisor

SAFETY CLASSIFICATION

☒ Nuclear Safety Related☐ Important to Safety☐ Not Important to Safety

QC CLASSIFICATION

☒ QC Yes ☐ QC No

AE-QA Approval (As Required)

GPUSC QA Approval (As Required)

GPU Section Mgr Sign/Date

Handwritten signature 11/19/80
Released Date

Conditional Release (No turn over until verification is completed)

DCN 1101-RT0039

GPUSC Const Site Manager/Date

ACKNOWLEDGEMENT

MLM

MLM

James Kondias

DDCC/Date

DEC 4 1980

A0000300 5-80

GPU Nuclear

ENGINEERING CHANGE MEMO

NUCLEAR SAFETY RELATED

2 Wright
7-258
Spine

STATION TMI-1

DESIGN ORGANIZATION

GPUSC

X

GAI

OTHER

S ECM 007 REV 6

PAGE 1 OF 6

SHEET 1 OF 1

TASK RM-14

TITLE HPI Modification

CHANGE

1. Modify hanger for MUH-330
(See Attachment 95)
2. Change dimensions to provide clearance for a cable tray at MUH-331. *Revised weld symbols.*
(See Attachment 96)
3. Provide revised design details for MUH-335.
(See Attachment 94)
4. *Provide corrected drawing for MU-293 (See Attachment 97)*
The Nuclear Safety/Environmental Evaluation and Fire Hazards Analysis are not affected by this change.

REASON FOR CHANGE

1. MUH-330 requires a trapeze hanger per FQ R-395 (See Ref. 15)
2. Clearance must be provided for a cable tray at MUH-331 per FQ R-396 (See Reference 16). *Weld symbols changes to reflect AS constructed conditions.*
3. Since hanger base plate/holes cannot be relocated, hanger MUH-335 must be redesigned per FQ R-366 (See Reference 14)
4. *Revised drawing for MU-293 to reflect correct AS built condition of existing hanger per EN D-00028*

W. E. Stinson
Responsible Engineer

12/4/80
Date

J. Schallenger
Supervisor

J. T. Trotter 1/12/81
Project Engineering Manager/Date

SAFETY CLASSIFICATION

- ☒ Nuclear Safety Related
☐ Important to Safety
☐ Not Important to Safety

QC CLASSIFICATION

- ☒ QC Yes ☐ QC No

W. E. Stinson 12/4/80
AE-QA Approval (As Required)

N/A per ENR 008.2.7 Appendix 8

GPUSC QA Approval (As Required)

GPU Section Mgr Sign/Date

J. Volante for APRaching 1/6/81
Released Date

Conditional Release (No turn over until verification is completed)

DCN N/A

J. T. Trotter 1/12/81
GPUSC Const Site Manager/Date

ACKNOWLEDGEMENT

MLM

MLM

James Kondras

JAN 13 1981
QCQC/Date

A0000300 6-80

Service

SAFETY EVALUATION
TMI-1 NUCLEAR STATION

S-ECM 007 Rev 6
Page 3 of 4
Sheet 1 of 1
Task RM-14


Safety Evaluation

~~To be supplied by GRING~~

The Nuclear Safety/Environmental Evaluation ARE
NOT Affected by this change

154
4/9/30

FOR INFORMATION ONLY

Included ECM(s)	NSR	ITS	NTS	Verified
SECM-007 Rev. 6	X			

	Yes	No	TR #
FSAR deviation must be documented	☐	☐	_____
Station Technical Specification amendment is required	☐	☐	_____
Quality Classification List amendment is required	☐	☐	_____
Other _____	☐	☐	_____


RESPONSIBLE ENGINEER

NRC APPROVAL HAS BEEN OBTAINED

ENGINEERING CHANGE ORDER THE UNIT NO. 1 RESTART	DESIGN ORGANIZATION ☒ GAI ☐ CPUSC ☐ OTHER	SER. NO. <u>S-007</u> REV. <u>0</u> DISCIPLINE <u>Mechanical</u> SUBJECT: <u>HPI system in</u> <u>Small Break LOCA</u> TASK NO. <u>RM 14</u>
--	--	--


<u>REFERENCES</u> Purchase Requisition 100-1689-ST SP-5509 SP-5544	<u>ATTACHMENTS</u> See Sheet 2	<u>QUANTITY</u> <u>45</u>
---	-----------------------------------	---------------------------

CHANGE Add cross connects inside containment between loop A and B high pressure injection lines. ~~Add cavitation & venturi's FC 384, 385, 386 and 387 to the high pressure injection lines. Add bypasses, with their associated valves, around valve MU-V17, and cavitation venturi FC 385.~~

REASON FOR CHANGE

This change is necessary to provide adequate high pressure injection flow and prevent pump runout under all postulated conditions during a small break LOCA.

J. Sheldon Fabricating Engineer	6/12/79 Date	 Supervisor 6/21/79	☒ MET-ED Approval Required	☒  For Installation 6/21/79 1600
------------------------------------	-----------------	--	--	--

<u>FOLLOW-UP ACTION</u> Issue REVISE DWG. C-302-661 SA-2 C-301-504 SA-2 E-304-661 SA-2	REV. <u>0</u> APPROVED FOR ISSUE AND CONSTRUCTION  CPUSC CONSTRUCTION MANAGER DATE: <u>6/21/79</u> TIME: <u>1600</u>	ACKNOWLEDGMENT  JUN 22 1979 DATE
---	---	--

METROPOLITAN EDISON COMPANY

Subsidiary of General Public Utilities Corporation

Subject MODIFICATIONS FOR LONG TERM CORRECTIVE ACTION,
SMALL BREAK LOCA

Location Reading

Date June 5, 1979
GEM 2137

To T. HAWKINS

BACKGROUND

The mechanical piping cross connect has been accepted by the NRC as a viable long term solution for additional corrective action on the small break LOCA issue. The issue, and the scenario to arrive at the solution are extensive, well documented, and will not be repeated in this memo.

The basic concept is derived from B&W's B-SAR-205. Various analyses to verify the proper operation of the HPI system with the cross-connects installed, have been done in-house and by GAI. Results of these analyses have been reviewed and concurred with by B&W.

CONCLUSION

Generation Engineering approves the design of the HPI and Make-up System modification as shown in the attached drawings, and concurs with the installation of the modifications.

REFERENCES

- | | |
|--------------------------------------|--------------------------------------|
| 1. C-301-055 Rev. IA-1 | Spool Piece Drawing |
| 2. B-326-004 Rev. IA-0 | Schedule of Valve Stem Leakoffs |
| 3. E-301-054 Rev. IA-1 | Erection Diagram |
| 4. E-304-666 Rev. IA-2 | Piping Diagram |
| 5. S-317-809 Rev. IA-0 through | GAI Hanger Drawings |
| S-317-818 Rev. IA-0 | |
| 6. C-302-661 Rev. IA-2 | Flow Diagram, MU&P |
| 7. Basic Engineers Hanger Drawings | Sheet numbers: MU45, 46, 86, 87, 88, |
| (Shop Order 8563-MU) | 90, 91, 243, 244, 245, 252, 296, 421 |
| 8. B&W Letter TMI-79-17 dated 2/5/79 | |

DISCUSSION

By memo GEM 0899, dated March 9, 1979, Generation Engineering approved core boring of the 308' level floor in the Reactor Building to accommodate the routing of the cross-connect piping.

The flow diagram C-302-661, Rev. IA-2, is enclosed to schematically show the changes. The high pressure injection lines are cross-connected inside containment downstream of the MU-V-107 valves. Under normal operation, the cross-connect would introduce a second make-up flow path through the "D" injection nozzle. To avoid this, it is necessary to change the normal make-up line. It will be routed through a new containment penetration (utilizing an existing sleeve) and rejoined to the "B"

INTER-OFFICE MEMORANDUM

ATTN SECM 007
R-0

8/1/83

June 4, 1979 2-7
GEM 2137

injection line downstream of the cross-connect. A new check valve, MU-V-220 will prevent the cross flow to the "D" injection line. Check valve MU-V-219 will be the new containment isolation valve, and gate valve MU-V-222 will facilitate local leak rate testing.

An additional by-pass loop is added to the make-up line, with MU-V-217, to allow a higher rate of make-up under certain upset conditions. After installation of the cross connects and make-up modification, MU-V-16B will no longer be used for high rate make-up due to the cross-connect to the "D" nozzle. The by-pass loop with MU-V-217 will not be added at this time but will be installed in the future during a refueling outage. The cavitating venturries will not be installed as was previously planned.

The mechanical piping additions for penetration 323, and valves MU-V-217, 219, 220, and 222 are being secured on specifications through Generation Engineering. The penetration was purchased to the original GAI design specification 5490. The check valves (MU-V-219, 220) were purchased from Rockwell to GED-CS-10.3 Rev. 0. MU-V-217 is a motor operated 2 1/2 in. N-2, S-1 1500# globe valve to be purchased to GED-CS-25.3 Rev. 0 and MU-V-222 is a 2 1/2 in. N-1, S-1 1500# manually operated globe or gate valve to be purchased to GED-CS-10.4 Rev. 0.

Work Order for this job is T8709. To date only design engineering funds have been approved. By GEM 1056 dated 2/26/79, the remainder of the construction project was submitted for GPUSC approval. When this approval is received, the revised CA-8 will be routed for approval, after which funds will be released for TMI use.

Per GP 0026, the TMI Welding Engineer will have control of all welding, including maps, histories and non-destructive examinations.

SAFETY ANALYSIS

Any accident associated with the added portions of the HPI system to affect the cross connect or new make-up line, would be no different than any accident analysed for the existing system.

The addition will not affect the Basis of T.S. 3.3.

In the analysis of May 1, 1978 as provided to the NRC by B&W, the justification was based on 70% of 500 GPM total flow of one make-up pump being added to the RV under the SBL conditions. A Met-Ed computer program was written to model the HPI system with cross-connects. The program was verified correct by direct comparison with GAI's PIPF Code which has been reviewed and accepted by the NRC. Using the Met-Ed program, the worst case flow split under accident conditions was shown to be 66%/34%. The results of this program were then referred to B&W to resolve the discrepancy from the desired 70%/30% split. B&W determined that Unit 1 already operated at a power level which was 7% below the power used in their May 1 analysis. Therefore they do feel the reduced flow to be acceptable. See Reference #8. The results of the Met-Ed and GAI analyses will be outlined in a separate report to be issued in the near future.

ATTN TO SECH 007
RO
Pg 2 of 3

The proposed modifications for the makeup system will allow high pressure injection to handle all small break LOCA's. No operator action is required for twenty minutes following a SBL. During that period of time, the SBL can be identified. If the SBL has occurred in one of the injection lines downstream of the last check valve, the operator must shut the MU-V-16 valve to curtail the abnormally high injection flow in this line.

The subject change/modification will ensure that the requirements of the B&W Small Break Accident Analysis can be satisfied and will result in no degradation in the design of the high pressure injection system.

GP 1008 CHANGES

No changes are required. GP 1008, as presently written, will cover the changes as described in this change/modification.

FSAR CHANGES

The FSAR shall be modified to reflect the modifications as prescribed herein and the analyses required to substantiate the plant changes. The following sections shall be revised: 6.1.3.1, 9.1 (which describe the functions of the makeup and purification system) and 14.2.2.3 (which describes the accident analyses).

TEST/RETEST

The piping shall be hydrostatically tested at a multiple of the system nominal operating pressure per Section XI, Section IWB5000 of the ASME Code. An initial flow test of the high pressure injection piping shall be performed. A test resume will be prepared by Generation Engineering which will delineate the test conditions and what parameters are to be measured. Generation Engineering will evaluate the data prior to startup.

THE GENERATION SHALL BE PRESSURE
TESTED USING METHODS AND ACCEPTANCE
CRITERIA SIMILAR TO LOCAL LEAK
RATE TESTING.

DW

Submitted by:

E. G. Skuchas
E. G. SKUCHAS, EXT. 6543

Reviewed by:

J. F. Fritzen
J. F. FRITZEN, EXT. 6542 6/15/79

Approved by:

R. M. Klingman
R. M. KLINGMAN, EXT. 6515
MANAGER-GENERATION ENGINEERING

Approved by:

G. J. Troffex
G. J. TROFFEX, EXT. 6566 6/15/79
MANAGER-GENERATION QUALITY ASSURANCE

GJT:RMK:JFF:EGS:dlw

Attachments

cc: R. R. Lefin
R. L. Summers

R. O. Barley
T. A. Mackey

Task 7202

File: 61.1000.0005

ATT6 SECW 00
R0

Pg 3 of 3

ENGINEERING CHANGE MEMO	DESIGN ORGANIZATION	SER. NO. <u>S-ECM-007</u> <u>1</u>
TMI UNIT NO 1	<u>X</u> CAI	DISCIPLINE <u>Electrical</u>
RESTART	GPUSC	SUBJECT: <u>HPE System For</u> <u>Small Break Lock</u>
	OTHER	TASK NO. <u>24-19</u>

REFERENCES	ATTACHMENTS	QUANTITY
	(Number each)	<u>3</u>
	1. DRAWING LIST	
	2. DRAWINGS	
	3. SEPIAS	
	4. Purchase Req. - 86535, 86536, 86537	

CHANGE Transmitt Electrical Dwg's for Above Referenced Task

REASON FOR CHANGE

Electrical Dwg's Were Not Transmitted With Original Transmittal

<u>Thomas Frank</u> 6/26/79	<u>[Signature]</u>	☒ MET-ED Approval Required	☐ FOR INSTALLATION
Orig. Engineer Date	Supervisor		
GPUSC QA	(for safety related GPUSC ECM only)	per Tel. #	

FOLLOW-UP ACTION	REV. <u>1</u> APPROVED FOR ISSUE AND CONSTRUCTION:	ACKNOWLEDGEMENT
REVISE SPEC. _____	<u>[Signature]</u>	<u>James Fordina</u>
REVISE DWG. _____	GPUSC CONSTRUCTION MANAGER	MET-ED NAME
	DATE: <u>7-5-79</u> TIME: <u>0930</u>	DATE

J. Wright

Service ENGINEERING CHANGE MEMO	DESIGN ORGANIZATION <u>Y</u> GAI <u> </u> GPUSC <u> </u> OTHER	Page <u>1</u> of <u>6</u> SER. NO <u>S-EGM-007</u> REV. <u>3</u> DISCIPLINE <u>I & C</u> SUBJECT: <u>APPROVED HPI</u> MODIFICATIONS TASK NO. <u>RM-14</u>
THIS UNIT NO. <u>1</u>		

REFERENCES SEE LIST OF REFERENCES PAGE 6	ATTACHMENTS (Number each) QUANTITY <u>28</u> SEE ATTACHMENT LIST - PAGE 5
---	--

CHANGE

REMOVE MU-24-FE, MU-24-DPT AND MU-24-FY NARROW RANGE FLOW MEASUREMENTS AND REPLACED WITH SONIC WIDE RANGE FLOW MEASUREMENTS MU-24-FE, MU-24-FY AND MU-24-FY.

LIMITED

REASON FOR CHANGE

FQ-R34 AND PREVIOUS MODIFICATIONS TO REACTOR COOLANT MAKE-UP SYSTEM.

5-14-80

GPUSC

VALIDATED MED-ED/PH

<u><i>R. J. Fisher</i></u> Orig. Engineer	<u>3-11-80</u> Date	<u><i>R. D. Hattenstein</i></u> Supervisor	<u><i>D. G. Sledge</i></u> PORC Approval Required	<u> </u> For Installation
Revise Spec. <u> </u>	Revise Dwg. <u> </u>			

QA CLASSIFICATION <u><i>R. J. Fisher</i></u> QA APPROVAL (As Req'd) <u><i>R. J. Fisher</i></u> Engineer (if CC-No)	REV. <u>3</u> APPROVED FOR ISSUE AND CONSTRUCTION: <u><i>J. Haulman</i></u> GPUSC Const. Site Manager, Date <u>5/19/80</u>	ACKNOWLEDGEMENT <u><i>James Kordas</i></u> MAY 09 1981 DDCC, Date
--	--	--

POOR ORIGINAL

S-ECM-007-3 2-12
PAGE 2 OF 6

TMI Nuclear Station - Unit 1 Nuclear Safety/Environmental Impact Evaluation

The Unit 1 plant design change, test or experiment, directed by the engineering document identified above, has been reviewed and the following has been concluded:

1. Does it make a change to systems or components as described in the TMI-1 PSAR? NO ☒
YES ☐
 (If NO, delete #2, #3 & go to #4. If YES, proceed to #2.)
2. Does it involve a system or component that is Nuclear Safety related? NO ☐
YES ☐
 (If NO, delete #3 & go to #4. If YES, proceed to #3.)
3. (a) Does it increase the probability of occurrence or the consequences of an accident or malfunction of equipment important to safety? NO ☐
YES ☐
 (b) Does it create the possibility for an accident or malfunction of a different type than any evaluated previously in the safety analysis report? NO ☐
YES ☐
 (c) Does it reduce the margin of safety as defined in the basis for any technical specification? NO ☐
YES ☐

Explain why answers to 3(a), (b), or (c) are NO:

If any of the answers to 3(a), (b), or (c) are YES, the change must be approved by the NRC prior to implementation.

4. It has been determined that this design change, test or experiment does not adversely affect Nuclear Safety; therefore, it is not an "Unreviewed Safety Question" (per 10CFR50.59).

R. B. Fike 3-11-80 R. J. Kuttuva 3-11-80
 Reviewed by Cognizant Engineer Date Approved by Project Engineer Date

(If the statement in 4 above is NOT true, do not sign this form. Return the entire package to the Project Engineer who will convene design review conferences with Project personnel to pursue additional action.)

5. Does it possibly involve a significant environmental impact?

NO ☒
YES ☐

R. B. Fike 3-11-80 R. J. Kuttuva 3-11-80
 Reviewed by Cognizant Engineer Date Approved by Project Engineer Date

(If 5 is YES, do not sign this form. Return the entire package to the Project Engineer who will convene design review conferences with Project personnel to pursue additional action.)

Items 1 through 5 approval:

[Signature] 4-16-80 [Signature] 4/16/80 [Signature] 5/9/80
 Mgr. Generation Eng. Date Mgr. Generation QA Date Unit Superintendent Date
 (or alternate) (or alternate) (or alternate)

AFTER ERM
 ISSUE AND PRIOR
 TO TIE-INS.
 272 5/9/80

Safety Evaluation

THE COMPONENTS ADDED BY THIS MODIFICATION ARE NOT SAFETY RELATED, WHICH PRECLUDES THE PROBABILITIES OR CONSEQUENCES OF ACCIDENTS OR MALFUNCTION OF EQUIPMENT IMPORTANT TO SAFETY. THE INSTRUMENTATION ADDED IS PROVIDED FOR MONITORING NORMAL RC MAKEUP FLOW & SERVES NO SAFETY FUNCTION.

Included ECM(s)

FQ-R54

NSR

Non-NSR

YES

Verified

R. L. Hottenstein

S.R.D. 4/16/1980

References

Appendices

L. B. Fitch 3-11-80

Fire Hazards Analysis

Job Title RM-14 Date 3-11-80
Task Description APPROVED HPI MODIFICATIONS
RE R. B. Fisher PS A. M. Rogers

1. Fire Hazards Preliminary Information

1. Identify the ECM Area. SEE ATTACHMENT
Bldg. Elevation Column

*2. Identify the addition or removal of components
List:

COMPONENTS ADDED ARE CABLE AND CONDUIT. THE DRAWINGS
AFFECTED ARE AS SHOWN ON THE ATTACHMENT TO THE ECM.

*3. Identify the addition or removal of combustibles
Add Qty Type

~~Remove Qty~~ ~~Type~~

SEE PAGE 4b FOR A LIST OF COMBUSTIBLES IN THE
CONT. BLDG. AND FUEL HOLG. BLDG.

Yes

No

- Penetration of fire barriers
- Addition or removal of space separations
- HVAC operation or modification
- Fire suppression water system
- Fire suppression gaseous system
- Fire suppression CO₂ system
- Fire suppression other - including hand extinguishers
- Fire protection surveillance system
- Fire detection system

5. Identify and describe the presence of NAB system components that may be impacted by a positive response to Item 2. One example is: This shall include mechanical or electrical control system components.

Responsible Engineer: Date

II. Fire Hazards Analysis

1. Fire Hazards Analysis required _____
2. Fire Hazards Analysis completed _____
3. Fire Hazards Analysis amendment is required _____
4. Fire Hazards Analysis amendment has been completed _____

Yes

No

C. 1.

Fire Protection Program Coordinator Date

Mech Comp Sect Mgr Date

POOR ORIGINAL

S-ECM-007, Rev 3

TASK RM-14

4. Identify and describe any interface on existing fire protection services. (If yes checked - attach reference document or written explanation)

Yes	No	
X	—	Penetration of fire barriers
—	X	Addition or removal of space penetrations
—	X	HVAC operation or modification
—	X	Fire suppression water system
—	X	Fire suppression manual system
—	X	Fire suppression CO ₂ system
—	X	Fire suppression other - including hand extinguishers
—	X	Fire protection surveillance system
—	X	Fire detection system

5. Identify and describe the presence of NSR systems components that may be impacted by a positive response to items 2, 3 and 4 above. This shall include mechanical or electrical control system components.

THE ADDITION OF THIS MODIFICATION HAS NO SIGNIFICANT EFFECT ON NUCLEAR SAFETY RELATED SYSTEMS OR COMPONENTS.

R. B. Fisher 3-11-80

Responsibility Engineer Date

II. Fire Hazards Analysis

- | | | | | |
|---|-----------------|----------------|-----|----|
| 1. Fire Hazards Analysis required | <u>RD Angus</u> | <u>3-11-80</u> | Yes | No |
| 2. Fire Hazards Analysis completed | _____ | _____ | X | — |
| 3. Fire Hazards Analysis amendment is required | _____ | _____ | — | X |
| 4. Fire Hazards Analysis amendment has been completed | _____ | _____ | — | — |

Date

W. F. Fisher 4/11/80

Fire Protection Program Coordinator Date

R. Moore Jr 4-11-80

Chief, Safety Section Date

POOR ORIGINAL

POOR ORIGINAL

PAGE 4b OF 6

S-ECM-007-3

RM-12

2-77

<u>FIRE ZONE</u>	<u>ELEVATION</u>	<u>FLR/WALL</u>	<u>ELEV./COL.</u>	<u># CABLES</u>
CONT. BLDG. CB-3C	338'-6"	W	WEST	2
CONT. BLDG. CB-3d	338'-6"	W	NORTH	2
FUEL HDLG. FH-FE1	281'-0"	W	WEST	2
FUEL HDLG. FH-FE2	305'-0"	F	305'-0"	2
FUEL HDLG. FH-FE5	322'-0"	F	322'-0"	2

12.125 lbs. CABLE INSULATION IN CONTROL BLDG. AREA CB-3C

4.95 lbs. CABLE INSULATION IN CONTROL BLDG. AREA CB-3d

7.14 lbs. CABLE INSULATION IN FUEL HDLG. AREA FH-FE1

2.55 lbs. CABLE INSULATION IN FUEL HDLG. AREA FH-FE2

0.535 lbs. CABLE INSULATION IN FUEL HDLG. AREA FH-FE5

ROUTE



itants

215 775:26

GAI/TMI-1CS-3100

APR 2 1980

2m.14

Re: Three Mile Island Nuclear Station
Unit No. 1
Fire Hazard Analysis
W.O. C44692-502
Task SECM-007, Rev. 3

Dear Mr. Slear:

GAI has performed a fire hazard analysis to assure continued compliance with TMI-1 Fire Hazard Analysis Report (FHDR) for providing approved HPI modifications as outlined in SECN-007, Rev. 3. The following information relates to findings of the analysis.

- A. The increased quantity of combustibles added by SECM-007, Rev. 3 does not exceed the limit established for the fire areas or zones as described in the PHAR.
- B. The increased quantity of combustibles added by SECM-007, Rev. 3 is insignificant, therefore, the allowable transient combustibles loading will not be adjusted.
- C. Control Building Area CB-3C (Elevation 338'-6") contains engineered safeguards actuation cabinets A & B, and engineered safeguards relay cabinets 1, 2 & 3 which are redundant. To prevent loss of function of the redundant safe shutdown related equipment within this area, due to a fire, the following protection has been provided:
 - 1. Engineered Safeguards actuation cabinets and engineered safeguards relay cabinets are protected internally with fire resistive material with a 1/2 hour fire resistance rating.
 - 2. Ionization type smoke detectors provide early warning fire detection within the area.
 - 3. Manually actuated, closed fusible link sprinkler system.

4. 1½" fire hose stations outside the area.
5. CO₂ and dry chemical portable fire extinguishers.

For Control Building Area CB-3C and other areas affected by SECM-007, Rev. 3 the safe shutdown of TMI-1 will not be prevented by the change in combustible loading, since the change is insignificant. The addition of components to provide approved HPI modifications, as outlined in SECM-007, Rev. 3, will not prevent safe shutdown in the event of a fire in the area. In the event of a fire within the area, safe shutdown capability will not be prevented by the modifications of systems or components of SECM-007, Rev. 3. The fire suppression or fire detection systems will not be modified or affected by SECM-007, Rev. 3. Where fire barriers are altered due to penetrations, site procedure GED-GS-9, Rev. 1, "Technical Specification - Penetration Seals for Fire Protection at TMI-1" for new penetrations and Met-Ed Maintenance Procedure 1420 FB-1 for repairs to existing penetrations assures that those penetrations will be sealed to provide the required fire resistance of that barrier.

SECM-007, Rev. 3 was also reviewed to assure conformance to the requirements of the point by point comparison of TMI-1 to Appendix "A" of the NRC Branch Technical Position APCS 9.5-1 as described in the FHAR.

Amendment to the Fire Hazard Analysis Report will not be required.

The incorporation of this ECM completes the recommended requirements of Task RM14.

Very truly yours,

Rodney D. Angus


Rodney D. Angus
Fire Protection Engineer

R.M. Rogers

R.M. Rogers
Project Manager

RDA/RMR:daf

cc: D.K. Croneberger
J.P. Moore
G.R. Capodanno
R.M. Rogers (2)
W.F. Itschner
H.N. Goldstein
P.J. Shipper, Jr.
V.H. Willems



Service

NUCLEAR SAFETY RELATED

PAGE 1 OF 2-20

SHEET 1 OF 3

ENGINEERING CHANGE MEMO

DESIGN ORGANIZATION

ECM NO. S-ECM-CO7 REV. 4TMI UNIT NO. 1

GAI

DISCIPLINE I & C

GPUSC

SUBJECT: APPROVED HPI

OTHER

MODIFICATIONS

TASK NO. 24-14

CHANGE

REVISED DWG'S SS-201-303 IA-1, SS-202-016 IA-1 SH. 42
 RE-1, B-308-813 IA-1, B & W DWG. 22-03-401 IA-1, C-210-710
 IB-1, C-302-661 IA-1, B & W DWG. 21-15-009 IA-1 B & W DWG.
 22-03-500 IA-1 AND E-304-666 IA-5. ADDED PAGE 1, SH. 2

AND PAGES 5 (5 SHEETS) AND 6. REVISED TO RE-DESIGNATE THE
 MODIFICATION AS "IMPORTANT TO SAFETY" REQUIRING QUALITY CONTROL INSTALLATION
 SURVEILLANCE. INSTRUMENTATION MOUNTING, CONDUIT INSTALLATIONS, CABLE PULLS
 AND TERMINATION SHALL BE INSPECTED PER ATTACHMENT 889, 890, 891 AND
 PAGES 2, 3 & 4 NOT CHANGED BY THIS REVISION. CONTINUED ON SHEET 2 OF 3 (SEE
 ITEM 1)

REASON FOR CHANGE

THIS SECM PACKAGE HAS BEEN REVISED PER GPU
 COMMENTS IN LETTER TMI-1/E653 AND TO CONFORM
 TO REVISION 8 OF THE OPERATIONAL QA PLAN GPUNCM-ED
 - CONTINUED ON SHEET 2 OF 3 (SEE ITEM 2)
 THIS CHANGE RESOLVES FC-R200 COMMENTS

REMARKS

DRAWINGS B-308-813 IA-1, C-302-661 IA-1, E-304-666 IA-1
 AND PURCHASE REQUISITION * 86609 ARE NUCLEAR SAFETY
 RELATED. ALL OTHER DRAWINGS AND ATTACHMENTS TO
 THE SECM ARE NON-SAFETY RELATED OR IMPORTANT TO
 SAFETY, AS SHOWN.

ORIG. ENGINEER R. J. Fisher DATE 5/16/80 C. J. Fisher
 REVISE SPEC. _____ REVISE DWG. _____
 FORC APPROV. 7/17 FOR INSTALLATION 6/27/80
 SRD 7/8/80

SAFETY CLASSIFICATION

☒ NUCLEAR SAFETY RELATED☐ IMPORTANT TO SAFETY☐ NOT IMPORTANT TO SAFETY

QC CLASSIFICATION

☒ QC YES☐ QC NO

QA APPROVAL (AS REQUIRED)

GPUSC QA APPROVAL (AS REQUIRED)

REV. 4 APPROVED FOR ISSUE
AND CONSTRUCTION:

N/A TO UNIT NO. 1

GPUSC COMM. SITE MANAGER/DATE

J. J. James
8/1/80

ACKNOWLEDGEMENT

eln MLM MLMJames Kondras

DOCC/DATE

SEP 5 3 1980

ITEM 1: "CHANGE" PARAGRAPH CONTINUED TASK RM-14

- SECM-007, REV. 0, 1 & 2 DEALT WITH HPI CROSS CONNECT TASK WHILE REV. 3 & 4 ARE PERTAINING TO PIPING AND INSTRUMENTATION FOR RC MAKEUP FLOW MONITORING
- SECM-007, REV. 3 DEALT WITH:
 - REMOVAL OF A FLOW NOZZLE (MU-24-FE), DIFFERENTIAL PRESSURE TRANSMITTER (MU-24-DPT - BAILEY TYPE BY XMTR) AND A SQUARE ROOT EXTRACTOR (MU-24-FT)
 - ADDITION OF A PIECE OF PIPE ^(SPOOL PIECE) IN PLACE OF MU-24-FE (DISCUSSED ABOVE), AND AN ULTRASONIC TYPE TRANSDUCERS/FLOWMETER IN PLACE OF MU-24-DPT. THE ULTRASONIC TRANSDUCERS & FLOWMETER WERE TAGGED MU-24-FE & MU-24-FT, RESPECTIVELY.
 - MAKING THE OUTPUT OF ULTRASONIC MU-24-FT COMPATIBLE WITH THE ICS/NNI & TYING-IN THIS OUTPUT INTO THE EXISTING ICS/NNI LOOP & MU-24

NOTE: SECM-007-REV. 3 WAS RELEASED FOR J.T. FAULKNER'S REVIEW AND APPROVAL ON APRIL 17, 1990 ALONG WITH GPUSC COMMENTS ATTACHED TO IT AS ATTACHMENT 13. ALSO BY LETTER TMI-1/E653, GPUSC DIRECTED GAI TO INCORPORATE THESE COMMENTS. IN RESPONSE GAI ISSUED SECM-007-REV. 4.

- SECM-007, REV. 4 IS RELEASED FOR CONSTRUCTION WITH ONE EXCEPTION. NOTE THAT THE ATTACHMENT 78 TO THE SECM-007, REV. 4 WHICH IS A B&W DRAWING, HAS A HOLD ON THE WIRING TERMINATIONS AT MU-24-FT. GAI SHALL BE DIRECTED TO ISSUE REV. 5 TO THIS ECM SHOWING CORRECT TERMINATIONS.

ITEM 2: "REASON FOR CHANGE" PARAGRAPH CONTINUED

ADDITION OF MU-V217 REQUIRED THE RC FLOW MONITORING INSTRUMENTS TO BE SENSITIVE FOR A FLOW RANGE OF 0-160 GPM DURING NORMAL PLANT OPERATION AND 0-500 GPM IN TRANSIENT MODE WHEN MU-V217 WAS OPENED FOR A FAST MAKEUP PURPOSE (MAXIMUM EXPECTED FLOW OF 425 GPM). THE EXISTING MU-24-DPT WAS CALIBRATED FOR 0-200" H₂O (= 0-160 GPM) AND WAS RATED FOR A MAXIMUM DP OF 200" H₂O. ∴ THE EXISTING MU-24-DPT WAS RECOMMENDED TO BE REPLACED WITH ULTRASONIC DEVICES (SEE GPUSC'S RESPONSE TO FQ-R54 FOR DETAILS)

Service		ECM SECM-007 Rev 4	
		TASK RM-14	
TITLE		PAGE 1 OF 6 SHEET 3 OF 23	
REV	SUMMARY OF CHANGE	APPROVAL	DATE
4	THE IMPACT EVALUATION, SAFETY EVALUATION AND FHA HAVE NOT BEEN AFFECTED BY THIS REVISION. HOWEVER, THE LIST OF ATTACHMENTS AND THE LIST OF REFERENCES HAVE BEEN REVISED AND ATTACHED.	<i>En/Slavut</i> <i>GAUC Section</i> <i>Mgy</i>	

FOR INFORMATION ONLY

GENERATION COMPANY JOB TICKET FORM (WORK REQUEST)-THREE MILE ISLAND

UNIT 1

ATTACHMENT 3

COMPONENT DESIGNATION				LOCATION UNIT	JOB TYPE	JOB TICKET NUMBER	REQUEST DATE		
SYS	COMP TYPE	COMP ID	Q				MO	DAY	YR
MU	V	0107C	0	035001	CM	CR	04	23	80

1D

REPAIR
FUNCTION
OR
MODIFICATION
REQUIRED

INSPECT VALVE INTERNALS - DOCUMENT
CONDITION

SCOPE OF
MODIFICATION
REQUIRED

ORIGINATOR'S EMP NO
0

ORIGINATOR'S SIGNATURE

DATE

SUPERVISOR'S EMP NO
06248

SUPERVISOR'S SIGNATURE

DATE

[Signature]

4-24-80

WORK ORDER NUMBER		OF	ACCOUNT	PLANT CONDITION				APPROVAL		START					
LOCATION	SERIAL	CODE	NUMBER	SU	OP	HO	CO	RF	HS	LR	YR	MO	DAY	HR	MIN
035001	06187BE		5301	1	1	1	1	1	1	1					

CHARGE TO REG'D	BY SAFETY	NO RD	REG AGENCY CODE	CHG/MOD NUMBER
0	6	1	0	

ENV CODE	OUTAGE CAUSE CODE
X	

STATUS HOLD CODE

APPROVAL COMMENCE WORK
MO DAY YR
052380

RESP LOCATION OR CONTRACTOR
MO DAY YR
200969

Limits and Precautions:

a) Personnel

b) Equipment

c) Environment

d) Nuclear

ALARA REVIEW REQUIRED
PRIOR TO COMMENCING WORK
COMPLY WITH THE PROVISIONS
SET FORTH IN 10 CFR 100.3
AND NRC'S SAFETY MANUAL

INSURE WORK AREA CLEAN
UP AT COMPLETION

Post Maintenance Testing required and Acceptance Criteria.

Attached data/comments sheet filled out. Valve is reassembled
and bonnet is leak tight.

ORIGINATOR—SUPERVISOR—SUPERVISOR OF MAINTENANCE—MAINTENANCE FOREMAN—
JOB PERFORMER—MAINTENANCE FOREMAN—SUPERVISOR OF MAINTENANCE

COPY 1

GENERATION CORRECTIVE MAINTENANCE SYSTEM JOB TICKET FORM (WORK REQUEST) - THREE MILE ISLAND

UNIT 1

3-2

COMPONENT DESIGNATION										LOCATION / UNIT		JOB TYPE	JOB TICKET NUMBER	REQUEST DATE			RECOMMENDED PRIORITY	
SYS	COMP. TYPE	COMP. ID	LOC. NO.	LOC. UNIT	JOB TYPE	JOB TICKET NUMBER	MO	DAY	YR									
5	7	8	11	12	13	14	15	16	17	22	23	24	25	28	32	33	38	
MU	W		01	07	C	03	50	01	CM					CS	16	00	42	80

ID

DESCRIBE MALFUNCTION OR MODIFICATION DESIRED

CAUSE OF MALFUNCTION (IF KNOWN)

INSPECT VALVE INTERNALS - DOCUMENT CONDITION

ORIGINATOR'S EMP. NO.

SUPERVISOR'S EMP. NO.

0

ORIGINATOR'S SIGNATURE

DATE

06248

SUPERVISOR'S SIGNATURE

DATE

WORK ORDER NUMBER		GC CODE	ACCOUNT NUMBER	PLANT CONDITION				NPRO FAILURE		START					
LOCATION	SERIALS			SU	OP	MO	CO	RF	HS	LR	YR	MO	DAY	HR	MIN
0350	187BE		5341												

REQ. D.	RUC SAFETY	NP	AGENCY CODE	APP. NO.	ENV. CODE	OUTAGE CAUSE CODE	STATUS HOLD CODE	ESTIMATED DOLLARS
0	1	0		08306	X			

S/M APPROVAL COMMENCE WORK			S/F APPROVAL COMMENCE WORK			PROCEDURE NUMBER	RESP. LOCATION OR CONTRACTOR	EST. CREW SIZE	EST. MANHOURS
MO	DAY	YR	MO	DAY	YR				
05	23	80	05	20	80	1410-4-31	2C086902000480		

ASSISTING DEPARTMENT			ASSISTING DEPARTMENT			ASSISTING DEPARTMENT		
RESP. LOCATION OR CONTRACTOR	EST. CREW	EST. MANHOURS	RESP. LOCATION OR CONTRACTOR	EST. CREW	EST. MANHOURS	RESP. LOCATION OR CONTRACTOR	EST. CREW	EST. MANHOURS

JOB COMPLETION DATE			FIELD WORK COMPLETION DATE			SIGN OFF REASON CODE	TOTAL ACTUAL MANHOURS	PURCHASE REQUISITION NUMBER	PURCHASE ORDER NUMBER	MATERIAL ORDER NUMBER
MO	DAY	YR	MO	DAY	YR					
05	23	80	05	20	80	000300				

RESOLUTION DESCRIPTION															
07 DISASSEMBLED VALVE CLEANED RENEWED HELIC															
08 OILS AND INTERNALS INSPECTED AND REASSEMB															
09 OK KA AS PER SECM 145. THE ECM IS ATTACHE															
10D TO JOB TICKET C3164															

NPRO FAILURE END						FAILURE NO.	FAILURE STATUS	ORIGINATOR - SUPERVISOR - SUPERVISOR OF MAINTENANCE - MAINTENANCE FOREMAN - JOB PERFORMER - MAINTENANCE FOREMAN - SUPERVISOR OF MAINTENANCE - CM COORDINATOR - DATA ENTRY - SUPERVISOR OF MAINTENANCE - CM COORDINATOR - DATA ENTRY										
YR	MO	DAY	HR	MIN														
39						48	49	50										

NPRO FAILURE TYPE		NPRO FAILURE MODE		CAUSE OF FAILURE CODES		EFFECT OF FAILURE CODES		FAILURE DETECTION CODE	ACTION TAKEN CODES		LICENSE EVENT REPORTED DATE			
YR	MO	DAY	HR	MIN					A	B	YR	MO	DAY	
39	40	41	42	43			50	51	55	56	57	58	59	60

COPY 2

POOR ORIGINAL

TXN CD 807A

TXN CD 801A
801A
801A
301A

TXN CD 308A

TXN CD 809A

JOB TICKET (WORK REQUEST) **REVIEW - CLASSIFICATION - ROUTING CONTROL FORM**

JOB TICKET NUMBER _____

1. Does work represent a change or modification to an existing system or component? If yes, an approved change modification is required per AP 1021.

C/M No. _____ Yes _____ No ☒

- 2a. Does work requires an RWP?

Yes ☒ No _____

- 2b. Is an approved procedure required to minimize personnel exposure?

Yes _____ No _____

- 3a. Is work on a QC component as defined in GP 1008?

Yes ☒ No _____

- 3b. If 3a is yes does work have an effect on Nuclear Safety? If 3b is yes, PORC reviewed Superintendent approved procedure must be used.

Yes ☒ No _____

4. Agreement that a PORC reviewed, Superintendent approved procedure is not required for this work because it has no effect on nuclear safety. (Applies only if 3a is Yes and 3b is No).

UNIT SUPERINTENDENT

DATE

1410-V-731
modified

- 5a. Is the system on the Environmental Impact list in AP 1026?

Yes _____ No ☒

- 5b. If 5a is YES, is an approved procedure required to limit environmental impact?

Yes _____ No _____

6. Agreement that 5b is No. (Required only if 5a is Yes).

UNIT Supt./Supv. of Operations

DATE

7. Plant status or prerequisite conditions required for work. (Operating and/or shutdown)

8. QC Dept. review, if required in item No. 3.

QC SUPERVISOR

DATE

9. Does work require code inspector to be notified?

Yes _____ No ☒

10. Supervisor of Maintenance approval to commence work:

R. Troutman

Date 5-23-80

11. Maintenance Foreman Assigned:

B. K...

12. Code Inspector Notified Name:

Date _____

13. Shift Foreman's approval to commence work:

R. B...

Date 5-30-80

Initial if Shift Foreman signature is not required.

3-4

**JOB TICKET (WORK REQUEST)
REVIEW — CLASSIFICATION — ROUTING CONTROL FORM**

JOB TICKET NUMBER _____

14. Retest met acceptance criteria? Yes _____ No _____

15. Work Performed By Date/Time: D. WINTROBE, L. TICE & R. SAWYER. 1002 1982

Work Reviewed—Maint. Foreman's Signature: M. D. Long

16. Work completed and component aligned for testing.

_____ Initial if S.F. signature is not required.

M. D. Long 11-7-82
SHIFT FOREMAN'S SIGN. DATE

17. Testing completed and component released for normal use.

_____ Initial if S.F. signature is not required.

_____ DATE

18. Quality Control Department review of work and testing completed (QC work only).

_____ SURVEILLANCE RPT. NO. _____ QC DEPARTMENT _____ DATE

19. Supervisor of Maintenance Job Ticket (Work Request) and procedure are complete and signed off as required. Change/modification form has been signed off as required.

_____ SUPV. OF MAINTENANCE SIGN. _____ DATE

ATTACHMENT 4

CAUSE OF
MALFUNCTION
(IF KNOWN):

ORIGINATOR'S EMP. NO.		SUPERVISOR'S EMP. NO.	
04737		04737	
ORIGINATOR'S SIGNATURE		SUPERVISOR'S SIGNATURE	
DATE		DATE	

WORK ORDER NUMBER				JC CODE	ACCOUNT NUMBER	PLANT CONDITION							NPRO FAILURE			START	
LOCATION		SERIAL				SU	OP	MO	CO	RF	HS	LR	YR	MO	DAY	HR	MIN
0350		001875H			5												
CHANGE MOD REQ'D		R W P	NUC SAFETY	NPR RDC	REG AGENCY CODE	CHG/MOD NUMBER		TAGGING APPLICATION NO.		ENV CODE		OUTAGE CAUSE CODE		STATUS HOLD CODE		ESTIMATED DOLLARS	
000								05749		X							

S/M APPROVAL COMMENCE WORK			S/F APPROVAL COMMENCE WORK			PROCEDURE NUMBER	P R I O R I T Y	RESP LOCATION OR CONTRACTOR	EST CREW SIZE	EST MANHOOURS	
MO	DAY	YR	MO	DAY	YR						
10	21	00	06	27	20	1420	1	1111	3	2052	07000160

[illegible]

TXN CD	A C T	JOB COMPLETION DATE			FIELD WORK COMPLETION DATE			SIGN OFF REASON CODE		TOTAL ACTUAL MANHOURS		PURCHASE REQUISITION NUMBER		PURCHASE ORDER NUMBER		MATERIAL ORDER NUMBER	
		MO	DAY	YR	MO	DAY	YR	51	52	53	58	59	66	67	73	74	80
807A		07	11	80	07	09	80	1		000320							

4		39	RESOLUTION DESCRIPTION	UTRS	30
3	01A	07	FREQ CAPTURE RANGE WAS OUT OF SPEC ADJUS		
3	01A	08	TED POT & CALLED CAPTURE RANGE WITHIN		
3	01A	09	SPEC BY KEEPING DOOR CLOSED FOR INTERNAL		
3	01A	10	LEFT PROCEDURE CHANGE WAS SUBMITTED		

1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56	57	58	59	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	93	94	95	96	97	98	99	00																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																				
1. IN										2. NO										3. YES										4. UNKNOWN										5. OTHER										6. UNCLASSIFIED										7. CONFIDENTIAL										8. SECRET										9. TOP SECRET										10. UNCLASSIFIED										11. CONFIDENTIAL										12. SECRET										13. TOP SECRET										14. UNCLASSIFIED										15. CONFIDENTIAL										16. SECRET										17. TOP SECRET										18. UNCLASSIFIED										19. CONFIDENTIAL										20. SECRET										21. TOP SECRET										22. UNCLASSIFIED										23. CONFIDENTIAL										24. SECRET										25. TOP SECRET										26. UNCLASSIFIED										27. CONFIDENTIAL										28. SECRET										29. TOP SECRET										30. UNCLASSIFIED										31. CONFIDENTIAL										32. SECRET										33. TOP SECRET										34. UNCLASSIFIED										35. CONFIDENTIAL										36. SECRET										37. TOP SECRET										38. UNCLASSIFIED										39. CONFIDENTIAL										40. SECRET										41. TOP SECRET										42. UNCLASSIFIED										43. CONFIDENTIAL										44. SECRET										45. TOP SECRET										46. UNCLASSIFIED										47. CONFIDENTIAL										48. SECRET										49. TOP SECRET										50. UNCLASSIFIED										51. CONFIDENTIAL										52. SECRET										53. TOP SECRET										54. UNCLASSIFIED										55. CONFIDENTIAL										56. SECRET										57. TOP SECRET										58. UNCLASSIFIED										59. CONFIDENTIAL										60. SECRET										61. TOP SECRET										62. UNCLASSIFIED										63. CONFIDENTIAL										64. SECRET										65. TOP SECRET										66. UNCLASSIFIED										67. CONFIDENTIAL										68. SECRET										69. TOP SECRET										70. UNCLASSIFIED										71. CONFIDENTIAL										72. SECRET										73. TOP SECRET										74. UNCLASSIFIED										75. CONFIDENTIAL										76. SECRET										77. TOP SECRET										78. UNCLASSIFIED										79. CONFIDENTIAL										80. SECRET										81. TOP SECRET										82. UNCLASSIFIED										83. CONFIDENTIAL										84. SECRET										85. TOP SECRET										86. UNCLASSIFIED										87. CONFIDENTIAL										88. SECRET										89. TOP SECRET										90. UNCLASSIFIED										91. CONFIDENTIAL										92. SECRET										93. TOP SECRET										94. UNCLASSIFIED										95. CONFIDENTIAL										96. SECRET										97. TOP SECRET										98. UNCLASSIFIED										99. CONFIDENTIAL										00. SECRET									

TAN CD		A CD		NPRD FAIL TYPE				NPRD FAIL MODE				CAUSE OF FAILURE CODES				EFFECT OF FAILURE CODES				FAILURE DETECT CODE				ACTION TAKEN CODES				LICENSE EVENT REPORTED DATE			
				A		B		A		B		A		B		A		B		A		B		YR		MO		DAY			
3	0	9	A	39	40	41	42	43						50	51	A	B	55	56	57	58					55	56		71		

COPY 2

COPY 2

GENERATION CORRECTIVE MAINTENANCE SYSTEM
JOB TICKET FORM (WORK REQUEST) - THREE MILE ISLAND

UNIT 1

1420-INV

COMPONENT DESIGNATION				LOCATION/UNIT	JOB TYPE	JOB TICKET NUMBER	REQUEST DATE		
SYS	COMP TYPE	COMP ID	MO				DAY	YR	
EL	EL	0005		035001CM		03463062180			

RECOMMENDED PRIORITY 4-2

3

DESCRIBE
FUNCTION
OR
MODIFICATION
DESIRED

CAUSE OF
MALFUNCTION
(IF KNOWN)

ORIGINATOR'S EMP. NO.
04737

ReB... 6-21-80
ORIGINATOR'S SIGNATURE DATE

SUPERVISOR'S EMP. NO.
04737

ReB... 6-24-80
SUPERVISOR'S SIGNATURE DATE

WORK ORDER NUMBER		CC CODE	ACCOUNT NUMBER	PLANT CONDITION						NPP FAILURE			START	
LOCATION	SERIAL			SU	OP	HO	CD	RF	HS	LR	YR	MO	DAY	HR
0350001875H			5315	1	1	1	1	1	1	10				

CHANGE VDD REQ D	W P	NUC SAFETY	HP PO	REG AGENCY CODE	ORG/MOD NUMBER
0001					

ENV CODE	OUTAGE CAUSE CODE
X	

STATUS HOLD CODE

S/M APPROVAL COMMENCE WORK		
MO	DAY	YR
06	26	80

RESP LOCATION OR CONTRACTOR
3035L

JUN 25 1980

Limits and Precautions:

- a) Personnel
- b) Equipment
- c) Environment
- d) Nuclear

Comply with the Provisions
set forth in AP 1002 and
Met Ed Safety Manual

Post Maintenance Testing required and Acceptance Criteria.

INSURE WORK AREA CLEANED
UP AT COMPLETION OF JOB

as required by 1420-INV-3

ORIGINATOR — SUPERVISOR — SUPERVISOR OF MAINTENANCE — MAINTENANCE FOREMAN —
JOB PERFORMER — MAINTENANCE FOREMAN — SUPERVISOR OF MAINTENANCE

COPY 1

**JOB TICKET (WORK REQUEST)
REVIEW - CLASSIFICATION - ROUTING CONTROL FORM**

JOB TICKET NUMBER _____

1. Does work represent a change or modification to an existing system or component? If yes, an approved change modification is required per AP 1021.

C/M No. _____ Yes _____ No ☒

- 2a. Does work requires an RWP?

Yes _____ No ☒

- 2b. Is an approved procedure required to minimize personnel exposure?

Yes _____ No ☒

- 3a. Is work on a QC component as defined in GP 1008?

Yes ☒ No _____

- 3b. If 3a is yes does work have an effect on Nuclear Safety? If 3b is yes, PORC reviewed Superintendent approved procedure must be used.

Yes _____ No ☒

4. Agreement that a PORC reviewed, Superintendent approved procedure is not required for this work because it has no effect on nuclear safety. (Applies only if 3a is Yes and 3b is No).

UNIT SUPERINTENDENT

DATE

1420 INU-3

- 5a. Is the system on the Environmental Impact list in AF 1026?

Yes _____ No ☒

- 5b. If 5a is YES, is an approved procedure required to limit environmental impact?

Yes _____ No ☒

5. Agreement that 5b is No. (Required only if 5a is Yes).

UNIT SUPV/SUPV OF OPERATIONS

DATE

7. Plant status or prerequisite conditions required for work. (Operating and/or shutdown)

8. QC Dept. review, if required in item No. 3.

QC SUPERVISOR

DATE

9. Does work require code inspector to be notified?

Yes _____ No ☒

10. Supervisor of Maintenance approval to commence work:

Date

6/26/80

11. Maintenance Foreman Assigned:

Date

12. Code Inspector Notified. Name:

Date

13. Shift Foreman's approval to commence work:

Date

6-27-80

Initial if Shift Foreman signature is not required.

4-4

**JOB TICKET (WORK REQUEST)
REVIEW - CLASSIFICATION - ROUTING CONTROL FORM**

JOB TICKET NUMBER C34 E

14. Retest met acceptance criteria? Yes ✓ No

15. Work Performed By Date/Time: MILITARY 6-27-80 1455

Work Reviewed—Maint. Foreman's Signature: C. R. [Signature]

16. Work completed and component aligned for testing.

Initial if S.F. signature is not required.
[Signature] 6/27/80
SHIFT FOREMAN'S SIGN DATE

17. Testing completed and component released for normal use.

Initial if S.F. signature is not required.
[Signature] 7/9/80
SHIFT FOREMAN'S SIGN DATE

18. Quality Control Department review of work and testing completed (QC work only).

 [Signature] 7/11/80
SURVEILLANCE RPT. NO. QC DEPARTMENT DATE

19. Supervisor of Maintenance Job Ticket (Work Request) and procedure are complete and signed off as required. Change/modification form has been signed off as required.

[Signature] 7-11-80
SUPV. OF MAINTENANCE SIGN DATE

GENERATION CORRECTIVE MAINTENANCE SYSTEM
JOB TICKET FORM (WORK REQUEST)-THREE MILE ISLAND

UNIT 1 *ME* ATTACHMENT 5

COMPONENT DESIGNATION				LOCATION/UNIT	JOB TYPE	JOB TICKET NUMBER	REQUEST DATE			PRIORITY
S-S	COMP TYPE	COMP ID	Q NO				MO	DAY	YR	
AC	H	00018		03500	1CM	C35	05	22	80	

DESCRIBE
MALFUNCTION
OR
MODIFICATION
DESIRED

CAUSE OF
MALFUNCTION
(IF KNOWN)

CONDUCT EDDY CURRENT EXAMINATION OF
ABOUT 6% OF TUBES IN B OTSG TO COMPLY WI
TH TECH. SPEC. 4.19.
PERIODIC INSPECTION OF OTSG TUBING AFI
PREVENT TUBE LEAKAGE

ORIGINATOR'S EMP NO	<i>JR Bohate</i>	DATE	5-22-80	SUPERVISOR'S EMP NO	<i>MEB</i>	DATE	5-22-80
00469	ORIGINATOR'S SIGNATURE			06248	SUPERVISOR'S SIGNATURE		

T8073 / 530.2

WORK ORDER NUMBER		CO CODE	ACCOUNT NUMBER	PLANT CONDITION				NPRO FAILURE		START					
LOCATION	SERIAL			SU	OP	NO	CD	RF	HS	LR	YR	MO	DAY	HR	MIN
03500	00147CB		5302	00011					00						

CHANGE MADE REQ'D	W D	NO SAFETY	NO AD	REG AGENCY CODE	CHG/MAO NUMBER
0110					

ENV CODE	OUTAGE CAUSE CODE
X	

STATUS HOLD CODE

COMMENCE WORK		
MO	DAY	YR
06	13	80

RESP LOCATION OR CONTRACTOR	
3	0351

INSURE WORK AREA CLEANED
UP AT COMPLETION OF JOB

Limits and Precautions:

a) Personnel

b) Equipment

c) Environment

d) Nuclear

ALARA REVIEW REQUIRED
PRIOR TO COMMENCING WORK
COMPLY WITH THE PROVISIONS
SET FORTH IN AP1002, 1003
AND MET ED SAFETY MANUAL

Post Maintenance Testing required and Acceptance Criteria

Requirements of Tech Spec 4.19 satisfactorily met.

ORIGINATOR—SUPERVISOR—SUPERVISOR OF MAINTENANCE—MAINTENANCE FOREMAN—
JOB PERFORMER—MAINTENANCE FOREMAN—SUPERVISOR OF MAINTENANCE

COPY 1

3-2

JOB TICKET (WORK REQUEST)
REVIEW - CLASSIFICATION - ROUTING CONTROL FORM

JOB TICKET NUMBER 1221

1. Does work represent a change or modification to an existing system or component? If yes, an approved change modification is required per AP 1021.

C/M No. _____ Yes _____ No ☒

- 2a. Does work requires an RWP?

Yes ☒ No _____

- 2b. Is an approved procedure required to minimize personnel exposure?

Yes _____ No ☒

- 3a. Is work on a QC component as defined in GP 1008?

Yes ☒ No _____

- 3b. If 3a is yes does work have an effect on Nuclear Safety? If 3b is yes, PORC reviewed Superintendent approved procedure must be used.

Yes ☒ No _____

4. Agreement that a PORC reviewed, Superintendent approved procedure is not required for this work because it has no effect on nuclear safety. (Applies only if 3a is Yes and 3b is No).

J. G. Toole RST
UNIT SUPERINTENDENT

6/12/80
DATE

- 5a. Is the system on the Environmental Impact list in AP 1026?

Yes _____ No ☒

- 5b. If 5a is YES, is an approved procedure required to limit environmental impact?

Yes _____ No ☒

6. Agreement that 5b is No. (Required only if 5a is Yes).

UNIT SUPT./SUPLY. OF OPERATIONS

DATE

7. Plant status or prerequisite conditions required for work. (Operating and/or shutdown)

8. QC Dept. review, if required in item No. 3.

[Signature]
QC SUPERVISOR

6/12/80
DATE

9. Does work require code inspector to be notified?

Yes _____ No ☒

10. Supervisor of Maintenance approval to commence work:

D. M. Shorter

Date 6-13-80

11. Maintenance Foreman Assigned: R. D. Breyer

12. Code Inspector Notified. Name: N/A Date _____

13. Shift Foreman's approval to commence work: [Signature] Date 6-13-80

Initial if Shift Foreman signature is not required.

7-3

**JOB TICKET (WORK REQUEST)
REVIEW - CLASSIFICATION - ROUTING CONTROL FORM**

JOB TICKET NUMBER C 3313

14. Rerest met acceptance criteria? Yes ☒ No ☐

15. Work Performed By Date/Time: _____

Work Reviewed—Maint. Foreman's Signature: *REB*

16. Work completed and component aligned for testing.

S.F. Initial if S.F. signature is not required.

SHIFT FOREMAN'S SIGN DATE

17. Testing completed and component released for normal use.

REB Initial if S.F. signature is not required.

SHIFT FOREMAN'S SIGN DATE

18. Quality Control Department review of work and testing completed (QC work only).

SURVEILLANCE RPT. NO. QC DEPARTMENT DATE

19. Supervisor of Maintenance Job Ticket (Work Request) and procedure are complete and signed off as required. Change/modification form has been signed off as required.

SUPV. OF MAINTENANCE SIGN DATE

GENERATION CORRECTIVE MAINTENANCE SYSTEM
CM STATUS ACTIVITY FORM

5-4

COMPONENT DESIGNATOR				LOCATION UNIT		JOB TYPE	WORK AUTHORIZATION NUMBER	REQUEST DATE			
SYS	COMP. TYPE	COMP. ID.	SGT	17	1	22	23	24	MO	DAY	YR
5	3	12	16	17	1	22	23	24	02	23	1 1 30
RC	H			00016	0.3	5	0	0	1	C	M

TIN CU	ACT	CHS/1103 1114424
304A		
TIN CO	ACT	RESP-LOCATION OR CONTRACTOR
005A		20351
TIN CO	ACT	PURCHASE REQUISITION NUMBER
807A		
TIN	ACT	PURCHASE ORDER NUMBER
310A		
STATUS HOLD		
CODE	START DATE	RELEASE DATE
37-40	MO DAY YR	MO DAY YR
	45 47	52 53 55 56
		61 62 63 64 65 66 67
0.1		
0.2		
0.3		
0.4		
0.5		
0.6		
0.7		
0.8		
5.0		
5.1		
5.2		
5.3		
5.4		
5.5		
5.6		
OUTAGE HOLD		
PART HOLD		
QUALITY CONTROL PART HOLD		
QUALITY CONTROL PROCEDURE HOLD		
OPERATIONS HOLD		
CHANGE MODIFICATION HOLD		
ENGINEERING HOLD		
PLANNING HOLD		
MANPOWER NOT AVAILABLE		
AT PORC		
AT QUALITY CONTROL		
AT UNIT SUPERINTENDENT		
AT READING		
POST MAINTENANCE TEST HOLD		
AT ALARA		

INTERIM ALARA REVIEW (ATTACHMENT 1) 80-6-17

Task Description: Body Current
Examination

Received on: 6-11-80
Review Date: 6-12-80
C-3313

Component Designation

SYS	COMP TYPE	COMP ID
<u>ALC</u>	<u>H</u>	<u>ACC 1/B</u>

Type of Review Performed:

Radioactive Materials Movement ☐
Radiation Levels ☒
One-Man Rem Exposure ☒

Contamination Levels ☒
Airborne Concentrations ☒
Environmental Release ☐

Approved _____ Disapproved _____ Conditional Approval ☒

If disapproved, see Discussion Section for requirements for approval. If conditional approval, RWP must reflect requirements stated in Discussion Section.

Reviewed by: ARTHUR C. TATE

ALARA Consideration Adequate	Yes	No	N/A	Remarks
1. Traffic Pattern-Personnel/Vehicles	☒			
2. Proper Access Control Point(s)	☒			
3. Sufficient Space to Perform Maintenance	☒			
4. Rigging Equipment Installed	☒			
5. Remote Readout Instruments			☒	
6. Placement and Adequacy of Shielding	☒			
7. Background Radiation Levels Considered	☒			
8. Provision for Temporary Shielding	☒			

ATTACHMENT 1 cont'd

ALARA Consideration Adequate	Yes	No	N/A	Remarks
9. Adequate Communications	X			
10. Location and Adequacy of Monitor	X			
11. Proper Air Flow Patterns/Volumes	X			
12. Proper Air Filtration	X			
13. Appropriate Sampling Mechanisms	X			
14. Provisions for Draining/Flushing			X	
15. Provisions to Minimize Contamination	X			
16. Provisions for Decontamination	X			
17. Provisions for Chemical Flushing/Cleaning			X	
18. Drainage to Proper System			X	
19. Provisions to Prevent Crud Traps			X	
20. Provisions to Isolate Equipment			X	
21. Adequate Waste Storage Facilities			X	
22. Provisions for Confined Area Entry	X			
23. Adequate Supervision	X			
24. Adequate Rad Con Supervision	X			
25. Adequate Job Familiarization	X			
26. Personnel Requirements (# of them)	X			
27. Review of Similar Tasks	X			
28. Use of Special Tools/Remote Operations	X			
29. Training (mock up - audio visual - etc.)	X			
30. Extremity Monitoring	X			
31. Special Anti-C's	X			
32. Adequate Respiratory Devices	X			
33. Rad Con Steps in Procedure				
34. Details of Procedure	X			
35. Other	X			

Dose Assessment (Expected Man-rem, MPC - hours, etc.)

< 1 Man-Rem.

Discussion Section

1. HEAD, HAND, FEET TLD'S REQUIRED.
2. HIGH & LOW RANGE POCKET DOSIMETERS REQUIRED
3. DOUBLE COTTON ANTI-C'S, ONE SET OF RAIN SUITS - WILL RE-EVALUATE REQUIREMENT AFTER JOB STARTS.
4. FAMILIARIZE STM GENERATOR ENTRY PERSONNEL IAW STATION AIR OPERATING PROCEDURE.
5. CONSTANT RAD CON COVERAGE REQUIRED
6. AIR SAMPLE TO BE TAKEN IN STEAM GENERATOR PRIOR TO START OF WORK. RESULTS TO BE AVAILABLE BEFORE EDDY CURRENT CREW ALARA Review By Date
7. BREATHING ZONE AIR SAMPLE, BENEATH HOOD, REQUIRED FOR ENTRY.

DeTate
6-12-85

JOB TICKET FORM (WORK REQUEST)-THREE MILE ISLAND

UNIT 1

ATTACHMENT 6

COMPONENT DESIGNATION				LOCATION UNIT	JOB TYPE	JOB TICKET NUMBER	REQUEST DATE		
SYS	COMP TYPE	COMP ID	LOC				MO	DAY	YR
RC	H	00018	035001	CM	C	27	03	16	80

IT

DESCRIBE
MALFUNCTION
OR
MODIFICATION
DESIRED

2759 LOWER MANWAY BOLTS HAVE BEEN
BUILT UP INDICATING POSSIBLE LEAKAGE. RE
MOVE CLEAN AND REINSTALL

CAUSE OF
MALFUNCTION
(IF KNOWN)

ORIGINATOR'S EMP NO.
04680

ORIGINATOR'S SIGNATURE

DATE

SUPERVISOR'S EMP NO.
04680

SUPERVISOR'S SIGNATURE

DATE

WORK ORDER NUMBER		LOC CODE	ACCOUNT NUMBER	PLANT CONDITION				NPRO FAILURE			START				
LOCATION	SERIAL			BU	OP	HD	CD	RF	HS	LR	YR	MO	DAY	HR	MIN
035000	18708	5302		00	01	1		00							

CHANGE MTO REQ	R S	SEC SAFETY	HP RD	REG AGENCY CODE	CHG/MOD NUMBER
0	1	0			

ENV CODE	OUTAGE CAUSE CODE
X	

STATUS HOLD CODE

COMM APPROVAL COMMENT WORK		
MO	DAY	YR
05	08	80

RESP LOCATION OR CONTRACTOR	
MO	DAY
22	08

Notify Q.C. @ PRIOR
TO START. Resuming 5/30/80

Limits and Precautions:

a) Personnel

b) Equipment

c) Environment

d) Nuclear

Post Maintenance Testing required and Acceptance Criteria.

INSURE WORK AREA CLEANED
UP AT COMPLETION OF JOB

ORIGINATOR — SUPERVISOR — SUPERVISOR OF MAINTENANCE — MAINTENANCE FOREMAN —
JOB PERFORMER — MAINTENANCE FOREMAN — SUPERVISOR OF MAINTENANCE

COPY 1

GENERATION CORRECTIVE MAINTENANCE SYSTEM
JOB TICKET FORM (WORK REQUEST)-THREE MILE ISLAND

UNIT 1

1401-4.4

RECOMMENDED
PRIORITY 6-2

COMPONENT DESIGNATION										LOCATION/UNIT		JOB TYPE	JOB TICKET NUMBER	REQUEST DATE							
5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	
RC	H									03	50	01	CM								

0754 LOWER MAINWAY BOLTS HAVE BEEN REMOVED
BUILT UP INDICATING PROBLEM LEAKAGE. RE
MOVE CLEAN AND REINSTALL

DESCRIBE
MALFUNCTION
OR
MODIFICATION
DESIRED

CAUSE OF
MALFUNCTION
(IF KNOWN)

ORIGINATOR'S EMP. NO.	SUPERVISOR'S EMP. NO.
04680	04680
ORIGINATOR'S SIGNATURE	SUPERVISOR'S SIGNATURE
<i>[Signature]</i>	<i>[Signature]</i>
DATE	DATE
10/21	10/21

WORK ORDER NUMBER		GC CODE	ACCOUNT NUMBER	PLANT CONDITION		NPRO FAILURE		START	
LOCATION	SERIAL			SU	OP	MO	CO	RE	HS/LR
0350	00187	08	5302	00	01	1			
CHANGE MOD REQ'D	3	WUC SAFETY	NP RD	REG AGENCY CODE	CHG/MOD NUMBER	TAGGING APPLICATION NO.	ENV CODE	OUTAGE CAUSE CODE	STATUS HOLD CODE
0110							X		
								ESTIMATED DOLLARS	
								1920	

S/M APPROVAL COMMENCE WORK			S/F APPROVAL COMMENCE WORK			PROCEDURE NUMBER			RESP. LOCATION OR CONTRACTOR			EST. CREW SIZE			EST. MANHOURS		
MO	DAY	YR	MO	DAY	YR												
10	20	86	10	20	86	200867			200867			128					

JOB COMPLETION DATE			FIELD WORK COMPLETION DATE			SIGN OFF REASON CODE			TOTAL ACTUAL MANHOURS			PURCHASE REQUISITION NUMBER			PURCHASE ORDER NUMBER			MATERIAL ORDER NUMBER		
MO	DAY	YR	MO	DAY	YR															
10	20	86	10	20	86	0725801			256.3											

RESOLUTION DESCRIPTION																		
07 MAINWAY BOLTS HAVE BEEN REMOVED CLEANED																		
08 & REINSTALLED & TORQUED TO 3RD SEQUENCE.																		
09																		
10																		

NPRO FAILURE END					FAILURE NO.		FAILURE STATUS		ORIGINATOR — SUPERVISOR — SUPERVISOR OF MAINTENANCE — MAINTENANCE FOREMAN — JOB PERFORMER — MAINTENANCE FOREMAN — SUPERVISOR OF MAINTENANCE — CM COORDINATOR — DATA ENTRY — SUPERVISOR OF MAINTENANCE CM COORDINATOR — DATA ENTRY									
YR	MO	DAY	HR	MIN	48	49	50											
10	20	86																

NPRO FAIL TYPE		NPRO FAIL MODE		CAUSE OF FAILURE CODES		EFFECT OF FAILURE CODES		FAILURE DESCRIPTION CODE		ACTION TAKEN CODES		LICENSE EVENT REPORTED DATE	
39	40	41	42	43	44	45	46	47	48	49	50	51	52

TXN CD	A CT
307A	

TXN CD	A CT
801A	
801A	
801A	
801A	

TXN CD	A CT
808A	

TXN CD	A CT
308A	

6-3

JOB TICKET (WORK REQUEST)
REVIEW - CLASSIFICATION - ROUTING CONTROL FORM

JOB TICKET NUMBER

1. Does work represent a change or modification to an existing system or component?
If yes, an approved change modification is required per AP 1021.
C/M No. Yes No ✓
- 2a. Does work require an RWP Yes ✓ No
- 2b. Is an approved procedure required to minimize personnel exposure. Yes No
- 3a. Is work on a QC component as defined in GP 1008. Yes ✓ No
- 3b. If 3a is yes does work have an effect on Nuclear Safety? If 3b is yes,
PORC reviewed Superintendent approved procedure must be used. Yes ✓ No
4. Agreement that a PORC reviewed, Superintendent approved procedure is not required for this work because
it has no effect on nuclear safety. (Applies only if 3a is Yes and 3b is No).

1401-144

Unit Superintendent

Date

- 5a. Is the system on the Environmental Impact list in AP 1025 Yes No ✓
- 5b. If 5a is Yes, is an approved procedure required to limit environmental impact Yes No
6. Agreement that 5b is No. (Required only if 5a is Yes).

Unit Superintendent/Supervisor of Operations

Date

7. Plant status or prerequisite conditions required for work. Shutdown
8. QC Dept. review, if required in item No. 3

QC Supervisor

Robert H. Prince

Date

5/24/80

CODE INSP. REQUIRED? YES NO ✓

9. Supervisor of Maintenance approval to commence work:

Date

5/30/80

10. Maintenance Foreman Assigned:


W. J. Miller 6-18-80

11. Shift Foreman's approval to commence work

W. J. Miller

Date

6-18-80



Initial if Shift
Foreman

signature is not required

Radiation Work Permit No.

6-4

JOB TICKET (WORK REQUEST)
REVIEW - CLASSIFICATION - ROUTING CONTROL FORM

JOB TICKET (WORK REQUEST) NUMBER _____

12. Retest met acceptance criteria

Yes

☐

No

☐

13. Work Performed by date/time

Work Reviewed - Maintenance Foreman's Signature

Date

14. Work completed and component aligned for testing.

☐

Initial if S. F. signature is not required.

Shift Foreman's Signature

Date

15. Testing completed and component released for normal use.

☐

Initial if S. F. signature is not required.

Shift Foreman's Signature

Date

16. Quality Control Department review of work and testing completed (QC work only).

Surveillance Report No.

QC Department

Date

17. Supervisor of Maintenance Job Ticket (Work Request) and procedure are complete and signed off as required. Change/modification form has been signed off as required.

Supervisor of Maintenance Signature

Date

In accordance with the terms, conditions, and provisions of General Maintenance Contract, Met-Ed P.O. #38735, Catalytic, Inc. is hereby authorized to perform the work described on Work Request No. 2798 attached hereto and forming a part hereof.

Acceptance:

Date:

6/3/80

Supervisor of Maintenance U-1

D. V. DYCKMAN

Date:

6/17/80

MET-ED BY: (Print Name, Title & Initial)

Bede T. Portz Planner B.T.P.

CATALYTIC, INC. By: (Print Name, Title & Initial)

cc: M. R. Dendler

WORK COMPLETED BY CATALYTIC, INC.

The attached Work Request # 1-2798

JO # 11,095

has been completed and hereby returned as noted below.

Remarks:

Torqued to the third stage then returned to Met-Ed.

Bede T. Portz 10/2/80
Planning Department

POOR ORIGINAL

INTER-OFFICE MEMO

CATALYTIC, INC.

C-337

DATE: 9/11/80

TO: Dennis Dyckman

AT Met-Ed

FROM: E. Faust

AT Catalytic Unit 1

COPY TO:

SUBJECT: Work Requests

As per your note of 9/9/80, the following Work Requests have previously been copied & returned to your office. I have copied only the cover page and first page of them:

C2310 - 10,887	C3214 - 11,089
C2309 - 10,888	23019 - 10,238
C2508 - 11,037	22651 - 10,348
C2505 - 11,007	C3181 - 11,080
C2577 - 11,049	

If you need a copy of the complete package of the above listed Work Requests please advise.

A complete copy of the next list is being sent to you. These Work Requests are in our open files. Are they to be closed and returned to you?

C2798 - 11,095	C3854 - 11,112
C1871 - 10,777	C3181 - 11,080
C3201 - 11,092	C3068 - 11,065
C3251 - 11,088	

Complete copies of this next list are being sent to you and I have closed them out of our open file with the exception of Work Request #04875 which I show no record of having and #C3202 - 11,084 which was closed previously and copies already sent to your office.

C2619 - 11,004	C1925 - 10,774
04875 - No	C2091 - 10,803
C3007 - 11,077	C2557 - 11,034
C2451 - 11,002	C3090 - 11,069
22120 - 10,856	C3202 - 11,084 (prev. closed)
C1624 - 10,745	C3592 - 11,102


Eileen Faust

EF/sk