LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

LICENSEE CODE	LICENSE NUMBER	LICENSE TYPE	CAT
C A H M B I (2)	0 0 - 0 0 0 0 0 - 0 0 (3)	4 1 1 1 1 (4)	(5)

REPORT SOURCE: L (6) | DOCKET NUMBER: 0 5 0 0 0 1 3 3 (7) | EVENT DATE: 1 2 2 2 8 0 (8) | REPORT DATE: 0 1 2 1 8 1 (9)

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

With the nuclear unit shutdown, a breaker supplying electrical power to one of four screen wash pumps in adjacent fossil units failed. The tip of a movable contact had broken off. These pumps are backup sources of cooling water to the Suppression Pool Cooler. All four pumps have the same type breaker. This is reportable under T.S. IX. I.2.b.(2), and has been the subject of LERs 80-03 and 80-04. There were no adverse effects from this event; alternate cooling sources were available even though not needed because of the length of shutdown (4 years).

SYSTEM CODE	CAUSE CODE	CAUSE SUBCODE	COMPONENT CODE	COMP. SUBCODE	VALVE SUBCODE
E B (11)	E (12)	A (13)	C K T B R K (14)	B (15)	Z (16)

(17) LER/RO REPORT NUMBER

EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE	REPORT TYPE		REVISION NO.
8 0	—	0 0 8	/	0 3	L	—	0

ACTION TAKEN	FUTURE ACTION	EFFECT ON PLANT	SHUTDOWN METHOD	HOURS (22)	ATTACHMENT SUBMITTED	NPRD-4 FORM SUB.	PRIME COMP. SUPPLIER	COMPONENT MANUFACTURER
A (18)	C (19)	Z (20)	Z (21)	0 0 0 0	N (23)	N (24)	A (25)	G 0 8 0 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

Contacts are believed to have failed from shock of repeated cycling (breaker was over 22 years old). Breaker is G.E. Type AK-1-15; contact part number 6372777G1. Contacts were replaced. Final action is to replace all such breakers with newer model prior to power operation.

FACILITY STATUS	% POWER	OTHER STATUS (30)	METHOD OF DISCOVERY	DISCOVERY DESCRIPTION (32)
G (28)	0 0 0 (29)	N/A	A (31)	Operator observation

ACTIVITY RELEASED	CONTENT OF RELEASE	AMOUNT OF ACTIVITY (35)	LOCATION OF RELEASE (36)
Z (33)	Z (34)	N/A	N/A

PERSONNEL EXPOSURES

NUMBER	TYPE	DESCRIPTION (39)
0 0 0 (37)	Z (38)	N/A

PERSONNEL INJURIES

NUMBER	DESCRIPTION (41)
0 0 0 (40)	N/A

LOSS OF OR DAMAGE TO FACILITY (43)

TYPE	DESCRIPTION
Z (42)	N/A

PUBLICITY

ISSUED	DESCRIPTION (45)	NRC USE ONLY
N (44)	N/A	

420

NAME OF PREPARER B. C. Getty PHONE: (707) 443-2787

GPO 817-926