NRC FORM 366
(7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | NDCCN2 (2) | 00-0000-00 (3) | 41111 (4) | (5)
LICENSEE CODE — LICENSE NUMBER — LICENSE TYPE — CAT

CON'T 01 | REPORT SOURCE L (6) | 05000318 (7) | 011881 (8) | 012981 (9)
DOCKET NUMBER — EVENT DATE — REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 At 0847 with the Reactor Coolant System (RCS) at 220 degrees F and 230
03 psia, a pressure transmitter failed high causing power relief valve RC-
04 404-ERV to open. After the operator verified the open valve, he closed
05 the blocking valve terminating the discharge. The relief valve was
06 open ≤1 minute and RCS pressure decreased ≤ than 6 psi. This report
07 is being made per I&E inspection report 317-79-23. This is not a repet-
08 itive occurrence.

09 SYSTEM CODE IE (11) | CAUSE CODE A (12) | CAUSE SUBCODE C (13) | COMPONENT CODE INSTRU (14) | COMP. SUBCODE T (15) | VALVE SUBCODE Z (16)

(17) LER/RO REPORT NUMBER: EVENT YEAR 81 — SEQUENTIAL REPORT NO. 005 — OCCURRENCE CODE 01 — REPORT TYPE T — REVISION NO. 0

ACTION TAKEN H (18) | FUTURE ACTION Z (19) | EFFECT ON PLANT Z (20) | SHUTDOWN METHOD Z (21) | HOURS (22) 0000 | ATTACHMENT SUBMITTED Y (23) | NPRD-4 FORM SUB. N (24) | PRIME COMP. SUPPLIER N (25) | COMPONENT MANUFACTURER F120 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 The cause of the event was a loose oscillator/amplifier assembly within
11 transmitter 2-PT-103-1 (F&P Co. 50EP1041BCNS). The assembly mounting
12 screws were found loose and intermittent contact through its connector
13 caused signal current to increase driving controller 2-PIC-101-1 to maxi-
14 mum pressure indication. No reoccurrence since mounting screws tightened.

15 FACILITY STATUS 0 (28) | % POWER 000 (29) | OTHER STATUS (30) NA | METHOD OF DISCOVERY A (31) | DISCOVERY DESCRIPTION (32) Operator Observation

16 ACTIVITY RELEASED Z (33) | CONTENT OF RELEASE Z (34) | AMOUNT OF ACTIVITY (35) NA | LOCATION OF RELEASE (36) NA

17 PERSONNEL EXPOSURES NUMBER 000 (37) | TYPE Z (38) | DESCRIPTION (39) NA

18 PERSONNEL INJURIES NUMBER 000 (40) | DESCRIPTION (41) NA

19 LOSS OF OR DAMAGE TO FACILITY TYPE Z (42) | DESCRIPTION (43) NA

20 PUBLICITY ISSUED N (44) | DESCRIPTION (45) NA | NRC USE ONLY

NAME OF PREPARER S.M. Davis PHONE: (301) 269-4742

GPO 917-926

8102030426