

SOUTH CAROLINA ELECTRIC & GAS COMPANY

POST OFFICE BOX 764

COLUMBIA, SOUTH CAROLINA 29218

January 28, 1981

T. C. NICHOLS, JR.  
VICE PRESIDENT AND GROUP EXECUTIVE  
NUCLEAR OPERATIONS

Mr. James P. O'Reilly, Director  
U. S. Nuclear Regulatory Commission  
Region II, Suite 3100  
101 Marietta Street, N. W.  
Atlanta, Georgia 30303

Subject: Virgil C. Summer Nuclear Station  
Docket No. 50/395  
Potential Reportable Item  
NE File 3.1051

Dear Mr. O'Reilly:

This letter is confirmation of a phone conversation with Mr. John K. Rausch of NRC Region II and Mr. J. A. Wactor, January 26, 1981. It was reported to Mr. Rausch that the item reported to him as a potential significant deficiency under the topic "Failure to Inspect Conduit Supports" had been determined to be not reportable. The item was originally reported by phone December 2, 1980, and an interim report was made by letter dated December 23, 1980.

The item involved a failure to inspect certain seismic designed conduit supports used on non-safety related conduits. The conduits involved have been inspected and it was determined that they would not fall and damage any safety related equipment.

This item is considered to be closed.

Very truly yours,

*T. C. Nichols, Jr.*  
T. C. Nichols, Jr.

JAW:TCN:glb

cc: B. A. Bursey  
V. C. Summer  
G. H. Fischer  
W. A. Williams, Jr.  
T. C. Nichols, Jr.  
E. H. Crews, Jr.  
H. N. Cyrus  
D. A. Nauman  
O. S. Bradham  
O. W. Dixon, Jr.

J. B. Knotts, Jr.  
R. B. Clary  
A. R. Koon  
A. A. Smith  
I&E (Washington)  
Document Management Branch  
(55e/21/LER Only)  
NPCF/Whitaker  
File

8102030465

Boia 7/10