

OPERATING DATA REPORT

Rev. 1 - 1/22/81

DOCKET NO. 50-346  
 DATE December 8, 1980  
 COMPLETED BY Bilal Sarsour  
 TELEPHONE 419-259-5000, Ext. 251

OPERATING STATUS

1. Unit Name: Davis-Besse Unit 1
2. Reporting Period: November, 1980
3. Licensed Thermal Power (MWt): 277.2
4. Nameplate Rating (Gross MWe): 925
5. Design Electrical Rating (Net MWe): 906
6. Maximum Dependable Capacity (Gross MWe): 934
7. Maximum Dependable Capacity (Net MWe): 890
8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons:

Notes

9. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_
10. Reasons For Restrictions, If Any: \_\_\_\_\_

	This Month	Yr.-to-Date	Cumulative
11. Hours In Reporting Period	720	8,040	28,565
12. Number Of Hours Reactor Was Critical	684.7	2,762.7	13,726.7
13. Reactor Reserve Shutdown Hours	6.3	6.3	2,882.1
14. Hours Generator On-Line	530.8	2,539.5	12,413.8
15. Unit Reserve Shutdown Hours	3.42	3.42	1,731.42
16. Gross Thermal Energy Generated (MWH)	1,012,290	5,699,595	25,899,102
17. Gross Electrical Energy Generated (MWH)	339,042	1,922,601	8,646,112
18. Net Electrical Energy Generated (MWH)	309,064	1,792,851	7,963,429
19. Unit Service Factor	73.7	31.6	44.1
20. Unit Availability Factor	74.2	31.6	50.6
21. Unit Capacity Factor (Using MDC Net)	48.2	25.1	33.3
22. Unit Capacity Factor (Using DER Net)	47.4	24.6	32.7
23. Unit Forced Outage Rate	10.7	13.6	25.0
24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each):			

25. If Shut Down At End Of Report Period, Estimated Date of Startup: \_\_\_\_\_

26. Units In Test Status (Prior to Commercial Operation):	Forecast	Achieved
INITIAL CRITICALITY	_____	_____
INITIAL ELECTRICITY	_____	_____
COMMERCIAL OPERATION	_____	_____

8102030 590