



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

50-10  
50-237

DEC 15 1980

LS05-80-12-035

LETTER FOR ALL SEP LICENSEES

STANDARD DOCUMENT FILE COPY

SUBJECT: GUIDELINES FOR SEP SOIL-STRUCTURE INTERACTION  
REVIEWS

Enclosed for your information are guidelines for performing soil-structure interaction reviews for SEP facilities. Also included is a simplified analytical approach for evaluating the effects of soil-structure interaction using a lumped parameter model. The simplified approach presented does not preclude the use of other procedures which would be reviewed and approved on a case-by-case basis.

Sincerely,

*Dennis M. Crutchfield*  
Dennis M. Crutchfield, Chief  
Operating Reactors Branch #5  
Division of Licensing

Enclosure: SSRT Guidelines  
for SEP Soil-Structure  
Interaction Review

cc: See next page

DEC 15 1980

RECEIVED

8102040003  
P

Mr. J. S. Abel

DRESDEN NUCLEAR POWER  
STATION, UNIT NO. 2  
DJCKET NO. 50-237

C:  
Isham, Lincoln & Beale  
Counselors at Law  
One First National Plaza, 42nd Floor  
Chicago, Illinois 60603

Mr. B. B. Stephenson  
Plant Superintendent  
Dresden Nuclear Power Station  
Rural Route #1  
Morris, Illinois 60450

Natural Resources Defense Council  
917 15th Street, N. W.  
Washington, D. C. 20005

U. S. Nuclear Regulatory Commission  
Resident Inspectors Office  
Dresden Station  
RR #1  
Morris, Illinois 60450

Susan N. Sekuler  
Assistant Attorney General  
Environmental Control Division  
188 W. Randolph Street  
Suite 2315  
Chicago, Illinois 60601

Morris Public Library  
604 Liberty Street  
Morris, Illinois 60451

Chairman  
Board of Supervisors of  
Grundy County  
Grundy County Courthouse  
Morris, Illinois 60450

John F. Wolfe, Esquire  
3409 Shepherd Street  
Chevy Chase, Maryland 20015

Dr. Linda W. Little  
500 Hermitage Drive  
Raleigh, North Carolina 27612

Department of Public Health  
ATTN: Chief, Division of  
Nuclear Safety  
535 West Jefferson  
Springfield, Illinois 62761

Director, Technical Assessment  
Division  
Office of Radiation Programs  
(AW-459)  
U. S. Environmental Protection  
Agency  
Crystal Mall #2  
Arlington, Virginia 20160

U. S. Environmental Protection  
Agency  
Federal Activities Branch  
Region V Office  
ATTN: EIS COORDINATOR  
230 South Dearborn Street  
Chicago, Illinois 60604

Dr. Forrest J. Remick  
305 East Hamilton Avenue  
State College, Pennsylvania 16801

Mr. J. S. Abel  
Director of Nuclear Licensing  
Commonwealth Edison Company  
Post Office Box 767  
Chicago, Illinois 60690

Richard E. Schaffstall, Executive Director  
for SEP Owners Group  
1747 Pennsylvania Avenue, NW  
Washington, D.C. 20006

NATHAN M. NEWMARK  
CONSULTING ENGINEERING SERVICES

1211 CIVIL ENGINEERING BUILDING  
URBANA, ILLINOIS 61801

8 December 1980

Mr. William T. Russell, Chief  
Systematic Evaluation Program Branch  
Division of Licensing  
Office of Nuclear Reactor Regulation  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555 (Mail Stop 516)

Re: SSRT Guidelines for SEP Soil-Structure  
Interaction Review  
Contract NRC-03-78-150

Dear Mr. Russell:

The Guidelines for SEP Soil-Structure Interaction  
Review, as prepared by the Senior Seismic Review Team, are trans-  
mitted herewith with signature approval.

We are appreciative of the help of the many individuals  
who contributed to the preparation of these guidelines.

Sincerely yours,

*N. M. Newmark*

N. M. Newmark  
Chairman, SSRT

dp  
Enclosure

Distribution:

W. T. Russell - 2  
T. Cheng - 1  
N. M. Newmark - 2  
W. J. Hall - 1  
R. P. Kennedy - 1  
R. Murray - 1  
J. D. Stevenson - 1

RECEIVED DISTRIBUTION  
SERVICES UNIT

DEC 10 PM 12 55

MISC

8012110 291

Dupe

MISC

X003  
5/11

December 8, 1980

## SSRT GUIDELINES FOR SEP SOIL-STRUCTURE INTERACTION REVIEW

### Background

When a structure is founded within or on a base of soil, it interacts with its foundation. The forces and displacements transmitted to the structure and the feedback to the foundation regions are complex in nature; the interactions that take place modify the free-field motions. Many methods for dealing with soil-structure interaction have been proposed by a number of writers. These methods can be classified in various ways and involve generally: (1) procedures similar to those applicable to a rigid block on an elastic half-space; (2) finite element or finite difference procedures corresponding to various forcing functions acting on the combined structure-soil complex; and (3) substructure modeling techniques that may or may not include use of the direct finite element method. Another, and perhaps more convenient, classification of soil-structure interaction analysis procedures is that of (a) direct solution techniques and (b) substructure solution techniques as described in the report entitled "Recommended Revisions to Nuclear Regulatory Commission Seismic Design Criteria", Report NUREG/CR-1161, May 1980.

The elastic half-space theory considers a foundation plate resting on an elastic medium with harmonic oscillation applied to the plate; the few test results available to date in general have been obtained for this type of model in this excitation condition. This concept is the basis for the first of the three procedures described above, although for seismic excitation the problem is the inverse of the original problem formulation

in that the excitation originates in the earth. The other two methods noted also involve modeling of the structure-soil system; as such the system has intrinsic properties reflecting the make-up of the modeled system, physical properties, and especially the boundaries (for example, as they affect motion input, and reflection).

These analysis methods represent major advances in computational ability, but unfortunately all the techniques have limitations, and in many cases are not well understood. At present their use involves a great deal of interpretive judgment.

One principal difficulty with all of the techniques is associated with the handling of the ground input. Except for special long period waves, in most cases the ground motion is noncoherent and nonuniform. Thus far it appears that the analysis models may not be able to handle a broad spectrum of complex wave motions. None of the techniques adequately handle nonlinear effects, which are known to be of importance. As yet no good confirmatory comparison basis exists between field observations and computations made prior to an earthquake.

This entire topic is one that requires the most careful consideration. Exercise of judgment as to the meaning of the results, in the light of the comments given above, is required. Reliance on any sole approach is to be avoided.

#### SEP Review Guideline Recommendations

In keeping with the SEP approach to review existing facilities, and as reflected in the philosophy and criteria developed to date, it appears

desirable to outline briefly one technical procedure for estimating soil-structure interaction effects. As a result of extensive discussions between members of the SSRT and the NRC/LLL staff, and with recognition of the many uncertainties and complexities of the topic under consideration, the general approach presented below is recommended at this time as a guideline. It will be appreciated that many decisions will have to be made as a part of the calculational procedures described below and the exercise of judgment obviously will be required. Justification and documentation are necessary parts of the final analysis product.

At the outset it should be noted that the simplified approach described below is not intended to preclude the use of any other procedures. The structural input motions (at the foundation level), however developed and justified, under no conditions shall correspond to less than 75 percent of the defined control motions (normally taken as the free-field surface motions); if a reduction in translational input motion is employed, then the rotational components of motion also should be included. If other procedures are employed they should be reviewed on a case-by-case basis.

For purposes of SEP review, one simplified approach for evaluating the effects of soil-structure interaction, involving a lumped parameter model, is deemed to be acceptable when employed under the following conditions.

1. The control motions are defined as the free-field surface motions and are input at the structure foundation level.
2. The soil stiffness, as represented by springs anchored at the

foundation level, shall be modeled as follows.

i) To account for uncertainty in soil properties, the soil stiffnesses (horizontal, vertical, rocking and torsional) employed in analysis shall include a range of soil shear moduli bounded by (a) 50 percent of the modulus corresponding to the best estimate of the large strain condition, and (b) 90 percent of the modulus corresponding to the best estimate of the low strain condition. For purposes of structural analysis three soil modulus conditions generally will suffice corresponding to (a) and (b) above, and (c), a best estimated shear modulus.

For structural capacity review the analyst generally should employ the worst case condition. For equipment review the in-structure response spectra shall be taken as a smoothed envelope of the resulting spectra from these three analyses.

ii) When embedment is to be considered it is recommended that the soil resistances (stiffnesses as noted above) shall correspond to 50 percent of the theoretical embedment effects. This reduction is intended to account for changes in soil properties arising from backfilling, and any gap effects.

iii) Where it is judged necessary to model the supporting soil media as layered media, the stiffnesses are to be estimated through use of acceptable procedures.

3. The radiation and material energy dissipation (i.e., the damping values) are considered to be additive for computation convenience. Normally the material damping can be expected to be about 5 to 8 percent.

The geometric damping (radiation energy dissipation) is recognized to be frequency-dependent. However, in order to reduce the calculational



effort (at least initially), and to be sure that excessive damping is not employed, it is recommended that values of damping be estimated theoretically (on a frequency-independent basis) as follows.

i) Horizontal to be taken as 75 percent of the theoretical value.\*

ii) Vertical to be taken as 75 percent of the theoretical value.\*

iii) Rotation (rocking and torsional) to be taken at 100 percent of the theoretical value.\*

In the case of layered systems the approach employed in establishing these values needs to be justified.

4. The following analysis approaches are considered to be acceptable.

i) When all composite modal damping ratios\*\* are less than 20 percent, modal superposition approaches can be used without any validation check.

ii) If in investigating the use of modal superposition approaches it is ascertained that a composite modal damping ratio\*\* exceeds 20 percent, one must perform a validation analysis. To perform this validation, it is generally acceptable to use a time-history analysis in which the energy dissipation associated with the structure is included with the structural elements, and that associated with the soil is included with the soil elements.

---

\*As calculated by generally accepted methods, as for example given in the book *Vibrations of Soils and Foundations*, by F. E. Richart, Jr., J. R. Hall, Jr., and R. D. Woods, Prentice-Hall Inc., 1970.

\*\*As defined by generally accepted methods.



In-structure response spectra obtained from a modal superposition analysis employing composite modal damping throughout the frequency range of interest must be similar to or more conservative than those obtained from the validation analyses.

It is emphasized that the aforementioned procedures are intended to be guidelines and may be subject to revision as experience is gained under the SEP Program in attempting to arrive at relatively economical and simplified techniques for estimating the possible effects of soil-structure interaction.

Respectfully submitted by the Senior Seismic Review Team:

N. M. Newmark

N. M. Newmark, Chairman

W. J. Hall

W. J. Hall

Robert P. Kennedy

R. P. Kennedy

Robert C. Murray

R. C. Murray

J. D. Stevenson

J. D. Stevenson