

MINRO REGIONAL  
ATLANTA, GA 30303

DEC 22 12:42

**Florida  
Power**  
CORPORATION

December 18, 1980  
3-0-3-a-2  
CS-80-290  
3-120-31

Mr. J. P. O'Reilly, Director  
Office of Inspection & Enforcement  
U.S. Nuclear Regulatory Commission  
Atlanta, GA 30303

Docket No. 50-302  
Licensee No. DPR-72  
Ref: 80-33/RII:TFS  
50/302/80-33

Dear Mr. O'Reilly:

We offer the following responses to the Items of Noncompliance in the referenced report.

NOTICE OF VIOLATION

- A. Based on the NRC inspection September 2 - October 3, 1980, certain of your activities were apparently not conducted in full compliance with NRC requirements as indicated below:
- a. The intent of the original procedure is not altered.
  - b. The change is approved by two members of the plant staff management staff, at least one of whom holds a Senior Reactor Operator's License on the unit affected.
  - c. The change is documented, reviewed by the PRC and approved by the Nuclear Plant Manager within 14 days of implementation.

Contrary to the above, on April 12, 1980, a temporary change was made to Surveillance Procedure SP-161, Remote Shutdown Instrument Calibration, without the approval of two members of the plant management staff and was not reviewed by the PRC and approved by the Nuclear Plant Manager within 14 days of implementation.

- A. Response: As a result of this event, appropriate plant procedures have been reviewed with the cognizant supervisors to assure their understanding of the consequences of noncompliance with procedures.

A modification (80-9-76) has been initiated to install 0-3000 psig pressure gauges in place of the 0-2000 psig gauges. In addition, a revision will be submitted to Surveillance Procedure SP-161, Remote Shutdown Instrumentation Calibration to change the appropriate

8102040 348

Notice of Violation Response  
Ref: 80-33/RII:TFS  
Page 2


pressure indicator calibration sheets to conform to the higher range gauges.


Full compliance will be achieved upon procurement of the gauges which is anticipated prior to 1 May 1981.

Should you have any further questions, please contact us.

Very truly yours,

FLORIDA POWER CORPORATION

  
\_\_\_\_\_  
Nuclear Plant Manager

  
J. A. Hancock  
Assistant Vice President  
Nuclear Operations

KFL/rc