

LICENSEE EVENT REPORT

CONTROL BLOCK: \_\_\_\_\_ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 N Y J A F I 2 0 0 - 0 0 0 0 - 0 0 0 3 4 1 1 1 1 4 5  
7 8 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 31 CAT 58

CON'T  
0 1 REPORT SOURCE L R 6 0 5 0 0 0 3 3 3 7 0 6 1 0 8 0 8 0 2 0 2 8 1 9  
7 8 9 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

0 2 | During normal shutdown and during surveillance testing, following routine  
0 3 | preventive maintenance work, Emergency Diesel Generator C tripped on high  
0 4 | circulating current. Subsequent tests could not duplicate the problem.  
0 5 | The other EDG system was operable meeting TS 3.9.D requirements. The event  
0 6 | did not represent a significant hazard to the public health and safety.  
0 7 |  
0 8 |

0 9 SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE CCAP SUBCODE VALVE SUBCODE  
E E 11 E 12 A 13 C K T B R K 14 E 15 Z 16  
17 LER NO REPORT NUMBER 18 EVENT YEAR 19 SEQUENTIAL REPORT NO. 20 OCCURRENCE CODE 21 REPORT TYPE 22 REVISION NO.  
8 0 0 5 6 0 3 X 1  
23 ACTION TAKEN 24 FUTURE ACTION 25 EFFECT ON PLANT 26 SHUTDOWN METHOD 27 HOURS 28 ATTACHMENT SUBMITTED 29 NRC-4 FORM 305 31 PRIME COMP SUPPLIER 32 COMPONENT MANUFACTURER  
C Z Z Z 0 0 0 0 N N N C 7 7 0  
33 34 35 36 37 38 39 40 41 42 43 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

1 0 | The cause was due to high resistance contacts on the regulatory droop switch  
1 1 | resulting in trip. This determination was made following a recurrence on 1/6/81  
1 2 | (See LER 81-004). Switches were replaced. No additional action is required.  
1 3 |  
1 4 |

1 5 FACILITY STATUS 16 % POWER 17 OTHER STATUS 18 METHOD OF DISCOVERY 19 DISCOVERY DESCRIPTION 20  
G 0 0 d NA B Surveillance  
21 ACTIVITY RELEASED 22 CONTENT OF RELEASE 23 AMOUNT OF ACTIVITY 24 LOCATION OF RELEASE 25  
Z Z NA NA  
26 PERSONNEL EXPOSURES 27 NUMBER 28 TYPE 29 DESCRIPTION 30  
0 0 0 Z NA  
31 PERSONNEL INJURIES 32 NUMBER 33 DESCRIPTION 34  
0 0 0 NA  
35 LOSS OF OR DAMAGE TO FACILITY 36 TYPE 37 DESCRIPTION 38  
Z NA  
39 PUBLICITY ISSUED 40 DESCRIPTION 41  
N NA

NRC USE ONLY