

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401  
1750 Chestnut Street Tower II

February 20, 1981

POOR ORIGINAL

Mr. James P. O'Reilly, Director  
U.S. Nuclear Regulatory Commission  
Office of Inspection and Enforcement  
Region II  
101 Marietta Street, Suite 3100  
Atlanta, Georgia 30303

Dear Mr. O'Reilly:

TENNESSEE VALLEY AUTHORITY - BROWNS FERRY NUCLEAR PLANT UNIT 3 - DOCKET  
NO. 50-296 - FACILITY OPERATING LICENSE DPR-68 - REPORTABLE OCCURRENCE  
REPORT BFRO-50-296/8107

The enclosed report provides details concerning the setpoint for 3-PS-1-76  
which was found to be 0.7 percent below Technical Specification 3.2.A  
limits. This report is submitted in accordance with Browns Ferry unit 3  
Technical Specification 6.7.2.b(1).

Very truly yours,

TENNESSEE VALLEY AUTHORITY

H. J. Green  
Director of Nuclear Power

Enclosure (3)  
cc (Enclosure):  
Director (3)  
Office of Management Information and Program Control  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555

Director (40)  
Office of Inspection and Enforcement  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555

Mr. Bill Lavallee  
Nuclear Safety Analysis Center  
Palo Alto, California 94303

Mr. R. F. Sullivan, NRC Inspector, Browns Ferry

A002  
S  
1/1

S

81022504(2)

An Equal Opportunity Employer