

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | N | Y | J | A | F | I | 2 | 0 | 0 | - | 0 | 0 | 0 | 0 | - | 0 | 0 | 0 | 3 | 4 | 1 | 1 | 1 | 1 | 4 | 5

CON'T
01 | REPORT SOURCE | L | 6 | 0 | 5 | 0 | 10 | 10 | 3 | 3 | 3 | 7 | 0 | 1 | 2 | 0 | 8 | 1 | 3 | 0 | 2 | 1 | 9 | 8 | 1 | 9

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 | INTERIM REPORT: During normal shutdown it was discovered that the off gas vent
03 | pipe (stack) sample pumps had been off since a loss of instrumentation power
04 | about 72 hours earlier. While power had been restored within 10 minutes, the
05 | sample pump control circuit does not automatically restart the pumps. The
06 | power loss also resulted in a scram which placed the plant in a hot shutdown
07 | condition as required by Environmental TS 2.3.B.9. No significant hazard
08 | existed.

09 | SYSTEM CODE | M | C | 11 | CAUSE CODE | B | 12 | CAUSE SUBCODE | A | 13 | COMPONENT CODE | Z | Z | Z | Z | Z | Z | 14 | COMP SUBCODE | Z | 15 | VALVE SUBCODE | Z | 16

17 | LER NO REPORT NUMBER | 8 | 1 | 21 | 22 | SEQUENTIAL REPORT NO. | 0 | 1 | 2 | 24 | 26 | OCCURRENCE CODE | 0 | 4 | 28 | 29 | REPORT TYPE | L | 30 | REVISION NO. | 0 | 32
18 | ACTION TAKEN | X | 33 | 19 | FUTURE ACTION | X | 34 | 20 | EFFECT ON PLANT | Z | 35 | 21 | SHUTDOWN METHOD | Z | 36 | 22 | HOURS | 0 | 0 | 0 | 0 | 37 | 40 | 23 | ATTACHMENT SUBMITTED | N | 41 | 24 | NRC-4 FORM SUB. | N | 42 | 25 | PRIME COMP SUPPLIER | Z | 43 | 26 | COMPONENT MANUFACTURER | Z | 9 | 9 | 9 | 44 | 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 | A design deficiency is considered the cause. Immediate corrective action
11 | consisted of starting the sample pumps. Permanent corrective action, in the
12 | form of design changes or procedure changes, remains under evaluation. No
13 | additional action will be required.

14 | _____

15 | FACILITY STATUS | G | 28 | 9 | 10 | % POWER | 0 | 0 | 0 | 29 | 12 | 13 | OTHER STATUS | NA | 30 | 44 | METHOD OF DISCOVERY | A | 31 | 45 | 46 | DISCOVERY DESCRIPTION | Operator Observation | 32 | 48

16 | ACTIVITY RELEASED | Z | 33 | 9 | 10 | CONTENT OF RELEASE | 7 | 34 | 11 | AMOUNT OF ACTIVITY | NA | 35 | 44 | LOCATION OF RELEASE | NA | 36 | 48

17 | PERSONNEL EXPOSURES NUMBER | 0 | 0 | 0 | 37 | 9 | 11 | TYPE | Z | 38 | 12 | DESCRIPTION | NA | 39 | 13 | 48

18 | PERSONNEL INJURIES NUMBER | 0 | 0 | 0 | 40 | 9 | 11 | DESCRIPTION | NA | 41 | 12 | 48

19 | LOSS OF OR DAMAGE TO FACILITY TYPE | Z | 42 | 9 | 10 | DESCRIPTION | NA | 43 | 11 | 48

20 | PUBLICITY ISSUED | N | 44 | 9 | 10 | DESCRIPTION | NA | 45 | 11 | 48

21 | _____