



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

FEB 17 1981

Docket No. 50-370

Duke Power Company
ATTN: Mr. William O. Parker, Jr.
Vice President - Steam Production
P. O. Box 33189
422 South Church Street
Charlotte, North Carolina 28242



Dear Mr. Parker:

SUBJECT: PRESERVICE INSPECTION AND TESTING OF SNUBBERS - MCGUIRE NUCLEAR
STATION, UNIT 2

The Office of Inspection and Enforcement has requested that preservice inspection and test requirements for snubbers be included in the licensing process. Based on this request and the long history of snubber problems as documented by Licensee Event Reports on the subject of inoperable and incorrectly installed snubbers, it is requested that the enclosed requirements to insure snubber operability be implemented at the McGuire Nuclear Station, Unit 2.

Sincerely,

Robert L. Tedesco, Assistant Director
for Licensing
Division of Licensing

Enclosure:
As stated

cc w/enclosure:
See next page

P 8102280469

Mr. William O. Parker, Jr.
Vice President, Steam Production
Duke Power Company
P. O. Box 2178
422 South Church Street
Charlotte, North Carolina 28242

cc: Mr. W. L. Porter
Duke Power Company
P. O. Box 2178
422 South Church Street
Charlotte, North Carolina 28242

Mr. R. S. Howard
Power Systems Division
Westinghouse Electric Corporation
P. O. Box 355
Pittsburgh, Pennsylvania 15230

Mr. E. J. Keith
EDS Nuclear Incorporated
220 Montgomery Street
San Francisco, California 94104

Mr. J. E. Houghtaling
NUS Corporation
2536 Countryside Boulevard
Clearwater, Florida 33515

Mr. Jesse L. Riley, President
The Carolina Environmental Study Group
854 Henley Place
Charlotte, North Carolina 28207

J. Michael McGarry, III, Esq.
Debevoise & Liberman
1200 Seventeenth Street, N. W.
Washington, D. C. 20036

Robert M. Lazo, Esq., Chairman
Atomic Safety and Licensing Board
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Dr. Emmeth A. Luebke
Atomic Safety and Licensing Board
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Dr. Cadet H. Hand, Jr., Director
Bodega Marine Lab of California
P. O. Box 247
Bodega Bay, California 94923

Richard P. Wilson, Esq.
Assistant Attorney General
State of South Carolina
2600 Bull Street
Columbia, South Carolina 29201

Office of Intergovernmental Relations
116 West Jones Street
Raleigh, North Carolina 27603

County Manager of Mecklenburg County
720 East Fourth Street
Charlotte, North Carolina 28202

U. S. Environmental Protection Agency
ATTN: EIS Coordinator
Region IV Office
345 Courtland Street, N. W.
Atlanta, Georgia 30308

Mr. Tom Donat
Resident Inspector McGuire NPS
c/o USNRC
Post Office Box 216
Cornelius, North Carolina 28031

Shelly Blum, Esquire
1402 Vickers Avenue
Durham, North Carolina 27707

TO ALL APPLICANTS:

Due to a long history of problems dealing with inoperable and incorrectly installed snubbers, and due to the potential safety significance of failed snubbers in safety related systems and components, it is requested that maintenance records for snubbers be documented as follows:

Pre-service Examination

A pre-service examination should be made on all snubbers listed in tables 3.7-4a and 3.7-4b of Standard Technical Specifications 3/4.7.9. This examination should be made after snubber installation but not more than six months prior to initial system pre-operational testing, and should as a minimum verify the following:

- (1) There are no visible signs of damage or impaired operability as a result of storage, handling, or installation.
- (2) The snubber location, orientation, position setting, and configuration (attachments, extensions, etc.) are according to design drawings and specifications.
- (3) Snubbers are not seized, frozen or jammed.
- (4) Adequate swing clearance is provided to allow snubber movement.
- (5) If applicable, fluid is to the recommended level and is not leaking from the snubber system.
- (6) Structural connections such as pins, fasteners and other connecting hardware such as lock nuts, tabs, wire, cotter pins are installed correctly.

If the period between the initial pre-service examination and initial system pre-operational test exceeds six months due to unexpected situations, re-examination of items 1, 4, and 5 shall be performed. Snubbers which are installed incorrectly or otherwise fail to meet the above requirements must be repaired or replaced and re-examined in accordance with the above criteria.

Pre-Operational Testing

During pre-operational testing, snubber thermal movements for systems whose operating temperature exceeds 250° F should be verified as follows:

- (a) During initial system heatup and cooldown, at specified temperature intervals for any system which attains operating temperature, verify the snubber expected thermal movement.
- (b) For those systems which do not attain operating temperature, verify via observation and/or calculation that the snubber will accommodate the projected thermal movement.
- (c) Verify the snubber swing clearance at specified heatup and cooldown intervals. Any discrepancies or inconsistencies shall be evaluated for cause and corrected prior to proceeding to the next specified interval.

The above described operability program for snubbers should be included and documented by the pre-service inspection and pre-operational test programs.

The pre-service inspection must be a prerequisite for the pre-operational testing of snubber thermal motion. This test program should be specified in Chapter 14 of the FSAR.