

NPDES NOTIFICATION
Apparent Difference From Daily Average/Maximum Limitation
February 13, 1981

Plant: Palisades

Permit No: MI-0001457

Outfall Description: Neutralizer Tank Waste
(Outfall 00F)

Outfall No: 800213

Parameter: Suspended Solids

Parameter No: 00530

1. Date of Incident: January 1981.
2. Identification of specific effluent limitation or monitoring requirement affected: Total suspended solids daily average limitation of 30 mg/l.
3. Description of Incident: The following results for total suspended solids were obtained during January 1981:

<u>Date</u>	<u>TSS (mg/l)</u>
1/11/81	70
1/14/81	60
1/25/81	<u>3</u>

Average = 44.33

4. Apparent Cause: The two relatively high values at the beginning of the month appeared to be representative of an isolated occurrence, the cause of which was not apparent.
5. If not immediately corrected, the anticipated time the condition is expected to continue: NA.
6. Corrective Action - The following corrective action was taken or will be taken to reduce, eliminate and prevent recurrence:
 - a. The trend of values improved (decreased) throughout the month.
 - b. Continued scrutiny of the neutralizer tanks operating conditions should aid in anticipating any future difficulties with total suspended solids levels.
7. Additional Comments: NA.
8. Signed: Ronald L Fobes

Ronald L Fobes