

NUCLEAR REGULATORY COMMISSION

ORIGINAL

POOR ORIGINAL

In the Matter of: ADVISORY COMMITTEE ON REACTOR SAFEGUARDS
SUBCOMMITTEE ON ELECTRICAL SYSTEMS

TO REVIEW MATTERS RELATING TO THE
USE OF COMPUTER PROTECTION SYSTEMS

DATE: February 24, 1981 PAGES: 1-253

AT: Washington, D. C.



ALDERSON  REPORTING

400 Virginia Ave., S.W. Washington, D. C. 20024

Telephone: (202) 554-2345

8102260 724

T

TRO4
0/11

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS
SUBCOMMITTEE ON ELECTRICAL SYSTEMS

TO REVIEW MATTERS RELATING TO
THE USE OF COMPUTER PROTECTION SYSTEMS

Nuclear Regulatory Commission
Room 1046
1717 H Street, N. W.
Washington, D. C.

February 24, 1981

The subcommittee convened, pursuant to notice, at

9:00 a.m.

ACRS MEMBERS PRESENT:

- W. KERR, Chairman
- J. C. EBERSOLE
- J. J. RAY

CONSULTANTS PRESENT:

- S. DITTO
- E. EPLER
- W. LIPINSKI

DESIGNATED FEDERAL EMPLOYEE:

R. SAVIO

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

ALSO PRESENT:

- H. ALDERMAN
- F. BOYD
- A. PEARSON
- B. MORRIS
- L. PHILLIPS
- M. SRINIVASAN
- E. KENNEDY
- A. SPINELL
- T. COGBORN
- T. STARR
- T. ROZEK
- B. GILL
- W. MOODY
- E. BROWN

* * *

1 A transcript of the meeting is being kept and will
2 be available by March 12 of 1981.

3 We request that each speaker identify himself and
4 use a microphone.

5 We have received no written comments or requests
6 for oral statements from members of the public.

7 We will proceed with the meeting. We have a
8 proposed agenda and we begin with an executive session
9 according to that agenda. The executive session will be
10 short and indeed I guess part of it has already occurred.

11 The only thing I would add is that this
12 subcommittee in its pursuit of today's review and in further
13 meetings will be examining the philosophy and approach used
14 by the staff in its review of reactor protection systems and
15 reactor control systems in an effort to provide some answers
16 to Mr. Stewart Udall's committee.

17 Mr. Udall has asked us to look at the staff's
18 review practice and philosophy and make some comments. One
19 of our responsibilities today I think will be to further
20 explore that philosophy.

21 Are there any comments or questions on the part of
22 committee members or consultants before we begin our
23 presentation?

24 Mr. Ray.

25 MR. RAY: Is there any intent to make the results

1 of this discussion part of the input to the San Onofre
2 operating license review? Is there any purpose?

3 MR. KERR: Mr. Bender specifically asked that some
4 of the specific topics being looked at today be looked at by
5 this subcommittee as part of that review, yes.

6 Other questions or comments?

7 (No response.)

8 MR. KERR: There being none, I will ask Mr.
9 Kennedy, who is here from Combustion Engineering to begin
10 the presentation.

11 MR. KENNEDY:

12 INTRODUCTORY REMARKS OF
13 ERNIE KENNEDY OF COMBUSTION ENGINEERING

14 MR. KENNEDY: Thank you, Dr. Kerr, and good
15 morning. My name is Ernie Kennedy. I am Manager
16 of Project and Generic Licensing at Combustion Engineering
17 and we are happy to be here today.

18 As you stated, our purpose in being here today is
19 to discuss computer based reactor protective systems. As
20 you are no doubt aware Combustion Engineering from some time
21 has used computer technology in some of the reactor
22 protective functions in our protective systems. Those we
23 have called core protection calculators.

24 We currently have one system operational at
25 Arkansas Nuclear One Unit 2. The second of these systems

1 will be going into operation in San Onofre Unit 2 which
2 currently is before another ACRS subcommittee pending its
3 operating license review.

4 We will in large part direct our presentation and
5 our comments to those two plants since they are of
6 particular interest to you.

7 We have an agenda which I would like to go over
8 very briefly. I am not going to take a lot of your time
9 this morning in introductory remarks.

10 We would like to take some time to compare the
11 core protection calculator system as it currently exists on
12 Arkansas Nuclear One Unit 2 and that being proposed for San
13 Onofre Unit 2 so you will have some base line for relying on
14 our previous discussions on Arkansas.

15 That then would be a convenient point where I
16 would intend to turn the presentation over to a
17 representative from Arkansas Power and Light who is with us
18 today. Arkansas Power and Light will give us the benefit of
19 their experience in operating the core protection calculator
20 system at ANO 2.

21 We would turn to the meeting back over to
22 Combustion Engineering for a discussion of the software, the
23 programming, the change procedures that we have used and are
24 using, the changes which in fact have been incorporated into
25 the system based largely on experience at ANO 2 and then we

1 would turn the meeting back over to you for comments by the
2 NRC staff on the review of the core protection calculators.

3 That is the agenda we have laid out for today and
4 I think we can proceed expeditiously with that. If there
5 are not problems with the agenda I would like to introduce
6 our first speaker.

7 MR. KERR: Let's proceed expeditiously.

8 MR. KENNEDY: Our first speaker is Mr. Al Spinell
9 from Combustion Engineering. Mr. Spinell is the Assistant
10 Project Manager for our San Onofre Units 2 and 3 project at
11 Combustion Engineering. Mr. Spinell will make a few
12 introductory remarks on his objectives and then proceed to a
13 description of the core protection calculators and a
14 comparison of the Arkansas and San Onofre design.

15 Mr. Spinell.

16 PRESENTATION OF AL SPINELL
17 PROJECT MANAGER, SAN ONOFRE UNITS 2 AND 2 PROJECT
18 COMBUSTION ENGINEERING

19 MR. SPINELL: Thank you, Ernie.

20 Good morning gentlemen.

21 Let me make my remarks here stating our overall
22 objectives for this meeting from this position and then I
23 will move up and make my presentation formally using slides
24 on the overhead.

25 Combustion Engineering has five objectives I think

1 this morning or during the day's meeting that we would like
2 to convey to the subcommittee and the consultants and they
3 are as follows.

4 One, we would like to put in perspective the
5 relationship of the CPC trips to the remainder of the plant
6 protective system and to emphasize the backup features that
7 exist in the remainder of the plant protective system which
8 provide alternate protection.

9 Second, we would like to highlight the
10 similarities between the ANO 2 design and the San Onofre
11 design emphasizing that what we are doing for this nth
12 plant, the San Onofre plant, is a relatively small
13 extrapolation of the base line design.

14 Thirdly, we would like to provide an assessment of
15 the CPCS behavior during the first one and a half years
16 approximately of operation at ANO 2.

17 Fourth, we would like to demonstrate that a
18 structured orderly process is in place for design and
19 qualification of the software changes for San Onofre Units 2
20 and 3 and to identify how the ANO 2 experience over the last
21 one and a half years has been factored in to the San Onofre
22 software.

23 Lastly, Combustion would like to highlight the
24 progress that we have made so far in the qualification
25 process for the San Onofre software and its relationship to

1 the licensing documentation which we have prepared for the
2 staff.

3 MR. KERR: That sounds like a reasonable approach
4 and it also sounds as if you have a lot to cover. So the
5 expeditious approach suggested by Mr. Kennedy is in order.

6 (Slide presentation.)

7 My presentation this morning will cover these four
8 topics. What I intend to do first is to cover an overall
9 description of the system. What I intend to do is not
10 present any new information that has been before the
11 subcommittee before but for new members present plus for the
12 members that have been through the Arkansas review it will
13 provide a refresher. I will speed through that process as
14 best as I can striking an optimum approach of what I thought
15 would be relevant here for purposes of the discussion.

16 Secondly, I would like to give a comparison
17 between San Onofre Units 2 and 3 and the Arkansas designs.

18 Third, I want to provide a status of the overall
19 system design qualification and field status of the
20 equipment.

21 Fourth, I want to work in a summary statement with
22 respect to our licensing status and the submittals we have
23 presently into the NRC.

24 (Slide.)

25 The first several slides I have this morning deal

1 with the concept of why we went to digital processing
2 technology. I think they are embodied in three general
3 design criteria for which I don't want to go into in detail
4 but the first of which is general design criterion 10 of 10
5 C.F.R. 50, Appendix A which deals with the protection system
6 requirements and margins required to preserve fuel design
7 limits related to anticipated operational occurrences.

8 (Slide.)

9 These fuel design limits which we are relying upon
10 are defined thusly for reference purposes, a linear heat
11 corresponding to fuel centerline melt and the DNBR equal to
12 1.3 in the case for Arkansas and in the case of San Onofre
13 Unit 2, 1.19 based on CE-1 correlation.

14 (Slide.)

15 This is the second of the three criteria. It
16 embodies our philosophy regarding the core protection
17 calculator system.

18 (Slide.)

19 And the third thusly.

20 (Slide.)

21 Now, over the years we found as well as relating
22 our experiences within the industry and the NRC that there
23 was a considerable discussion and changing opinions and
24 attitudes about the interpretation of those criteria and
25 based on our knowledge and experience in protection system

1 design we felt there were reasons to make changes and the
2 reasons therefor are embodied in the following two examples
3 as I have listed here.

4 For example, with regard to single failures of an
5 active component and inclusion of those as an initiating
6 mechanism for an anticipated operational occurrence.

7 I cite two particular rod related events here
8 which were not afforded direct protect by our protection
9 system but in earlier days by control systems.

10 Secondly, I cite for example the case involving
11 axial flux perturbations as might be caused by certain boron
12 dilution events which were not embodied in part of our
13 earlier protection system design.

14 (Slide.)

15 In order to accommodate those types of changes we
16 felt that there was a potential need for make the protection
17 system more responsive to these requirements.

18 The three things that we felt needed to be
19 embodied in that upgrade of that protection system was that
20 (1) we needed to sense the power distribution with increased
21 accuracy, (2) we needed to include control rod position
22 inputs in a discrete manner and, (3) we needed to provide
23 increased direct line or on-line assessment of the thermal
24 margin of the local power density characteristics dealing
25 with the relevant cooling system parameters.

1 To more effectively implement this we came to the
2 conclusion in the early to mid-'70s that digital processing
3 technology as far as we were concerned could be incorporated
4 into the plant protective system.

5 MR. KERR: Mr. Spinell, in your consideration of
6 these operational features I think I understand the point
7 you are making. I would appreciate your telling me,
8 however, how you decided that these features to which you
9 refer, for example, sense of power distribution with
10 increased accuracy, include measured control rod position as
11 input and so on should become part of the reactor protection
12 system rather than, say, part of the reactor control system.

13 In a sense you are talking about handling the
14 plant in situations which are anticipated to occur during
15 the life of the plant. So that although they are not
16 perhaps the day-to-day operational events, they are events
17 which you expect to occur and which hence the plant needs to
18 be able to handle.

19 How did you decide that the handling of these
20 should be the responsibility of the reactor protection
21 system rather than the responsibility of the reactor control
22 system?

23 MR. SPINELL: Let me try and cite an example that
24 deals with the rod drop event. In our early plant designs
25 initially we typically afforded an overpower margin in the

1 plants that would accommodate a rod drop event. That
2 overpower margin typically was substantial, i.e., it would
3 potentially penalize the plant capability in terms of
4 operating flexibility, but that was a given tradeoff.

5 In order to handle that kind of an event we
6 provided not only that overpower margin but we had features
7 in the control system in the secondary plant that provided
8 turbine run-back capability to minimize the mismatch between
9 the primary and secondary system.

10 During various reviews by the staff as well as
11 ourselves regarding that type of an event, and it was
12 categorized as an anticipated operational occurrence. If
13 you will refer to the appendix in the general design
14 criteria it is defined as occurring once or more in the
15 40-year lifetime of the plant.

16 We sensed an increasing need either to design more
17 appropriately that control system feature where we had more
18 rod block, if you will, as well as rod runback, or as an
19 option to put in some automatically responsive redundant
20 single failure proof feature in the plant protective system
21 proper which could accommodate that rod drop event
22 automatically. One way to do that would be to have the
23 protection system have in a sense discrete rod inputs on
24 line.

25 MR. KERR: Mr. Lipinski.

1 MR. LIPINSKI: On Turkey Point you had implemented
2 the linear heat rate and the DNBR via analogue computers,
3 but, if I recall, you did not have the ability to sense the
4 rod positions. So you are taking the penalty on Turkey
5 Point.

6 MR. SPINELL: Are you referring to St. Lucie?

7 MR. LIPINSKI: I am sorry, St. Lucie.

8 MR. SPINELL: Yes.

9 MR. KERR: Let me see if I understand the import
10 of your comment. I could interpret it to mean that having
11 recognized that you needed to handle these infrequent but
12 nevertheless expected during the life of the plant events
13 and having concluded that the reliability of the system
14 needed to handle them possibly because of their consequences
15 or whatever was something that needed to have some
16 quantitative significance like the single-failure criterion
17 and a qualitative significance perhaps you decided that the
18 way to get that would be to build a system which would have
19 the characteristics now attributed to protection systems,
20 namely, redundant channels, single-failure criteria and so
21 on. And having made that decision that it must meet the
22 criteria of a reactor protection system it sort of became
23 part of the reactor protection system.

24 MR. SPINELL: That is correct.

25 MR. KERR: Let me ask one other question. You

1 have referred to the general design criteria of the NRC as
2 background for general guidance I guess in deciding how to
3 design. Does Combustion Engineering have any similar set of
4 criteria that may be similar or perhaps independent of the
5 general design criteria of NRC?

6 MR. SPINELL: Bill.

7 MR. GILL: My name is William Gill from Combustion
8 Engineering. I don't think we really have any different
9 criteria. I believe our interpretation of the criteria
10 varies somewhat from industry interpretations. As designers
11 we are more sensitive to certain issues like operator
12 actions.

13 As Al was pointing out in the CEA misoperation we
14 relied on control systems but we also relied on the operator
15 to trip the plant. At the time we were making the decision
16 to go to the core protection calculator we interpreted the
17 criteria such that operator action would only be appropriate
18 if you had a clear unambiguous indication of the process and
19 if you had sufficient time to implement that action. So I
20 don't believe our criteria are different but it is just our
21 interpretation of the criteria.

22 MR. KERR: That comment is relevant. I also had
23 in mind the possibility that you might have specific
24 criteria for performance of control systems. NRC's design
25 criteria are much less applicable to, say, determine

1 reliability of control systems and, as I understand the
2 argument, this philosophy is based on the assumption that
3 the combined design of control and protection systems is
4 such that the reactor protection system bears the burden of
5 whatever reliability one enforces.

6 Now, it is not obvious to me that a nuclear steam
7 supply designer would have the same approach and I wondered
8 if, for example, you have design criteria which perhaps you
9 apply to control systems, reliability criteria, for example?

10 MR. GILL: I will answer your question in a time
11 frame. At the time we made the decision to implement the
12 digital protection system and during the design process
13 which was in the mid-'70s to, say, 1978 the answer is no, we
14 didn't put the rigor into criteria for control systems that
15 we did for protection systems.

16 MR. KERR: Excuse me. I didn't mean to imply that
17 you would have the same ones. I just wondered if you had
18 any?

19 MR. GILL: At that time they were minimal. I
20 think at the present time we are developing criteria for the
21 reliability and failure of control systems. This is
22 primarily prompted by their impact on plant availability.
23 That is our initiating mechanism for looking at it.

24 In developing these criteria though we do find
25 that there is a link between the control system reliability

1 and the protective system design criteria and that if we
2 develop criteria for control systems and design those
3 control systems to that criteria then your failure modes or
4 their reliability is much higher and the potential for
5 failure is much lower.

6 In this case we could move certain events say from
7 anticipated operational occurrences to say anticipated
8 accidents would be a lower probability event. This in turn
9 would relieve some of the say pressure or some of the
10 requirements on the protection system.

11 So that development of criteria for the control
12 system is something that is underway but it is at the very
13 early stages of development.

14 MR. KERR: Any estimate of when you will have
15 those criteria developed? I presume they never become fully
16 developed because as you have learned they may change.

17 MR. GILL: I can't give you the calendar time but
18 I can give you the process by which we would hope they would
19 become developed. CE has recommended and is working with
20 various industry committees to try and establish say an IEEE
21 A&S Committee on Classification of Instrumentation where we
22 would develop the various classes of instrumentation.

23 Once we developed the classification we would then
24 develop criteria for each class. This would include control
25 systems and safety systems and in all likelihood it would

1 also break the safety systems into two pieces, safeguards
2 type protective systems and reactor type protection systems
3 which could have different criteria.

4 Our intent would be to approach this as an
5 industry effort rather than CE approach it by themselves and
6 we are working toward that goal.

7 MR. KERR: So when you tell me that development is
8 underway you are referring to an industrywide effort carried
9 on, for example, by an IEEE committee?

10 MR. GILL: We as a designer are proceeding with
11 that criteria. Our incentive to implement a criteria like
12 that as a sole designer of power plants is not that high.
13 It has a significant impact on our, you know, position in
14 the industry to be the only one to impose a criteria on
15 control systems unless we can convince ourselves that the
16 benefit of doing so, you know, is significant.

17 MR. KERR: It is hard for me to see how one could
18 fail to be convinced that control system reliability would
19 be an asset. How does one avoid such a conclusion?

20 MR. GILL: Control system reliability is an asset.

21 MR. KERR: Mr. Ditto.

22 MR. DITTO: I hear about the control system
23 reliability and I think of an equally important part of the
24 control system and that is its performance capability. I
25 think part of the reason for going to a different kind of

1 protection system, an improved protection system is the fact
2 that your control system was not capable even when it worked
3 of assuring sufficient margin. That is, you could not
4 reduce the margin enough because your control system did not
5 take into account rod position in a way that let you be
6 assured that your protection system would be adequate
7 without putting in a great deal of margin.

8 So I think when you develop these criteria they
9 must include as well as reliability a very strong concern
10 for the capability to keep the plant in an ideal state if
11 you please when it is working.

12 MR. GILL: I think you are addressing two issues.
13 The control system can maintain the initial conditions for
14 the accident. The control system can also reduce the
15 probability of the event.

16 MR. DITTO: Certainly.

17 MR. GILL: However, once the event is initiated,
18 if that event left uncorrected could result in violation of
19 fuel design criteria or plant design criteria, then it must
20 have a safety system in terms of the redundancy,
21 reliability, et cetera.

22 MR. DITTO: Certainly.

23 MR. GILL: So our decision as to whether we use a
24 control system or a safety system is pretty simple. If the
25 process proceeds without mitigation and that process would

1 result in violation of either the fuel design criteria,
2 pressure boundary or containment design criteria then a
3 safety system designed to the IEEE 279 criteria, et cetera,
4 is required to mitigate that event.

5 MR. DITTO: Yes. I was only trying to make the
6 point that if your control system does not have the
7 capability even when it is working of maintaining the plant
8 in a state that your protection system can mitigation if it
9 gets into the accident condition then the reliability
10 becomes not very much of an issue.

11 MR. GILL: Correct. Let me just point out one
12 thing. We rely on the control system to maintain the
13 overall process. However, we rely on monitoring systems
14 such as our core operating limit supervisory system and
15 other systems to maintain the plant within the initial
16 conditions in the accident.

17 So there is really a level of control system that
18 is say one notch up in terms of criteria which maintains the
19 plant consistent with the initial conditions in the safety
20 analysis. CE has developed criteria for the design of that
21 type of system. For example, we apply certain aspects of CA
22 to those systems.

23 MR. KERR: Mr. Lipinski.

24 MR. LIPINSKI: In the case of the rod drop
25 accident if you were to employ a rod runback rather than a

1 scram is there sufficient time to guarantee that you do not
2 exceed the core limits or must you scram?

3 MR. SPINELL: I think it depends on the conditions.

4 MR. GILL: Sir, are you asking is there sufficient
5 time for operator action to trip the reactor?

6 MR. LIPINSKI: No, no. I am talking about an
7 automatic rod insert as opposed to a total reactor scram.
8 Let's say I have a rod drop accident. If I were to employ a
9 rod runback do I guarantee that the fuel design limits are
10 not exceeded or is the time such that I must employ a scram?

11 MR. GILL: You must employ a scram.

12 MR. LIPINSKI: Okay, that answers the question.
13 You really can't protect against this type of an event with
14 a control system action. You must employ scram.

15 MR. GILL: On the Arkansas and later plants, the
16 high-power density plants and the large cores that is true.
17 On the operating reactors there is more time and sufficient
18 time that a trip is not needed. It depends on the margins
19 in the plant.

20 MR. LIPINSKI: That is what I was going to comment
21 on. If you do not employ the fast ground then you have to
22 increase the margins such that the fuel limits are not
23 exceeded.

24 MR. GILL: That is correct.

25 MR. KERR: Mr. Ray.

1 MR. RAY: Referring to criteria reliability do you
2 have any performance standards which you require your
3 computer system component suppliers to demonstrate such as
4 mean time between failure of components and that sort of
5 thing?

6 MR. KERR: Mr. Ray, are you referring now when you
7 say "computer" to the core protection calculator computer or
8 the plant computer?

9 MR. RAY: You said digital processing technology
10 was incorporated into the PPS. I am talking about that
11 digital computer technology, the systems that are involved.

12 MR. KERR: Do you understand the question?

13 MR. GILL: We will be discussing that in some
14 detail at later parts of the presentation. So if you don't
15 object we would like to put that off and we will be getting
16 into reliability.

17 MR. RAY: No objection.

18 MR. KERR: Okay.

19 MR. GILL: Dr. Kerr, if I could just add one more
20 item on the control system. The implementation of the
21 protection system for CEA events was a licensing condition
22 for Arkansas. It was part of the PSAR safety evaluation
23 report. Its safety grade rod protection must be
24 incorporated in the plant. There was an alternative for
25 analysis but that alternative was not viable.

1 MR. KERR: Thank you.

2 Mr. Lipinski.

3 MR. LIPINSKI: That last one leaves me confused
4 because St. Lucie was licensed without it, right?

5 MR. SPINELL: St. Lucie Unit 1; that is correct.

6 MR. LIPINSKI: So now what happened between
7 St. Lucie and Arkansas that required that you use the rod
8 information and generate a scram?

9 MR. GILL: Reinterpretation of the criteria on St.
10 Lucie.

11 MR. LIPINSKI: By NRC or Combustion?

12 MR. GILL: I would say by both. The staff issued
13 a directive that said a safety grade rod block is required
14 on the Arkansas plant. CE was involved in criteria that
15 limited operator action if that action were required in
16 short periods of time. Trying to decide who got there first
17 and impose the criteria is very difficult. Looking back I
18 would say it was an overall industry interpretation of
19 criteria imposed by the NRC.

20 MR. LIPINSKI: Thank you.

21 MR. KERR: Any other questions?

22 Please go ahead.

23 (Slide.)

24 MR. SPINELL: This slide, what I want here to do
25 is to convey in the proper perspective the relationship

1 between the plant protective system and the core protection
2 calculator trips.

3 The plant protection system as defined consists of
4 two basic components, an engineering safety features
5 actuation system and a reactor protection system.

6 The core protection calculator initiates two of
7 the twelve trips in the reactor protection system portion,
8 the low DNBR trip and the high local power density trip for
9 San Onofre Units 2 and 3. They are represented here
10 pictorially. There are ten other analog type trips, typical
11 trips that are consistent with Arkansas as well as our other
12 earlier plants. In addition, there are seven analog safety
13 functions for actuating emergency safeguards such as ECCS.

14 MR. KERR: I hate to introduce a discordant note
15 into your presentation but remind me what SONGS means.

16 MR. SPINELL: San Onofre Nuclear Generating
17 Station.

18 MR. KERR: I was afraid of that.

19 (Laughter.)

20 (Slide.)

21 MR. SPINELL: For these two trip functions and the
22 relationship between the remainder of the protection system
23 I have this slide. The point I want to get across to you is
24 that given the fact that we have undergone an extensive
25 review of this system and given the fact that we have put a

1 lot of time and effort into it the relationship of the core
2 protection calculator to the remainder of the system is such
3 that even with a diverse common mode, if you will, failure
4 of all of the four redundant channels in this computer
5 system an evaluation has been performed.

6 We have come to the conclusion that we have event
7 specific backup trips, diverse analog trips that are
8 embodied within the remainder of the protection system and
9 these I have listed by event and have listed the backup trip
10 that is implemented at San Onofre.

11 MR. KERR: Excuse me. I guess I am not altogether
12 certain of the significance of your statement. Is the
13 significance that even if the CPC were obliterated you would
14 still be able to take care of trips for most of the events
15 of which you can conceive?

16 MR. SPINELL: That are part of the present design
17 basis for the CPC, yes.

18 MR. KERR: I am sorry. Would you repeat that.

19 MR. SPINELL: I have a later slide which defines
20 the individual design basis events and these are categorized
21 accordingly. The answer to your question is yes, there are
22 backup trips.

23 MR. KERR: Thank you.

24 Mr. Ray.

25 MR. RAY: Are these backup trips part of the

1 computerization or are they an entirely independent system?

2 MR. SPINELL: They are part of the analog portion
3 of the reactor protective system.

4 MR. RAY: They are not then an independent channel
5 within your CPC system? They are completely independent of
6 any computer component?

7 MR. SPINELL: They are completely independent of
8 the CPC channels.

9 MR. RAY: You said you had four redundant channels
10 within the CPC system. What happens when one of those
11 malfunctions and goes out? Is it automatically switched or
12 must an operator intervene to switch over to the other
13 channels?

14 MR. SPINELL: Well, there are two principal ways,
15 if I can use your term, that a channel goes out. One, it
16 can automatically trip or the operator can take it out of
17 service for a periodic testing, maintenance or whatever.

18 In the case of the first obviously the function is
19 an automatic trip of that channel and that provides part of
20 the coincidence logic for tripping the reactor. There needs
21 to be two like channels to provide that trip function.

22 In the case of the latter the operator can simply
23 take the channel out of service at the appropriate panel and
24 perform whatever maintenance or testing functions he has to
25 to meeting the technical specification requirement. He then

1 has the other three channels in this case to provide him the
2 necessary protection which meets the criteria.

3 MR. LIPINSKI: May I add to that statement.
4 Channels can fail two ways, unsafe or safe. If the safe
5 failure occurs then one channel has failed and that is a two
6 out of four system. Any one of three remaining channels
7 provides a trip if an event occurs. If it is an unsafe
8 failure then that system reverts to a two out of three
9 system and then you require two channels to come up to
10 generate to trip.

11 MR. RAY: So you don't necessarily have a half
12 scram situation.

13 MR. LIPINSKI: No, no. The scram goes to
14 completion if it comes up but based on the two out of four.
15 If it unsafe you revert to two out of three. If it is a
16 safe failure then it is one out of three.

17 MR. RAY: Another question. Does the system have
18 any self-diagnostic capability so that when one channel
19 fails the computer diagnostics can take over and tell the
20 operator possibly which component in that channel failed or
21 must this be an entirely separate investigation?

22 MR. SPINELL: Depending on the set of
23 circumstances there can be immediate indication of the cause
24 of the problem or under certain circumstances the operator
25 or the technician might have to take a channel out of

1 service to perform some diagnostics. He can do that by
2 interrogating the components.

3 MR. RAY: So there is a partial self-diagnosis in
4 your design?

5 MR. SPINELL: That is correct.

6 MR. KERR: Mr. Ditto.

7 MR. DITTO: I presume there are cases in which you
8 could have failures that are there lying dormant which you
9 don't know about and may not even detect during tests.

10 MR. KERR: I am sorry, you could have what lying
11 there?

12 MR. DITTO: Failures, component failures or system
13 failures in channels that you don't get at by any of these
14 methods. You can have a channel out of service for
15 particular accidents in a way that you don't know about,
16 senses that have failed in some peculiar way. Your
17 diagnostic is of the computer system and it is not of the
18 entire system.

19 MR. KERR: Is that a statement or a question,
20 Mr. Ditto?

21 MR. DITTO: I am asking him is that not true.

22 MR. SPINELL: There are separate diagnostic
23 procedures, and I will let Arkansas if they are willing to
24 address that, introduced for the processing equipment
25 upstream of the core protection calculators specifically for

1 the sensors themselves, the transmitters and the processing
2 equipment, response time testing, et cetera, that determine
3 the operability or status of that equipment.

4 MR. KERR: Mr. Lipinski.

5 MR. LIPINSKI: One of the purposes of connecting
6 the Arkansas CPC's to the plant computer was to use the
7 plant computer to do an interchannel comparison and to sound
8 an alarm if there was a deviation on any single channel
9 compared to the others. Right now you don't have the
10 intercomparison capability, do you? I am asking it of him.

11 MR. KERR: He is not Arkansas.

12 MR. LIPINSKI: No, but he was involved with the
13 design of the system.

14 MR. SPINELL: Can you repeat the question again,
15 please?

16 MR. LIPINSKI: The purpose of interconnecting the
17 Arkansas CPC's to the plant computer was to use the plant
18 computer to do an interchannel comparison on the CPC's and
19 to sound an alarm if there was a significant deviation of
20 any one channel from the average performance. That
21 connection was not allowed to be made and consequently you
22 are not performing those intercomparisons.

23 MR. SPINELL: Let me have Mr. Cogburn from
24 Arkansas Power and Light address your question.

25 MR. COGBURN: My name is Thomas Cogburn.

1 Regarding the data links from the core protection
2 calculators to the plant process computer the resolution
3 that was agreed upon at the time of licensing of ANO 2 was
4 that at the completion of the start-up test program plus ten
5 days the data links would be removed.

6 Prior to that time, prior to completion we sent a
7 letter to the NRC staff asking concurrence that we leave the
8 data links in service. Because we received no response to
9 that letter we took it as concurrence and we still have them
10 installed and we are using them now.

11 MR. LIPINSKI: Thank you. I wasn't aware of
12 that. I knew the first one was in force but I didn't know
13 it never was implemented.

14 MR. KERR: Mr. Ditto.

15 MR. DITTO: I have to say one thing here about
16 this. It is my understanding that the use of redundant
17 channels is so that each of four or three independent
18 channels can tell the protection system what it thinks the
19 status of the plant is.

20 In this intercomparison that is easily done with a
21 computerized system you somewhat sacrifice this independence
22 and you lead people into the notion that agreement among
23 these channels is a good thing. I suggest that agreement
24 among protection channels to a very close comparison is
25 probably not a good thing to insist upon. So I just throw

1 that in as one of the hazards that you have of making this
2 easy intercomparison that you somewhat lose the independence
3 of the channels in a rather subtle way.

4 MR. KERR: But very, very subtle. It is so subtle
5 that I have never understood it.

6 MR. LIPINSKI: I was going to ask for him to
7 amplify it because now it is a fifth computer that is the
8 referee.

9 MR. DITTO: Which has only one set of inputs or a
10 number of them.

11 MR. KERR: You and Walt and I will have to go out
12 in the hallway and debate this further. Let's continue with
13 the presentation.

14 (Slide.)

15 MR. SPINELL: In the next series of slides I would
16 like to define the CPC scope, the hardware, the software,
17 the inputs and the outputs.

18 The first of these slides introduces the scope of
19 the system and it embodies the following four items.

20 First, signals from sensors that monitor specified
21 core variables, and I will define those variables in a later
22 slide.

23 Secondly, dedicated computers, a total of six
24 divided up into four channels, to implement the algorithms
25 that will process the sensor information.

1 Thirdly, operators' modules for visibility
2 indication.

3 Fourthly, outputs for displays, alarms and reactor
4 trips.

5 (Slide.)

6 The next two slides I have in a package. They are
7 in reversed order if you will bear with me.

8 What I would like to cover in the next two slides
9 is a definition if you will of the design basis for the
10 system as it is presently embodied. This is an overall
11 design requirement in that it covers certain anticipated
12 operational occurrences and design basis accidents.

13 In the first with regard to anticipated
14 operational occurrences the system is designed to provide or
15 to initiate automatic protective action to preserve the
16 margin present to assure that we will not violate the fuel
17 design limits specified earlier on fuel centerline melt and
18 DNB.

19 Secondly, the core protection calculators for a
20 fixed finite set of design basis accidents coupled with
21 certain engineered safety features actions help to assure
22 that the consequences of those accidents are within the
23 analysis results that have been computed.

24 (Slide.)

25 The specific design basis events within those two

1 categories on your previous slide are identified thusly. In
2 the anticipated operational occurrence category Xenon
3 oscillations are included in the protection as well as the
4 rod-related events listed, excess and loss of load functions
5 on the secondary plant, complete and partial loss of forced
6 reactor coolant flow in the primary system, uncontrolled
7 boron dilutions initiated by manual misoperations or
8 failures of equipment in the chemical and volume control
9 system and asymmetric transients that perturbate one side or
10 another of the reactor coolant system via the heat sink.

11 In the accident category the core protection
12 calculator provides protection for the steam generator tube
13 rupture and reactor coolant pump shaft seizure events.

14 MR. KERR: Mr. Spinell, what is meant by steam
15 generator tube rupture as an accident? Does that rupture of
16 one tube or several tubes? How much of a rupture does it
17 have to be in order to put it into the accident category?

18 MR. SPINELL: Any partial or total rupture which
19 causes a loss of coolant rate that exceeds the make-up
20 capability of one charging pump which is 32 gallons per
21 minute.

22 MR. KERR: That is really in terms of leakage?

23 MR. SPINELL: Right.

24 MR. KERR: Thank you.

25 Mr. Pearson.

1 MR. PEARSON: Let me ask you a question. When you
2 say an uncontrolled Xenon oscillation does that implying
3 that a control system has failed to operate?

4 MR. KERR: Do you understand the question?

5 MR. SPINELL: Yes. I would like to call on Bill
6 Gill to handle that question.

7 MR. KERR: Mr. Gill, did you hear the question?

8 MR. GILL: No, I am sorry. Could you repeat the
9 question, please.

10 MR. PEARSON: When you say you have an
11 uncontrolled Xenon oscillation does that imply that a
12 control system has failed to operate?

13 MR. KERR: Mr. Pearson is referring to the first
14 of these listed.

15 MR. GILL: Yes, sir. No, it does not. We do not
16 have automatic control of axial power distribution. The
17 large cores, the Arkansas core and later are predicted at
18 certain times in life to be unstable. In other words, the
19 oscillation will diverge. It is the responsibility of the
20 operator to control that Xenon oscillation and bring it back
21 to a stable nonvarying condition. Should he fail in doing
22 that then a protective system would initiate a trip.

23 MR. KERR: Thank you.

24 Please proceed, Mr. Spinell.

25 (Slide.)

1 MR. SPINELL: Let me then highlight with this
2 slide the design features that we have incorporated in the
3 core protection calculators to provide protection.

4 First, included in the system is a set of fourfold
5 redundant three-level ex-core detector information. These
6 are vision chambers, three separate vision chamber assemblies
7 located outside the reactor vessel segmented into four
8 separate channels.

9 In addition there is a complete system of
10 dedicated digital computers to provide this four-channel
11 redundancy.

12 There is the use of analytical synthesis
13 techniques to construct radial and axial power distributions
14 on line.

15 Fourth, the use direct CEA position inputs based
16 on rod positions.

17 Next, flow determination based on direct reactor
18 coolant pump speed measurements based on revolutions of the
19 shafts of the pumps individually turning.

20 There is linear heat rate and DNBR calculated on
21 line in the system.

22 Lastly, an operator's console channelized to
23 provide a comprehensive data display that the operator can
24 interrogate via keyboards.

25 MR. KERR: Full determination based on RCP speed

1 measurements. Is that a one-for-one correlation or is that
2 based on RCP speed measurements plus some other things?

3 MR. SPINELL: In a static sense the process input
4 is a direct speed measurement based on a probe assembly that
5 sits around the shaft. The probe measures the revolutions
6 by monitoring a discretely defined set of grooves or discs
7 within that assembly. The proportionality of the speed of
8 the shaft turning with the number of counts, if you will,
9 that probe assembly picks up as the individual indicators
10 around the probe shaft turns is the input which is then
11 converted into individual flows based on the individual pump
12 head curves for this particular system.

13 MR. KERR: As I recall, and I haven't looked at
14 the CPC in a year or so, that measurement was then modified
15 somewhere in the calculation to come up with a corrected
16 flow. That is, if my memory serves me correctly, there was
17 some kind of a fudge factor, if you please, that had to be
18 applied farther down the line in the calculator.

19 You are saying that the head characteristics of
20 the pump and the speed is all that goes into the flow
21 calculation?

22 MR. SPINELL: I might call on again Bill Gill who
23 can address that in a dynamic sense of how those flows are
24 compensated.

25 MR. GILL: In terms of the on-line calculation in

1 the CPC you can look at it as a flow algorithm. In the
2 inputs, in terms of measured inputs to that algorithm are
3 pump speed, system pressure and system temperature, the
4 pressure and temperature being density, friction factor type
5 of corrections which are used in a flow calculation.

6 That basically allows the calculator normalized
7 flow. That flow must be calibrated to an off-line
8 determination of flow rate using a combination of pump DP
9 instrumentation and a heat balance on the primary side to
10 determine the absolute value of flow. That absolute value
11 of flow becomes a calibration factor which is entered into
12 the core protection calculator by the addressable constance
13 technique which are adjustment factors.

14 MR. KERR: Thank you.

15 Please continue.

16 (Slide.)

17 MR. SPINELL: This next slide depicts a
18 representation of the relationship between the calculators
19 and the rod position inputs. I might point out at the
20 beginning that the remainder of the process inputs that are
21 displayed on the next line are not shown in here for each of
22 understanding but on an individual channel-by-channel basis
23 across for the four redundant core protection calculators
24 there are also inputs for primary pressure, temperatures,
25 shaft speed sensing inputs and ex-core detector information

1 that are input functionally into the calculators here.

2 I might draw a line here and show these inputs.

3 Those are other process inputs.

4 If you start at the top of this diagram here there
5 are 91 CEAS in the San Onofre Units 2 and 3 design. Each of
6 them has two separate redundant reed switch position
7 transmitter assemblies that provide discrete position input
8 into the core protection calculator system.

9 There are 23 target rods, if you will, based on
10 the group and subgroup assignments that are input into the
11 individual core protection calculators which provide group
12 relationships to one another and identify certain peaking
13 factors to those relationships, if you will, if the groups
14 are separated more than a particular amount.

15 In addition, all of the rod position inputs for
16 individual groups are provided in the core element assembly
17 calculators. All 91 reed switch position inputs are in each
18 one of these calculators and these provide individual CEA
19 deviation information that has thus input into each of the
20 core protection calculators via data links. These data
21 links are isolated to maintain their proper separation.

22 In addition, the output of each of the control
23 element assembly calculators, CEA calculators, are isolated
24 and input into a CRT display on the control board that the
25 operator has the capability to obtain the information from

1 either of the two calculators.

2 One other point I would like to make with this
3 slide is that at the present time the data links that we
4 were referring to earlier today, the output, if you will,
5 from each one of these calculators goes to the plant
6 monitoring system, and I will draw in the other lines for
7 detail, that provide all of the information for the
8 interchannel comparisons and the information that is used
9 during the power essential test program for verification of
10 various constants in parameters.

11 (Slide.)

12 The next slide depicts the process input signals
13 and all of these were, as I pointed out, not represented
14 explicitly on the previous slide with the exception of the
15 target CEA position information. This slide depicts the
16 signal itself, the number per channel, the range of the
17 individual parameters and the signal types.

18 (Slide.)

19 To define the inputs to the system of hardware
20 itself then it is appropriate to define the algorithms
21 themselves that the calculators process with this process
22 input. They process four major application programs in
23 addition to a trip sequence program to identify to the plant
24 protective system the trip sequence necessary.

25 The four basic application programs are the

1 coolant mass flow program, the DNBR and local power density
2 update program, the power distribution program and the
3 static DNBR program.

4 (Slide.)

5 The major calculations within the system are
6 broken out in a little more detail for the four particular
7 programs involved.

8 First is the Flow Program. It calculates mass
9 flow rate in the system and it determines a projected DNBR
10 based on a projected change in the flow rate itself. As
11 Bill Gill identified, this information is compensated by
12 temperature and pressure inputs with respect to the effects
13 on density.

14 The second program, the Update Program, determines
15 the partial derivative, if you will, updates of a series of
16 parameters with respect to their impact on local power
17 density and DNBR, in particular temperature effects,
18 pressure effects and so on.

19 (Slide.)

20 The third program, the Power Program, is basically
21 a Delta F power program calculation, if you will, that uses
22 these inputs.

23 The fourth program is a Static Program or a static
24 computation of DNBR and local power density which uses the
25 major types of information identified here.

1 (Slide.)

2 So we have talked about the hardware itself, the
3 process inputs, the application programs and these are the
4 output signals from the calculators on a per-channel basis.

5 In addition to the normal DNBR and local power
6 density trip information we have pre-trip indications, we
7 have output signals for sensor failures, we have information
8 dealing with mass flow rate and calibrated neutron flux.

9 The signals that I have identified thusly are
10 here, the types involved, whether it be contact or analog
11 information, the setpoint where appropriate and then the
12 range of the particular signal where appropriate.

13 MR. LIPINSKI: Before you take that off, on that
14 range column the DNBR margin to trip, zero to ten, does this
15 mean you can make a digital entry of ten as an analog
16 setting? Is that the upper scale for a trip on DNBR, ten?

17 MR. SPINELL: Let me ask Bill Gill or Ed Brown to
18 address that.

19 MR. GILL: That is the scale on the analog
20 output. It is a zero to ten volt signal, and zero to ten
21 volts corresponds to zero to a ten DNBR margin where a zero
22 margin is a trip and a ten is a calculated DNB of ten plus
23 1.3 or 1.19. It is just a scaling factor.

24 MR. LIPINSKI: I know it is a scaling factor.
25 What I am getting at is normally you are talking about

1 levels of 1.3 and normally you are set in the vicinity of
2 1.3, are you not, for your trip?

3 MR. GILL: Correct.

4 MR. LIPINSKI: But you are telling me that if I
5 were to be an operator I could run that dial up to ten?

6 MR. GILL: No. That is the calculated output and
7 not the setpoint. The setpoint is basically a digital word
8 in memory. That is the analog output which goes to an
9 analog meter.

10 MR. LIPINSKI: Correct. So now what does range
11 mean zero to ten on that analog meter?

12 MR. GILL: It means that the calculated margin can
13 be zero to ten DNB units which corresponds to the full scale
14 on the meter. If you look at the face of the meter in the
15 control room it would show zero margin which would be a trip
16 condition and then it would go up to ten. When the reactor
17 is starting up say at ten or fifteen percent power you would
18 see that the DNBR margin would be up around nine or ten and
19 it is scaled so that the operator can observe its
20 performance during start-up and assure that the system is
21 functioning.

22 MR. LIPINSKI: You are telling me your scale is
23 not related then to the actual DNBR? I would normally
24 expect to see numbers like 1.3. What do I interpret when
25 see a number of ten?

1 MR. GILL: What is displayed to the operator is
2 not the calculated DNB. It is the calculated DNB minus the
3 setpoint. So it is the margin to trip where zero margin
4 means that he is at the trip setpoint of 1.3. We are
5 showing him on an analog meter the margin he has in DNB
6 units. So a reading of ten would mean that he has ten DNB
7 units to trip.

8 MR. LIPINSKI: 1.3 minus 1.3 is equal to zero.

9 MR. GILL: Right.

10 MR. LIPINSKI: 1.3 minus 1.2 is .1.

11 MR. GILL: Right.

12 MR. LIPINSKI: Where do I get ten?

13 MR. KERR: If your ratio is 11.3 you get ten, Walt.

14 MR. LIPINSKI: Okay.

15 (Slide.)

16 MR. SPINELL: For completeness within the system
17 let me show our next slide, the program execution intervals
18 and the sampling rates for the inputs by programs listed
19 here, the four major programs, the inputs sampled by program
20 and the execution or sampling interval.

21 The note down here dealing with the display of the
22 information on the operator's console which, depending on
23 the input, is some many times after a particular sampling
24 frequency adjusted accordingly.

25 In this case the execution and sampling interval

1 for the programs is consistent. There is a one-to-one
2 correlation between the sampling and the execution of the
3 program.

4 (Slide.)

5 This next slide will leave you with the impression
6 that there is ample information displayed to the operator by
7 various means within the control room not only via the
8 operator's module which receives a lot of attention and the
9 displays which have these features, but also the direct
10 analog indicators that are provided on a channel basis for
11 each of the three functions listed.

12 In addition, there are inputs to the station
13 annunciator system for a pre-trip and trip alarm indication.

14 In addition, there is individual process
15 information on each of the process inputs to the system that
16 is displayed on the control board.

17 Last, there is the CRT display for the discrete
18 rod position input or on a bank or subgroup basis. In fact
19 we have 91 control rods here listed instead of 81.

20 What I would like to move now to is a comparison
21 of designs between the ANO 2 system and the San Onofre Units
22 2 and 3 system.

23 MR. KERR: Mr. Spinell, this strikes me as a good
24 point for a break. If you agree I will declare a ten-minute
25 break.

1 MR. SPINELL: All right.

2 (Whereupon, a brief recess was taken.)

3 MR. KERR: Are you ready to begin, Mr. Spinell?

4 MR. SPINELL: Yes, I am, Dr. Kerr.

5 MR. KERR: Okay. Let's get started.

6 MR. SPINELL: For this portion of my presentation
7 I want to provide a comparison between the San Onofre Units
8 2 and 3 and Arkansas designs with respect to these three
9 categories: First the hardware, next the executive system
10 software and the application system software.

11 (Slide.)

12 For the sake of the hardware comparison after you
13 read through all of this what we are basically saying is
14 there are no hardware changes or, in other words, the
15 systems are identical hardware-wise between San Onofre and
16 Arkansas.

17 It so happens that we have different cable lanes
18 for some of the interconnecting equipment and we have
19 additional spare cards that handle the additional rod
20 position inputs. It so happens they appropriately
21 accommodate the increased number for San Onofre. But the
22 hardware, the vendors, the design of the hardware is
23 identical. In fact, they were made out of the same lot at
24 Systems Engineering Laboratories at the same time.

25 (Slide.)

1 The next slide is a comparison with respect to the
2 executive system software. As pointed out here there are no
3 differences in the software design between the two systems,
4 including the following functions dealing with task
5 scheduling, priority and software structure of the programs.

6 As pointed out here since the two plants have
7 different numbers of control element assemblies, 83 in
8 Arkansas versus 91 in San Onofre, the programs that service
9 the various input and output data dealing with that are
10 adjusted accordingly to accommodate those additional CEA
11 positions.

12 MR. LIPINSKI: What are the exact numbers of CEAs?

13 MR. SPINELL: Ninety-one on San Onofre and 81 on
14 Arkansas.

15 MR. KERR: So the numbers are 92 on San Onofre and
16 81 on ANC 2?

17 MR. SPINELL: Correct.

18 MR. KERR: Thank you.

19 (Slide.)

20 MR. SPINELL: The third of the last three elements
21 of this comparison deals with the application programs and
22 the difference in the programs between the presently
23 configured installed software in Arkansas and the pending
24 completion of the cycle one software for San Onofre. They
25 are embodied in these changes thusly dealing with the DNBP

1 algorithm itself where we are going to the torque CE-1
2 thermal hydraulics code correlation methodology for
3 determining static DNBR. There are assorted data base
4 changes to reflect plant specific cooling system
5 characteristics and related power distribution information.

6 Thirdly, there are CEA related changes dealing
7 with the numbers of rods, the penalty factors, et cetera.

8 MR. KERR: Mr. Spinell, help me a bit. In the
9 previous slide I saw that there were no differences in the
10 software design and in this slide I find that there are
11 differences in the algorithms.

12 Now, I presume what you are saying is that there
13 is no difference in the software design but there is some
14 difference in the software. Is that the way I interpret
15 those two slides?

16 MR. SPINELL: Dr. Kerr, the previous slide could
17 have been clarified by saying an executive software design
18 or executive system software design in lieu of software
19 design as a point of clarification.

20 MR. KERR: That refers only to the following
21 executive system functions, whatever that means.

22 MR. SPINELL: Correct.

23 MR. KERR: Okay. So there are some differences in
24 the software between the two systems?

25 MR. SPINELL: In the application programs, correct.

1 MR. KERR: Okay.

2 MR. SPINELL: One more point I would like to make
3 here is these changes that are undergoing implementation on
4 San Onofre Units 2 and 3 are planned to be implemented in
5 the cycle 2 software for Arkansas Power and Light.

6 MR. KERR: Is somebody going to discuss the reason
7 for those changes and the implications thereof?

8 MR. SPINELL: We will be getting into those
9 changes in a session in the afternoon as far as that goes.

10 MR. KERR: Thank you.

11 (Slide.)

12 MR. SPINELL: The third item I would like to give
13 you an overview on this morning is a status of the design,
14 qualification and field activities dealing with the system
15 on San Onofre for purposes of having the perspective on
16 where the basic elements of the system stand at this point.

17 The first four items on your list here deal with
18 the hardware principally.

19 I might point out, first of all, that the hardware
20 design was completed approximately in August 1976. The
21 hardware was completely fabricated and delivered and
22 installed to the site and that activity was completed in
23 approximately June of 1978.

24 In approximately October of 1980 the actual base
25 line field acceptance test on the hardware was performed.

1 At that time the system was initially energized with the
2 proper uninterruptible power supply filtered appropriately
3 to meet the requirements. In fact, that is a benchmark
4 test, if you will, for warranty and other purposes.

5 Since that time we have initiated the field
6 preoperational test on the system which includes various
7 continuity checks on the process inputs. We have tested
8 software in the calculator system itself to determine
9 electrically that the system functions properly.

10 The remaining activities that we have to perform
11 on the system itself are a set of tests which include prior
12 to fuel load response time testing on the equipment and just
13 as importantly during the post-fuel load phase a series of
14 tests to measure and monitor the inputs and outputs of the
15 system as well as various constants and data base inputs and
16 a series of tests during the power ascension test program at
17 the various plateaus.

18 The additional activities that we have going on in
19 parallel right now dealing with the software include the
20 following, the functional design activities of the
21 software. If you will, the description of the final form
22 of the algorithms to be implemented in cycle one for San
23 Onofre was completed earlier this month with the release of
24 appropriate functional description documentation.

25 In addition, we are approximately 90 percent

1 complete at this time with the data base documentation for
2 the over 5,000 constants that are a part of those
3 application programs in the software.

4 In addition, we are proceeding and are about half
5 way towards completing the software design process, the
6 actual final flow charting and software implementation, if
7 you will, via the programmers of the functional description
8 forms of the algorithms.

9 Lastly, we are initiating efforts that are
10 approximately five percent complete on the software testing
11 phase of the work which would be completed approximately in
12 April of this year.

13 The major effort now in that phase is defining the
14 ensemble of test cases and the initial test conditions for
15 those series of static and dynamic tests that are to be
16 performed that qualify that software.

17 MR. KERR: Let me see if I understand the
18 relationship between 7 and 8. Seven says that the software
19 design is about 50 percent complete and should be completed
20 in March or '81?

21 MR. SPINELL: That is correct.

22 MR. KERR: And eight says that the software
23 testing will be finished or that the design of the test will
24 be finished in April of '81, which?

25 MR. SPINELL: We intend to complete the testing in

1 April 1981, two months hence.

2 MR. KERR: That strikes me as being a remarkably
3 accelerated schedule, but so be it.

4 MR. SPINELL: The actual program, and we will be
5 getting into this in a little further detail later today, is
6 such that with the methodology in place and with the test
7 system in place what we need to is to complete a definition
8 of and the boundary conditions for the test cases and
9 actually test that software.

10 The actual fundamental turning of the crank to run
11 all these test cases is an uncovering process of two or three
12 weeks. So we believe it is a realistic schedule under these
13 circumstances.

14 MR. LIPINSKI: When did ANO 2 go operational?

15 MR. SPINELL: Tom.

16 MR. COGBURN: The operating license was received
17 on July 18th of '78.

18 MR. LIPINSKI: When did you get the power?

19 MR. COGBURN: Initial criticality was December 5
20 of '78 and the power operation continued in testing
21 throughout '79. I will be describing that in a little more
22 detail.

23 MR. LIPINSKI: Now, on this list you are showing
24 that you had a field hardware acceptance test, and since you
25 are working on the software naturally there was no software

1 test. But with ANO 2 you had your software tested offsite
2 before the equipment was installed, did you not?

3 MR. SPINELL: That is correct.

4 MR. LIPINSKI: So in this case you won't have a
5 systems test until that software is completely developed and
6 loaded into the onsite computers.

7 MR. SPINELL: We will have a system test on the
8 Windsor single-channel facility via complete channel of
9 hardware with the software integrated accordingly.

10 MR. LIPINSKI: Okay. So that facility is still
11 available to you for development purposes.

12 MR. SPINELL: That is correct.

13 MR. LIPINSKI: And we are going to talk about
14 these tests in detail as part of this afternoon's schedule?

15 MR. SPINELL: We will be talking in more detail
16 about the whole change procedure methodology which a part of
17 that embodies the actual test program, the qualification
18 program.

19 MR. LIPINSKI: And you will detail the tests
20 themselves in terms of the inputs that you are going to
21 generate?

22 MR. SPINELL: We will be able to discuss that.

23 MR. LIPINSKI: Okay. Thank you.

24 (Slide.)

25 MR. SPINELL: The fourth topic that I would like

1 to talk about briefly this morning and to wrap up my
2 presentation covers the licensing status from our
3 perspective at this standpoint. It embodies three elements
4 in summary.

5 One, the extent of compliance with the 27 NRC
6 staff positions on the core protection calculator system
7 that were identified during the Arkansas review.

8 Secondly, the SER open item, the safety evaluation
9 report item that is currently identified in the NUREG
10 document issued earlier this month.

11 Thirdly, other what I might categorize relevant
12 issues to the CPC review.

13 (Slide.)

14 With respect to the 27 staff positions the San
15 Onofre Units 2 and 3 design, and not 1 and 2 as listed
16 there, is in full compliance with the 27 positions with the
17 exception of the position taken by the staff with respect to
18 the data links between the calculator system and the plant
19 monitoring system and Edison position I have listed thusly
20 at this point.

21 MR. LIPINSKI: Let me ask this question. In the
22 case of Arkansas it was silence that allowed those links to
23 be maintained. What is the situation on San Onofre? Has
24 the question been asked or are you proceeding on the basis
25 of the Arkansas silence?

1 MR. KERR: I think that question probably ought to
2 be asked of of the NCEP people rather than CE.

3 MR. LIPINSKI: Well, it probably should be asked
4 of the staff.

5 MR. KERR: Well, maybe you should ask both, but I
6 doubt if CE wants to answer that question.

7 MR. EPLER: I would like to raise a question in
8 that area and it may be fundamental. After having observed
9 35 years of experience of operation it turns out that we
10 never see a case where one with four redundant channels
11 fails and nobody does anything and then another one fails
12 and nobody does anything and we get demand and we have a
13 system failure. It has never happened.

14 I don't think it ever will happen because we have
15 claimed I think correctly that we have a test procedure to
16 discover failure and we discover it and we do something. If
17 they fail every day we have got a pile of junk. If they
18 fail once a year we can handle this and we do handle it.

19 But if you look at the experience what we discover
20 is some idiot turned off the protection and started an
21 excursion and we had an accident. Maybe the designer did it
22 and we have had cases where the designer did, where the
23 operator did and where the excursion itslef has knocked out
24 the protection.

25 Now, armed with this knowledge that the failure

1 mechanism is not to be discovered by interchannel comparison
2 but has to be looked at on the basis of somebody has turned
3 off the protection that initiated the transient then I would
4 ask this question.

5 Have we not by now determined that indeed this is
6 not a pile of junk, that indeed our failure rate is
7 sufficiently low that we can take off this coupling which
8 interconnects to a degree the various independent channels
9 and say that surely by now we have assured ourselves that
10 the failure mechanism which never gives us any trouble is
11 indeed not giving us any trouble here and that we should
12 therefore withdraw from the situation where we compromise
13 the independence of the various channels by the data link?

14 So my question is what is our experience? Haven't
15 we by now shown that the failure rate is acceptable?

16 MR. KERR: I don't think that is a question. I
17 think that is a declamation.

18 (Laughter.)

19 MR. KERR: But I accept it for that.

20 MR. EPLER: Well, I do have a question. Have you
21 not by now shown that the failure rate is acceptable or have
22 you not?

23 MR. SPINELL: Mr. Epler, I think I would like to
24 ask Mr. Tom Cogburn from AP&L to address that.

25 MR. LIPINSKI: That is the next discussion.

1 MR. KERR: Are you going to discuss your
2 experience with the data link?

3 MR. COGBURN: Yes, I can.

4 MR. KERR: Are you willing to wait or do you want
5 an answer to that question at this point, Mr. Epler?

6 MR. EPLER: At any time.

7 MR. KERR: Okay. I would suggest that you do that
8 because I think you need to put your answer in some context
9 rather than answering it yes or no.

10 (Slide.)

11 MR. SPINELL: Let me then refer to the safety
12 evaluation report and the open item as it is currently listed
13 in Section 1.3 or Chapter 2 of the SER. The SER item
14 embodies three items listed thusly.

15 Over on the right I have identified the
16 documentation that we prepared for independent staff review
17 with respect to these items.

18 In each case we have submitted a set of function
19 description or data base documentation which we believe
20 meets the staff requirements. I understand that the staff
21 will talk later today about this documentation.

22 I can say this much. We are in a stage of review with
23 the staff and back and forth in a question and answer kind
24 of mode at this point on that documentation. This
25 documentation is to the same level of detail as what was

1 submitted on the Arkansas docket and what was reviewed
2 during that time frame.

3 MR. KERR: Is it your view that given time to
4 review the information available to the staff they probably
5 have enough information or would your experience up to now
6 indicate that in order to complete the review you are going
7 to have to provide additional documentation?

8 MR. SPINELL: Well, we may have to provide some
9 additional documentation to show more detail on certain
10 calculations instead of identifying results, but that is not
11 in our opinion going to be a time-consuming process because
12 that work is basically done at this point.

13 We will probably interact with the staff
14 considerably over the next month or two to converge on this
15 item and to help them progress and complete their review.

16 MR. KERR: Thank you.

17 MR. LIPINSKI: A question on that last item on the
18 thermal hydraulic methods. Are you going to cover that in
19 detail in the discussion after lunch on software changes?

20 MR. SPINELL: Correct.

21 MR. LIPINSKI: Okay.

22 (Slide.)

23 MR. SPINELL: My last slide this morning is an
24 identification, if you will, of other relevant licensing
25 items with respect to the software package itself, the

1 software qualification package, and I have listed two items
2 here.

3 First, the actual methodology or the framework by
4 which we go from a conceptual stage to a fully qualified
5 implemented stage of a particular software item that we want
6 to correct, modify or update.

7 Secondly, the software testing program that is
8 underway for San Onofre Units 2 and 3.

9 The software change procedure methodology which
10 will be covered in greater detail this afternoon is embodied
11 in a document CEN-39(A)-P listed here and its supplement.
12 The document embodies a complete methodology from conceptual
13 design stage through design implementation and
14 qualification, including the test cases that are required
15 for the test program, the test fixtures themselves and the
16 test facility.

17 This document was submitted to the staff for
18 review and it was approved for use with that single channel
19 facility in Windsor.

20 MR. LIPINSKI: What was the date for Revision 2
21 and the supplement? Are they recent documents or are they
22 old?

23 MR. SPINELL: They are not recent in the sense of
24 a few months.

25 Bill, can you help me a little more on this?

1 MR. LIPINSKI: Well, they were issued since ANO-2
2 review?

3 MR. SPINELL: They were issued after the initial
4 fuel load license for Arkansas.

5 MR. LIPINSKI: Okay.

6 MR. SPINELL: December of '78 I think is the date
7 on the document supplement.

8 I would like to further point out with respect to
9 this change procedure methodology that Edison has committed
10 to the use of this approved method to implement the software
11 changes that we will be discussing this afternoon. This
12 document then provides the framework for the existing
13 functional description and test program documentation which
14 we have. In the case of the test program we will be
15 submitting to the staff within two months.

16 The second point with respect to the software
17 testing program itself, in that we are performing it in
18 accordance with the CEN-39 as I pointed out, the results of
19 that test program for the various data and dynamic cases in
20 the Phase 1 and Phase 2 types of cases that we will be
21 running in accordance with that procedure as I identify will
22 be submitted in April '81.

23 In summary this this morning for my presentation I
24 have tried to provide you with an overview of the system, a
25 comparison of the San Onofre and Arkansas designs, the

1 status of the field equipment and the design and licensing
2 activities associated with that equipment.

3 In an overall sense we are in an advanced stage of
4 work with respect to both the hardware and the software both
5 in the field and at the Windsor site with respect to
6 qualification.

7 MR. KERR: Does that complete your presentation?

8 MR. SPINELL: It does, that is correct.

9 MR. KERR: Are there questions?

10 (No response.)

11 MR. KERR: Can you or will someone else indicate
12 how you have taken into account the experience with ANO 2 in
13 any changes or corroborations of the CPC design which you
14 are going to use on San Onofre?

15 MR. SPINELL: Well, Dr. Kerr, the next speaker,
16 Mr. Tom Cogburn, will be providing you a detailed assessment
17 of the ANO 2 experience.

18 MR. KERR: I understand that. What I am trying to
19 find out is how you have used that in order to either say,
20 hey, CPC was great the way we originally designed it or we
21 need to make these changes.

22 I recognize he is going to tell me about the
23 experience and maybe it makes more sense to answer my
24 question after I have heard more about the experience.

25 MR. SPINELL: We will be covering the second half

1 of that in the afternoon.

2 MR. KERR: Okay.

3 MR. SPINELL: We intend to give you our experience
4 first and then to show how that experience was incorporated
5 or is being incorporated into the cycle one.

6 MR. KERR: That sounds eminently logical.

7 Are there other questions?

8 (No response.)

9 MR. KERR: Okay. The next man up is from ANO 2,
10 Mr. Cogburn.

11 MR. KENNEDY: Dr. Kerr, I would like to point out
12 that Mr. Spinell in his presentation has effectively covered
13 Item 5 in the agenda, the San Onofre design and test status
14 with his slide that reviewed that test status. We will not
15 be covering Item 5 again so there is 15 minutes we can gain.

16 MR. KERR: Thank you, sir.

17 MR. KENNEDY: Now I will turn it over to Mr.
18 Cogburn. Mr. Cogburn is Superintendent of Plant Analysis at
19 Arkansas Power and Light.

20

21

22

23

24

25

1 (Slide.)

2 First of all, a brief summary of the ANO-2
3 milestones. The operating license was received on July 18,
4 1978. We began initial fuel loading July 23rd. Following
5 that, a post-fuel loading hot functional test period, and
6 then initial criticality in early December.

7 We first reached 100 percent power in January of
8 1980. You will notice that there is an extended period of
9 time from initial criticality to achieving full power. Of
10 course, one thing that affected that was the accident at
11 Three Mile Island which occurred in that timeframe.

12 Also, we had fairly significant problems with our
13 main steam safety valves which eventually had to be replaced
14 in total, and we had some significant failures in emergency
15 diesel generators.

16 The testing program was conducted primarily -- the
17 power phase of it was conducted primarily in the summer of
18 1979 and completed, largely completed in early 1980 with
19 commercial operation on March 26th of 1980. We anticipate
20 beginning our first refueling about a month from now.

21 (Slide.)

22 ANO-2 is rated at 15 megawatts. The first cycle
23 design burnup is 12,500 megawatt days per metric ton, and
24 this is equivalent to 326 effective full power days. The
25 burnup history I have given here for reference, this is the

1 amount of burnup accumulated in a year -- not a cumulative
2 number, but only the amount in that year.

3 We were at low power and only started up in late
4 '78, so there was very little burnup in '78. In '79 there
5 were many equipment problems, and we were involved in low
6 power testing through a lot of the period.

7 In 1980 the performance of the plant and the
8 burnup achieved was considerably larger, and through the
9 early part of 1981 it has been very good.

10 The capacity factor after achieving commercial
11 operation in this first cycle up to the middle of this month
12 has been 65 1/2 percent roughly.

13 MR. KERR: And commercial operation began at the
14 beginning of 1980?

15 MR. COGBURN: Correct. It was March 26 of 1980.

16 MR. KERR: Thank you.

17 MR. COGBURN: The items that I intend to proceed
18 with next are startup testing program, and then following
19 that the CPC system performance during testing period and
20 during operation during this first cycle.

21 (Slide.)

22 This slide shows really just a list of the tests
23 that were performed. Basically, the testing program
24 regarding the core detection calculators went very well.
25 There were no required hardware or required software changes

1 that resulted from the test program. All of the testing was
2 completed satisfactorily. There were minor modifications to
3 addressable constants, many of which were expected, some of
4 which were not expected but were easily accommodated.

5 Prior to criticality a test we called CEA exercise
6 test was conducted. This was basically just a movement of
7 the control rods in various operating configurations, both
8 normal and off-normal, and verification of the proper
9 indication of rod position with the CEACs and CPC system and
10 also the control system and plant processor computer.

11 We also verified the correct calculation and
12 look-up within the CEACs and CPCs based upon deviation or
13 overlap, rod overlap, exercise limits, etcetera. There were
14 no anomalous findings during that test.

15 We also conducted a response time test in the core
16 production calculator inputs. These response time tests
17 were primarily from single input through trip
18 generation-type test. The CEA response time was conducted
19 by a rod drop at subcritical condition with simulated inputs
20 for -- written into the computer for other signals.

21 The reactor coolant pump speed sensor and response
22 time was done by a two-pump trip under similar conditions.
23 The CEA position in the reactor coolant pump were actual
24 plant trips. A rod was dropped; pumps were tripped. The
25 other parameters were by signal injection, ramp, or in most

1 cases there were step changes, and then the predicted
2 response was done previously.

3 We had in the measured sensor response time to the
4 time it took from signal injection to CE and breakers open.

5 MR. LIPINSKI: Substituting for the sensor input?

6 MR. COGBURN: Correct.

7 During the power ascension phase we conducted
8 several tests related to the core production calculator
9 system. One test referred to is the CPC verification test.
10 We have really three different parts.

11 The first, at the power level shown here, involved
12 a comparison of field-measured inputs and outputs for DNBR
13 and local power density from the CPC system, and these were
14 compared off-line after the fact by inputting those same
15 inputs into the Fortran version back at Windsor. And the
16 Fortran version statistically varied the inputs and outputs
17 in the expected range of this, which we used to compare and
18 verify that the CPCs were proper calculating in the field as
19 they should.

20 Also, at the request of the NRC staff a test was
21 performed at various power levels to evaluate the noise and
22 core calculator protection system. These tests involved
23 recording of process signals, taking the data bank to
24 Windsor, using the hardware at Windsor to compare a
25 noise-free signal to one with process noise, and verify that

1 process noise always made the resulting DNBR and LPD
2 conservative.

3 Also, at the request of the staff we conducted an
4 electromagnetic interference survey. This was done at one
5 power level in the control room, in the core protection
6 calculator room which we had for calculators. Surveys were
7 done, and the signals that were measured were compared to
8 minimum susceptibility for interference limits that had been
9 established previously, and the signals measured were
10 considerably below the thresholds.

11 MR. LIPINSKI: Could we go back to number one, the
12 CPC versus Fortran? Did you record all the input parameters
13 to the CPC as well as their outputs?

14 MR. COGBURN: Yes, we did.

15 MR. LIPINSKI: And this is how the comparison was
16 generated?

17 MR. COGBURN: We observed the CPCs for a period of
18 time -- several minutes -- and determined the minimum and
19 maximum value for each and every parameter and also observed
20 the minimum and maximum output per calculated result, the
21 DNBR.

22 MR. LIPINSKI: Did you do any rod drops or any
23 initiating transients, or is this just a static comparison?

24 MR. COGBURN: This is a static comparison.

25 MR. LIPINSKI: Did you do any effort on dynamic

1 performance?

2 MR. COGBURN: Not in the field, no. The C-SEC
3 verification which is -- some tests were conducted regarding
4 the CE code, C-SEC, for transient analysis, and there was a
5 little data generated at that time but not specifically for
6 that purpose.

7 MR. LIPINSKI: So this system is installed, and
8 all you know is that it has steady performance, but you have
9 no verification of dynamic performance?

10 MR. COGBURN: The dynamic performance is evaluated
11 by off-line testing of the software compared to many cases
12 that are generated by the design codes for design of the
13 plant. This will be described in the startup -- excuse me
14 -- software change procedure discussion later.

15 MR. LIPINSKI: I'm aware of the procedures testing
16 it off-line, but it seems like one or two dynamic tests
17 would have been beneficial.

18 MR. GILL: Excuse me. You did run the rod drop in
19 --

20 MR. COGBURN: Yes, that's correct. We did. Those
21 tests included evaluation. There are a couple of tests that
22 I did not include here -- a loss of flow test from 80
23 percent power, a tripping of all reactor coolant pumps,
24 which part of that test -- part of the purpose of that test,
25 one of the C-SEC verifications of the test was to evaluate

1 the CPC performance.

2 MR. LIPINSKI: Now, were the input parameters
3 recorded in the CPCs as well as the outputs in the course of
4 the test?

5 MR. COGBURN: Some of them were, the ones that
6 could be recorded from the analog signals that exist. The
7 data links to the plant computer cannot access or do not
8 access at that frequency. Maximum time was ten seconds from
9 scan.

10 MR. LIPINSKI: The system works under dynamic
11 conditions.

12 MR. COGBURN: We measured the time to trip for
13 that condition. We also did a couple of rod drop tests
14 which were performed where we recorded system parameters,
15 CEA position, etcetera, and also measured the trip time.

16 I believe the important inputs to the analysis
17 were recorded, but not all of the inputs could be recorded.

18 MR. LIPINSKI: Okay. Thank you.

19 MR. COGBURN: I'll go very quickly through the
20 rest of these tests. The flow rate measurement, the
21 calibration that Bill Gill mentioned earlier, we called it
22 the RCS calorimetric flow rate measurement. This test was
23 performed to verify adequate reactor system flow and to
24 adjust the CPCs to the measured flow, minus some drift
25 allowance.

1 CEA shadowing factor was performed. The
2 measurement was performed to compare the ex-core detector
3 response observed to CEA insertions with those that were
4 installed or inspected in the CPC system.

5 Temperature decalibration --

6 MR. KERR: Excuse me. Would you say a little bit
7 more about C?

8 MR. COGBURN: How it was performed?

9 MR. KERR: Or what it -- it is referred to as a
10 shadowing factor measurement, and I just wondered what one
11 measures as a shadowing factor.

12 MR. COGBURN: Control rods, when inserted in the
13 core, especially peripheral rods, have a significant effect
14 on the ex-core detector response because of their shadowing
15 or shielding effect.

16 MR. KERR: That I understand, but what is it you
17 measure?

18 MR. COGBURN: We measure in this case the neutron
19 detector response with CEAs inserted and not inserted, and
20 compare those to the calorimetric power level and adjust the
21 signal response or verify the signal response of the neutron
22 detectors is adequately compensated. We also use in-core
23 detector signals for power distribution from the core.

24 MR. KERR: I guess I can't tell then whether C,
25 was an effort to verify previous calculations or was in

1 effect a calibration procedure.

2 MR. COGBURN: It was both. In effect, the purpose
3 was to either verify that existing correction CEA shadowing
4 factors were adequate within the acceptable margins or to
5 verify that by changing addressable constants, they became
6 acceptable.

7 In this particular test we did require additional
8 uncertainties to be added in the addressable constants to
9 cover a small amount of difference between the shape --
10 excuse me -- the shadowing factors built into the CPCs and
11 those measured.

12 There were no addressable constants that
13 explicitly included to adjust CEA shadowing factors in the
14 original design.

15 MR. KERR: In an RCS calorimetric flow measurement
16 what does one measure, flow rate or power or --

17 MR. COGBURN: We assume the biggest unknown in the
18 primary heat balance is the reactor system coolant flow, so
19 basically we do a heat balance across the steam generator,
20 the primary calorimetric as compared to the secondary
21 calorimetric, assuming all of the inputs or knowns, with the
22 exception of reactor system coolant flow rate, and then
23 those two equations are solved for the known system flow
24 rate.

25 MR. KERR: So you assume that you can measure

1 accurately the heat rate in the secondary heat output?

2 MR. COGBURN: Yes, that's true. Prior to this
3 point we had done --

4 MR. KERR: No. I want to understand what you did
5 here. You assume a secondary heat balance is a known.

6 MR. COGBURN: The industry practice, which I'm
7 sure you're well aware of --

8 MR. KERR: No. I'm not well aware of industry
9 practice.

10 MR. COGBURN: There is --

11 MR. KERR: Believe it or not, there is
12 occasionally one of these documents that I don't read.

13 (Laughter.)

14 But assuming that the secondary heat balance is
15 known --

16 MR. COGBURN: Yes.

17 MR. KERR: You then do a primary heat balance with
18 the flow as an unknown, and you calculate the flow on that
19 basis, is that what it amounts to?

20 MR. COGBURN: Yes, sir.

21 MR. KERR: Thank you.

22 MR. LIPINSKI: Your flow in the primary system is
23 by delta P on elbows, is that correct?

24 MR. COGBURN: We have pump speed.

25 MR. LIPINSKI: No, forget about the pump speed on

1 the CPCs, but you did have delta P measurements across the
2 elbows, I believe, do you not?

3 MR. COGBURN: Across the pumps.

4 MR. LIPINSKI: Not across the elbows at any point
5 for a pressure dump? No? Okay. That's a Westinghouse
6 plant then.

7 MR. KERR: And it is industry practice to assume
8 that this secondary heat balance can be made within two
9 percent or something like that?

10 MR. COGBURN: That's correct.

11 MR. KERR: Do you believe that?

12 MR. COGBURN: Yes, I do. If it's properly -- if
13 the instrumentation is properly surveilled and maintained as
14 it should be. The CPC assumes the accuracy of the RCS
15 calorimetric load to be 3 1/2 percent, I believe, and that
16 uncertainty is built into the CPC system.

17 MR. LIPINSKI: What's the accuracy then on your
18 total thermal power?

19 MR. COGBURN: Two percent.

20 Shall I continue?

21 MR. KERR: Please.

22 MR. COGBURN: I believe the next test that I have
23 not discussed is the temperature decalibration measurement.
24 This is also measurement of the effect of temperature
25 changes, cold leg temperature changes upon the response of

1 the neutron detectors, the ex-core neutron detectors.

2 MR. KERR: Can you tell me what a decalibration is?

3 MR. COGBURN: The amount of change or inaccuracy
4 that is induced by changes in the coolant temperature unless
5 -- in the standard PWR design prior to ANC-2, I believe all
6 plants such as our Unit 1 do not compensate for this
7 directly. It requires a manual calibration. The effect, of
8 course, is cold leg temperature decreasing, higher moderator
9 density, less neutron flux reaching the ex-core detectors,
10 causing a decalibration.

11 For the same power if you drop cold leg
12 temperature, the response of the neutron detectors becomes
13 decalibrated in a non-conservative direction.

14 MR. KERR: Would this mean the same thing if it
15 were called temperature calibration measurement?

16 MR. COGBURN: It wouldn't to me. It might to
17 someone.

18 MR. KERR: Okay. Because it would seem to me from
19 what you've said, you are calibrating the system to take
20 account of temperature effects.

21 MR. COGBURN: That's correct. The CPC system does
22 this automatically on-line. The radial peaking factor
23 verification involves setting up different control rod
24 conditions in critical geometries at steady power level and
25 measuring with the in-core detectors the radial power

1 distribution, calibrating the maximum radial peaking factors
2 using in-core detectors and in-core analysis codes, and then
3 comparing these calculated radial peaks to those in the CPC
4 look-up tables, and verifying that the measured values were
5 more conservative or smaller values than the CPCs assume
6 given rod configuration.

7 This was in fact the case. I think the magnitude
8 of conservatism was varied, from 4 to 10 percent roughly
9 depending on which CEA banks were inserted.

10 MR. KERR: These were compared with radial peaking
11 factors calculated for 50 percent power?

12 MR. COGBURN: Yes. The radial peaking factors are
13 actually not power level dependent.

14 MR. KERR: How do you know?

15 MR. COGBURN: I would see if someone from CE could
16 answer that for me.

17 MR. KERR: I thought that's the reason one
18 measured them, because one was trying to verify the fact
19 that calculations are valid.

20 MR. COGBURN: That is not really the purpose of
21 this test, but we also verified core power distribution
22 measurements. I did not detail all of the procedures that
23 we ran by any means, but I just picked the ones that were
24 specifically run for CPCs. But there were several other
25 core power distribution verifications to go back to design

1 comments. This was simply a checkpoint really on the CPCs.

2 Mr. Gill.

3 MR. GILL: Bill Gill from Combustion Engineering.

4 Let me have one item on the radial peak power dependency.

5 The analytical calculations that are now predicted, the

6 power peaks to be power dependent, but that is of little

7 importance when you have the ability to measure.

8 CE does have a core follow program on many of our
9 operating reactors where we get monthly snapshots of in-core
10 detector ratings at various power levels, and these
11 snapshots are continuously used to validate the design
12 codes, and that's the basis for this statement.

13

14

15

16

17

18

19

20

21

22

23

24

25

1 MR. COGBURN: The other CPC specific test was
2 actually conducted at 20 percent and 50 percent of power, as
3 opposed to what I have written here. The shape annealing
4 matrix test involves establishing or setting up an axial
5 xenon oscillation at a stable power level. This is done by
6 achieving criticality with the lead bank control rods
7 inserted in the midpoint of the core, operating for several
8 hours to achieve near-equilibrium xenon conditions, then
9 withdrawing them rapidly.

10 This -- at 20 percent power the oscillation that
11 we induced that way dampened rather quickly. At 50 percent
12 power it lasted for well over 60 hours, which was the goal.
13 And the reason for doing it that way was to establish a
14 large variety of different axial shapes.

15 During the test we measured and recorded the
16 ex-core detector signals, using the CPC-to-plant computer
17 data links and various other inputs to the CPC in that
18 manner, and recorded the power distributions that result
19 basically -- the in-core detector measured power
20 distributions recorded concurrently.

21 Then the shape annealing matrix is a square fit
22 for the three detectors in each channel, which compares the
23 in-core detector, three segments of the core -- or three
24 segments of the core, top, middle, and bottom, based on
25 in-cores to top, middle, bottom signals from the ex-cores.

1 The boundary condition is just measuring the
2 reflector savings point or the point where the flux goes to
3 zero from in-core detectors.

4 The objective was to calculate a matrix that would
5 be representative of the -- of many different shapes and
6 would be able to be used to synthesize from the three
7 ex-core detector signals and the boundary points from those
8 five points an axial shape -- an axial power distribution
9 for the core.

10 So we determined the shape annealing matrix and
11 put that into the CPC system and made some minor adjustments
12 to the boundary condition by way of additional uncertainty
13 factors through addressable constants.

14 MR. LIPINSKI: This was done by analysis prior to
15 your going into operation. How close did your measurements
16 compare to the analysis that had been done previously?

17 MR. COGBURN: I don't think there was ever any
18 expectation that they would be very close, and they were, in
19 my opinion, not that close.

20 It's very difficult to predict the ex-core
21 detector response, of course, because of the complicated
22 geometry around the reactor vessel. The concrete structural
23 members and so on are not really possible to model. But the
24 response of the upper and lower chambers was better than
25 predicted.

1 So with the predicted shape annealing matrix or
2 the initial shape annealing matrix, for a co-sine-shaped
3 distribution, we actually saw a somewhat saddle-shaped
4 distribution, a double hump. Because of this, we
5 implemented the shape annealing matrix at 20 percent power,
6 and we had only planned to run and implement one at 50
7 percent power.

8 And then we modified it by the results at 50
9 percent power, because they would be expected to be a little
10 bit better, because the signals are larger at 50 percent.

11 MR. LIPINSKI: Could you refresh my memory. Were
12 you using a fit as part of the shape annealing matrix?

13 MR. COGBURN: Yes. Maybe Howard or Bill --

14 MR. GILL: The answer is yes. We could elaborate
15 on it if you would like.

16 MR. LIPINSKI: I would like a better discussion,
17 because when you are doing the development of this system it
18 was based on being able to make measurements with a certain
19 accuracy on these ex-core detectors. Now you've got the
20 experimental data. Were you surprised or not?

21 MR. GILL: I think the answer is no, we were not
22 surprised. If you look at the fitting technique, it is a
23 matrix and it is a series of numbers, a three by three
24 matrix. A very small change in that matrix can have a large
25 impact on the power distribution.

1 I think our ability to predict was good. We knew
2 that one of the most vital or critical measurements in terms
3 of CPC calibration was the determination of that matrix.

4 But, as Tom had mentioned, our ability to
5 calculate the transport of neutrons from the peripheral
6 bundles out to the ex-core detectors is one we did not have
7 a high degree of confidence in. It is a complex phenomenon
8 where it is actually faster with neutrons getting to the
9 detectors being slowed down, not only through the water in
10 the vessel, but also through the concrete, with a high
11 degree of scattering.

12 So we were aware that we had to make measurements
13 and that those measurements would not really be a check or a
14 validation of matrix, but would be a determination.

15 MR. LIPINSKI: Having measured this double hump
16 rather than the uniform distribution, are you now able to
17 explain the double hump by analysis?

18 MR. COGBURN: I don't -- well, refer that to Bill
19 again, or Howard.

20 MR. GILL: We could have our physics people try to
21 explain that. It would probably take a half hour or more.
22 I can't explain it.

23 MR. LIPINSKI: I don't know that it's necessary at
24 this time.

25 MR. KERR: Well, the question simply was, I think,

1 whether you were able to explain it. You didn't ask for an
2 explanation.

3 MR. COGBURN: And the answer is yes, I believe.

4 MR. KERR: The answer seems to be being formulated
5 at this point.

6 (Laughter.)

7 MR. GILL: I think we have a consensus vote. We
8 understand why it happened and we understand the phenomenon
9 which resulted in the double hump.

10 MR. KERR: So the answer is, I think, that
11 qualitatively it can be explained, but it has not yet been
12 explained quantitatively; is that fair?

13 MR. GILL: I think it's been explained both
14 qualitatively and quantitatively. It's a repeatable
15 phenomenon where we understand how we calculate the matrix
16 that was there and we understand how the ex-cores were
17 processed and why we came up with a double hump.

18 We know what we did to fix it, and there is no
19 surprises or unknowns in the scenario, in the power
20 distribution.

21 MR. LIPINSKI: Had you approached the problem from
22 the design standpoint in the forward direction, could you
23 generate a double hump?

24 MR. GILL: There's always a matrix I can find that
25 would give you a double hump, given the ex-core readings.

1 MR. LIPINSKI: That's not the question. Given
2 three detectors stacked one on top of another, with the
3 shape of the flux within the core, would you be able to
4 predict that those ex-core detectors would measure a double
5 hump?

6 MR. KERR: I guess I'm not quite sure what you
7 mean by the question, because are you asking, given the
8 state of knowledge before they made this measurement or the
9 present state of knowledge? Clearly, with the existing
10 information, one could predict the double hump. Either you
11 or I could do it if we knew it existed.

12 MR. LIPINSKI: That's not the question, because
13 they have a technique --

14 MR. KERR: Are you asking whether they could
15 predict it before they had the existing information or
16 whether they could predict it now?

17 MR. LIPINSKI: Whether they could predict it now,
18 knowing that it's a phenomenon that does take place.

19 MR. KERR: With five good Combustion engineers,
20 they could do it. There's just no question about it.

21 MR. LIPINSKI: Well, what's bothering me is
22 whether they have even looked at their analysis techniques
23 to explain why it has taken place. I know of the fact that
24 it has taken place. Fudge factors have been put into the
25 matrix to make it match what they have measured.

1 MR. COGBURN: Well, I think in a sense it was
2 expected all along, as discussed with the NEC staff during
3 review, I know. I'm not sure of the ACRS. It was expected
4 that we would not predict the shape exactly right.

5 MR. LIPINSKI: But in all of the prior review
6 there was no anticipation of a double hump.

7 MR. COGBURN: I don't know about that. You expect
8 to see double humps.

9 MR. GILL: Let me turn this over to Howard
10 Neuschaeffer, who actually analyzed the data from the
11 plant. He can give a summary that might help you analyze
12 your question.

13 MR. KERR: Can he do it in less than five
14 minutes?

15 MR. GILL: Let me check.

16 Yes.

17 MR. NEUSHAEFFER: I think there is first a minor
18 degree of confusion here in that the double hump
19 distribution was not a real measure distribution that was
20 double humped. The power distribution in the core at the
21 time of measurement was a co-sine distribution, so that we
22 were expecting to have a co-sine.

23 The preliminary shape annealing matrix that we had
24 installed was based on prior calculations, which are a
25 fairly difficult calculation to perform in terms, as

1 mentioned by Mr. Cogburn, of you have got a very diffused
2 degree of scattering out there in the cavity.

3 As you get from the core and the vessel and bounce
4 around the structure, your neutrons are doing all kinds of
5 weird things. So you make estimates of this, using some
6 fairly difficult techniques. And it's a calculation that
7 tends to be uncomfortable. You're uncomfortable with
8 relying on the results too much.

9 So we went in and developed this test procedure
10 where the calculation of the matrix was verified
11 experimentally. Now, what would have been nice, were it
12 possible -- and it does not seem to be possible, with the
13 state of the data we were able to measure -- is if we could
14 go in and predict the scattering of core neutrons or measure
15 the way the core neutrons will scatter from various parts of
16 the core to the detectors in enough detail that we could go
17 back and precalculate a good shape annealing matrix and not
18 have to do this measurement again.

19 What we did instead is, we get the matrix itself,
20 which is a three by three, nine data items, rather than a
21 detail of about 20 by 3 or some 60 data items that you would
22 need to try and do the prediction of the ex-core, of the
23 shape annealing matrix very accurately.

24 So I think the situation is that we know what has
25 happened. We understand the basic phenomenon that we -- our

1 calculation of the neutron scattering effects was not as
2 good as we would like it to be, but there does not seem to
3 be at this point a way of improving that in a
4 calculationaly feasible way.

5 In principal, you could run thousands of hours of
6 computer calculations and perhaps improve it. What you are
7 getting instead is a measurement technique that will allow
8 you to account for the fact that this is a difficult
9 calculation to do and that it is in effect a callibration
10 procedure of this particular component of the CPC's to the
11 real situation.

12 MR. LIPINSKI: May I summarize what I thought I
13 just heard? Given experimental data, you still say you
14 cannot take your analytical results and modify them to
15 predict what you measured experimentally.

16 MR. NEUSHAEFFER: No, I didn't quite say that. I
17 said I cannot take my measurement data and use it to predict
18 a shape annealing matrix which will be as good as the
19 measured shape annealing matrix. I can measure better than
20 I can predict this phenomenon, because the measurement does
21 not have enough detail in the axial sense to allow me to
22 calculate better.

23 MR. LIPINSKI: Maybe we're saying the same thing.
24 Let me say it again. Given a co-sine flux distribution in
25 the core and the transport of neutrons from the various

1 regions in the core to the three detectors, can you now make
2 a better prediction as to what each detectors sees,
3 integrated over the total length of that core?

4 MR. NEUSHAEFFER: In a sense better, but not good
5 enough to alleviate the need for this measurement.

6 MR. LIPINSKI: No. Given the measurement, can you
7 then adjust your calculational techniques?

8 Are you trying to do it? That's the next
9 question. I suspect that you may not have. All you've done
10 is put the fudge factors in.

11 MR. GILL: There's nothing we see in a power plant
12 that we don't go back and try to understand our analytical
13 methods. So the answer is we've gone back and modified our
14 analytical methods to the extent practicable. It is not
15 sufficient to replace the measurement.

16 MR. KERR: Mr. Gill, I'd be careful if I were you,
17 because I believe that with today's state of the art, if you
18 want to spend the necessary money, you could calculate
19 this. I think it would be foolish to do it, but it's within
20 the state of the art.

21 It seems to me the important issue here is whether
22 you can use this particular matrix for a different power
23 shape in the core. My guess is you cannot, because you have
24 arrived at the matrix on the basis of a co-sine power shape,
25 and if you get something in the core that is different from

1 the co-sine power shape, it seems to me you have some
2 difficulty demonstrating that you could use this matrix.

3 Now, perhaps you have arrived at several different
4 matrices, each of which is appropriate to a different power
5 shape. Or perhaps you always have a co-sine power shape,
6 which I doubt.

7 MR. COGBURN: One of the purposes of the
8 surveillance, the core follow program, we call it, is to
9 verify that the CPC axial shape in synthesis is adequately
10 reflected throughout the cycle. And we have observed that
11 the shape annealing matrix has been adequate for this first
12 cycle. We will determine a new one.

13 MR. KERR: But that may simply mean you have the
14 power shape through the first cycle that is about the same
15 as the power shape you used to derive the matrix. And it
16 seems to me the question is whether you could use it if you
17 have a rather different power shape.

18 MR. NEUSHAEFFER: The answer to that question is
19 you can use it for a range of power shapes, the reason being
20 that the measurement of the matrix itself covered a wide
21 range of power shapes.

22 The oscillation that Mr. Cogburn mentioned
23 included ASI ranges from, I believe it was, plus .2 to minus
24 .2, approximately, which is a fair range of shape at
25 beginning of cycle. So that you have covered both top and

1 bottom peak and center peak shapes in the measurement.

2 The matrix is thus kind of a weighted average
3 matrix, which will cover that range of shapes. If you get
4 later in cycle and your power shapes tend to flatten in the
5 center and go saddle, calculations have indicated that you
6 will become more conservative in your estimate of both
7 linear heat rate and DNB, since your beginning of cycle
8 shape measurement will have left you with a shape annealing
9 matrix that tends to make you appear more highly peaked.

10 It's a higher axial peaking factor than your axial
11 shape would have. So you tend to build in with lifetime a
12 little bit of extra conservative calculation, because the
13 CPC will think it has a somewhat more peaky shape than it
14 really does.

15 So we have considered that. And we have also, in
16 our uncertainty assessments, looked at a much wider range of
17 shapes out to the full range of what CPC has been qualified
18 for. And the uncertainty values themselves include an
19 allowance for the fact that you can possibly get shapes
20 which are wider than the range of shapes that were actually
21 used in the measurement.

22 MR. LIPINSKI: Has the topical report been written
23 on the experimental work in comparison to the original
24 analysis?

25 MR. COGBURN: The ANO-2 startup report documents

1 the comparison of this information. I have a copy with me
2 if you would care to look at it, a copy of that portion.

3 MR. LIPINSKI: Mr. Chairman, when we reviewed this
4 system initially there were these concerns with respect to
5 the shape annealing matrix. And from the discussion that is
6 proceeding now, you now have the feedback from experimental
7 information back to the original analysis.

8 And I have not seen the report referred to, but I
9 think there is a question here in terms of performance of
10 the system and how these constants are being handled in this
11 shape annealing matrix. I wouldn't propose that we go into
12 it in detail at this time.

13 MR. KERR: Okay. You might think some about what
14 you would propose.

15 Please continue.

16 MR. COGBURN: Thank you.

17 In conclusion, regarding the startup test program,
18 it was our conclusion that the testing was accomplished
19 accurately and some minor adjustments were necessary, but
20 all within the capability built in the core protection
21 calculator system.

22 We did identify some desirable features in-- to
23 make changes in the area in software, and these are planned
24 and they will be described later on in the afternoon.

25 The next area I intend to cover is the experience,

1 or really, the problems that we have had with the core
2 protection calculator system. The initial performance of
3 the calculators has resulted in a number of failures and
4 trips. I will go into those in detail.

5 The kind of problems that we have had are
6 basically -- I haven't put a slide up here yet -- room and
7 cabinet cooling, AC power supply inverter problems,
8 connector problems, insufficient diagnostics. And there
9 were a couple of algorithm oversights. And I will discuss
10 how they occurred and what we do about them.

11 First of all, the CPC's have initiated a number of
12 plant trips -- reactor trips, a total of 28 to date,
13 including one that occurred about a week ago. The numbers
14 and when they occurred, I have broken down on this table.

15 Of these trips, I'm going to use the terms "valid
16 trips" and "non-valid trips." By valid trips I mean the
17 CPC's were responding in their trip to some plant event,
18 design basis event which occurred. And by non-valid trips I
19 mean spurious trips or trips that occurred because of a
20 hardware failure, because of an error, a human error, or
21 because of a spurious signal of some sort.

22 (Slide.)

23 The valid trips on this list are nine: four of
24 them in '79, four in 1980, and one in 1981. The rest are,
25 quote, "non-valid trips," and I will go into a slide that

1 breaks this down a little further in a moment.

2 I would like to point out here that the CPC's and
3 all of their failure mechanisms that we have observed have
4 always failed safe.

5 MR. KERR: Mr. Cogburn, do you know, during this
6 period during which 28 trips were CPC-initiated, how many
7 total trips you experienced? Not exactly, but 2 or 20 or 50?

8 MR. COGBURN: 70.

9 MR. KERR: 70?

10 MR. COGBURN: Many of these trips occurred at very
11 low power levels, one percent or less.

12 MR. KERR: Does 70 include these 28?

13 MR. COGBURN: Total.

14 MR. KERR: Thank you.

15 MR. COGBURN: I can give you an exact number.

16 MR. KERR: That's close enough.

17 MR. COGBURN: I would like to point out that the
18 majority of these trips occurred prior to commercial
19 operation in the early part of the cycle. If you go back to
20 the second slide, very little burnup had occurred at that
21 time.

22 Since commercial operation, the number has been
23 eight.

24 MR. LIPINSKI: For the date, you are using March
25 26th, 1980 as the dividing line?

1 MR. COGBURN: Yes. I believe 74 full power days
2 before commercial was the number I had there -- no, excuse
3 me -- yeah, 74, approximately 220 power days since
4 commercial.

5 I have plotted a curve for the frequency of trips
6 and the amount of core burnup that has been achieved between
7 CPC trips and just non-valid trips.

8 (Slide.)

9 Because I think that is probably of concern or
10 interest, versus time. I just averaged the numbers that
11 occurred over time, and I tried to account for the operating
12 down time by factoring in the burnup that occurred in this
13 time period.

14 So I would like to point out here that the
15 frequency of trips or the time between trips is increasing
16 -- has been increasing all along, particularly since the
17 early problems were resolved. We are going to discuss today
18 a couple of software modifications that were made.

19 MR. KERR: I have a suggestion. I think that
20 curve would look better if you rotated it 90 degrees, but
21 that's incidental.

22 MR. COGBURN: That way?

23 (Laughter.)

24 MR. COGBURN: Well, I like it this way.

25 MR. KERR: Okay.

1 (Laughter.)

2 MR. COGBURN: But I'm sure I respect your
3 opinion.

4 The two software modifications that I was
5 referring to did occur approximately here and here in time,
6 and I think they had something to do with the improved
7 performance.

8 (Slide.)

9 MR. LIPINSKI: Let me make sure I understand.
10 Each point on that curve was a trip? No?

11 MR. COGBURN: Actually, that is -- I realize this
12 is kind of confusing. I had a hard time figuring out how to
13 present this. But what it is is each point is not a trip.
14 It may be several trips.

15 MR. LIPINSKI: It says "between trips," though.

16 MR. KERR: It's an average over a period.

17 MR. COGBURN: It's an average over a period that
18 accounts for the operating time in the plant. It normalizes
19 it.

20 MR. LIPINSKI: You could have put it in the right
21 form. Since this is integrated time, you could have put it
22 in the right.

23 MR. COGBURN: That's true. It might have been
24 better.

25 MR. LIPINSKI: You didn't know that you got all

1 this good advice from the ACRS Subcommittee, probably.

2 (Laughter.)

3 MR. COGBURN: I'm pleased to have it.

4 (Laughter.)

5 MR. COGBURN: I would like to point out, as an
6 excuse for maybe the poor quality, there was very little
7 time.

8 MR. KERR: It's an excellent quality slide.

9 (Laughter.)

10 MR. COGBURN: Thank you. I drew it myself.

11 (Slide.)

12 I said that I would try to break down the cause of
13 the trips and then describe the reasons for them, and I will
14 attempt to do that. Of the 28 trips, we have attributed 12
15 of those to hardware failures. All of those hardware
16 failures were related to the CEA position input and are a
17 direct result of the one out of two design with the core
18 element assembly calculators -- control element and assembly
19 calculators.

20 Seven of those 12 trips were caused by an
21 intermittent hardware failure. One specific hardware
22 failure that we had a lot of trouble defining, it wasn't
23 until after some additional diagnostics had been added and a
24 software change, that we were able to determine the failure
25 and repair it, and that was done in June of 1980.

1 These all occurred on CEA No. 2.

2 MR. KERR: What sort of hardware was it that was
3 intermittent?

4 MR. COGBURN: Cable, an open cable. It was a
5 section -- well, connector. We narrowed it down to a piece
6 of cable with connectors on it about yea-long and replaced
7 that.

8 The other five were independent similar problems,
9 but independent of that one. What it was was a single CEA
10 position, rod number 67, position indication to CEA number
11 2, was intermittently going to zero. So it looked like a
12 dropped rod as far as that CEA. That's what we put.

13 It generated a large penalty factor. The CPC is
14 solid and dropped all four channels.

15 MR. LIPINSKI: I missed the first part of your
16 statement. Did the CEA's actually drop or not?

17 MR. COGBURN: No, it was a spurious signal, a
18 hardware failure. The CEA's did not actually drop. There
19 are CEA drops in here and I will get to them next.

20 MR. LIPINSKI: Well, that's a mislabel.

21 MR. COGBURN: No, that's B. That's the second
22 item.

23 One other thing I would like to say while I am
24 still on the hardware failures is, I said we improved --
25 this situation was improved by software. And Mr. Rozek of

1 Combustion will describe that in more detail.

2 But the one feature I would like to describe out
3 of that is we added a feature to try to discriminate out
4 failures of CEA position. That was done by a rate of change
5 of CEA position. If the rod was indicated to fall faster
6 than it could physically fall, then that failure is now not
7 considered valid and it causes that input to be marked as
8 failed and that calculator is not used. The other one is
9 relied on.

10 MR. LIPINSKI: I'm going to make a note. This is
11 another change that was not in the original review.

12 MR. DITTO: I'd like to comment here on your
13 statement earlier that all of the failures were safe
14 failures.

15 MR. COGBURN: Well, the reactor protection
16 occurred.

17 MR. DITTO: Now, the reason this thing was
18 detected was because you had one failure which went to the
19 CEA calculator, and then it went from there to all four
20 channels. Had it been a safe failure you might never have
21 known it existed -- I mean unsafe failure. Excuse me.

22 So your statement that all of the failures, all of
23 them you saw were safe failures -- but then there could have
24 been a dozen or a hundred, even, unsafe intermittent
25 failures that you didn't see because you weren't testing or

1 you didn't have an accident. So be a little careful.

2 MR. COGBURN: I cannot refute what you are saying,
3 but I completely believe that --

4 MR. DITTO: I believe it. But then it's not
5 obvious from the data you have.

6 MR. KERR: I thought what he said was all of the
7 failures he observed were safe failures, and I don't think
8 --

9 MR. COGBURN: If there were any that occurred that
10 were not observed, I can't say anything about them.

11 (Laughter.)

12 MR. DITTO: It's almost obvious, though, that all
13 you observed will be the safe ones.

14 MR. COGBURN: No, I don't think so. There are
15 other ways of detecting failures that may not result in
16 channel trips issuing. And what I'm saying is that all
17 failures that occurred of instrument nature or processing
18 nature or timing or anything have always resulted in CPC
19 trips.

20 MR. KERR: There's a design criterion and it says
21 all failures have to be safe failures.

22 MR. DITTO: It's obvious.

23 MR. LIPINSKI: Let me summarize what I think I
24 just heard. You have hardware failures indicating spurious
25 rod drops, and in order to inject hardware failures you have

1 now modified the software.

2 MR. COGBURN: Yes, that is correct. We have done
3 other things also.

4 MR. LIPINSKI: Rather than fixing the hardware
5 failures, you now have modified software that's going to
6 look the other way and say this is a hardware failure, it's
7 not a legitimate failure.

8 MR. COGBURN: We have also tried to correct the
9 hardware problems as well, because the problems have been
10 typical in my experience of instrumentation systems. When
11 they are started up, connector problems are common with new
12 systems, and you will always have such. You cannot
13 eliminate them.

14 But we have tried to eliminate open signals,
15 shorts, this kind of thing, through testing and through
16 replacement. And it might be a good time to point out that
17 AP&L's maintenance practice or philosophy of maintenance
18 practice is to not replace components until we know the
19 class of failure.

20 Even though we have a general area pinned down as
21 to the failures in here, we do not go replace in a shotgun
22 fashion several components, saying, well, somewhere in here
23 we replaced that. We might have had better plant
24 availability if we had done that, but our philosophy has not
25 been to do that.

1 It has been to try to narrow down the problems and
2 eliminate the startup problems and new system problems.
3 Because our experience has shown us in the long run that it
4 pays.

5 MR. LIPINSKI: What disturbs me is your philosophy
6 of not fixing a cause, but going further downstream.

7 MR. COGBURN: We are doing both, sir.

8 MR. LIPINSKI: There are other ways to fix a
9 hardware problem. You have a variety of things at your
10 disposal.

11 MR. COGBURN: This is something we are evaluating
12 right now. That is a major change, though, and it requires
13 a serious evaluation to go in and change the miles of wiring
14 involved in the system.

15 MR. KERR: When you get this spurious signal that
16 might be caused by hardware failure, does the total system
17 ignore that or does it record it but just not trip the
18 reactor?

19 MR. COGBURN: It records it but does not trip the
20 reactor. And it also causes a failure indication on the
21 channel affected as well.

22 MR. LIPINSKI: But the recording is via the
23 connection through the plant computer?

24 MR. COGBURN: No, sir. The recording is a
25 software diagnostic that was added.

1 MR. LIPINSKI: So that it comes off on an on-line
2 typewriter?

3 MR. COGBURN: No, it is recorded in the core
4 memory. The parameters are recorded in the core memory.
5 And then you must hook up a teletype in an off-line mode to
6 dump this information out, or some of it is just playable
7 through the operator's module.

8 MR. LIPINSKI: How often do you dump to find out
9 that you've got misbehaving rods?

10 MR. COGBURN: Any time that we have an indication
11 of a misbehaving rod.

12 MR. LIPINSKI: But these contacts are not going to
13 be displayed to you.

14 MR. COGBURN: No, there is a flag set on the out
15 module to tell you that it occurred, and we examine that log
16 once a shift. And if there is a set, a value set, then we
17 dump that automatically or by administrative controls.

18 MR. LIPINSKI: There weren't too many display
19 lights on that console. Which particular one comes up?

20 MR. COGBURN: There is a point ID. There is a CEA
21 fail light that comes on. But that may not stay in if the
22 signal clears itself, which is commonly the problem that I
23 am talking about here.

24 But there is also a flag set or an addressable
25 point ID that we examine once a shift, the operators examine

1 and see if it is set in each of the six computers. And then
2 if it is set, we get the report out.

3 Also, the number of failures is logged in
4 addressable values, not changeable values but addressable
5 values that you can examine and see when they occurred,
6 which sensor was affected and which direction the failure
7 occurred in.

8 MR. LIPINSKI: If I have a spurious indication of
9 a dropped rod, is there an immediate indication on the
10 console?

11 MR. COGBURN: Yes.

12 MR. LIPINSKI: What light comes up?

13 MR. COGBURN: The CEAC failure.

14 MR. GILL: CEA failure or sensor failure,
15 depending on where the failure occurs. It's also an audible
16 annunciator.

17 MR. KERR: Any other questions, Walt?

18 MR. LIPINSKI: No.

19 MR. KERR: Please continue, Mr. Cogburn.

20 MR. COGBURN: I defined "valid trips" earlier as
21 those trips that should have occurred based on the design of
22 the system, based on a response to an operating event.
23 Reactor protection we call that here.

24 There have been nine such trips. Eight of those
25 were due to actual dropped control rods. One was an axial

1 shape out of range trip that occurred at low powers
2 following a startup after a trip, where we had a significant
3 amount of xenon in the core and back where we were still
4 learning how to control the xenon in the core.

5 The operators let the axial shape get out of range
6 and the calculators tripped.

7 There's a term used here called algorithm design
8 error. I believe "oversight" would be a better word than
9 "error." But it is in fact an error.

10 There were six plant trips that occurred because
11 of this. Five of the six were of the same nature exactly,
12 and that was corrected by the first software modification.
13 It was not just improved, it was corrected.

14 The problem was that on re-initialization of a CEA
15 calculator, the calculator used a worst case penalty factor
16 and had a certain probability of coming up live with that
17 value and before it actually calculated an actual penalty
18 factor. And so following periodic tests, it would also
19 occur following a power fill restart or something like
20 that.

21 Any kind of re-initialization of the calculator,
22 there was a certain probability, I think estimated around 10
23 percent probability, that that CEAC would generate this
24 large penalty factor, which all four CPC's would use as a
25 penalty factor and would cause a DNBR trip.

1 MR. EPLER: I have a question. If I understand
2 you correctly, the valid trips, the nine valid trips, one of
3 those resulted from a dropped rod -- I mean, eight of them
4 from a dropped rod. It would appear to me that your control
5 system could have circumvented that trip and kept you on
6 line if you had worked at it.

7 MR. COGBURN: Well, I think what this page points
8 out, if you would eliminate the one out of two problems with
9 CEA position input in some way -- I don't know what the
10 answer is -- you would find that this 28 trips would go to
11 two trips only. And none of them was --

12 MR. EPLER: The thing is really related to rod
13 position indication failures.

14 MR. COGBURN: Either that or rod drops.

15 MR. EPLER: I would ask you if your plant computer
16 has any connection with that at all.

17 MR. COGBURN: Any connection with what? Excuse
18 me? With what?

19 MR. KERR: Do you understand? If the on-line
20 computer data link would have helped this situation any, I
21 think. Isn't that the question?

22 MR. EPLER: I'd like to see us get rid of that
23 thing, but I wouldn't want to get rid of it if it has a
24 function. But I don't see any function.

25 MR. COGBURN: Well, I hope to describe to you what

1 the function is. But I hadn't got to that point yet.

2 MR. EPLER: Okay. I'm still looking.

3 MR. COGBURN: I don't perceive a connection in
4 this particular problem with the data link.

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

1 MR. KERR: But you felt good knowing it was there,
2 didn't you?

3 MR. COGBURN: Yes.

4 MR. KERR: See.

5 (Laughter.)

6 MR. DITTO: Did you say you could eliminate all
7 but two of these if you didn't have but one out of two CEA
8 arrangements?

9 MR. COGBURN: I did say that. I'm sorry. I'm
10 glad you corrected me. I should have said we would have had
11 only two if CEA were not an input to the protection system.
12 One out of two would have eliminated all of these hardware
13 problems.

14 MR. DITTO: But not the 8, because you actually
15 dropped the CEA and both systems saw it.

16 MR. COGBURN: I have a comment in my statement
17 here that the probability of plant trip was reduced again.
18 This is different than the other one here, because the
19 system that was initially -- this is going to be described
20 in much more detail, but basically we had rod drops that
21 occurred at one percent power, and they resulted in plant
22 trips. The penalty factors were highly conservative. This
23 was a result of, in my opinion, of having to freeze the
24 software at such an early stage before we could refine it;
25 but I'm not taking that as an excuse, just a fact of the way

1 things occurred.

2 We did make modification -- Mod 2-B it's going to
3 be referred to later -- which reduces the magnitude of some
4 of the penalty factors. It becomes more position specific
5 penalty factors rather than just a case number; so those low
6 power rod drops should no longer cause plant trips.

7 There were two rod drops that occurred at full
8 power, and they undoubtedly would also still cause plant
9 trips, and they should for reactor protection -- fuel
10 protection.

11 MR. LIPINSKI: How are the CPC channels powered?
12 Do they have individual DC supplies?

13 MR. COGBURN: They are powered from AC inverters
14 which are backed up by batteries.

15 MR. LIPINSKI: Now, what happens if one is turned
16 off and it is reinitialized?

17 MR. COGBURN: You would have a power fail restart
18 and the channel would trip, a channel would trip. If a CEAC
19 were to be powered down, the way it's designed, the failed
20 bit would be sent. The CPCs would then acknowledge the
21 failure and say that guy is no good, I won't use it.

22 The technical specifications then have a
23 requirement that we follow up on in that event, so power
24 failure should not cause a plant trip; a single channel
25 failure should not cause a plant trip.

1 The category called algorithm design areas, we
2 covered one of them; that was the CEAC initialization
3 problem. The other one was discovered at very low power,
4 down around five percent power, where the software switches
5 over from a fixed axial shape because of the low signals on
6 the ex-core detectors to a measured axial shape, and then
7 making that transition, the extrapolation or the -- what's
8 the word I'm looking for -- the Update Program saw that
9 change as going -- there was no dead band provided, so that
10 when you go across that boundary, it would switch back and
11 forth between a fixed shape that was very conservative to a
12 measured shape which was not adverse. So that in going from
13 the good measured shape to the adverse fixed shape, it would
14 look like a rapid rate of change, and we would get a DNBR
15 trip.

16 This was corrected by software modification by
17 providing a dead band and also by providing a less
18 conservative fixed axial shape at low power.

19 Mr. Rozek will describe that in more detail this
20 afternoon.

21 There was also one trip which I call technician
22 error. I believe I should have called it procedural error.
23 It involved one CEAC in the in-op mode and the technician
24 going to test on the other one, which made them both look
25 failed. When the CPCs see that, they will trip. We

1 corrected that by a procedure change, and it has not
2 happened again.

3 MR. KERR: Mr. Cogburn, I need some advice from
4 you. Our schedule shows that we're going to stop for lunch
5 at some point. What is a good point from your point of
6 view? Is it better to stop now, or is there a better
7 transition point in the next 15 or 20 minutes?

8 MR. COGBURN: I believe I can be finished in 20
9 minutes, allowing approximately half that time for questions.

10 MR. KERR: Let's do it then.

11 MR. COGBURN: Okay.

12 (Slide.)

13 The next area I want to cover regarding operating
14 performance of the CPC system, I want to cover the licensee
15 event reports.

16 A licensee event report is generated as a result
17 of the channel failure and then being bypassed. The normal
18 practice if a channel fails, it will trip, and the operators
19 will bypass it. This generates a licensee event report.
20 Also, three restarts that occur in one day will also require
21 the writing of the licensee event report.

22 The system -- the CPC system was designed as a two
23 out of three system with installed spare. It was, however,
24 licensed as a two out of four system, because there were
25 some unresolved points at the end of the period, licensing

1 period.

2 If the system had been licensed as designed, as a
3 two out of three system, then many less than this total
4 number of 34 LERs would have resulted; and in fact, I
5 believe there would have been only 10 total events, 9 of
6 those related to CEA calculators, because going into an
7 action state when the tech spec requires generation of a
8 licensee event report, there was one other human error that
9 generated a licensee event report.

10 The frequency of occurrence of these events you
11 can probably assess for yourselves. In '78 there were two
12 LERs, in '79, 18. In 1980 there were 14, and so far in '81
13 we have not had a failure with an LER.

14 I broke this down into hardware failures and human
15 errors, and I further broke down the hardware failures that
16 caused these as either a solid failure, one that was easy to
17 diagnose and repair, or intermittent failures. So that the
18 intermittent failures have been identified and fixed; some
19 of them have not yet. The human errors were primarily
20 associated with test instrument connection which technically
21 made one channel inoperable.

22 (Slide.)

23 The hardware failures that have occurred during
24 reactor operation, for this purpose I used the time that the
25 reactor has been critical, because that is the time that the

1 core protection calculators are required to be in service.

2 MR. LIPINSKI: Before you start on this, on the
3 other one you only listed the hardware failures and human
4 error. There were not LERs involving software?

5 (Slide.)

6 MR. COGBURN: No. Software did not -- the
7 software caused plant trips, but a plant trip does not
8 necessarily require an LER.

9 MR. LIPINSKI: Yes. That was discussed
10 yesterday. That was one of the proposed changes for LERs.

11 MR. COGBURN: The plant trips are reported in the
12 monthly operating reports and the cause. This table,
13 hardware failures, integrates the licensee event reports
14 with the failures that have occurred that have caused plant
15 trips; and I have broken it down to the failures that
16 occurred by channel and by specific calculator. The number
17 -- the total number of failures I believe comes out to 49.

18 I have also calculated a mean time to failure
19 based on the hours critical and the total number of trips
20 that have occurred, and I got an average channel
21 availability or a mean time between failures of 896 hours
22 based on our operating experience and its initial
23 criticality.

24 MR. RAY: Is there any indication on the part of
25 suppliers -- that Combustion Engineering requires on such a

1 figure, the average mean time between failures of components
2 in the system?

3 MR. COGBURN: Is there specification on what it
4 should be?

5 MR. RAY: Does CE have a specification on its
6 suppliers as to what they would consider acceptable?

7 MR. COGBURN: Bill, would you care to answer that,
8 or Ed?

9 MR. BROWN: Ed Brown, Combustion Engineering.
10 At the time this system was designed and
11 fabricated there were no specification values for target
12 availability at that time.

13 MR. RAY: How about today?

14 MR. BROWN: Today there are.

15 MR. RAY: Can you tell us how that compares with
16 8967

17 MR. BROWN: 896 is calculated based on reactor
18 time availability, not total operating time. When we
19 specify the system we base it on calendar time and
20 availability, so it is hard to compare this number without
21 knowing the total operating time.

22 MR. COGBURN: We do not make any effort to --
23 well, when we are not operating, that's the time we shut the
24 CPCs down and perform preventive maintenance and things like
25 that; so there is not sufficient data to do that, I'm

1 afraid. Failures are not specifically addressed or noted .
2 that occur other than by job order at the plant, the
3 documentation system that we have; but I might revise that.
4 I have not done that research. It might be possible to do
5 it. I don't know.

6 MR. KERR: Mr. Pearson.

7 MR. PEARSON: I have a question. Have you found
8 any unsafe failures? All the failures you're talking about
9 are those that have either been detected because the system
10 failed safe or a diagnostic forced it to fail safe.

11 Now, when you do some routine testing that's the
12 time when unsafe failures should be uncovered.

13 MR. COGBURN: Okay. That really leads into what I
14 would like to say, is one of the reasons why we believe the
15 data links are valuable.

16 The most probable mechanism for such a failure to
17 occur is an instrument drift, a non-conservative instrument
18 drift. We have not noted that, because the sensors have
19 tended to fail completely. However, drift has occurred, and
20 the way we have picked up that instrument drift is by
21 frequent logging and comparison of the various sensors and
22 intercomparison of the systems.

23 Possibly there might be another way to do it, but
24 the best way we have come up with is to have the plant
25 reactor operators logging and comparing channel to channel

1 by looking solely at the CPCs, their operator modules.

2 As an independent look I have my reactor engineers
3 perform periodic and at least weekly trends of all of these
4 signals simultaneously through the data links, and this is
5 the only way that we have presently available the data links
6 to do this.

7 If you trend this over a period of time, both
8 hours, days, weeks, and look at it in various lights, you
9 can pick up tendencies for those instruments to drift out of
10 what your calibration error should be, and we have been
11 successful at that so far in identifying the drift before it
12 became non-conservative.

13 To the extent it was not accounted for and to be
14 able to put the channel into a repair situation where you
15 fix the sensor, and there is my position of what the best
16 use other than startup testing where the links are
17 absolutely essential to do the shape annealing matrix test
18 and some others.

19 I believe there is also a necessary future of a
20 good core follow program. Instrumentation surveillance is
21 an important part of the CPC or any protection system
22 surveillance to improve safety and operability. If we wait
23 for the instruments to get way out of tolerance, then there
24 can be an unsafe failure.

25 Does that answer your question, sir?

1 MR. PEARSON: Yes.

2 (Slide.)

3 MR. COGBURN: Let me summarize the last couple of
4 slides on failures.

5 I calculated the mean time between failures per
6 channel. This is the same number, 896 hours average. That
7 includes the CEACs. A mean time to repair based on our
8 experience of 1.3 hours. This includes some long times and
9 some very short times, for it only required free
10 initialization of the calculator.

11 The total number of failures peg at 49. The time
12 that the CPCs are in service, and from 6,208 hours
13 calculated an average channel and availability of .0017,
14 which I believe is a fairly good unavailability.

15 I think there are still some improvements that can
16 be made, but this also includes the early problems, and the
17 performance has improved significantly since the beginning.
18 The problems that we have had --

19 MR. KERR: Help me with my arithmetic. I'm having
20 problems here. With an average mean time to repair of 1.3
21 hours, you ought to have about 65 hours out of service.

22 MR. COGBURN: This number of failures is all the
23 channel failures, and this availability -- unavailability is
24 per channel; so this number really is divided by six, six
25 calculators.

1 MR. KERR: Okay.

2 MR. COGBURN: I meant to point that out. I'm
3 sorry.

4 Again, the problems that we have observed ha
5 been early on. The room cooling for the room, the CPCs in
6 our plant are located in their own room. The initial design
7 called for the emergency control room chillers to be the
8 room cooling for that room. Those do not normally run to
9 cool the control room. They are the emergency system.

10 The chillers, therefore, are way over capacity for
11 the CPC room, so we found they would not run as installed.
12 They would freeze up. They get too cold. And so we added a
13 separate room air conditioning unit early in the operating
14 time.

15 Now, this system has not been as good as it might
16 have been, and we are still looking at changes. We are
17 adding an alarm in the control room on high temperature, and
18 operators would then start the emergency cooling system. We
19 are making changes to the emergency chillers to allow them
20 to run without tripping out on too low a load or freezing up.

21 But the design of the system -- and AP&L was at
22 fault here in not determining this earlier -- must consider
23 a good air conditioning and humidity control system, and we
24 still have a ways to go in that regard, but we have made
25 some progress.

1 We also have some power supply problems with our
2 inverters. They had spikes on them. The design was a new
3 one, and it required modifications. There would be power
4 failures with the inverters. This mostly occurred before we
5 ever went critical. But I think both the room cooling and
6 the inverter problems have been improved.

7 MR. KERR: Is the inverter part of the CPC or it
8 is not?

9 MR. COGBURN: No. Each PBS channel has an
10 inverter, and the CPC is powered from one inverter. I think
11 there is good reason to believe that the cooling problems
12 and the inverter problems may have caused some hardware
13 problems that we have not recovered from yet; and one of the
14 things we are evaluating seriously is --

15 MR. KERR: Did you have the inverter problem
16 because it was a new inverter, or because the CPC is
17 especially sensitive to inverters which would be okay on an
18 analog system?

19 MR. COGBURN: I think it's the inverters. The
20 CPCs are very sensitive, that's true; but the inverters
21 were, I believe, the fault. The problem was resolved by
22 them, because the analog system was also affected by the
23 inverters.

24 We had an inadvertent containment spray-down
25 before -- back during hot functional testing that was

1 related to inverters, and a lot of modifications were done
2 before we went critical.

3 MR. KERR: I would like a little more information
4 on your air conditioning system. You had said something
5 about having a long way to go, which implies that it may be
6 a 20-year period ahead of you to get the air conditioning
7 system operating.

8 MR. COGBURN: Well, there have been several
9 modifications that we have been making steps. Each one we
10 hope is going to solve the problem. I don't believe it has
11 yet, because even with a new system we have an unreliability
12 problem, so there are two avenues we are approaching. They
13 are not 20-year programs. They are probably 12 or 18 month
14 programs, in my opinion.

15 One is to evaluate the need for a backup air
16 conditioning system for the CPC room. Another is, as I
17 mentioned, was to improve the existing backup, the emergency
18 control room chiller system so that they can be a more
19 effective backup. Making the operators aware of the
20 situation has been our most recent change, so that they can
21 respond quickly to higher temperatures in the room and start
22 the emergency chillers.

23 So I see it as an ongoing thing. I don't believe
24 we have accomplished where we need to be.

25 Mr. Epler said something about we had achieved an

1 adequate reliability, I believe, and I'm not really sure
2 what you were referring to; but there is a point in
3 reliability where you say yes, that's good. I don't feel
4 like we're there yet, but we've made good improvements.

5 MR. KERR: I don't think Mr. Epler was talking
6 about air conditioners, because if there's one place where
7 American technology has completely failed, it must be in air
8 conditioners.

9 (Laughter.)

10 MR. COGBURN: But the air conditioning has an
11 indirect effect on the protection system.

12 MR. KERR: I'd say it's pretty direct, and that's
13 why I'm concerned that it's 18 months. It seems to me you
14 ought to be able to fix the air conditioner sooner than that.

15 MR. COGBURN: Well, of course you realize when you
16 have things in the room like that, seismic design is a
17 problem. Electrical interferences are concerned, and you've
18 got to evaluate a lot of things. It's not that simple. At
19 least as I perceive it, it's not that simple. I would
20 suspect that it would be 12 to 18 months.

21 MR. KERR: My only comment is it seems to me this
22 air conditioner is a fairly integral part of the reliability
23 of your CPC.

24 MR. COGBURN: Well, I'm extrapolating my own
25 opinions here.

1 MR. KERR: I didn't get that from your opinion. I
2 got that from reading the LERs.

3 MR. COGBURN: Right. But I'm saying we have made
4 changes that many of our engineers believe are going to fix
5 the problem. I'm skeptical, yes. I guess I have to be
6 proven wrong or right, one or the other.

7 MR. LIPINSKI: Are the air conditioner failures
8 total, or are you failing to maintain temperature?

9 MR. COGBURN: They typically are totally. It
10 trips off. The temperature rises. It's noted eventually,
11 and then the backup system is started. We are trying to
12 make that recognition process more prevalent now.

13 MR. LIPINSKI: Is that enunciated in the control
14 room?

15 MR. COGBURN: Yes. But it's in the back of the
16 control room, and they are not very prominent. What we have
17 added is enunciation on the cooling temperature outlet to
18 the new parameter before we ever get to the cabinets,
19 because there is such a lag time between -- I'm sorry.

20 MR. LIPINSKI: Have you described the TMI
21 situation of information that's not available to the
22 operator because s somewhere in the back?

23 MR. COGBURN: I think this is nowhere near as
24 significant as the problems at TMI, but it is a feature that
25 deserves some attention.

1 MR. LIPINSKI: Is there an audible enunciation
2 when this temperature goes up or just visual?

3 MR. COGBURN: There is both now. We actually --
4 I'm not sure if it's implemented today, but it's very near
5 implementation, where a new alarm and a new sensor on the
6 outlet temperature from the air conditioner is measured to
7 give a more immediate sensing of the problem. And this is
8 now a front panel enunciator, audible and visual.

9 MR. LIPINSKI: It is now front panel?

10 MR. COGBURN: As I said, I'm not sure it is
11 implemented today, but it was getting very close. The
12 implementation is in progress on this particular item.

13 Other problems that we have had which the
14 diagnostics -- the area diagnostics -- we have made one set
15 of changes to add some diagnostics. Based on that we found
16 they were very helpful for finding sensor failures that were
17 difficult to track before. We found a few problems with
18 that which we are planning to modify for cycle 2, and the
19 San Onofre system would have the same features for
20 additional failure diagnostics.

21 Still, we are having quite a few failures that we
22 have not been able to diagnose as failures, within the IO
23 hardware some of the peripheral equipment associated with
24 the protection calculators. And I believe Combustion and
25 Arkansas Power and Light have been discussing the need for

1 additional diagnostics which we hope to add to help track
2 down failures and make them a little easier and a little
3 quicker to assess.

4 This is another feature of our improved
5 performance. As I said earlier, I feel like the
6 unavailability is reasonably good now, and I would like to
7 see it a factor of three better myself, and I believe we can
8 get there, but our priority on this has been satisfied
9 somewhat because we have made quite a few improvements.

10 MR. KERR: Would a factor of three be significant?

11 MR. COGBURN: I believe it would be. At least --
12 I would like to say at least that much, maybe more, is
13 achievable. But that would mean instead of -- you know,
14 we'd be up around 3,000 hours between channel failure, which
15 with the existing computer technology is, I think, we're
16 going to be hard-pressed to beat that.

17 Also, as I mentioned earlier, there were some
18 oversights in the algorithm design. These have been
19 corrected, the software changes, and they will be described
20 further.

21 MR. LIPINSKI: Before you leave your failures, one
22 sheet showed you still had two failures in '81.

23 MR. COGBURN: We had two trips in '81. One of
24 those was a rod drop, and one of them happened during a
25 surveillance. We had no LERs but two trips. One was a

1 protection trip from a hundred percent power rod drop. The
2 other one was during surveillance periodic test where the
3 test procedure specified testing the reed switch position
4 supply over logic, which required powering down one reed
5 switch position transmitter.

6 Apparently -- and this is not completely analyzed
7 yet because it only occurred last week -- but apparently
8 that didn't function, and we found it by the periodic test,
9 and we suffered a trip because of that.

10 MR. LIPINSKI: That was a legitimate trip due to a
11 system failure?

12 MR. COGBURN: I would call it a non-valid
13 failure. The rod drop was a valid failure. This one I
14 would call a non-valid failure. We know the reason or we
15 think we know the reason for it and can correct it.
16 However, it still occurred.

17 MR. LIPINSKI: So you're still uncovering problems
18 with this system as you gain operating experience.

19 MR. COGBURN: Yes, sir. I'm sure we will always
20 continue to uncover problems, because we have to determine
21 what the expected life of the components is.

22 MR. LIPINSKI: No. I'm thinking of -- the one you
23 just described --

24 MR. COGBURN: No, sir. I don't consider that
25 design. It's a hardware failure.

1 MR. LIPINSKI: The numbers -- there are two
2 numbers of interest. One is the failure rate that leads to
3 undetected failures. This number is not, because you said
4 you have had no undetected failures; so all your operating
5 hours to date go in the column with no failures or unsafe
6 failures. These numbers here are for your safe failures
7 which are leading to spurious trips.

8 MR. COGBURN: Yes, sir. Invalid trips.

9 MR. LIPINSKI: Right.

10 MR. COGBURN: These numbers are spurious, yes.

11 MR. LIPINSKI: The reliability of the system is
12 generally associated with the probability of getting a
13 failure on demand, and that number looks excellent with no
14 unserved figures recorded; so from an operational standpoint
15 you are being plagued by the safe failures.

16 MR. COGBURN: I think our belief is this is
17 availability of plant performance concern and certainly not
18 a safety concern.

19 I will wind up in about two or three minutes
20 except for questions that occur.

21 I think the things I would recommend that need to
22 be followed up on and factored into new designs, or in other
23 words what I would change, we need a solution to the one out
24 of two protection problem. ANO-2 is the first of a kind to
25 get that protection system, and this is an action item that

1 AP&L and Combustion Engineering needs to address, but I
2 think the industry needs to address, because if CEA input is
3 going to be used, and it apparently needs to be used -- the
4 other reactor vendors are going this direction also -- then
5 the one out of two system needs to be resolved from a
6 reliability standpoint, not from a safety standpoint.

7 This system should be -- and we intend to pursue
8 licensing as a two out of three systems deal versus two out
9 of four. It was designed to be a two out of three system.
10 Many other power plants that I am aware of are licensed as
11 three-channel systems. Our Unit 1 is a three-channel system
12 with an installed spare.

13 A couple of other things that I have checked with
14 San Onofre about to make sure they don't have this problem,
15 but we ended up locating our core protection calculators in
16 the radiation control area. This makes them a little more
17 difficult to maintain and is not desirable, and their
18 temperature and humidity control seems to be much better
19 thought out than ours was. They are located in a regular
20 control room environment.

21 MR. KERR: Considering the relative reliability of
22 air conditioning systems in this country, they might want to
23 consider putting them in a refrigerator.

24 MR. COGBURN: One thing that's critical with this
25 system and anyone that uses data link information, and data

1 links are installed between the CPCs and CEACs, is that
2 steady temperature and humidity is desirable. The
3 oscillator frequencies will vary and the cable resistances
4 vary, and data linking errors can result.

5 Some of our problems are related to that. Some of
6 these unknown problems I believe are --

7 MR. KERR: I noticed in one LER that you lost a
8 bit, and I was curious as to how you noticed that, but I
9 won't pursue it.

10 MR. LIPINSKI: How sensitive are these temperature
11 changes? Are we talking about 50, 60 degrees or 5 or 10
12 degrees?

13 MR. COGBURN: On the order of 10 to 20 degrees.

14 Evaluation of the CPC system, in summary, I
15 believe that it is very fail-safe, and the fuel protection
16 provided by it is very good. It's probably the best in the
17 industry in that regard.

18 Fuel failures are a real problem in the industry,
19 and I think the CPCs and the monitoring systems in the ANC-2
20 and later designs are probably the frontrunner in the
21 industry.

22 The software in my opinion is very good, and the
23 display features are extremely good. The human factors
24 design is good, and the quantity of information is very
25 helpful to the operators.

1 I think the hardware still needs further
2 improvement but is adequate, and again, the one out of two
3 system for CEA inputs is hurting our availability.

4 And that's my summary of the CPC system. I'm
5 ready to close except for questions.

6 MR. KERR: Are there questions?

7 MR. LIPINSKI: I have one question. If you have a
8 spurious trip, how quickly can you restart in terms of what
9 your average down time amounts to?

10 MR. COGBURN: It typically takes 24 hours to get
11 back on the line.

12 MR. LIPINSKI: You lose one day?

13 MR. EPLER: It's one day a month.

14 MR. COGBURN: Yes.

15 MR. LIPINSKI: Are you associating power cost with
16 one day yet?

17 MR. COGBURN: The power cost for one day for our
18 system are on the order of half a million dollars, the
19 replacement power cost, and financially that is very -- in
20 the rate structure in Arkansas that hurts AP&L pretty badly,
21 because if the availability is below a specified number,
22 then we pay all the difference to buy fuel and to replace
23 the nuclear generation.

24 MR. LIPINSKI: So you have an economic incentive
25 to make an investment to improve this availability.

1 MR. COGBURN: We have a strong economic incentive,
2 and our engineering and operating staffs have a strong
3 management pressure -- we feel a strong management pressure
4 to improve the system because of that.

5 MR. KERR: Mr. Boyd.

6 MR. BOYD: May I just ask a question for
7 clarification? Does a control rod drop cause a trip or only
8 through a DNER or other calculation?

9 MR. COGBURN: A control rod drop will cause a
10 one-channel trip almost directly. It will cause a plant
11 trip only if its deviation is large enough and its worth or
12 effect on power distribution is great enough to cause a
13 large penalty factor to be generated by the two CEA
14 calculators and then transmit that penalty to the CPCs which
15 apply it to the DNER and local power density calculations.
16 So it is an indirect plant trip. It is essentially a direct
17 channel trip. If one of the rods is designated as a safety
18 rod bank, that will cause essentially an immediate trip of
19 one channel.

20 MR. BOYD: I don't understand, therefore, why you
21 had, I gather, several plant trips due to rod drops at low
22 power.

23 MR. COGBURN: Well, this is because in the initial
24 design there was only one penalty factor essentially for a
25 rod deviation, and it was the worst case rod deviation, and

1 it was a very large number.

2 Mr. Rozek will describe this quite a bit further.

3 I believe. Yes.

4 MR. KERR: Are there other questions?

5 (No response.)

6 I declare a recess until 1:40 p.m.

7 (Whereupon, at 12:40 p.m., the meeting was
8 recessed for lunch, to be reconvened at 1:40 p.m., the same
9 day.)

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

1 AFTERNOON SESSION

2 (1:40 p.m.)

3 MR. KERR: We come, according to my interpretation
4 of the agenda, to a section called "Software Changes to the
5 CPCS," and I assume that's going to be handled by CE.

6 MR. KENNEDY: That's a correct assumption, Dr.
7 Kerr. Our next speaker is Mr. Tom Starr. Tom is the
8 supervisor of our CPC design group, and he is going to cover
9 the software change process.

10 MR. STARR: Mr. Chairman, the purpose of my
11 presentation is that prior to remarks by Rozek this
12 afternoon on the software changes that have been made to
13 Arkansas and are being made now to SONGS, I would like to
14 present the software change process that occurs when we make
15 such modifications.

16 This is the process of implementing the software
17 changes as dictated by the functional designers and placing
18 that design into an assembly language code.

19 (Slide.)

20 CE has developed a highly structured and detailed
21 software change process, and this process was documented in
22 the software change procedure called CEN-39, which was also
23 referred to this morning.

24 CEN-39 has been approved by the NRC staff during a
25 resolution of staff position number 19 during the ANO-2

1 review, and that was completed in mid-'79.

2 CEN-39 has been followed for all ANO-2 and SONGS
3 software changes, and its fundamental approach has been used
4 for the original ANO-2 design, so that for the current SONGS
5 and Arkansas work, we are at the fourth time for using this
6 procedure; and the following discussion covers several
7 important features of that software change process.

8 (Slide.)

9 To ensure that the process of specifying and
10 implementing the software modifications is done in a manner
11 that maintains the integrity and reliability of the software
12 is the purpose of this CEN-39 process. When we go into
13 change the software we want to be absolutely assured that we
14 are introducing no new errors and that the functional design
15 is correctly implemented.

16 The scope of the process includes the functional
17 design, and by functional design I mean specification in
18 algebra to the assembly language programmers of the programs
19 that we want implemented. That includes data also. At the
20 stage that the functional design is complete, one could take
21 that design and implement it in any computer or language
22 that one would choose. In this case it's Perkins-Elmer
23 equipment, and it's been done in an assembly lab.

24 The idea of functional design is that it's an
25 engineering design. It's based on engineering analysis and

1 completed prior to implementation.

2 Software coding and implementation is also covered
3 in this procedure, as is the software testing. All
4 documentation related to functional design, software coding
5 and implementation, and testing is covered by this procedure.

6 A wide spectrum of detail is included from a
7 relatively high level of requirements from this system down
8 to very precise, specific instructions for generation of
9 listings and so forth.

10 The applicability of CEN-39 is that it is
11 applicable to all software changes, no matter how minor.

12 MR. KERR: Could you tell me what is meant by the
13 first statement on that slide, please, sir?

14 (Slide.)

15 It strikes me as being a rather qualitative
16 statement.

17 MR. STARR: To a large degree it is a qualitative
18 statement. We're striving to ensure that what we change, we
19 change correctly, and what we do not intend to alter, we do
20 not alter.

21 In the testing that we have done to date since we
22 have been making modifications, we have found a relatively
23 few number of errors.

24 MR. KERR: Let me be more specific. Is your goal
25 to set up a procedure that will eliminate errors, or do you

1 have as a goal a procedure that will make the probability of
2 errors smaller, or do you have some sort of quantitative
3 goal?

4 MR. STARR: It's a matter of making the
5 probability of errors acceptably small. We not have a
6 quantitative data base to which we are striving.

7 MR. KERR: How do you know when you have an
8 acceptable procedure other than that the NRC approves it?

9 MR. STARR: Well, we are quite satisfied with it.

10 MR. KERR: Well, I'm not being facetious since
11 you're willing to stand back of it, but how did you -- what
12 criteria do you use to conclude that your procedure is a
13 good procedure? I think it isn't just a change in software;
14 that what you're concerned about is validity of software
15 generally.

16 MR. STARR: I think it's a matter of the
17 constructs of this software itself, that is, modulization.
18 It's a matter of keeping all documentation current. It's a
19 matter of what we consider --

20 MR. KERR: I have difficulty believing that
21 documentation produces anything except documents.

22 MR. STARR: Well, it helps keep the probability of
23 errors acceptably small.

24 MR. KERR: Well, it does if it's good
25 documentation. I'm trying to get a feel for how internally

1 you conclude that your procedure is one that will produce
2 results that you want to achieve. Is it just a matter of
3 somebody sitting back and saying well, now, I have this
4 quality assurance program, and this documentation, and these
5 good people; I must have a good procedure?

6 MR. STARR: It is a matter of judgment, and that
7 judgment is made by engineers and programmers; and that is
8 about all I can say.

9 MR. KERR: So aside from faith in the system, I
10 really don't have any very objective criteria?

11 MR. STARR: We have not done any qualitative
12 evaluation of our success and our goals.

13 MR. KERR: Do you have any outside group -- I
14 don't mean necessarily outside of Combustion, but outside of
15 your own immediate group to look at this and say from our
16 perspective this is the way we think you should go, or
17 perhaps there are some changes that you could make or some
18 pitfalls you might avoid?

19 MR. STARR: There is a current draft standard
20 generated by IEEE in the ANS group, I think, which is
21 outside CE. We believe that we meet or exceed what is in
22 the standard, but we do not have an outside organization
23 currently reviewing what we do, if that's what you mean.

24 MR. KERR: Again, when I say "outside," I don't
25 mean outside Combustion but outside -- there must be a

1 number of places in Combustion where people are concerned
2 about software reliability.

3 I raise this question because my own limited
4 observation is that people don't know very much about how to
5 make sure the software is reliable; and I'm trying to
6 understand what approach you used.

7 I'm going to defer to Ed Brown.

8 MR. BROWN: Dr. Kerr, there are essentially two
9 ways that we measure the software success of our system.
10 One is in the efficiency of the procedures. In other words,
11 we measure the effectiveness of our procedures by seeing its
12 operational benefit.

13 The systems that we have implemented changes in,
14 we have discovered no errors in the software through
15 continued operation. So that is a quantitative measure of
16 the acceptability of procedures.

17 In cases where we have discovered an error -- for
18 example, in the original design of the system,
19 initialization, we factored that into our original
20 procedures and our testing program to make sure that type of
21 error would be gone by the original software change
22 procedures, so we have a type of feedback based on
23 operational experience.

24 MR. LIPINSKI: Is there any redundancy in terms of
25 having something go down two paths and then comparing it?

1 MR. STARR: Yes, there is. That occurs or the
2 comparison occurs during testing, and I will explain that in
3 a few moments.

4 MR. LIPINSKI: By your particular system as well
5 as Fortran's comparison?

6 MR. STARR: I was going to explain the Fortran in
7 comparison.

8 MR. EPLER: I have a question. When you have a
9 few hundred years of light-water reactor operation, in a
10 small fraction of those we embrace the two-unit operation;
11 yet, we have had several cases where an operation has been
12 performed in the wrong unit with disastrous results.

13 Now, I don't care how smart we are in getting the
14 software; we can still have an awful time. How do we know
15 that you will never get an operation on the wrong generating
16 unit? Somebody off somewhere gets a job to put on the
17 software, but he puts it on Unit 2 instead of Unit 1. How
18 do we know?

19 MR. STARR: In the case of Arkansas Nuclear Unit
20 2, of course Unit 1 is not a CPC plant, but Unit 2 is; so I
21 think for Arkansas that problem does not exist. In the
22 future where CPC will be shipping software discs to
23 multi-unit plants we as yet do not have a feature in the
24 procedure that covers that possibility. It will occur in
25 the future.

1 I think that is a matter of administrative and QA
2 procedures on CE's part, as well as the positive assurance
3 that at the other end, the utility's end, those QA
4 procedures and administrative efforts are also made.

5 There are ways to assure through software that
6 that does not happen. I think we can implement those ways
7 as a positive assurance that that possibility you were
8 referring to doesn't happen.

9 MR. EPLER: Do you believe this problem is being
10 anticipated?

11 MR. STARR: Quite frankly I have not thought of
12 it. I will defer to Ed Brown again.

13 MR. BROWN: Mr. Epler, we have given it thought.
14 We have a formal configuration for each generating unit. It
15 is essentially the same for hardware and software, because
16 the problems are identical. The problems of making the
17 wrong hardware change in one unit, for example, the wrong
18 constant, are the same as making the wrong software change.

19 We do have a configuration, a hardware and
20 software management plan which is essentially a design
21 administrative control to assure ourselves that the proper
22 hardware changes and proper software changes are made to the
23 correct unit, unit by unit. That is proceeding.

24 MR. LIPINSKI: Given that you have a software
25 change and you go through your change procedure, do you then

1 issue a test procedure such that software can then be
2 checked after it's loaded into the actual system in plant?

3 MR. STARR: Yes. There are installation
4 procedures and checks made at the time the software is
5 installed in the plant. They are designed as a more or less
6 double check of the correctness of the software after it is
7 installed. However, before we ship the hardware to the
8 plant, we have extensive testing to assure ourselves that
9 the implemented design as it leaves CE is correct.

10 The fundamental thing we are trying to do, I
11 think, in testing is to look at two different things. One,
12 did you design the algorithms correctly; and two, did you
13 implement them correctly?

14 Our tests are separable in that generally tests
15 are designed to do one and only one of those two things, to
16 look at the design or the implementation.

17 MR. LIPINSKI: Proper tests in the plant should
18 uncover both of those if you're going to have a functional
19 requirement in terms of whatever that software was going to
20 do, and if you design your testing plan properly, it should
21 cover all errors.

22 MR. STARR: The reason we have gone this way is
23 that in searching for software errors we have to be very
24 precise. You are tracking down milliseconds on occasion.
25 You are tracking down numerical errors on the order of --

1 very small numerical differences. And when you get into an
2 in situ condition where you either have to -- you generally
3 have to use the plant hardware or bring your own test
4 hardware to the plant, it turns out that the inputs you need
5 to generate to produce an output are much, much less precise
6 than you can do in a more controlled environment in your own
7 laboratory or on your own system.

8 It has been our experience that software errors
9 were much more readily caught when they are done with
10 special test software or with special tests that are done
11 before the software leaves the site.

12 Now, of course, you can never be sure that your
13 software shipped to this plant is perfect. You can test and
14 test and test and be very sure that your errors are not
15 going to impair safety, but even when you ship it, you want
16 to test at this plant to be sure as a double check that the
17 system is performing as you predict it should perform and
18 that there is no overt evidence of any further problem. But
19 once it gets to the plant, your best chance of catching
20 software has essentially been passed.

21 MR. LIPINSKI: Let me summarize what you have just
22 said, and that is that your in plant test procedures have
23 certain shortcomings. Does this imply then that you should
24 look at improving the ability to test in plant?

25 MR. STARR: I'll defer to Bill Gill.

1 MR. GILL: What we're saying is we do not find it
2 practical to ship a number of people to the site or test
3 equipment at the site to test the overall equipment. We
4 look at this as a high technology test best done in the lab,
5 not in the plant. There's nothing unique here. We test
6 many components in a factory before we go to the plant.

7 What we are attempting to do in a plant test is to
8 assure that those aspects which we cannot achieve in a lab,
9 such as specific plant signatures, the impact of say the
10 actual process noise and other signals, are tested at that
11 point, and that nothing happened to the software from the
12 time it left the factory until it was installed in a plant;
13 it did not get altered in any way, nor was it changed.

14 So we implement the field procedures to assure
15 that there were no changes to that disc or that software
16 during the transport from the factory to the site.

17 Those aspects which we could not achieve in the
18 lab, that actually require live plant signals, that testing
19 we do in the plant. We divide the overall test program
20 between the factory and the lab or the site based on
21 practical considerations of economics and where we can best
22 prove our goals.

23 MR. LIPINSKI: Your checks on the software will
24 pick up single failures, but if you have got double-fit
25 changes, I don't think this is one hundred percent

1 effective, is it?

2 MR. STARR: I'll defer to Ed Brown.

3 MR. BROWN: Ed Brown, CE.

4 The error-checking hardware from the disc load
5 into the system has a probability of error or about 10⁻⁹
6 per bit. That's a multi-bit longitudinal redundant check.
7 The check signs are a further verification of loading bit by
8 bit in the core memory.

9 Following that, the input-output testing provides
10 the final verification that the software is correct. There
11 is a higher degree, in my opinion, of certainty that the
12 soft wiring of the system is correct than the hard wiring.
13 In other words, there is a much more controlled environment,
14 much more stringent testing over the installation of
15 software than there is over the wiring of the system in any
16 particular plant installation.

17

18

19

20

21

22

23

24

25

1 MR. STARR: I'd like to cover some of the
2 documentation that goes with the disc for the CPC system.

3 (Slide.)

4 MR. OKRENT: The documentation is categorized for
5 purposes of discussion in three general areas: design
6 specification, which is generally what I refer to as
7 functional design; design implementation, which is
8 documentation that covers the assembly language,
9 implementation of the system; and documents related to
10 testing.

11 The design specification is based on analysis, use
12 of the FORTRAN code to determine that the functional design,
13 when implemented, will meet all safety requirements for the
14 design basis list of events for the system: rod drops,
15 losses, low power, changes and depressurizations and so
16 forth.

17 This information is passed to assembly language
18 programmers in the form of functional design specifications
19 or functional descriptions -- they go by either name -- and
20 basically a data base document that goes with it. The
21 functional design specification covers basically the
22 algorithms and the data base document covers those data that
23 should be inserted into the program.

24 The software specifications cover assembly
25 language, flow charts and equations that are implemented in

1 the software. And the testing documents cover two types of
2 testing, phase one testing and phase two testing, which I
3 will explain in a moment.

4 The test case documents you see here are documents
5 which are used to test modules of the software. Phase one
6 and phase two test reports are written and the disc is
7 accompanied by disc and test certification analysis which
8 certifies that a large body of this work was done.

9 As you say, documentation cannot assure lack of
10 errors, but it is important and we do take a lot of care
11 with it.

12 MR. LIPINSKI: How is it organizationally divided
13 in terms of responsibility? Are we looking at different
14 groups that are involved in design specifications,
15 implementation and testing, or do we have overlapping of
16 activities or feedback?

17 MR. STARR: In general, the design specification
18 is done by engineers who are familiar with the design basis
19 of the system in terms of what response times are required.
20 They design the algorithms based on NSSS design codes. That
21 is to say, the algorithms have to be sufficiently accurate
22 and rapid to produce a trip in time to prevent safety limits
23 from being violated.

24 Their work is embodied in functional design
25 specifications, which are then passed to, in general, the

1 group which does the assembly language program and who are
2 not as familiar with the design basis of the system. At
3 that point it's being implemented.

4 When we do testing, for the most part phase one
5 testing involves test cases performed or determined by
6 programmers, and the testing is supported by engineers or
7 functional designers. When we come to phase two testing, it
8 is a system level test, administered for the most part by
9 engineers who are familiar with the functions.

10 MR. LIPINSKI: That's the point I wanted to touch
11 on in terms of the feedback. Are the people that were
12 involved with the initial design specifications the same
13 people that are looking at the test procedures, to see
14 whether these functional specifications are being
15 supported?

16 We are not dealing with static systems here.
17 These are dynamic systems, so that the test procedures are
18 very important.

19 MR. STARR: Could you repeat your question?

20 MR. LIPINSKI: You have a group of engineers doing
21 design specification. Are they the same people looking at
22 the test procedures that are used to verify the performance
23 of the system?

24 MR. STARR: Yes.

25 MR. LIPINSKI: Okay. So effectively you have got

1 feedback.

2 MR. STARR: Yes. It's not uncommon in design and
3 testing for a programmer to say, during a test to say, we
4 have a problem, I'm not sure if it's a bug or if it's a
5 design problem. And you go to an engineer and you say, can
6 you help me solve this.

7 So there is feedback. We are continually seeing
8 how this process works and basing our work on our
9 experience.

10 MR. LIPINSKI: Well, it's more than an engineer.
11 It's got to be a specific engineer that understands the
12 nuclear performance.

13 MR. STARR: Correct. I was referring to someone
14 familiar with the work, yes.

15 MR. LIPINSKI: Thank you.

16 (Slide.)

17 MR. STARR: This block diagram gives further
18 information on the process that we have just been talking
19 about. On the top you will see a series of what I will call
20 recorded calculations. In the middle you will see that
21 these calculations are input to both functional descriptions
22 and to data base document.

23 And work above that line is what I will refer to
24 as functional design. These calculations, as I say, are
25 both associated with design of the algorithms and data.

1 They are done by engineers and analysts, who base their work
2 on the safety requirements and design basis of the system.
3 These calculations are referenced by the functional
4 descriptions and the data base document.

5 And I might add that the functional description is
6 a complete description of the system. It includes all
7 system level requirements, in addition to the algebra of the
8 algorithms. And by system level requirements, I mean the
9 configuration of the system, the timing, permissives,
10 interlocks, alarms, annunciators, man-machine interface
11 requirements, and so forth.

12 So it is a fairly comprehensive document.

13 At the point these documents are generated, they
14 are then used in software as referenced by software design
15 specifications covering assembly language programming. From
16 those specifications the discs are generated and sent to the
17 site.

18 In addition, we are generating phase one and phase
19 two test reports. And I will explain phase one and phase
20 two testing in the following slides.

21 Phase one testing is designed to implement the
22 changes to the CPC software, and the implementation is the
23 translation of system functional requirements in the modules
24 of machine executable code and the integration of these
25 modules into a real time software system. This is strictly

1 a software test. It is done on individual modules of code.

2 Any module that is changed or modified is tested.

3 Any module that accesses updated data constants is tested,

4 and test cases are selected to exercise all branches of any

5 module that has been modified.

6 After phase one testing is completed, we do what

7 we call phase two testing. Phase two testing is performed

8 in a single channel CPC-CEAC system located in Windsor at

9 the CE offices.

10 I might add that this system includes an input

11 simulator with analog and digital generation equipment, an

12 FM tape recorder and various other recording equipment, such

13 as a strip chart recorder.

14 Our objectives are to verify that the

15 modifications have been properly integrated with the CPC and

16 CEAC system hardware, and to confirm that the static and

17 dynamic operation of the system is as we predict with the

18 FORTRAN code. As I say, the basis for the comparison is the

19 FORTRAN.

20 Item 3 should be basis for comparison is the

21 CPC-CEAC FORTRAN simulation code.

22 The phase two tests that we performed are called

23 input sweep dynamic software verification tests, or DST, and

24 live input single parameter, or LISP, tests.

25 (Slide.)

1 MR. LIPINSKI: Could you expand on each one of
2 those?

3 MR. STARR: Yes, I will.

4 One of the characteristics of our testing
5 comparison between the FORTRAN and the Perkin-Elmer
6 equipment that we do testing on is that they are different
7 machines, and we want to know, first of all, what is the
8 inherent difference in the processing of the algorithms
9 based on machine difference. And we call those processing
10 uncertainties.

11 The Interdata 716 is a 716 machine. The FORTRAN
12 code i. run on a CDC 7600, which is a 64-bit machine. So we
13 want to do two things. We want to find out if there are any
14 small differences based on machine, and we want to verify
15 over the operating space that these algorithms can
16 initialize without any abnormalities.

17 We run a minimum of 500 test cases, and these test
18 cases are selected based on judgments associated with the
19 type of modification that we are doing. If we modify
20 hypothetically the program, we will place more emphasis on
21 flow-related test cases.

22 It so happens in cycle one, the current version
23 was tested with 2,000 cases for the CPC's and 1200 cases for
24 the CEAC calculators. We intend to run the same number for
25 the San Onofre software.

1 This is a static, steady-state test. The dynamics
2 involved only relate to the initialization.

3 (Slide.)

4 Following the input sweep test in phase two, we
5 run the dynamic software verification test. This is a
6 dynamic test that is intended to properly assure the dynamic
7 response of the system and further assure the correct
8 software implementation -- we run a minimum of five test
9 cases.

10 Example cases are the following design basis
11 events: a four-pump loss of flow, a single CEA drop,
12 control bank withdrawal, rapid depressurization, and an
13 increasing power ramp. These cases are designed to be as
14 much like a real basis design event as we can make them.

15 It is strictly a software test, and we have found
16 it to be very useful in detecting software errors.

17 MR. LIPINSKI: Now, the inputs for these test
18 cases come from analog test?

19 MR. STARR: No, they do not. They are established
20 by special software. And the reason we do that is when you
21 are comparing a FORTRAN code to the assembly language code
22 you want to be very, very precise in getting the inputs
23 exactly the same with respect to time for both systems. So
24 we do that with software.

25 A special disc has these test cases on it. They

1 are loaded in a memory and the transient is initiated, so
2 that the inputs versus time are exactly the same, which
3 enables us to see more clearly any software errors that the
4 outputs versus time are not the same.

5 MR. LIPINSKI: How is that disc generated?

6 MR. STARR: It is generated by our software
7 group. The test cases are selected by engineers who are
8 working on phase two testing. The process of generating
9 that disc, I believe, is in accordance with CEN-39, although
10 I don't know for sure. I'm getting a yes from Ed Brown.

11 So the disc generation process for this software
12 is as rigorous as it would be for the actual software.

13 MR. LIPINSKI: Somewhere you've got something that
14 is generating a full characteristic that's gone onto that
15 disc with digital values at discreet time increments that
16 would correspond to a real time event in the plant.

17 MR. STARR: That is correct. If you're asking how
18 we select test cases --

19 MR. LIPINSKI: No. How you're generating the test
20 cases. Somewhere you've got something generating on your
21 digital computer, that is in turn producing --

22 MR. STARR: For the most part, the NSSS design
23 code we use is C-SEC. However, we do have other codes we
24 may choose to use. But in general, C-SEC is the one that we
25 use. It is a full-scale NSSS design code that simulates the

1 RCS, steam generators, core pressurizer, and so forth.

2 MR. LIPINSKI: Then you bypass your
3 analog-to-digital converters on the input to the actual
4 system and put it in the digital banks?

5 MR. STARR: That's correct. This test does not
6 include analog-to-digital conversion. And as I say, the
7 reason we do that is we want to be very, very precise.

8 (Slide.)

9 The third part of phase two is called the live
10 input single parameter test, and this test does include
11 analog-to-digital conversion. Its objectives are to further
12 assure the dynamic response and the implementation of the
13 software, and to evaluate the dynamic response of the input
14 hardware and software together.

15 We have a minimum for the five test cases that are
16 required for any case. The example cases are pump speed
17 ramp, the ex-core detector signal ramp, temperature signal
18 ramp, pressure signal ramp, and single CEA signal ramp.

19 The reason that we include, of course, the analog
20 to digital hardware here is that we did not do it in a test
21 and we want to make sure that we exercise those inputs
22 during our testing.

23 (Slide.)

24 The message, then, or summary that I want to leave
25 you with is that we do have a highly structured and detailed

1 process; staff reviewed that process in CEN-39 and
2 concurred; and that we are applying this process to the
3 Arkansas changes, and that we will be applying it to
4 others.

5 That completes my presentation. I will take any
6 further questions.

7 MR. LIPINSKI: Question. If I go back to your
8 dynamic software verification, I see changes in plant
9 parameters that may not be singular, although I guess if you
10 only got flow all you're going to generate is a flow signal,
11 no changes in the temperature signal; is that correct?

12 MR. STARR: These cases are based, as I say, as
13 nearly as we can make them on our simulation code results.
14 And I think for loss of flow in the time scale of that
15 event, temperature changes are very minimal, if anything.
16 It's a very rapid transient.

17 MR. LIPINSKI: But the question is, what's on the
18 disc? Are all the measured parameters on the disc that the
19 system would be sampling?

20 MR. STARR: Yes.

21 MR. LIPINSKI: So your simulation would develop
22 the change in all parameters, if they should occur?

23 MR. STARR: Yes.

24 MR. LAWROSKI: And now, if I go to your other
25 cases, you only have a single parameter being changed at any

1 one time.

2 (Slide.)

3 MR. LIPINSKI: You do not generate an FM analog
4 tape with all parameters changing for the test cases. Well,
5 in these particular test cases they can't, the reason you
6 selected them.

7 MR. STARR: The reason we used the
8 single-parameter ramps again goes back to our objective of
9 changing software errors. It's our belief that if you drive
10 the system with a lot of things changing at the same time,
11 your ability to isolate software errors can be affected. We
12 would rather go down and select a single signal,
13 particularly here where we were dealing with input with
14 analog-digital conversion. We'd rather select a single
15 signal and drive the system with that signal, and examine
16 with particular care those areas of the code that are
17 affected by that signal, so that we can better isolate any
18 possible software errors. That's our objective.

19 MR. LIPINSKI: Well, that's fine. You've picked
20 out your first five initial test cases. But there's nothing
21 that says that the list cannot be continued.

22 MR. STARR: That's true. I might add, in terms of
23 continuation of testing, I might add on DSVT, we do run much
24 more than the minimum. And I think the signals have been,
25 in our experience, pretty informative in terms of driving

1 the system. You can make a lot of things happen with just
2 one signal changing.

3 In answer to your question, yes, the list can be
4 made longer. And if in our judgment it should be, we will.
5 Each time we do a test, we take a look at what we are doing
6 and don't follow the procedure blindly. We do make an
7 ongoing evaluation each time of what it is we are doing.

8 MR. LIPINSKI: How do you know you're not getting
9 into trouble with sampling rates and data transfer, when you
10 are operating in real time, if you only do one of these
11 single parameter bases?

12 MR. STARR: I don't quite understand the
13 question. I think Ed Brown would like to speak, so I will
14 defer to him.

15 MR. BROWN: Dr. Lipinski, we have designed the
16 system to have a very simple sampling structure and data
17 transfer structure, such that it can be completely analyzed
18 and predicted. The DSVT test, reading the perfect inputs,
19 simulates all of the sampling rates and data transfer rates
20 that you would see in real time.

21 So that if there were an error in the system, it
22 would be at that time detected.

23 MR. LIPINSKI: If I recall, this is implemented in
24 the floating point?

25 MR. BROWN: Right now, with all the changes we

1 have made, all of the CPC changes are implemented in the
2 floating point.

3 MR. LIPINSKI: So you don't have to --

4 MR. BROWN: That's correct. One of the changes
5 that Mr. Rozek will talk about later on is that we did have
6 in an earlier version the flow algorithm in fixed point, and
7 we made a conversion of fixed point based on what we thought
8 was an increase in overall reliability of the system for
9 that consideration.

10 MR. LIPINSKI: Without the floating point, you
11 have the same results you had in --

12 MR. BROWN: That's correct.

13 MR. KERR: Another question?

14 MR. BELTRACCHI: My name is Leo Beltracchi.

15 In regards to your question, the examples of the
16 single variable transients, the staff in its original review
17 with the core protection calculator system required that
18 these be done in single variable, in order to test a
19 specific dynamic algorithm. And the only way you could
20 really assure that you could achieve this was by initiating
21 that variable, the key values for that algorithm, in a
22 single manner, rather than attempting to incorporate the
23 changes of all variables simultaneously.

24 MR. LIPINSKI: One thing that's bothering me, what
25 are there, eight inputs typically in terms of temperature,

1 pressure, flow, flux?

2 MR. STARR: If you include the CEA's, you're up to
3 about 30.

4 MR. LIPINSKI: Not each CEA individually, but
5 generically.

6 MR. STARR: Well, generically, you have ex-cores,
7 temperature, pressure and CEA, I believe generically, unless
8 you want to break down temperature in the cold leg and the
9 hot leg. But if you don't, then you have five inputs here.

10 MR. LIPINSKI: But for each of these five inputs,
11 I have a magnitude. If I want to think of this as a vector
12 set, I also have a rate. So I would have ten variables as
13 an input that I can assign initial conditions to in order to
14 initiate a transient into the system.

15 MR. STARR: Five initial conditions and five
16 rates.

17 MR. LIPINSKI: So I have a ten-variable set that I
18 can walk off into a vector space and go from all corners of
19 this space to make sure that I'm not having trouble in
20 getting the information processed through the system to
21 generate output signals.

22 MR. STARR: Correct.

23 MR. LIPINSKI: I'm still not convinced that you
24 can walk in any corner of the space that represents a
25 reasonable starting point of linear transients and guarantee

1 that you generate the required output.

2 MR. STARR: We do not run dynamic tests all over
3 the operating space. We select our cases based on our
4 experience and judgment.

5 I would remind you that the input sweep test,
6 which is a very large set of static test cases, shows that
7 initially we have implemented the software correctly, at
8 least in a steady-state sense, so that each point in
9 operating space can initialize and gets the correct answer.

10 Dynamically, we do not do that.

11 MR. LIPINSKI: Static cases only take care of the
12 magnitudes. It does not take care of the rates.

13 MR. STARR: That's correct. We choose our rates
14 for the --

15 MR. LIPINSKI: Individual parameters.

16 MR. STARR: Individual parameters, yes. But we do
17 not go all over the operating space with them.

18 MR. KERR: Are there other questions?

19 (No response.)

20 Can you think of anything within your experience
21 that has been of value insofar as where you now are on this
22 procedure, that has made a significant change in what you do
23 or what you look for?

24 MR. STARR: Not with regard to the ANO-2
25 operation. But with regard to our early testing of the

1 software, I would again point out that we found it best to
2 separate the goals of testing for functional adequacy, just
3 to separate that goal from the goal of testing for correct
4 implementation.

5 If you try to set up a test that is trying to do
6 both at the same time, it seems to detract from each goal.
7 And it appears best to us to look at each one separately.

8 I would defer to Bill Gill.

9 MR. GILL: There are two major learning
10 experiences in terms of software testing from the first,
11 say, two years. One is our original approach to testing was
12 to have one processor, and you figure that is either a CPC
13 test and then you can figure it as a CEA calculator. So we
14 did not have the ability to test the interaction between the
15 CEAC and the CPC.

16 As Mr. Cogburn had mentioned earlier, one of the
17 design problems we had was an interaction problem. Today we
18 have a CEAC and CPC with the data link as part of our single
19 channel. So it was a lesson learned. We have upgraded to
20 single channel.

21 The second major change we made is we previously
22 ran the input sweep, which to us is the test that gives us
23 the most confidence, only on the CPC. The CEA calculator
24 was a simplified software structure, and we were confident
25 we could analyze it by inspection or testing, other than

1 input sweep.

2 Based on the changes that Tom Rozek will talk
3 about, we have increased the complexity of the CEA
4 calculator software and its sophistication is such that it
5 approximates, although much less, the CPC. In response to
6 the additional complexity, we have input sweep testing on
7 the calculator. So we have significantly increased our test
8 ability of the CEA calculator and the CPC in the last year.

9 MR. KERR: Mr. Brown?

10 MR. BROWN: There's one other thing we've learned
11 from the software engineering aspects, and that is that the
12 testing that we have is extremely sensitive. We were able
13 to detect differences in the hardware implementation between
14 the 716 and CEC 7600, specifically in the way in which they
15 handled floating point numbers.

16 Our test criteria were so sensitive we thought we
17 had a hardware error until we modeled the actual floating
18 point hardware of the machine. And the test was so
19 sensitive we could see the differences.

20 MR. KERR: Do you have a mechanism that will
21 continue to follow the operation of this equipment, so that
22 if lessons do show up or things do show up you will be in a
23 position to learn from it?

24 MR. BROWN: Yes, we do, sir. We have two
25 mechanisms, two formal mechanisms. One is a field action

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS
SUBCOMMITTEE ON ELECTRICAL SYSTEMS

TO REVIEW MATTERS RELATING TO
THE USE OF COMPUTER PROTECTION SYSTEMS

Nuclear Regulatory Commission
Room 1046
1717 H Street, N. W.
Washington, D. C.

February 24, 1981

The subcommittee convened, pursuant to notice, at

9:00 a.m.

ACRS MEMBERS PRESENT:

- W. KERR, Chairman
- J. C. EBERSOLE
- J. J. RAY

CONSULTANTS PRESENT:

- S. DITTO
- E. EPLER
- W. LIPINSKI

DESIGNATED FEDERAL EMPLOYEE:

- R. SAVIO

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

ALSO PRESENT:

- H. ALDERMAN
- F. BOYD
- A. PEARSON
- B. MORRIS
- L. PHILLIPS
- M. SRINIVASAN
- E. KENNEDY
- A. SPINELL
- T. COGBORN
- T. STARR
- T. ROZEK
- B. GILL
- W. MOODY
- E. BROWN

* * *

1 request from our utilities and the other is our corrective
2 actions program, which transmits data such as LER's and
3 indications and things like this back to the designers.

4 And there is also the informal communications
5 right in the utility. We constantly factor back in our
6 operating experience and our design.

7 MR. KERR: Thank you.

8 Mr. Lipinski?

9 MR. LIPINSKI: On your ramp signals, who specified
10 the ramps? What people in your organization?

11 MR. STARR: Engineers associated with the
12 functional design of the system.

13 MR. LIPINSKI: So it went back to the front end,
14 where it was specified?

15 MR. STARR: Phase two in general was administered
16 by engineers associated with the functional design and
17 analysis of the system. Phase one in general was assembled
18 by assembly language programmers.

19 MR. KERR: Does that complete your presentation?

20 MR. STARR: Yes.

21 MR. KERR: Thank you, sir.

22 MR. STARR: You're welcome.

23 MR. KERR: Is that part A of number 4?

24 MR. KENNEDY: That was part A of number 4. Part B
25 and C of item number 4 will be presented by Mr. Tom Rozek.

1 Mr. Rozek is the cognizant design engineer for the
2 calculators, and he has the enviable task of responding to
3 all the questions we've been putting off all day.

4 Mr. Rozek.

5 MR. KERR: His last name is spelled --

6 MR. KENNEDY: R-o-z-e-k.

7 MR. ROZEK: Good afternoon.

8 (Slide.)

9 I would like to divide the software modifications
10 into two areas. The first area is based on the changes that
11 were made during Arkansas Cycle 1 operation. We made two
12 sets of software modifications based on operating experience
13 at Arkansas.

14 The second area of modifications are those that
15 will be implemented SONGS 2 above and beyond those made in
16 Arkansas Cycle 1. In addition, these modifications that we
17 are making for SONGS 2 and 3 will be implemented in ANO-2,
18 Cycle 2.

19 (Slide.)

20 Since I have a tendency to talk in acronyms
21 occasionally, I have provided a list of acronyms, and I hope
22 they are helpful for you.

23 (Slide.)

24 ANO- is the first plant with a CPC system. The
25 original software, since it was a first of a kind design,

1 the first plant with a digital protection system licensed in
2 the United States, the original software was conservative.
3 This conservatism impacted plant performance during Arkansas
4 Cycle 1 operation.

5 During Arkansas Cycle 1 operation, we made two
6 sets of software modifications. The first set which I will
7 call Mod 1/2A or Mod 1/2A, was implemented June 24th, 1979.
8 These changes were based on the early software qualification
9 and testing, original phase one and phase two testing, and
10 early ANO-2 operation, before Arkansas reached about the 20
11 percent power plateau.

12 The second set of modifications, called Mod 2B/3,
13 were implemented in May of 1980, and these changes were
14 based on later ANO-2 operation, feedback we got from AP&L,
15 and a rough breakdown on that would be about 50 percent
16 power, that we gained from Arkansas operation before they
17 had 50 percent power.

18 The notation Mod 1, Mod 2, and Mod 3 are just
19 notations that CE and AP&L have agreed to in defining these
20 changes. They are sets of changes. We have three sets
21 defined. We implemented 1 and part of 2 at one time, and
22 the rest of 2 and part of Mod 3 at a later time.

23 Both sets of software modifications were made in
24 accordance with the software change procedure CEN-39, which
25 was discussed by Tom Starr.

1 MR. KERR: Just as a matter of curiosity, is the
2 word "impacted" a pejorative term?

3 MR. ROZEK: Could you repeat the question?

4 MR. KERR: Is the word "impacted" as used in 1B
5 considered a pejorative term?

6 MR. ROZEK: I don't know what that word means.

7 MR. KERR: Well, is "impacted" good, bad or
8 neutral?

9 MR. ROZEK: In this sense, it would be bad. It
10 caused spurious trips at Arkansas.

11 MR. KERR: Thank you.

12 (Slide.)

13 MR. ROZEK: In a diagram to show where these
14 changes have been made, and with Arkansas Cycle 1
15 milestones, I have provided this slide. Initial fuel load
16 was in July of 1978. Initial criticality was in December of
17 1978.

18 About eight months or seven months later, in late
19 June, we implemented the first set of CPC software
20 modifications. In late January of 1980, ANO-2 first
21 achieved 100 percent power.

22 About five months later, we implemented the second
23 set of software modifications, Mod 2B/3.

24 Arkansas is planning to shut down late next month
25 for the end of its first fuel cycle, and beginning of a

1 second fuel cycle is predicted or hopefully predicted in the
2 middle of May or the first of June.

3 (Slide.)

4 What I'd like to present is some of the software
5 modifications that we did make for Arkansas Cycle 1. I
6 don't plan to go into a lot of detail on these changes, but
7 I will go into detail on the changes that Mr. Cogburn
8 brought up that aroused some interest, and I'll talk about
9 those in a little more detail.

10 And I will talk about what I consider the more
11 major changes we presented to the NRC staff last May.

12 The first change was we made changes to the low
13 power fixed ex-core shape in the CPC's. The CPC determines
14 power distribution from the ex-core signals. At low powers,
15 because of zero or near-zero ex-core signals, it cannot
16 calculate the power distribution.

17 So the CPC uses a fixed power distribution. In
18 the Arkansas Cycle 1 design, we had a couple of problems
19 with it. The first was the chattering about the breakpoint,
20 above which the fixed ex-core shape was not -- the real
21 shape was used, and below which the fixed ex-core shape was
22 used.

23 You don't have this slide because I just added
24 it.

25 (Slide.)

1 But our objective in this change was to preclude
2 the excessive conservative values of DNER at low power
3 because of the switching between the shapes. We had a
4 boundary point. We had no histories. The previous design
5 for powers lower than at breakpoint, as I said, we used the
6 fixed ex-core shape in the power distribution calculation.
7 Above this breakpoint, we used the actual power shape.

8 The changes that we made in this area -- Tom
9 Cogburn brought up that this problem did cause us what he
10 called "a design error," in quotes, that was the result of
11 one reactor trip at Arkansas. We made three changes in this
12 area.

13 We made the fixed ex-core shape consistent with
14 the measured, or the 20 percent measured power shape
15 annealing matrix. That was a major problem. We fixed our
16 ex-core shape on the predicted shape annealing matrix. When
17 the shape annealing matrix did change, our power
18 distribution calculated with the fixed ex-core shape was
19 very conservative.

20 It had an ASI calculated on the order of minus .6,
21 plus or minus .1. So it was a very conservative
22 calculation.

23 We implemented a corrected ex-core shape.

24 The second change was we raised the breakpoint
25 power. Previously the breakpoint power was about 1-2/3

1 percent linear power. Based on the ex-cores, the shape that
2 we were provided with would be conservative up to power
3 levels of about 15 percent. And we asked ourselves
4 questions about signal or signal-to-noise ratios at low
5 powers, and we decided to make the break point on the order
6 of 5 percent power.

7 The third change we did to eliminate the
8 chattering about the breakpoint was to add a hysteresis
9 band, so that we would use a fixed ex-core shape for powers
10 below 5 percent and the actual power shape for powers above
11 7 percent all the time, and in the range 5 to 7 percent it
12 depended on which direction we approached the breakpoint.

13 (Slide.)

14 After we implemented this change, Arkansas had no
15 problems with crossing this boundary point.

16 The second software change we implemented for the
17 Arkansas Cycle 1 was we made modifications to the CPC and
18 CEA position dead bands. In the early CPC design, we only
19 had dead bands of 7-1/2 inches. Technical specifications
20 require rod exercising every month, moving the rod five
21 inches to assure that they will move. And the five inches,
22 plus the uncertainties associated with CEA positions, could
23 possibly cause spurious trips, channel trips or plant
24 trips. So increase the dead band to 11 inches, or 7-
25 percent.

1 In the CEAC, we had no --

2 MR. KERR: Excuse me. What is meant by increasing
3 the dead band to 11 inches? In terms of indication or
4 movement or something? What is it?

5 MR. ROZEK: In the previous design, in the top 5
6 percent of the core or top 7-1/2 inches of the core we
7 permitted CEA deviations. The penalty factors were not
8 applied. Our uncertainty analysis took into account small
9 deviations in this upper 5 percent of the core.

10 This 5 percent, this is what I mean with the dead
11 band. It inhibits the calculation of penalty factors for
12 rod deviations within this 5 percent, because CEA exercising
13 will require insertion of rods 5 percent, which is roughly
14 3-2/3 percent.

15 We increased the size or the magnitude of this
16 dead band, so we would have a larger area without penalty.

17 MR. KERR: The dead band is now the upper 5
18 percent?

19 MR. ROZEK: The upper 7-1/2 percent.

20 MR. KERR: Thank you.

21 MR. ROZEK: In the CEAC, our original design did
22 not have dead bands at all, which could possibly result in a
23 reactor trip if, during the rod exercising, one of the
24 operators inserted the rods too far by accident. So we
25 increased the size or we added dead bands, with logic

1 similar to the CPC logic, with a magnitude of 7-1/2
2 percent.

3 The third change we made we made modifications to
4 the dynamic power calculations. The dynamic power thermal
5 calculation is based on the rate of change of the hot leg
6 temperature. This calculation was fairly sensitive to
7 noise. We reduced the sensitivity to noise.

8 MR. LIPINSKI: Could you be more specific? What
9 did you do, put a filter in?

10 MR. ROZEK: Okay. The filter that was in there,
11 that represented this dynamic term, was a lead filter. It
12 accommodated transport time delays and the RTD time delays
13 associated with the increase of hot leg temperature. And
14 the gain on this filter was 13 percent power per degree
15 Fahrenheit, which was fairly substantial.

16 We went back and looked at this gain and reduced
17 it.

18 MR. LIPINSKI: Wasn't that put in to try to
19 compensate for the lag time and not the measurement?

20 MR. ROZEK: That is true. But we found we could
21 compensate with a smaller gain.

22 MR. LIPINSKI: But you didn't effectively
23 compensate for it. In effect, you took some of the lag of
24 the measurement.

25 MR. ROZEK: Could you repeat your question?

1 MR. LIPINSKI: Well' first of all, you had a
2 measurement that had lag time in it. To try to offset the
3 lag time, you put in a lead filter. Now you found out that
4 it was noisy because it had a derivative characteristic to
5 it. So you backed off on the differentiation.

6 And effectively, you have gone back and accepted
7 more of the lag from the initial measurement.

8 MR. ROZEK: Can I illustrate this with you, the
9 difference between the old filter and the new filter? And I
10 hope I can satisfy your question.

11 MR. KERR: Well, if what Walt said is true, you
12 don't need to illustrate it any more. He understood it.
13 Does he understand what you meant or not?

14 MR. ROZEK: He has it half right.

15 (Laughter.)

16 MR. ROZEK: What we had essentially would be time
17 and power. During a single CEA withdrawal event, the actual
18 power would go up like this. The CPC-calculated thermal
19 power would have a lag. It would go up like this, where
20 this would be flux actual and this would be the CPC static
21 thermal power uncompensated.

22 By order of design, the gain on the dynamic
23 thermal power compensation ideally should bring the static
24 thermal power equal to or greater than the actual power.
25 The optimum compensation did this, but it brought it up like

1 this. So we were optimized with this increasing power, but
2 it jumped up and down. It was noisy as the power
3 increased.

4 What we did was reduce the magnitude of these
5 jumps, and then your design goes up sort of like this. So
6 there is less sensitivity.

7 MR. LIPINSKI: If I recall, I think you took your
8 simple first-order transient time constant and simply
9 applied a first-order difference. Now you are illustrating,
10 due to the fact that you have a sampling process, that
11 you've got an oscillation. I think if you went back to the
12 digital filtering theory, I think you could even get rid of
13 those oscillations and make it acceptable.

14 MR. ROZEK: The form of the filter --
15 (Slide.)

16 MR. KERR: He was just trying to illustrate that
17 he understood more than half of it.

18 (Laughter.)

19 MR. ROZEK: Okay. I'll accept that.

20 Based on the input sweep testing that Ed Brown
21 brought up earlier about the small differences in input
22 machines between the CDC 7600 and the Interdata-716, we
23 found that our heat flux and local power density filters
24 were susceptible to truncation at certain power levels.

25 The susceptibility began about 90 percent power

1 for heat flux, which is where you don't want to have
2 additional errors. This was due solely to differences in
3 machine precision between the Interdata and the CDC 7600.

4 We represented our filters previously by a direct
5 form, where the current value of the output depends on the
6 current value of the input plus current values of the input,
7 and on the current values or the past values of the
8 outputs. What we did was, we transformed this filter from
9 what we called the direct form, the way it was implemented,
10 to a cascade form, which was less sensitive to truncation
11 noise on the Interdata-716.

12 So the filters had the same response, but had less
13 sensitivity to machine precision truncation.

14 MR. KERR: What do you understand of that, Walt?
15 I understand about 20 percent of it.

16 MR. LIPINSKI: I'm willing to let that one pass,
17 rather than stimulate a half-hour discussion.

18 MR. KERR: Go ahead. He understands it.

19 (Laughter.)

20 MR. ROZEK: The fifth change was we went to
21 floating point arithmetic. Ed Brown mentioned this
22 earlier. We made this change because the software is easier
23 to maintain with this change, the software is more
24 accurate. And in the previous design the CPC's would be in
25 a continuous auto-restart mode, and would not be calculated

1 as certain shutdown conditions with no pumps running, for
2 instance, or three pumps running and shutdown rods
3 inserted. It would be in this continuous auto-restart
4 mode.

5 Changing to floating point arithmetic, we had the
6 capability to have the CPC run performance calculations in
7 shutdown conditions.

8 MR. LIPINSKI: How many digits are you carrying in
9 terms of the digital accuracy? They've got bits. I don't
10 know how they do their change to floating conversion.

11 MR. ROZEK: I will defer to Mark Stofko.

12 MR. STOFKO: Mark Stofko of CE.

13 The floating point arithmetic in the Interdata-716
14 computer has a 32-bit configuration. 24 bits represent the
15 mantissa and 8 bits for the exponent.

16 MR. LIPINSKI: Is that plus or minus, that
17 exponent?

18 MR. STOFKO: There is an excess 64 notation. I
19 don't know if you are familiar with that, but that would be
20 plus or minus.

21 MR. LIPINSKI: Plus or minus 8 bits? I'm trying
22 to get a feeling as to whether I'm going to see a number
23 that's 10,000 in terms of the mantissa part and 10 to the
24 minus 99 to 10 to the plus 99 in terms of the exponent
25 part.

1 MR. BROWN: Ed Brown, CE.

2 It's seven bits plus a sign bit. It's 10 to the
3 minus 69th to 10 to the plus 69th.

4 MR. LIPINSKI: Thank you.

5 MR. ROZEK: The next change we made is changes to
6 the CPC initialization. The CPC initialization was the
7 change of one constant to permit the calculator to be run
8 with less than four pumps running in shutdown conditions.
9 The CEAC initialization was a change that we implemented,
10 that Tom Cogburn brought up. It was the second design error
11 in the CPC's.

12 MR. KERR: What's this, quote, "design error"?

13 MR. ROZEK: The, quote, "design error," I would
14 say is the flaw.

15 MR. KERR: Okay, we'll accept flaw. Where we
16 would say "error," it is translated into "flaw."

17 MR. ROZEK: The objective with the CEAC
18 initialization was to eliminate the possibility of CEAC trip
19 caused by an unnecessarily large penalty factor being
20 generated after an auto restart. The CEAC auto restart
21 would be generated after the testing, periodic testing of
22 the CEAC, or after reload of the CEAC software.

23 In the previous design, a very large penalty was
24 applied on the length of the CPC after initialization. If
25 the CPC read this large penalty factor, it resulted in a

1 trip. In seven cases for Arkansas, it did result in a
2 trip.

3 What we did was, after the CEAC comes out of
4 initialization, instead of having an extremely large -- or
5 the largest penalty factor that could be transmitted, it
6 transmits the realistic penalty factor.

7 (Slide.)

8 The changes I have just listed are the changes
9 that were implemented as a part of the Mod 1/2A software
10 package that was implemented in June of 1979. The following
11 changes are the changes that were implemented at Arkansas in
12 May of 1980 and are part of the Mod 2B/3 changes.

13 We have added the capability for the CPC's to
14 provide reactor protection for certain asymmetric steam
15 generator transients. In the original Arkansas design and
16 the way it is licensed now is that protection for asymmetric
17 steam generator transients is provided by the low steam
18 generator level trip. This required a trip setpoint on the
19 order of about 40 to 50 percent, am I correct, Tom?

20 Without having to provide protection for certain
21 isometric steam generator transients, the setpoint could be
22 lowered on the order of 10 to 20 percent. During Arkansas
23 startup, when the feedwater controls were in the manual
24 mode, there was a possibility for reactor trips to be
25 generated because of not keeping the water level constant,

1 and reactor trips did occur. I don't know how many.

2 What we did was make a modification to the CPC
3 system to provide protection for single MSIV closure in the
4 CPC's. This changed the base on looking at the cold leg
5 temperatures during an asymmetric steam generator
6 transient. The cold leg temperatures will diverge and
7 account for sensor time delays, and essentially have put in
8 a trip based on the difference of cold leg temperatures.

9 MR. KERR: Now, steam generator transient is a
10 situation in which steam generators behave differently in
11 turn?

12 MR. ROZEK: That is true.

13 MR. KERR: Right.

14 MR. ROZEK: We altered the design slightly so that
15 we would have input for thermal filters, so that we would
16 have input based on thermal power and flux power.

17 The next two changes I am going to discuss in a
18 little more detail. They are the CEAC penalty factors and
19 the CPC-CEAC diagnostics that we added.

20 (Slide.)

21 The objective with the penalty factor changes are
22 to reduce the number of unnecessary CPC trips as a result of
23 the CEA deviation logic. As was brought out earlier, the
24 CPC's must provide protection for CEA deviation events. But
25 all deviation events do not need to result in a trip. For

1 example, rod drops at zero power, 10 percent power or
2 full power, there is enough margin in the core not to have a
3 reactor trip.

4 In the previous design, the CEAC calculated one
5 worst-case penalty factor that was applied both to the DNBR
6 calculation and the local power density calculation. This
7 worst case penalty factor was independent of the CEA
8 configuration. So therefore, the result of a dropped CEA
9 with all rods out, the same penalty was applied in the CPC's
10 as for a drop of a CEA with the rods heavily rodded. The
11 penalty factor was applied to the one pin radial peak and
12 the CEAC/RSPT, and our logic only permitted both CEA's to be
13 in service or both CEAC's out of service.

14 This change was requested by AP&L for the
15 following reasons: First, if there were spurious inputs to
16 one of the CEA calculators on one CEA, it required turning
17 off that CEA calculator. By turning off that CEA
18 calculator, you lost information from the other CEA's,
19 especially to the CRT display.

20 The only way to do it was physically turning off
21 the computer. What they wanted was a capability to leave
22 the computer running, but to inform the CPC's that the CEA
23 calculator was calculating spurious penalty factors, and
24 that essentially the plant is operating in the one out of
25 one CEA logic permitted, or the CEAC mode permitted by tech

1 spec.

2 The changes that we made are we now calculate
3 separate penalty factors for DNBR and local power density.
4 These penalty factors are based on the magnitude of the
5 deviation, how large is the deviation of one rod compared to
6 the other three rods in the core, the direction of the
7 deviation, is the deviating CEA above all the other CEA's in
8 the subgroup or below the CEA's in the subgroup.

9 This is as far as the dependency was in the
10 original Arkansas design, so the following changes were
11 added. Number C, we made the CEAC penalty factors dependent
12 on the subgroup division, which subgroup had the deviated
13 CEA.

14 We made the penalty factors based on the CEA
15 deviation on which rods or which banks are inserted into the
16 core. We also made the penalty factor dependent on time.
17 We have added a dynamic xenon component. We increased the
18 amount of information transmitted from the CPC -- from the
19 CEAC to the CPC.

20 Previously, we transmitted a fail flag which
21 informed whether the penalty factor was good or not good,
22 and one penalty factor. We have continued to transmit this
23 fail flag. We transmit both the DNBR and the local power
24 density factors, and we also transmit a penalty factor flag
25 which is essentially a trip flag, so that we can do our

1 scaling on our 16-bit length with the most benefit.

2 We applied the penalty factor to the heat flux.
3 The penalty factor on gain was based on power margin, and it
4 was appropriate to apply it on the heat flux.

5 We modified the logic so that one CEAC could be
6 left in service, the other CEAC, the CPC would know that
7 CEAC could or was providing a spurious output, but the
8 operator could use the CRT display to monitor the other 80
9 rods. And we modified the CEAC CRT display.

10 (Slide.)

11 The previous display was just a bar chart and
12 that's all there was. The numbers that are on the left-hand
13 and the right-hand side, and on the bottom and the top were
14 decals that were pasted to the CRT. And if there was a
15 horizontal problem with the rods, this underneath here did
16 not correspond to the numbers if there was a slight shift.

17 (Slide.)

18 We modified the CRT display to get more human
19 engineering into it, so that we would have the CEA positions
20 in the groups and subgroups and individual CEA names
21 provided on the screen, written by software. The first
22 column up here indicates which regulating group or shutdown
23 group the CEA's below it correspond to.

24 The second line is the subgroup number, subgroups
25 10 or 11 or in regulating group 1. And the next set of

1 lines are the individual CEA's in these subgroups. So for
2 these subgroups or regulating group 6, that is inserted;
3 that is group 12; and CEA's 46 through 49 and CEA 1 are in
4 this group.

5 If there was a failure of the CEAC sensor, the
6 operator, if he did not know immediately which rod it was,
7 he could go to the display and it would count over which rod
8 had the sensor indication.

9 We also put on the display what the values of the
10 penalty factors are, so that operators, if there is a
11 deviation of rods, the operator will have an immediate
12 indication, if he looks at a CRT, of what is that effect
13 going to be on his power or on his DNBR margin or his local
14 power density margin.

15 If he saw a penalty margin of a 5 percent penalty,
16 he would know that deviation is relatively small and he
17 should correct it. If he saw a very large penalty factor,
18 he would require a quicker action.

19 The number in the corner here --

20 MR. KERR: The change to which you have been
21 referring has been implemented only in ANO-2?

22 MR. ROZEK: Yes.

23 MR. KERR: And the operators tell you that they
24 get a lot more information on this display than they
25 previously got?

1 MR. COGBURN: Our operators are much more pleased
2 with this display than the previous one. I believe it gives
3 a substantial amount more information, and it is certainly
4 much easier to decipher.

5 MR. ROZEK: The number in the upper right-hand
6 corner corresponds to which CEAC is being looked at, either
7 CEAC number 1 or CEAC number 2.

8 The square is a cycling block that turns on and
9 off, to let the operator know that the CEA display is
10 valid. If this block was not turning on and off, it would
11 indicate that the CEAC had failed and the information here
12 is no good.

13 (Slide.)

14 This slide is similar to the first one. You
15 notice that the block is turned off and is cycling. It
16 indicates deviations overall. The "P" indicates that there
17 is a penalty being applied in the subgroup because of the
18 deviation of the subgroup. The "A" indicates that there is
19 an alarm condition. The deviation magnitude is sufficient
20 enough to cause an alarm. It is not sufficient enough to
21 cause a penalty factor.

22 The penalty factors are provided here.

23 The next change for Arkansas Cycle 1, the second
24 modification was a CEA-CPC diagnostics --

25 MR. KERR: Excuse me, Mr. Rozek. How much longer

1 is your presentation likely to take? I'm trying to judge as
2 to whether I should take a break now.

3 MR. ROZEK: 20 minutes or 25 minutes.

4 MR. KERR: Would you feel hurt if we took a
5 ten-minute break at this point?

6 MR. ROZEK: No, sir, I would not.

7 MR. KERR: Okay. I declare a ten-minute break.

8 (Recess.)

9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

1 (Slide.)

2 The next area of discussion is the CPC-CEAC
3 diagnostics that we added into the CPCs that were
4 implemented at Arkansas in May of 1980. Our purpose was to
5 provide additional diagnostics to identify the cause of
6 spurious CPC trips.

7 The previous design we had status words in the CPC
8 that would provide an indication that a sensor had failed.
9 That's the only information we had that some time from the
10 previous time it was looked at that a sensor had gone out of
11 range.

12 The changes that we made in order to facilitate
13 this diagnostic capability was we added fail sensor stacks
14 in both the CPCs and the CEACs. These stacks store up to
15 six entries. An entry is made when a sentry changes state
16 and goes from in-range to out-of-range or out-of-range to
17 in-range.

18 It contains an ID name which corresponds to the
19 sensor so the operator will look at it and see sensor 7 and
20 know it corresponds to a hot leg temperature. It contains a
21 status, whether it has failed out-of-range low, out-of-range
22 high, or is now currently opearable, and the time of the
23 entry. This time is a relative time since the CPC or CEAC
24 restart time.

25 This sensor stack can be assessed in one of two

1 ways. The first way is through the operator's module. We
2 have assigned 19 18-point IDs to look at these fail sensor
3 stacks so the operators can punch in numbers and record
4 numbers through the operator's module.

5 The second method is if the calculator is placed
6 in test, a hard copy record can be obtained through teletype.

7 The second diagnostic change we implemented in the
8 CPCs was to provide a snapshot in case the penalty factor
9 was calculated by CEAC or the trip was calculated by a CPC
10 channel. This snapshot we found to be useful for many trips
11 due to spurious reasons that Arkansas CPC would trip. It's
12 a very fast-responding system. It trips for some events
13 within 600 milliseconds, and we have no indication why it
14 tripped.

15 The snapshot stores in memory certain variables
16 used in the CPCs -- the inputs, the addressable constants,
17 certain intermittent variables like flow power, ASI, and the
18 outputs to the DNBR that's being calculated.

19 As I said earlier, this buffer is filled in the
20 CEAC if a off-normal penalty factor is generated. For CPC
21 this buffer is filled if the buffer is tripped.

22 MR. RAY: What triggers the snapshot?

23 MR. ROZEK: In the CPC, a channel snapshot, if it
24 calculates below that, it will take a snapshot of a certain
25 data and store it there until the operator releases that.

1 In this sense there is a large amount of data recorded in a
2 snapshot, about a hundred variables in point IDs and inputs
3 in this date list. It is accessible only through a teletype
4 when a calculator is placed into test.

5 Another change we made is we added logic to
6 prevent spurious penalties as associated with
7 RSPT-associated instrumentation anomalies. This was touched
8 on a little bit earlier. If sensed rod position was 150
9 inches withdrawn and 100 milliseconds later it was sensed at
10 zero inches withdrawn or was sensed grossly out of range, we
11 would alarm this indication. We would have the CEAC or no
12 penalty calculated for this instrumentation error due to
13 RSPT anomaly, and it would provide time for the operator to
14 take that CEAC out of service and be an effective one out of
15 one mode or both CEACs inoperable mode in a boiler reactor
16 trip.

17 (Slide.)

18 In addition, if there are other modifications made
19 during cycle 1, these are relatively minor modifications.
20 We changed the saturation trip logic following Three Mile
21 Island. There were some questions of the saturated
22 temperature. We said well, indirectly we have a trip based
23 on saturated enthalpy, because enthalpy is used in the DNBR
24 calculation.

25 In order to help assist operators, we are doing

1 this calculation, saturated temperature versus primary
2 pressure. We also made changes -- we input some of the
3 major power distribution constants.

4 MR. KERR: Excuse me. I'm not quite sure what you
5 did as a result of TMI-2. I heard your discussion, but what
6 did you do?

7 MR. ROZEK: After TMI there was some questions,
8 can the CPCs when the coolant is at saturated conditions --
9 we said yes, except these calculations are one in the
10 enthalpy space instead of temperature space.

11 As a result of Three Mile Island, we are doing
12 this calculation in temperature space where we calculate the
13 saturation temperature and the actual maximum temperature to
14 compare the two. The CPCs have a trip logic in it, except
15 this logic before was based on enthalpy.

16 By calculating on temperature, the operators can
17 go to CPCs and have an estimate of how far away from
18 saturation they are in temperature units.

19 MR. KERR: If it's calculated in enthalpy, can you
20 do this?

21 MR. ROZEK: They would have to go to steam tables
22 and convert the enthalpy back to temperatures. So there are
23 changes on this order of magnitude also for Arkansas.

24 MR. LIPINSKI: Is there an automatic trip, or is
25 it only displayed information if he chooses to look at it?

1 MR. ROZEK: No. There is a CPC trip when the
2 sensed temperature is at saturated conditions.

3 MR. LIPINSKI: Is that moot for an assigned
4 function?

5 MR. ROZEK: No, it is not moot. It was to provide
6 protection on specific volume and enthalpy, which are only
7 valid in the subcooled region. If we got out of the
8 subcooled region, these would be no good, and we wanted a
9 trip.

10 MR. LIPINSKI: Okay.

11 (Slide.)

12 MR. ROZEK: The next set of changes are the
13 SONGS-2 changes which will be an upgrade from this current
14 cycle 1 design. These changes will be also implemented in
15 Arkansas cycle 2 in the following areas: the DNBR
16 calculation, addressable constants, power distribution
17 calculation, diagnostics and plant specific data.

18 I don't have a slide on plant specific data, but I
19 will explain it briefly here. Plant specific data is
20 exactly what it says. It's the number of CEAs that will be
21 added to the CPCs using 91 instead of 81 characteristics of
22 the core -- the larger core, larger power level, higher flow
23 rate in that area.

24 (Slide.)

25 The DNBR calculation, we wanted to base our static

1 DNBR and our updated DNBR calculations on the CE critical
2 heat flux calculation.

3 MR. KERR: Could you tell me in a few words why
4 you wanted to do that?

5 MR. ROZEK: I'll defer to Bill Gill.

6 MR. GILL: Previous algorithms were an
7 approximation to the W-3. That basically had the same
8 information flow and the same functional form, where the CPC
9 algorithm used approximations and curve fits to sum up the
10 more complex iterations that would be in a design code like
11 the W-3.

12 When we were fitting the CPC W-3 algorithm to the
13 W-3 correlation, it fit very well and had low
14 uncertainties. When the design basis algorithm for Southern
15 Cal, the overall design plant basis correlation was
16 converted to the CE-1, we now had a mismatch between the
17 functional form and information flow to CPC in the design
18 algorithm. We therefore went in and redesigned the CPC
19 algorithm such that it was a better approximation, and
20 therefore, uncertainty analysis would result in more
21 uncertainty.

22 MR. KERR: I'm trying to understand what the
23 operational results of that description is. Does that mean
24 that you can get more power out of the same reactor?

25 MR. GILL: Yes.

1 MR. KERR: I was trying to search for -- to
2 respond to what you said there.

3 MR. ROZEK: This slide essentially says what Bill
4 said. The previous design was based on W-3 methodology,
5 basing it on our CE-1 methodology, the CPC and the
6 addressable constant area. We have implemented power
7 distribution constants for CEA shadowing, radial peaking
8 factor, and coolant temperature chattering which Tom Cogburn
9 called temperature decalibration.

10 All of these changes were based on Arkansas cycle
11 I startup experience. We found out that we could
12 accommodate what was measured at Arkansas, but it resulted
13 in increasing uncertainties that had to be applied all the
14 time.

15 With adding certain addressable constants we can
16 more accurately model the power distribution that CPC
17 calculates as compared to the actual power distribution. We
18 have made the DNBR and local power density pre-trips at
19 points addressable. In the previous design these were fixed
20 numbers.

21 Our philosophy in this is that it is the utility's
22 decision to decide where they want to have their alarm on
23 these calculations. What we foresee is that they would be
24 operating at a nominal condition and be, for example,
25 calculating the DNBR of 1.8. They would set the set point

1 at 1.7, so if they got off these nominal conditions, they
2 would have an alarm, and the operator could take the
3 appropriate action.

4 We have added a method for automated re-entry of
5 addressable constants. We can write the addressable
6 constants that we don't expect to change during the fuel
7 cycle such as a startup-related addressable constant to a
8 disc after a software reload. We can read these addressable
9 constants back into the memory.

10 MR. LIPINSKI: Question. The addressable
11 constants are entered from the console, and I believe they
12 have a decimal point as part of their entry.

13 MR. ROZEK: They can. The floating point numbers
14 will have a decimal point.

15 MR. LIPINSKI: Do you still have software validity
16 checks as to whether the number entered is within the
17 acceptable range?

18 MR. ROZEK: Yes.

19 MR. LIPINSKI: Did you have to change any of these
20 from what you had already implemented?

21 MR. ROZEK: I don't recall any.

22 Did we, Bill?

23 MR. GILL: No.

24 (Slide.)

25 MR. ROZEK: In the power distribution calculation

1 was made a couple of changes. We changed some fixed numbers
2 in the calculation data-based constants. These fixed
3 numbers are specified in our functional specification. They
4 were based on Arkansas cycle 1 optimization of the power
5 distribution calculation, and we wanted to make it so we
6 could add numbers based on the cycle in the plant, so
7 several numbers have been changed on that data base constant.

8 MR. KERR: Give me a for example.

9 MR. ROZEK: For example, in the shape annealing
10 matrix there were checks at the end of power, less than 3
11 percent, and that 3 percent was a fixed number. We would do
12 a certain set of logic. That 3 percent number is now a
13 constant that we can calculate on a plant specific basis.

14 MR. KERR: Okay. Thank you.

15 MR. ROZEK: The second change is we have added a
16 density dependent correction to the radial peaking factor.
17 In the previous design we used radial peaking factors with
18 uncertainties that were table look-up values based on CEA
19 configuration alone. We have a density correction now.

20 MR. KERR: Density of what?

21 MR. ROZEK: Density of the coolant.

22 MR. KERR: Thank you.

23 And the density is measured on a global scale or --

24 MR. ROZEK: We measure it based on the cold leg
25 temperature density.

1 MR. KERR: Okay.

2 (Slide.)

3 MR. ROZEK: Since Arkansas cycle 1 had our first
4 try, our first cut at diagnostics, I think we did a very
5 good job. We did want to improve them based on our
6 operating experience there.

7 One of the changes is we changed the CEAC snapshot
8 buffer. Before, it would take a snapshot whenever there was
9 a penalty factor and update it every five seconds. Right
10 now, based on the Arkansas design and because of delays in
11 applying penalty factors, our trips after penalty factors,
12 if the penalty factor is not large enough to cause a reactor
13 trip and a couple of seconds later it does cause a reactor
14 trip, we don't get a true indication of the data in the
15 snapshot buffer which causes the trip.

16 We have changed it so it models the CPC, and we
17 will think it will work better. I think it was kind of
18 confusing.

19 The fail sensor stack ID numbers, in general we
20 tried to keep the fail sensor stack ID numbers the same as
21 the point ID numbers. We also enter in the fail sensor
22 stack different --

23 MR. KERR: Excuse me. I don't understand the
24 difference between a sensor stack ID number and a point ID
25 number.

1 MR. ROZEK: Okay. A point ID number is when we go
2 to the operator's module on the CPC and we say display XYZ.
3 XYZ is called the point ID number, a number that corresponds
4 to a variable; and the number will be displayed along with
5 the value of that variable.

6 The fail sensor number is a notation; that stack
7 number is the number that we use in our fail sensor stack.
8 If you recall from an earlier slide --

9 MR. KERR: I remember that.

10 MR. ROZEK: -- Recall whether a sensor failed high
11 out-of-range, in range. And generally what we wanted in our
12 original design was to have the fail sensor ID number be the
13 same as the point ID number; so if point ID number 005
14 corresponded to cold leg temperature 1, we wanted a fail ID
15 stack sensor number to be -- if they saw 005 here, they
16 would have the reinforcement to know that.

17 In fail sensor stack we also record stuff that
18 is not true se values. We compared the difference in
19 the CEA deviatio. penalty factors. If the difference in the
20 penalty factors is larger than sum epsilon, it could be the
21 result of an anomaly or a spurious penalty being calculated
22 by on of the two calculators. For example, if one CEAC is
23 calculated in a penalty factor of 2.5 and one is calculated
24 in a penalty factor of 1.0, we would not expect that big a
25 discrepancy. With a discrepancy that big we want to alarm

1 it to the operator, have him go check it out.

2 And to store this stuff in the fail sensor stack
3 we arbitrarily assigned it numbers. These numbers
4 corresponded to point ID numbers, and when the operators
5 went in and they saw these numbers, they went to the point
6 ID table, and if it was the wrong indication, we changed the
7 numbers to something unique that would not be in a point ID
8 list.

9 The third change was a CEAC-CRT rewrite.

10 (Slide.)

11 In the CEA display that we developed, the only
12 portion of the CRT that is rewritten periodically is the
13 penalty factors here and here, and all this information
14 below here, the rod positions. The numbers above it, the
15 group and the subgroup and CEA number, is independent or
16 should not or is not going to change over the cycle life.
17 So once this is written following a restart, it is not
18 rewritten again.

19 What we have done is added an addressable constant
20 in the CEAC to rewrite the entire CEAC display, including
21 these numbers up here. This was required because when one
22 calculator was placed in the test, the screen would go blank
23 at one time during this test procedure. The operators,
24 wanting to see the rod positions, would switch to the other
25 calculator, and this information would be missing during the

1 switching procedure. So we wanted to have the capability
2 for the operator to put this information on the top back on
3 to the screen.

4 MR. LIPINSKI: Why are the two rows interchanged?
5 Look at the left, 44 and then 42?

6 MR. ROZEK: Okay. This is the Channel A target
7 rod, the Channel B target rod, the Channel target rod, and
8 the Channel D target rod, all the way down. Why the core
9 was -- that's the way it was wired.

10 The ex-core stack for Channel C is in front of rod
11 44.

12 MR. LIPINSKI: Those quadrants were progressive,
13 weren't they -- A, B, C, D, -- as you went around the radius
14 of the core?

15 MR. ROZEK: No.

16 MR. LIPINSKI: Okay. Then I don't see what the
17 correlation is by presenting these rows to the operator if
18 you are not giving him the geometric orientation.

19 MR. ROZEK: Okay. Presenting these rows as the
20 purpose of -- for example, if this rod was deviating right
21 here like in this case, if he did not know by immediately
22 looking at it which rod was deviating, he could go to this
23 display, counter over two rods, 46, 47, and then withdraw
24 that one rod.

25 MR. LIPINSKI: I understand that, but if I give

1 you an overhead view of the core and ask you to tell me
2 where section A, B, C, D are, then he doesn't have this
3 geometric overview here, so how do you correlate these rows?

4 MR. ROZEK: I'll defer this to Bill Gill.

5 MR. GILL: Bill Gill, Combustion Engineering.

6 There is a core mimic which is basically a picture
7 of the core on the control board which shows the rod
8 position relative to the core layout, the actual bundle that
9 the rod is in. That's another device that is not driven by
10 the CPC, but he does have correlation with respect to a rod
11 number in a spatial location.

12 MR. LIPINSKI: But how do I correlate the way you
13 write out your loads to the way the rod is positioned in the
14 core?

15 MR. GILL: You go to this core mimic. You go to
16 the core mimic, and you will see basically a map of the
17 core, a bundle arrangement. You will see a number and
18 location. You will see a detector with an A, B, C, D on it.

19 MR. LIPINSKI: Let's start from the beginning. I
20 was told that those rows were A, B, C, D.

21 MR. ROZEK: Target rod for Channel A and Channel B.

22 MR. LIPINSKI: Now, where are Channels A, B, C, D
23 with respect to this geometric plan?

24 MR. ROZEK: My guess -- and Tom can correct me if
25 I'm wrong -- if the core is divided into quadrants like

1 this, it would be A, B, D, and C, where the letters indicate
2 where the ex-cores are arranged, and everyone from CPN and
3 AP&L is agreeing with me. So that's the way it is wired up.

4 MR. LIPINSKI: That's a subject for presenting
5 information to the operator.

6 MR. ROZEK: We made other minor modifications to
7 the algorithm. These included logic for two CEA subgroups.
8 SONGS is different than Arkansas because it has the
9 subgroups with two CEAS in it. We had to put the logic into
10 it. Also, CRT here, for Arkansas we rewrote it at a
11 two-second interval. The rods were updated every two
12 seconds. For SONGS it has more rods.

13 We went over all possible rod configurations that
14 could be illustrated by the screen. We could not update it
15 on a two-second period. We've increased it to a period no
16 greater than three seconds.

17 Also, changes have been on this magnitude point ID
18 table associated with the other changes.

19 That concludes my presentation unless you have
20 some more questions.

21 MR. KERR: Mr. Lipinski?

22 MR. LIPINSKI: On one of these sheets there are a
23 couple of reports that indicate where the changes were
24 documented, and I think that was on -- yes, the static
25 DNER. Were all the other changes documented?

1 MR. ROZEK: They are also documented in CEN-135.
2 All the changes, with exception to the automatic re-entry of
3 addressable constants, are addressed in CEN-135. CEN-147 is
4 a CPC functional spec and contains all the related CPC
5 changes.

6 CEN-148 is a functional spec and contains all the
7 CEA changes.

8 MR. LIPINSKI: So there are three reports issued
9 since the ANO-2 review -- the 135, 147, and 148?

10 MR. ROZEK: These were reports issued for the
11 SONGS docket. There is one more report, the data base
12 document, which has also been issued.

13 MR. LIPINSKI: But I'm sure you issued the entire
14 reports in this supplement. These are not complete, are
15 they?

16 MR. ROZEK: CEN-147 is the complete
17 specification. CEN-148 is the complete functional
18 specification of the CEAC.

19 MR. LIPINSKI: Thank you.

20 MR. KERR: Are there other questions?

21 Thank you, Mr. Rozek.

22 I show CEN and their free design and test data is
23 the next item.

24 MR. KENNEDY: Dr. Kerr, we essentially covered
25 items 5 in Mr. Spinnell's presentation this morning where he

1 covered the design of the test data, but I believe Mr.
2 Spinnell would like to make a few closing remarks to
3 summarize the essence of today's presentations. It should
4 take no more than two or three minutes.

5 MR. KERR: Okay. Yes, at some point somebody was
6 going to comment on some of Dr. Lipinski's questions in more
7 detail. Was that Mr. Spinnell?

8 MR. KENNEDY: Which particular questions are you
9 referring to?

10 MR. KERR: I didn't write them down, but I thought
11 you were asking for some detailed information on test
12 procedures.

13 MR. LIPINSKI: I was given a copy from their
14 manual, and it's being reproduced right now.

15 MR. KERR: Oh, so you have the information you
16 need?

17 MR. LIPINSKI: I will have it after the
18 reproduction. It's about a quarter of an inch of paper.

19 MR. KERR: Okay.

20 Mr. Spinnell.

21 MR. SPINNELL: Dr. Kerr, what we have attempted
22 today to do is to cover the following topics.

23 One, we have attempted to put in perspective and
24 give an overview on the core protection calculator system
25 and its relationship to the plant protection system.

1 Secondly, we attempted to highlight the
2 similarities between the ANO-2 design and the San Onofre
3 design hardware and software.

4 Thirdly, we provided an assessment of the ANO-2
5 experience from operational aspects of the computers.

6 Fourth, we have discussed in detail the orderly,
7 structured process that we have laid out for implementing
8 software changes and factoring in this experience. And of
9 course with the software change procedure, the acronym
10 CEN-39.

11 And next, we have provided a description of how we
12 factored in that experience from ANO-2 into the San Onofre
13 cycle 1 software.

14 And lastly, we have provided an overall status of
15 the qualifications in testing efforts on the San Onofre
16 software.

17 If there are no further questions from the
18 committee or any of its consultants, we will turn the
19 meeting over to the NRC.

20 MR. KERR: Are there questions by the subcommittee
21 or the consultants?

22 Let me ask you, you have mentioned at various
23 times your efforts to eliminate some large fraction of
24 errors in software. In this and in consideration of the
25 maintenance and other things, what formal or structured, or

1 whatever the word is, attention have you given to decreasing
2 possibility of human error?

3 MR. GILL: I was afraid the last question would be
4 a tough one.

5 (Laughter.)

6 Probably the benefit that I see of reducing human
7 error is that we have added to the design process a defined
8 structure. That defined structure defines the flow of work
9 from exception through to the final software, by having that
10 definition defined repeatedly. And how we make these
11 changes, we bring new engineers on board or engineers or
12 lesser experience, we can direct them to a design procedure
13 which is very structured; and I believe that reduces error.

14 The penalty for an error is also much higher, a
15 human error, say the functional design up front where we
16 have basically a process that takes three months to make one
17 change. That's the calendar time to implement a software
18 change. The penalty of getting to the end and finding out
19 you had an human error up front is just very high, so there
20 is some built-in mechanism of, I will say, just paying more
21 attention to the review in the up front engineering prior to
22 the design effort as opposed to -- we are looking up front
23 to make sure the functional design is correct before
24 implementing the software design.

25 MR. KERR: I think I can characterize this by

1 saying you have tried to set up an orderly design process
2 where a number of people are responsible for seeing that
3 things get done correctly.

4 I don't know if there is a better way. I was just
5 looking for whether you had been able to come up with
6 something unique in structure that would make human error
7 less likely in this error.

8 I don't know what the answer is that I'm looking
9 for, but as I read the risk analysis, qualitative
10 discussions of it, it seems to me there is a consensus that
11 the equipment -- I'm not sure about the software -- but the
12 equipment works rather well, and that in a sense if one is
13 looking for ways to make risk less and reliability greater,
14 the area for concentration may be on human error.

15 And I just wondered if Combustion had any formal
16 program which was aimed at what I see at least as a very
17 important problem in however one wants to describe the risk
18 and reliability.

19 Now, you've talked some about the design process.
20 What about operation and maintenance? Have you or ANO-2
21 given any serious attention to a formal way of trying to
22 decrease human error as it might enter this part of the
23 process?

24 MR. BROWN: Ed Brown, CE.

25 We have been endeavoring to increase all areas of

1 reliability system with respect to the human interaction.
2 It's gone from an informal process to a much more formal
3 process of the last three years as we have done generic
4 research in human engineering.

5 A couple of areas I will highlight that we have
6 looked into, number one, the operators' interface with the
7 system. We have looked at the two basic elements of the
8 operators' interface, the operators' module, and the CEA
9 display and talked to the operational people to get their
10 feelings and their experience, and I have also looked at
11 possible errors and problems that have occurred in the
12 field. And as you have seen today, we have endeavored to
13 correct those problems.

14 The second area of operational concern is in the
15 maintenance and testing area. We are endeavoring to include
16 that interface so that the technician maintenance person can
17 more easily diagnose a system problem. That area is also
18 undergoing intensive review, and hopefully future
19 corrections. So we have concentrated basically on three
20 aspects -- the operational aspect, the design aspect, and
21 the maintenance aspect.

22 MR. KERR: Well, let me pick maintenance
23 particularly and ask a question or so. As you tried to
24 decrease the probability of error there have you concluded
25 that one is most successful by -- let me just throw out some

1 possible ways -- better trained maintenance people, better
2 procedures, simpler systems?

3 Is there any one thing that you have concluded
4 that is an area of greatest payoff?

5 MR. BROWN: Right now I think all of the areas are
6 equally important, with the status of the first system in
7 Arkansas cycle 1 probably the area of greatest efficiency
8 within the comprehensibility of diagnostics. In other
9 words, the system was structured with systems, with things
10 like error codes where a technician would have go to a
11 manual and look up to see what that error code is; and we're
12 trying to improve that by putting it in normal English
13 language.

14 So it's a combination of better procedures which
15 rely on better technical manuals and also better systems
16 use. It's a combination of the three, so the human being
17 can better read the information and has a better indication
18 of the system.

19 MR. KERR: Thank you.

20 MR. COGBURN: This is Tom Cogburn again. I would
21 like to add something to that.

22 Speaking in a general sense regarding training and
23 procedures and speaking for Arkansas Power and Light and the
24 way we approach this problem, we are placing considerable
25 amount of more emphasis from a management point of view,

1 from a money point of view, and a personnel point of view to
2 people-type training.

3 Our training staff at the site has gone from
4 approximately four individuals two years ago to about 15 now
5 and is projected to reach about 45. These are
6 instructor-type people.

7 Our training programs have gotten much more
8 formalized in the last two years, and we are -- new
9 personnel now don't even start a job until they have had
10 about six months of training, and that is a totally new
11 practice for our company.

12 I think the quickest payoff in making things more
13 reliable is in the area of procedures, though, in making the
14 procedures have a more structured approach and control
15 mechanism. And in the CPC area with regard to operator use
16 and maintenance technicians, this is the approach that we
17 have had the most success in, making the procedures more
18 detailed and more synthesized, and then relying on the human
19 element a little less and still being able to take credit
20 for the individual's ability to think and reason.

21 MR. KERR: Thank you.

22 Any other questions?

23 Let me ask CE if on the basis of experience at
24 ANO-2 you are satisfied with your reliability of the CPC
25 system. I don't mean that you think it has reached the end

1 product, but you have some expectations of reliability.

2 Have there been surprises, or do you feel it's
3 about as reliable as it needs to be, or where do you see
4 this and perhaps subsequent computer-based information
5 systems?

6 MR. GILL: I'd like to answer your question in two
7 parts. One is our satisfaction with the performance of the
8 system, and then I would like to turn it over to Ed Brown to
9 discuss our satisfaction with the hardware in terms of
10 specific reliability; that is, the reliability of the
11 specific hardware we have in the plant.

12 With respect to the performance of the system,
13 looking at it on a global scale, we were happy with the
14 performance. It was the first of a kind system. It was a
15 major step for CE to implement digital technology, and
16 realizing that we would be first and have a lot of
17 visibility, we had to assure ourselves that there would not
18 be major faults such as unsafe failures in the system that
19 would have a major impact on a setback in terms of putting
20 digital computers into vital functions in a power plant.

21 Our reasons for this are many-fold. The more
22 obvious ones are we are implementing a basically complete
23 digital control room. In our TVA Yellow Creek plant this is
24 our system. That plant relies on about 18 processors to
25 handle the overall control, both from control systems to

1 operating to monitoring systems to protection systems. That
2 is our advanced patrol system using the color-graphic CRT
3 display system. So we were concerned about the future of
4 putting computers in the plant, and that has significant
5 impact on the conservatism that we put into the initial
6 system.

7 Although on a global basis we are content or happy
8 with the performance, we actually cannot be very happy with
9 the large number of trips that have occurred at the Arkansas
10 plant. We have kept our key people working full-time since
11 criticality to make the software changes, monitor the
12 performance, and assure that we correct any deficiencies in
13 the plant such as performance and availability of that
14 system will exceed the analog system in the power plants
15 today.

16 We don't believe we're there yet. We believe
17 we're 90 percent of the way there. With additional data
18 from Southern Cal operation and official monitoring, about
19 one year to two years on the Arkansas plant, we think we
20 will be there.

21 In retrospect there is probably one area that was
22 the most difficult decision for us to make as designers, and
23 that was the safety grade rod drop protection. Putting a
24 one out of two system, a one out of two protection system in
25 a plant is obviously very risky. That's a system where a

1 single failure can cause the plant to trip. We
2 procrastinated a long time over that decision and looked at
3 the tradeoffs between relying on operator reaction or
4 control systems such as turbine run-back or other non-safety
5 grade control systems, and looked at what we thought the
6 risk in fuel failure would be based on history, and felt
7 that that risk was unacceptable.

8 At that time there was a decision made. It was
9 basically a safety performance decision as to whether we
10 were willing to sacrifice power capability and/or spurious
11 trips to have a higher degree of confidence to protect the
12 plant from rod-related events

13 We made a decision to put in a one out of two
14 protection system. We are still evaluating the performance
15 and the wisdom of that decision.

16 We believe within the next year or so we will be
17 able to reduce the one out of two trips, but it is not
18 obvious we will achieve that goal. If not, we will have to
19 look at alternatives, and I won't speculate here on what
20 those alternatives are.

21 I can point out that we are not the only vendor
22 that had to approach that problem. Other designers have
23 also, and they have looked more toward analytical methods --
24 approved analytical methods, basically to show that their
25 margin is in the core.

1 They have also looked at higher reliability
2 control systems, and we have discussed briefly this morning
3 the problems of relying on controls systems and the criteria
4 applied to control systems.

5 The decision on the one out of two system was a
6 complex one. It's one we're still evaluating, and it's one
7 we're still working to make viable in a nuclear power
8 plant. Whether we can proceed to four-channel CEA
9 monitoring or some other means to make that safety grade
10 protection more viable is still a question we have to pursue.

11 With respect to future goals we think the CPC has
12 encouraged us to continue with the application of digital
13 computers to power plants. We are in the process of
14 extensive backfits to computers to our operating plants.
15 These are to address things like NUREG-0696, safety display
16 systems, where we are relying on computer design to our CPC
17 system, so we are moving as a company full speed ahead.

18 We are cautious. We have learned some things from
19 maybe moving too quick on Arkansas, but overall we think the
20 experience was good, and we are content with the system.
21 The hardware reliability is something that I will turn over
22 to Ed Brown who can comment on our competence there and
23 where we are headed.

24

25

1 MR. BROWN: Ed Brown, CE.

2 As Mr. Cogburn said, we believe the hardware
3 system at Arkansas has adequate reliability. However, the
4 designers are not satisfied with its current performance.
5 In fact, Mr. Cogburn's goal of three times better is what I
6 would consider a little on the low side. We would like to
7 see it about an order of magnitude better.

8 MR. KERR: I was hoping you would say that, but I
9 couldn't coax him to do that.

10 MR. BROWN: Well, Mr. Cogburn is a very cautious
11 person.

12 (Laughter.)

13 MR. BROWN: We have constantly evaluated the
14 Arkansas performance, and we will work with Arkansas and
15 Southern California to continually improve the system. We
16 have taken lessons learned from the Arkansas performance and
17 factored that into the manufacturing of our second
18 generation reactor protection systems, the first of which
19 will be our Palo Verde system, our System 80 plant.

20 The areas of improvement that we make there are
21 the data links, which in the earlier plants are 16-bit rod
22 data links. We have changed to complete data links, so
23 there are now no electrical connections between channels.
24 This gives better isolation, better noise immunity, better
25 performance.

1 In the area of the input-output system, we have
2 gone to a much higher performance, much higher reliability
3 system that will cure many of the problems that Mr. Cogburn
4 talked about today. It has a much higher temperature
5 specification and is much more rugged seismically and
6 environmentally.

7 The computer system itself is essentially
8 functionally the same, but is a later generation that is
9 completely software-compatible. So the software developed
10 for Arkansas would run on this other system.

11 The hardware in total is form-fit and function
12 compatible with the Arkansas, Southern California Edison
13 hardware.

14 MR. KERR: Thank you, Mr. Brown.

15 In discussions this morning, my memory is that Mr.
16 Cogburn said that the hardware in ANO-2 was significantly
17 sensitive to a 5 to 10 degree change in temperature. I
18 think -- I don't want to misquote you -- I mean, 10 to 20.
19 I wrote down 5 to 10.

20 But is that what could be expected when you
21 designed the system?

22 MR. BROWN: We would expect to see some small
23 reliability degradation of those changes. We would expect
24 to see -- well, to give you an order of magnitude, when we
25 calculated the reliability of the system, we calculated 70

1 degrees Fahrenheit plus or minus 10 degrees.

2 The normal operating temperature is 70 degrees.
3 At 120 degrees Fahrenheit, which is the maximum operating
4 temperature of the module, we would expect to see about a
5 factor of 10 degradation in reliability, which is what the
6 military has experienced.

7 MR. KERR: When you say 70 plus or minus 10, you
8 would expect the system would perform anywhere within 60 to
9 80 degrees according to design specs?

10 MR. BROWN: That's correct.

11 MR. KERR: I don't want to get you into an
12 argument here that you'd rather not get involved in. That
13 was not the impression I got from your discussion. I don't
14 want to make a big thing about this, but it seems to me you
15 are making this fairly sensitive to the air conditioning
16 system. And I'm not opposed to that, but the air
17 conditioning system now becomes a very important part of
18 this reactor protection system, it would seem to me.

19 MR. BROWN: Let me categorize it as far as the
20 other process instrumentation in the reactor protection
21 system. The CPC system in Arkansas is no more sensitive
22 toward room temperature than the reactor protection system,
23 the process instrumentation or the electronic control
24 systems in that plant. They are all built to about the same
25 type of standards and specifications, and utilize the same

1 devices.

2 So their susceptibility to room air conditioning.
3 that is about the same. The physical isolation of the CPC's
4 in Arkansas 1 room to the closed ventilation system would
5 cause a differential between the performance of the CPC
6 system, the performance of the balancing process.

7 MR. LIPINSKI: Due to the fact it is isolated, you
8 then have a source for common mode failure. And what are
9 your technical specifications with respect to being able to
10 continue operation if that room isn't cool?

11 MR. COGBURN: Well, with regard to technical
12 specifications on room temperature, there are none.

13 MR. LIPINSKI: We now have plant protection
14 nt that is sensitive to its particular environment,
15 and since it is in an enclosure you have only one air
16 conditioner, now, I presume, in this air conditioner, that
17 is unreliable.

18 MR. COGBURN: Well, the system has been proven to
19 fail safe, and the failures in the air conditioning,
20 inadequacies, cause failures in a safe direction.

21 MR. LIPINSKI: Don't count on that, because the
22 only ones you have experienced to date have been safe
23 failures. But if you let that temperature go to a high
24 excursion, you couldn't convince me that you're not going to
25 have two channels fail unsafe.

1 MR. COGBURN: I'm not going to try to argue with
2 you about that.

3 I'd like to try to go back to the 10-20 degree
4 variations. What occurs with the air conditioning system we
5 have at ANO is that when the emergency cooling units are
6 used, because their capacity is so large -- we see the
7 temperature has risen considerably, and then they are turned
8 on and it cools it down very rapidly.

9 Then we have got to shut them off. And the
10 temperature control is cyclic. So there is a tendency to,
11 in that mechanism, that controlling mechanism, for
12 temperature -- to cycle temperatures up and down, and this
13 seems to generate some failures.

14 In my estimation, they are probably in the data
15 link time unit, and I don't really think that is probably a
16 design consideration to cycle temperature over that range
17 frequently. That is a problem that Arkansas Power & Light
18 needs to resolve.

19 MR. KERR: There again, we probably discussed
20 this, but it seems to me that the system is temperature
21 sensitive, in whatever way, both in terms of operation or
22 possible increase in failure rate. Everybody involved ought
23 to realize this, and this becomes a fairly important part of
24 the way in which it operates, because performance
25 characteristics, if they depend on temperature and depend on

1 temperature -- that is just about as important as anything
2 else.

3 And I would -- I mean, I don't know whether it's
4 too sensitive to temperature or not. But if one reads the
5 LER's, there clearly are situations in which the LER was
6 attributed to that, and I assume correctly.

7 MR. COGBURN: Well, I'm not sure that those LER's
8 -- sometimes they contain some speculation. I hope that
9 they make it clear that it is speculation when it is. The
10 --

11 MR. KERR: I always believe what I read in
12 official documents, especially LER's.

13 MR. COGBURN: My recollection of those LER's is
14 that the words were something like "high room temperature is
15 suspected" or something like that.

16 One point I meant to bring up while I was
17 discussing the operating experience, I would like to bring
18 up now, and this is reminding me of it, is the fact that the
19 failures have been -- the concentration of failures is
20 significantly higher in channels B and C, and this is
21 another piece of evidence that points to temperature
22 problems, because those channels are more heavily moded.
23 They contain the CEAC hardware in those channels.

24 Another point is that measuring room temperature
25 does not necessarily reflect a change in cabinet inside

1 temperature. And we have not thoroughly instrumented those
2 cabinets to determine what the temperature is. This is
3 something we're considering doing, to try to -- I think we
4 probably need to do, to make a more intelligent evaluation.

5 One other further item that is planned for the
6 refueling outage beginning next month is to remove the
7 in-core detector amplifiers from those cabinets. Each CPC
8 cabinet has an amplifier in it. We are removing those, and
9 that is a significant heat mode being removed from the
10 cabinets.

11 It also should help the air flow distribution in
12 the cabinets, and I believe that is going to help some.

13 MR. KERR: Thank you, Mr. Cogburn.

14 MR. LIPINSKI: I would like my memory refreshed.
15 But when the system was originally under development, I
16 recall that the cabinets were under full load and
17 thermocouple measurements were made in the interior to find
18 where the local hot spots were with respect to the solid
19 state equipment. And from that you had concluded what your
20 inlet air temperatures were and what you could tolerate, is
21 that correct?

22 MR. COGBURN: That's correct.

23 MR. LIPINSKI: So given that you could maintain
24 your air inlet temperature, based on your earlier work, you
25 would not expect to see equipment failures. Are we seeing

1 something different from what you experienced from your
2 initial tests?

3 MR. BROWN: The initial tests were based on steady
4 state values. They didn't include the cyclic nature of
5 ramping the temperature back and forth, which would tend to
6 aggravate problems and cause thermal shock on the integrated
7 circuits and things of that nature.

8 If I may --

9 MR. COGBURN: We also modified the air
10 conditioning.

11 MR. KERR: Mr. Brown?

12 MR. BROWN: One comment toward Mr. Lipinski's
13 comment about the nature of the fail-safe system. We have
14 analyzed the system and its analog and digital counterparts,
15 and we believe the digital system is much more likely to
16 fail safe in an adverse environment than an analog system,
17 for the following reasons:

18 It has a minimum number of analog components that
19 are monitored by the system itself. The basic structure of
20 the system from there on out is dynamic, two-state and
21 digital in nature. As temperature either goes up or down,
22 the device will not change state when it shouldn't. And
23 there are extensive diagnostics to pick this up and to cause
24 the system -- force the system into the trip state.

25 Because of this, the system does have a very great

1 tendency to fail safe in an analog nature. However, of the
2 same nature, it would drift, and the amplifiers can drift in
3 either direction, depending on whether they are inverting or
4 not, in the analog-type calculator.

5 I would believe that a digital calculator,
6 compared to an analog calculator in the same environment,
7 would tend to fail safe probably 99 percent of the time.

8 MR. KERR: Are you convinced, Mr. Lipinski?

9 MR. LIPINSKI: I'm dwelling on that. It depends
10 on how many bits fail and at what time interval, in terms of
11 the discrete components that are in that system.

12 MR. KERR: Are there other comments or questions?

13 (No response.)

14 MR. KERR: Well, thank you for your comments. I
15 think I certainly found them interesting and helpful.

16 I guess we have -- one thing I did not ask is
17 whether you felt that the NRC review had been thorough and
18 adequate. Have they reviewed what you have done
19 appropriately? Maybe you should think about that a while.

20 MR. GILL: No comment.

21 MR. KERR: Because we are now going to hear from
22 the NRC on the status of the San Onofre review. And Mr.
23 Bill Morris I believe is the chief spokesman today. Mr.
24 Morris?

25 MR. MORRIS: The primary basis for our review has

1 been the previous acceptance of the CPC design at ANO-2,
2 the adoption by San Onofre of the 27 ANO-2 positions
3 expressed in the SER, the evaluation of differences between
4 that design, especially of the software changes that have
5 been covered by the previous reviews, audits of the
6 verification and validation program, the review of operating
7 experience, and the reviews and audits of the test program,
8 which is what we consider to be closely related to the
9 verification and validation program.

10 (Slide.)

11 As I say, with regard to hardware, we have not
12 made a re-review of the system because of the similarity in
13 the design. There are only a few changes, as described by
14 the previous reviewer, of the executive software, and that
15 is now under review for San Onofre.

16 When previous changes to the software have been
17 made for ANO-2, we have reviewed that as necessary.

18 With regard to preoperational tests, we anticipate
19 that the test program for SONGS is adequate based on
20 similarity of the previous ANO-2 test program. We intend to
21 check that program after it is completed.

22 This program is closely related, as I said, to the
23 software verification and validation program. We will audit
24 the implementation of the VNB program for San Onofre to
25 confirm that it continues to be an acceptable process.

1 We have under review the operating experience that
2 has been discussed somewhat today, and we will continue to
3 look at that with regard to environmental effects, the
4 frequency of this, the sensitivity of the power supply
5 problems. And we will, if it is necessary, reflect this
6 review in what we do with regard to the tech specs as they
7 reflect the maintenance and surveillance programs for
8 SONGS.

9 Essentially, we are looking to confirm the
10 previous judgments made from the specification review on the
11 basis of what we see in the operating experience. If it is
12 obvious that some changes between SONGS and ANO-2 are
13 required because of this experience, that would of course
14 impact the ANO-2 tech specs, because we are, again, looking
15 at similarities between the two systems.

16 One of the areas of dispute has been the link
17 between the CPC and the plant computer. That is position 20
18 of the ANO-2 SER. No review of this issue is now planned by
19 the NRC.

20 We have based our review up to now and our
21 conclusions up to now on the commitment by San Onofre to the
22 27 positions expressed in the ANO-2 SER. If, as we have
23 been told today, there is no longer such a commitment, that
24 may perhaps have some impact on this issue.

25 However, at this time we expect all 27 positions

1 to be adhered to, including position 20.

2 Perhaps the major part of our review centers
3 around the new algorithms and input data that will be made
4 to incorporate the new thermohydraulics correlations and the
5 new physics correlation. And you have heard, I believe, the
6 explanation of what those changes are like.

7 Larry Phillips is going to continue with our
8 presentation by going into that in some more detail.

9 I believe that there were some questions that we
10 were expected to answer. They are on the second page of the
11 agenda, I believe.

12 Question number one is: What has been the
13 experience of the use of the data link between the CPC and
14 the plant computer, and how would the NRC relate this
15 experience to the NRC's current position on the use of this
16 device?

17 The answer is that this is not an active area of
18 review. In addition, I would say that the submittal made by
19 ANO-2 to justify the expanded use of the data link does not
20 necessarily contain the operating experience that we think
21 would be relevant to the questions that were raised
22 originally about the plant computer-CPC data link.

23 MR. LIPINSKI: Let me raise a question on the data
24 link. We heard that in the case of Arkansas they had asked
25 for you to rescind your position 20. They are kind of

1 pleasantly silent.

2 What bothers me about no feedback is, did you
3 receive the letter?

4 MR. MORRIS: We received a letter that essentially
5 said, we would like to use the data link. Normally when we
6 receive a request such as that, Licensee's silence typically
7 indicates that we are either reviewing or we will eventually
8 get around to the review and we will consider it at some
9 later date.

10 But it has hardly ever been considered to mean
11 that one can go ahead and make the connection and use the
12 data link. The answer to the question is we do not have
13 that as an active item under review.

14 MR. LIPINSKI: You do not?

15 MR. MORRIS: We do not.

16 MR. LIPINSKI: So effectively you concurred with
17 it?

18 MR. MORRIS: No. That's the Licensee's
19 assumption. That is not the assumption of the staff. It
20 never has been.

21 MR. LIPINSKI: Is it on your list of futures?

22 MR. MORRIS: I believe it is in the hopper
23 somewhere. But in the current situation it is not a very
24 high priority item.

25 MR. LIPINSKI: But how does this go with position

1 20, where they had 10 days to use it and they were told to
2 disconnect it? They did not disconnect it, according to
3 --

4 MR. MORRIS: We only learned of it today. Quite
5 frankly, I think we were all surprised.

6 MR. KERR: Mr. Morris, I'm a little puzzled by
7 that, because I read a letter in September which indicated
8 that the data link was -- addressed to the NRC, so I assumed
9 that it got somewhere -- that's the way I got it. It
10 indicated that the data link was connected and they wanted
11 to keep it connected.

12 It therefore comes as a surprise to me that this
13 is a surprise to you, unless you --

14 MR. MORRIS: I think we interpreted the letter to
15 say that, we are now using it -- we may want to go back,
16 knowing what we now know, and look at the wording in that
17 letter carefully. During the day I haven't had a chance to
18 look at it, but I think I interpreted the letter to mean
19 that they requested the expanded use, and I did not
20 interpret it to mean that they had adopted --

21 MR. KERR: I've read the letter and it doesn't say
22 anything about expanded use that I know of. But I guess it
23 would be a good idea for you to read it.

24 MR. MORRIS: Well, I would prefer not to go into
25 this in great detail now. I think it is probably for the

1 Office of Inspection and Enforcement to probably address
2 this issue.

3 MR. KERR: Okay. Then your question about the use
4 of the data link is that NRC really does not have much
5 information on the experience with the data link, and you
6 have not changed your position; is that your response?

7 MR. MORRIS: Yes.

8 MR. LIPINSKI: How does that apply to San Onofre?

9 MR. MORRIS: We had assumed, as I said before,
10 that San Onofre was adopting all 27 positions. Essentially,
11 we were going to utilize to the maximum the previous work
12 done on the acceptance of the ANO-2 design and the positions
13 regarding the CPC's, and that included position 20, which
14 was an explicit statement of how the data link was to be
15 used.

16 And on that basis, we had gone on the assumption
17 that San Onofre was not intending to use the data link in
18 another way than they had proposed in position 20.

19 MR. LIPINSKI: As a system for startup and then
20 not use it during operation?

21 MR. MORRIS: That's correct.

22 MR. EPLER: If I understand correctly, the data
23 link stands guard over instrument drift that could be
24 unacceptable. I don't think how we could be -- could
25 support a position of taking off the data link without

1 assuring ourselves that the operation would be safe.

2 MR. KERR: Mr. Epler, I have never supported
3 removing the data link from the first day I heard of it.

4 MR. EPLER: Well, I would agree with that.

5 MR. KERR: I am unable to prevail.

6 MR. EPLER: I'm not supporting the use of the data
7 link. I am simply saying I don't think we can operate
8 without it.

9 (Laughter.)

10 MR. KERR: But the problem is that the NRC doesn't
11 have this information. From what Mr. Morris said, they
12 really don't have any information on the experience with the
13 data link. And it seems to me that somebody has been remiss
14 in information transmittal. Because it seems to me that if
15 the experience has been favorable, that this should have
16 somehow been transmitted to the Nuclear Regulatory
17 Commission.

18 I would urge that whoever has this experience, let
19 the NRC have it.

20 MR. EPLER: Are you leaving me with the problem
21 because I raised the question, what is the experience? And
22 the answer I think I got, we can't operate without it.

23 MR. KERR: But the NRC didn't know that until
24 today.

25 MR. EPLER: But we know it now.

1 MR. KERR: Yes. Well, that takes care of question
2 one.

3 Question two, is that -- well, you received a
4 request in a letter and you haven't done anything about it,
5 at least through today.

6 MR. MORRIS: That is correct.

7 MR. KERR: Okay, so that takes care of question
8 two. And you have -- well, I'll let you comment on how you
9 want to answer three and four.

10 MR. MORRIS: I think a quick survey of the
11 elements of our review indicated to some extent how we
12 treated SONGS as opposed to ANO-2. And maybe it would be
13 best, if you have further questions, to look at those
14 specific items.

15 MR. KERR: Well, my impression from what you said
16 is that you really haven't done very much additional review,
17 that you had depended on the review of ANO-2.

18 MR. MORRIS: And the intention is that we would
19 look at the changes, the changes that were elaborated on
20 today. We will look at the operating experience and make
21 confirmatory audits of elements of the program, such as the
22 testing and verification validation.

23 MR. KERR: But up to now you have not looked at
24 the ANO-2 experience in reaching any conclusion?

25 MR. MORRIS: Not to the extent that we made a

1 conclusion about it. We have made cursory surveys of the
2 LER's, as you have.

3 MR. KERR: Will you be able to make any more
4 definitive a statement by the time the full Committee
5 discusses San Onofre?

6 MR. MORRIS: We will be looking at the issue. It
7 will be under review continually.

8 MR. KERR: But you will not reach a conclusion by
9 that time?

10 MR. MORRIS: What time is the meeting?

11 MR. KERR: I would expect that you would know that
12 better than I, since the NRC is reviewing it.

13 MR. MORRIS: Sorry. I thought you meant the full
14 Committee meeting.

15 MR. SAVIO: It's Thursday, March the 11th, the
16 second week in March.

17 MR. MORRIS: We will have had an opportunity to
18 look at the data at that time, but we may not be able to
19 make a final conclusion.

20 MR. KERR: And that gets us to question 4, which
21 has to do with the failure modes and effects analysis.

22 MR. MORRIS: We do not intend -- I think to answer
23 the question, we do not intend to request the failure modes
24 and effects analysis of the system. We believe the previous
25 seven man-years of review of the system by the staff and the

1 elaborate analysis that have been done and the verification
2 and validation program constitute an acceptable basis
3 without a further analysis.

4 MR. KERR: Are you convinced that all the failures
5 that might occur in the CPC would be fail-safe type
6 failures?

7 MR. MORRIS: Yes.

8 MR. KERR: Okay. I have no further questions on
9 those four questions.

10 Mr. Lipinski?

11 MR. LIPINSKI: In the earlier presentation,
12 reference was made to NRC Question 221.18, which dealt with
13 the software change. Could you amplify on what that
14 question was?

15 MR. MORRIS: We have recently received a summary.

16 VOICE: I am addressing that completely in the
17 first slide.

18 MR. LIPINSKI: Okay.

19 The other general question is, based on the
20 experience to date is NRC considering a reg guide, a
21 regulatory guide?

22 MR. MORRIS: We have plans --

23 MR. KERR: Excuse me. A regulatory guide on what,
24 Walt?

25 MR. LIPINSKI: On the application of digital

1 systems, because there are some do's and don't's that I
2 think we could come up with.

3 MR. MORRIS: The answer is, yes, we are beginning
4 some work on the guide. There is an ANSI standard, an IEEE
5 standard out now. I don't know just what its status is at
6 this stage. And we've looked at that and we have commented
7 on that, and we intend to enhance that somewhat with our own
8 experience from the ANO-2 reviews and other digital-based
9 computer systems that we have executed for B&W and
10 Westinghouse.

11 MR. KERR: Mr. Morris, on this -- that's one of
12 your slides, or is this Mr. Phillips'? Okay, I'll ask Mr.
13 Phillips.

14 MR. MORRIS: As I said, the algorithms and input
15 data Larry is going to address.

16 MR. KERR: Mr. Phillips, would you feel hurt if I
17 took about a five-minute break before your presentation?

18 MR. PHILLIPS: Not at all.

19 MR. KERR: Let's take five minutes.

20 (Recess.)

21 MR. KERR: Mr. Phillips, it's all yours.

22 MR. PHILLIPS: All right. I'm Larry Phillips,
23 Core Performance Branch.

24 In our thermohydraulics review of San Onofre, we
25 noted that the design basis for the thermohydraulic

1 algorithms in the DNB correlation were being changed, and
2 the CPC's.

3 (Slide.)

4 We felt that this was more than a trivial change
5 and requested the information tabulated here, and the
6 question 221.18, I believe was the number. On May 23rd,
7 1980, we asked for identification of revisions to the
8 software specs for the CPC and the CEAC, which had been
9 provided for ANO-2 and reviewed thoroughly there.

10 We asked for a test report on the San Onofre
11 software when completed. We asked what modifications would
12 be required to the ANO-2 base technical specifications as
13 relate to the CPC's. We asked for a commitment from San
14 Onofre to use the ANO-2-approved software change procedure,
15 CEN-39, to accomplish all the modifications to the ANO-2
16 software; and for a commitment for them to obtain an
17 independent review of software changes by a qualified
18 consultant, and to provide documentation of the final
19 software design.

20 After some -- oh, incidentally, in their initial
21 response to those questions they indicated that the tech
22 spec impact would be addressed later during the normal
23 review of the tech specs. Actually, they indicated there
24 would be no impact expected, but I don't see how that is
25 possible.

1 They also gave the commitment to get an
2 independent review from a qualified consultant. And after
3 some arm-wrestling and further interchange, it was agreed
4 that the documentation described in my next slide would be
5 provided to satisfy the rest of the requirements.

6 (Slide.)

7 MR. KERR: Excuse me, Mr. Phillips. What was the
8 qualified consultant going to review, the method for
9 changing software or the software change?

10 MR. PHILLIPS: He was going to review not the
11 method; they were going to use the methods of CEN-39. He
12 was going to review the change in methodology and review the
13 implementation in general, to just provide an independent
14 review of the design change, to see that the design itself
15 was accomplished correctly.

16 MR. KERR: The design of what?

17 MR. PHILLIPS: The design of the software change.
18 In other words, the models provided in the functional
19 specifications. That was our intent.

20 MR. KERR: So he was going to review the
21 software?

22 MR. PHILLIPS: Yes.

23 MR. KERR: Now what is meant by "qualified
24 consultant"?

25 MR. PHILLIPS: Well, a qualified consultant, I

1 guess the classical definition is he lives so far away. But
2 I believe there is a different -- probably a different
3 interpretation in everybody's mind. We haven't asked --

4 MR. KERR: I'm not trying to get you on the
5 record. I just wanted to know whether that term was
6 different than a consultant.

7 (Laughter.)

8 MR. PHILLIPS: Well, I think when we say
9 "qualified consultant," if the staff feels when they put
10 that on it, if we were to ask of the qualifications of
11 whoever was performing this independent review, if we felt
12 they were inadequate, it would give us an opportunity to
13 make that judgment.

14 MR. KERR: So you may ask them to tell you who
15 they are going to give as a consultant beforehand, so you
16 can pass on their qualifications?

17 MR. PHILLIPS: We may.

18 MR. KERR: But they don't know whether you're
19 going to or not?

20 MR. PHILLIPS: Right.

21 MR. KERR: When are you going to tell them?

22 MR. PHILLIPS: Well, our review is actually just
23 getting under way to a large extent. And if we're going to
24 require one, I would say they would probably be told next
25 month.

1 MR. KERR: Your review is just getting under way?

2 MR. PHILLIPS: Yes. Going to the next slide, I
3 think you will see why.

4 MR. KERR: Okay.

5 MR. LIPINSKI: I would like to continue this
6 discussion. Your consultant was for the software review; is
7 that correct?

8 MR. PHILLIPS: For a review of the software design
9 methods, methodology, and also, of course, looking at the
10 test results and implementation as part of the judgment.

11 MR. LIPINSKI: But as I review this problem, I can
12 take the CPC's as a black box and the problem is broader,
13 because I have to go back to the basic considerations where
14 some of these changes originated in terms of the functional
15 requirements, and the original system is based on
16 differential equations that got implemented by the
17 software.

18 So your consultant's charter starts at what
19 point? Where someone hands them different equations to
20 install, not looking back at the very origin of why the
21 change was made?

22 MR. PHILLIPS: Perhaps I'm being somewhat
23 misleading in addressing what his charter is. I am
24 addressing what seems to me to be the largest area of review
25 in these changes. I wouldn't say it's limited to that.

1 Let me review the question as it was posed and the
2 answer that was given exactly, and maybe you can draw your
3 own conclusions from that. Quote: "To utilize the services
4 of a qualified computer consultant to provide independent
5 verification that approved changes in the software were
6 properly made." Quote.

7 That was the commitment that was asked for.

8 MR. KERR: Approved changes, approved by whom?

9 MR. PHILLIPS: Approved by NRC.

10 MR. KERR: So in effect this consultant will also
11 be reviewing NRC's approval.

12 MR. PHILLIPS: In effect, yes.

13 MR. KERR: So this won't occur until after you
14 have approved --

15 MR. PHILLIPS: Well, "approved" would also be
16 approved by the designer, by approval all the way around,
17 actually.

18 And no, it does not have to wait on our review.

19 MR. KERR: Is somebody here from San Onofre?

20 MR. MOODY: Yes.

21 MR. KERR: Is it clear in your mind what you've
22 committed to?

23 MR. MOODY: My name is Wes Moody. I'm the manager
24 of nuclear licensing for Southern California Edison.

25 It's our interpretation of the staff's question

1 221.18 -- and this is the second part of the part identified
2 by the staff as 5 -- that the staff is asking Edison to
3 commit to retain, either as an outside consultant or an
4 Edison employee, someone who is qualified to the same extent
5 or to an extent similar to the requirement that's being
6 placed on ANO in the tech specs to retain and put on the
7 plant on-site review committee an engineer who is not only
8 qualified in nuclear power plant engineering, but also
9 qualified in software engineering.

10 And it's rather clearly identified in the Arkansas
11 tech specs that he has that qualification.

12 MR. KERR: So if I had a copy of those tech specs
13 I would understand. Is that in accordance with your
14 understanding, Mr. Phillips?

15 MR. PHILLIPS: Yes. Let me read the sentence of
16 their response which relates to it. Quote, it says: "SCE
17 intends to utilize the services of a qualified consultant
18 (may be an SCE employee) to independently review all
19 software changes prior to implementation at San Onofre Units
20 2 and 3."

21 MR. KERR: Thank you.

22 MR. PHILLIPS: The documentation that was provided
23 in response to our requirements was CEN-135, which was
24 provided last September to the staff. It is a summary
25 description of software modifications to the ANO-2 Cycle 1

1 CP software which is applicable to San Onofre.

2 The staff looked at that submittal, but did not
3 conduct any in-depth review. We looked at it to the extent
4 of understanding what was being done. But because of
5 workload and priorities, we did not get into depth on it.

6 CEN-148, the CEAC functional design specs, was
7 transmitted to us by letter dated January 19th. The CPC
8 functional design specs was transmitted to us by letter
9 dated January 21st. And the CPC and CEAC data base
10 documents were received last week.

11 CE has promised a test plan -- or rather, the test
12 plan will be asked for in ANO-2. But this would be a list
13 of the tests which are planned in the final test, and that
14 is basically due. And they will provide us the test
15 results. We put March to May here. The latest we hear is
16 that April is a good guess as to when that will come in.
17 But those things have a habit of slipping.

18 So I guess basically, based on this and some
19 things you are going to see in later slides, I would say
20 that around SER time, which will be around the end of April,
21 that the likelihood of our having completed this review and
22 approved it is slim.

23 We expect that the license may very well carry a
24 condition which is self-destructing upon completion of the
25 review. We would see no problem with going to -- with not

1 having approval prior to power operation.

2 MR. KERR: Let me see if I comprehended what I
3 have heard. You said that the dates there when you got
4 those documents through 149 -- and you say that the
5 commitments have precluded any very extensive review of the
6 documents so far.

7 Does the staff plan to review them?

8 MR. PHILLIPS: Yes, they are under review now. Of
9 course, the 135 document is the only one that we have had
10 for any significant length of time.

11 MR. KERR: No, I understand that.

12 Having reviewed them, is the staff planning to
13 write an SER or a supplement to an SER? Or in what form
14 will the staff's report on the review of those documents
15 be?

16 MR. PHILLIPS: Yes, we expect that by April, SER
17 time, that we will be able to provide substantial
18 information concerning the progress of our review. And we
19 will be able to indicate what is left to be done with the
20 remaining work being done, in order for us to complete our
21 review and approval.

22 MR. KERR: Okay. Thank you.

23 (Slide.)

24 MR. PHILLIPS: Some special considerations of the
25 review, areas which interact, we feel, and could impact the

1 schedule are: number one, there are a couple of items in
2 the basic design review which are related. One is that San
3 Onofre field has a modified grid spacer design, and we
4 currently have under review the test data which indicates --
5 which is supposed to provide justification for use of the
6 same DNBR limit value as being used -- as has been approved
7 for the CE-1 correlation for standard fuel.

8 At the present time we have some problems with
9 that. That limit value could change, of course. That would
10 impact the software.

11 The next item is the method, which was changed
12 rather late in the game. And this I think is just a matter
13 of the mechanics of completing our review of the loss of
14 flow calculation method. There are changes to the basic
15 software, which are the large part of our review, and that
16 would be the W-3, DNBR calculation, being replaced by CE-1,
17 and the revision of the thermohydraulic methods.

18 And we have considerable questions on that, which
19 we expect to get into with CE soon. The comparison we will
20 want to see is a comparison of the CE methods to the
21 approved design methods to assess the accuracy of the
22 modified design.

23 (Slide.)

24

25

237

500 7TH STREET, S.W. REPORTERS BUILDING, WASHINGTON, D.C. 20024 (202) 554-2345

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

And, finally, the area to be reviewed is the power distribution calculation change changes which are reflected by these items, so that completes my presentation.

MR. KERR: Are there questions?

(Pause.)

In Supplement No. 1 to Appendix D, to what I believe to be a Safety Evaluation Report -- oh, this is ANO-2. There is language in the SER which says, after a certain preamble:

"Therefore, we will require that the plant computer service data link to the protection computers be removed, and that the plant computer service routine be deleted, and automatic programs scheduled."

I guess later on you were more specific when they were supposed to be removed? Walt said something about 10 days.

MR. LIPINSKI: I believe that's what you have to conclude in their presentation.

MR. KERR: The ANO-2?

MR. LIPINSKI: Yes.

MR. KERR: Mr. Cogburn?



300 7TH STREET, S.W. REPORTERS BUILDING, WASHINGTON, D.C. 20024 (202) 537-2144



1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

MR. COGBURN: I have an excerpt in my hand from, I believe, Supplement 2 to the SER which says -- I'll read a paragraph from it:

"By letter dated" -- this is written, of course, by the NRC.

"By letter dated March 10, 1978, the Applicant agreed to use and operate the data links in accordance with our position; that is, all data links between protection computers and the plant computers will be connected during start-up and power system testing. Within 10 days after completion after the power system test, the six data links will be removed."

MR. KERR: That's where we got the 10 days. Now it would be helpful to me if I could -- I would have to make some sort of a report about this data, of the NRC Staff's review to Mr. Bender, and my apprehension is that there has been some additional review, but not much beyond ANO-2, but that you do now have these documents listed, that they will be reviewed, and that there perhaps will be some additional review of ANO-2 experience, and

ar-3

300 7TH STREET, S.W. REPORTERS BUILDING, WASHINGTON, D.C. 20024 (202) 554-2345

1 that this will appear in the SER. Help me with what I
2 should tell Mr. Bender.

3
4 I think, yes, that we intend to look at the
5 ANO-2 experience in determining -- in confirming or
6 examining the adequacy of the tech spec maintenance and
7 surveillance requirements.

8 MR. KERR: Okay. Now is it likely that that
9 review, that part of the review, will be completed by
10 what you referred to as SER time?

11 MR. PHILLIPS: April 30th?

12 MR. MORRIS: We intend to do that, yes. It is
13 my estimation that the algorithms and data associated
14 with the thermohydraulic correlations of the physics
15 data is a much more extensive review than we will have
16 to perform of the operating experience and the adequacy
17 of the tech specs.

18
19 MR. KERR: Okay. Are there any further questions?
20 Does that complete your presentation, Mr. Phillips?

21 MR. PHILLIPS: Yes.

22 MR. KERR: Does Staff have any further comment?

23
24 MR. MORRIS: With regard to the letter, I looked
25 at it again, the letter from ANO-2 requesting the

ar-4

300 7TH STREET, S.W. REPORTERS BUILDING, WASHINGTON, D.C. 20024 (202) 554-2345

1 continued operation of the data links. I don't see any way
2 we could have interpreted that to mean they intended to keep
3 them in place, and that we, by being silent, would concur
4 in that.

I wonder if Mr. Cogburn has any comment on that?

6 MR. COGBURN: I would prefer not to comment at
7 this time. I think NRC and AP&L need to discuss this.

9 MR. KERR: I would think that's probably the
10 case, too.

11 MR. PHILLIPS: I do have one additional comment
12 that I think is related. Back from the original review,
13 we had considerable difficulty in defining what changes are
14 permissible without Staff review, or without being brought
15 to the attention of the Staff, and we got language in
16 finally which we felt went pretty far towards making this
17 definition. A lot of the software changes -- or some of
18 the software changes have been described to you this morning
19 that have been accomplished in ANO-2.

21 There was a disagreement on whether these
22 constituted reduction in margin and therefore an unreviewed
23 safety question. So I think we -- as a matter of fact, we
24 got some rather extensive changes. We were informed that
25



300 7TH STREET, S.W. REPORTERS BUILDING, WASHINGTON, D.C. 20024 (202) 554-2344

1 they were being made or had been implemented, and the
2 start-up was scheduled about three or four days later, or
3 something like that, and we conducted a hasty review of
4 those changes and got out some sort of a letter, I believe.

5
6 But there seems to be a continuing sort of
7 problem as to what changes should be brought to the attention
8 of the Staff and what can be performed by the operators
9 without Staff review.

10 I believe that is kind of parallel to the data
11 link situation.

12 MR. KERR: Thank you, Mr. Phillips.

13 Any further comments from the Staff?

14
15 My agenda shows comments by anybody who wants
16 to make a comment at this point. Let me ask first if CE
17 has any further comments.

18 MR. KENNEDY: No, we do not.

19 MR. KERR: How about Southern California Edison?
20 Any further comments?

21 MR. MOODY: Yes, sir. Wes Moody.

22
23 From the standpoint of Southern California Edison,
24 there are several items that I think are significant
25 from today's discussion, and before I mention those two

300 7TH STREET, S.W. REPORTERS BUILDING, WASHINGTON, D.C. 20024 (202) 554-2345

1 items, I want to clarify what I mean by from the standpoint
2 of Southern California Edison.

3 We are right now delaying San Onofre Units 2
4 and 3 twice as a result of delays in licensing, and on
5 the present schedule, we would have the units complete
6 with construction some time this summer, which is substantially
7 earlier than even the earliest date that would get the
8 plant licensed.

9
10 The core protection calculators are one of just
11 several remaining open items in the NRC Staff review of
12 our application for an operating license, and so that's what
13 I mean by from the standpoint of Southern California Edison,
14 there is a couple of significant items here today.

15
16 The first item I wanted to mention was the fact
17 that Tom Cogburn of AP&L has identified several issues
18 whose significance has really become apparent as a result
19 of the year and a half or so that they have operated with
20 CPCs.

21 He indicated that they now recognize the
22 significance of the controlling environment for the CPCs,
23 and he also mentioned that they clearly recognize the
24 advantage in the two out of three logic in the CPCs.
25

ar-7

300 7TH STREET, S.W. REPORTERS BUILDING, WASHINGTON, D.C. 20024 (202) 554-2345

1 We have the advantage for San Onofre Units 2
2 and 3 to design the plant around the CPCs, at least by
3 comparison with Arizona -- excuse me, AP&L, and so both
4 those elements have been factored into the design of San
5 Onofre around the CPCs and, in fact, in case of the
6 controlling environment, the CPCs are in the control room
7 environment, and in the case of the logic, we have employed
8 the two out of three logic.

9 The other item that --

10 MR. KERR: Is your control room environment
11 better than Mr. Cogburn's CPC environment? The fact that
12 it's in a control room environment doesn't mean much to me
13 unless I know what the control room environment is.

14 MR. MOODY: At San Onofre we are able to put --
15 it's my understanding that Arkansas provided an environment
16 for the CPCs after -- or midway in the plant design, perhaps
17 even midway in plant construction, and as a result of that,
18 had to provide a single separate room for the CPCs; whereas
19 we are able to utilize -- we are able to incorporate in the
20 design of the control room environment, including areas
21 behind the panel, to house the CPCs as well as other
22 safety-related items.

300 7TH STREET, S.W. REPORTERS BUILDING, WASHINGTON, D.C. 20024 (202) 554-2345

1 MR. KERR: That's all very well and good, but
2 is the environment in the control room one that will take
3 care of the CPCs?

4 MR. MOODY: We believe so, yes.

5 MR. KERR: It will keep the temperatures within
6 the bounds that were discussed?

7 MR. MOODY: We believe so, yes.

8
9 The second point I wanted to mention was that
10 both Tom Cogburn and Tom Rozek of Combustion Engineering
11 identified software changes which have become important or
12 of significance, have been realized as a result of the
13 experience that AP&L has had for a year and a half, and
14 those software changes are changes which are being reflected
15 not only -- are reflected not only in the proposed changes
16 for Cycle 2, for Arkansas, but also in the initial cycle
17 for San Onofre.
18

19 So we and Arkansas are utilizing the results
20 of the first cycle operation at Arkansas with our respective
21 CPCs.

22 MR. KERR: Thank you.

23 Mr. Lipinski?

24 MR. LIPINSKI: When you say two out of three,
25

ar9

300 7TH STREET, S.W. REPORTERS BUILDING, WASHINGTON, D.C. 20024 (202) 554-1345

1 it's basically a four-channel system; right? And you're
2 calling it an installed spare, and only limited to two out
3 of three by tech spec?

4 MR. MOODY: Al Spinnell can address that.

5 MR. SPINNELL: Mr. Lipinski, early on the review
6 of the San Onofre document, we requested that the Staff
7 conduct a review of the entire protection system on a two
8 out of three basis, assuming that one channel of a particular
9 trip function or any given trip function was out of service
10 for whatever reason; maintenance, et cetera.

11
12 The Staff conducted that review not only of the
13 protection system logic itself, but all of the balance-of-
14 plant areas dealing with the power supplies from and
15 including the station batteries through to the cabinets
16 themselves, and the other interfaces that normally deal
17 with the balance-of-plant scope.

18 The Staff, as I understand it, has written up
19 in the SER in quite an amount of detail on Section 7 of the
20 SER, details of the scope of that review, and their audit
21 not only of the design documentation, but the walk-down of
22 the separation of the four channels in that system, and
23 we understand that they have confirmed that the operation
24
25



1 of the plant protection system for San Onofre is acceptable
2 on a two out of three basis, with one channel of a given
3 trip function out of service a specified amount of time
4 via the technical specifications.

5 MR. KERR: Mr. Ditto?

6 MR. DITTO: Do you still have only two CEACs?
7 They are sort of asymmetrical, if you go to a two out of
8 three system, instead of a two out of four.
9

10 MR. SPINNEL: That's correct.

11 MR. DITTO: Okay.

12 MR. KERR: Yes, sir?

13 MR. SRINIVASAN: My name is Srinivasan from the
14 Staff.

15
16 I would like to clarify sort of a misconception
17 that the protection system is an installed spare. You see
18 this kind of learning in the FSAR. We, as the Staff
19 technician -- there is a good reason in putting four channels
20 to start with. What we did on San Onofre 2 and 3 was
21 primarily to establish that there are really four independent
22 channels. The Staff has completed its review and concluded
23 that the design has really four different channels.

24
25 Now the Applicant, because of the Staff -- if he

1 could operate the plant under some extraneous conditions
2 where one of the channels is not operable, that becomes
3 another issue, normally in the tech spec. We do not let a
4 channel to be bypassed --- I mean not just bypassed, but
5 tripped.
6

7 In this case, the Staff is willing to consider
8 from only an external circumstance like the -- you may
9 have a failure where you cannot fix it immediately unless
10 you shut the reactor down, or there may not be an immediate
11 replacement available.
12

13 For those cases, the Staff is willing to consider
14 some external circumstances.
15

16 So I would like to correct the impression that
17 the Staff is not considering to operate the plant on a
18 three-channel basis. All four channels will be operable
19 at all times.
20

21 MR. KERR: Is there a Staff requirement that all
22 protection systems have to have four independent channels?
23

24 MR. SRINIVASAN: Well, if there is no requirement,
25 there should be. But there have been some designs with
four channel.

MR. KERR: If you have a three-channel, would you

1 refuse to review it?

2 MR. SRINIVASAN: No, I wouldn't, personally
3 speaking, I would not refuse to review it, because there
4 would still be deliberations.

5 MR. LIPINSKI: Well, correct me if I am wrong,
6 but you support IEEE 279. 279 allows one out of two and
7 you allow bypassing of some reasonable amount of time
8 to do maintenance on a single channel.

9 MR. SRINIVASAN: Yes, I do. As I said earlier,
10 there are a lot of variances in having a four-channel
11 system. Having got it, we don't want to give it up.

12 MR. KERR: But the merits of having a four-
13 channel system disappear if you don't have it. If you
14 require that people operate a four-channel system as if
15 they have a three-channel system, it strikes me that you
16 might have the fourth channel disappearing. I don't know,
17 but if I were the Staff, I would give that some serious
18 thought.

19 MR. SRINIVASAN: As I pointed out, we are not
20 going to give up an accepted system. The plant will operate
21 as a four-channel system.

22 MR. KERR: Yes, but suppose the next plant comes

1 in and they say, "Those bastards over at the NRC won't
2 give us any credit for having a four-channel system. Let's
3 put in a three-channel system."
4

5 MR. SRINIVASAN: Well, somebody has to make a
6 comparative assessment of what do you give up in giving
7 up one of the channels.

8 MR. KERR: You don't give up anything, according
9 to the single failure criterion, because you meet the
10 single failure criterion with three channels, and that's
11 all that the Staff currently requires, at least in the
12 general design criteria.
13

14 If you start reading between the lines, maybe
15 you'll find some other things. And I am simply asking
16 that you not penalize people for going a little bit beyond
17 the requirement.

18 MR. SRINIVASAN: That is exactly why we --

19 MR. KERR: I'm not discussing this issue, because
20 I don't know the details, and maybe there is a very good
21 reason that you want them to have four channels operating
22 all at the same time. I don't know.

23 MR. LIPINSKI: Have you gone to a qualitative
24 reliability requirement?
25

300 7TH STREET, S.W. REPORTERS BUILDING, WASHINGTON, D.C. 20024 (202) 554-2345

1 MR. SRINIVASAN: No. What do we gain and what
2 do we lose by having three versus four, two versus three
3 versus four.
4

5 MR. LIPINSKI: Improved reliability, for one.
6 But unless you quantify it, you can't compare different
7 systems.
8

9 MR. SRINIVASAN: We haven't done that exercise,
10 I am sorry.
11

12 MR. KERR: Thank you for your comments.
13 Is SCE finished with its comments?
14

15 MR. MOODY: Yes.
16

17 MR. KERR: Does the representative of AP&L want
18 to make any further comments?
19

20 MR. COGBURN: The point that I was trying to
21 make regarding the four channels versus the three channels
22 was mainly regarding the occurrences that are probably
23 less -- I don't know what NRC's objective is in the
24 licensee event reports system.
25

(Laughter.)

MR. KERR: Join the crowd.

MR. COGBURN: There is a wide disparity
primarily in significant to very significant events reported

300 7TH STREET, S.W. REPORTERS BUILDING, WASHINGTON, D.C. 20024 (202) 554-2345



1 in the system. There is a difference between a 14-day
 2 report and a 30-day report, but even within the 30-day
 3 reports, there is quite a bit of difference on one containment
 4 spray pump failing and being down. That is quite a bit
 5 more significant, I think, than having one CPC channel trip
 6 for a few seconds.

7
 8 And this is the thing that I was really objecting
 9 to. We built the system to be, we thought, a three-channel
 10 system with an installed spare, and it was our intention to
 11 -- and then the tech specs were written such that any time
 12 we bypass a channel for any reason other than surveillance
 13 testing, it requires a writing of an LER, and I don't know
 14 that that is all that meaningful to have it done that way.

15
 16 For instance, Arkansas Nuclear 1, Unit 1, is
 17 written -- the tech specs are written in the three-channel
 18 manner, and I think many plants -- probably all plants of
 19 that vintage are.

20 MR. KERR: Well, I think probably the representa-
 21 tives of the NRC who are here would agree with us, it would
 22 be nice if we could eliminate the trivial LERs from those
 23 that are important, and report only the important ones.

24 The problem is there is a "they" out there
 25

300 7TH STREET, S.W. REPORTERS BUILDING, WASHINGTON, D.C. 20024 (202) 554-2345

1 somewhere that continues to require LERs to be written
2 about things that probably should not be written. Some
3 day, that will be corrected.

4 MR. COGBURN: I hope so.

5 MR. KERR: I think safety will be enhanced,
6 too, because I think some LERs are important and they
7 ought to be looked at by everybody.

8 MR. COGBURN: Our reload licensing submittal
9 for Unit 2 will include the proposed rewording of the
10 tech specs to include that.

11 MR. KERR: Any further questions or comments?

12 Well, let me thank all of you. I must say
13 that I hope that nothing that this subcommittee does or
14 nothing that the Staff does will discourage people from
15 trying to make improvements on reactor control and
16 protection systems. Without trying to judge the merits of
17 what has been accomplished by CE, it seems to me that it
18 did take a certain amount of guts to probably -- the
19 recognition of some of the things you would have to go
20 through to work through the system, and it seems to me it
21 could be an improvement, and I would hope that the industry
22 continues, and I know that other people are doing the same
23
24
25

300 7TH STREET, S.W. REPORTERS BUILDING, WASHINGTON, D.C. 20024 (202) 554-2345

1 sort of thing -- continue to try to improve things, even
2 in the face of having to defend it before the ACRS.

3 (Laughter.)

4 Because it's only thereby that we are going to
5 reach the goal of reliability that I think we would like to
6 try to achieve.

7 So I hope that the questions and discussions
8 are not interpreted as discouraging improvement or
9 discouraging changes. I would hope that we don't do that.

10 Thank you again for your attendance and your
11 contributions today.

12 Before I adjourn the meeting, I would like the
13 consultants to give me any written comments that they
14 consider appropriate within the next week or so, and we
15 will be talking about the full committee meeting.

16 The meeting is adjourned.

17 (Whereupon, at 5:25 p.m., the meeting
18 was adjourned.)

19 * * * *



and

20
21
22
23
24
25

NUCLEAR REGULATORY COMMISSION

This is to certify that the attached proceedings before the

in the matter of: ACRS/Subcommittee on Electrical Systems

Date of Proceeding: 2-24-81


Docket Number: _____

Place of Proceeding: Washington, D. C.

were held as herein appears, and that this is the original transcript thereof for the file of the Commission.

Mary C. Simons

Official Reporter (Typed)



Official Reporter (Signature)

NUCLEAR REGULATORY COMMISSION

This is to certify that the attached proceedings before the

in the matter of: ACRS/Subcommittee on Electrical Systems

Date of Proceeding: 2-24-81

Docket Number: _____

Place of Proceeding: Washington, D. C.

were held as herein appears, and that this is the original transcript thereof for the file of the Commission.

ANN RILEY

Official Reporter (Typed)



Official Reporter (Signature)

#1

CORE PROTECTION CALCULATOR SYSTEM (CPCS)

1. DESCRIPTION
2. COMPARISON OF SAN ONOFRE 2 AND 3 AND ANO-2 DESIGNS
3. DESIGN, QUALIFICATION AND FIELD STATUS
4. LICENSING STATUS

CRITERION NUMBER 10
(10CFR:50, APPENDIX A)

"THE REACTOR CORE AND ASSOCIATED COOLANT, CONTROL, AND PROTECTION SYSTEMS SHALL BE DESIGNED WITH APPROPRIATE MARGIN TO ASSURE THAT SPECIFIED ACCEPTABLE FUEL DESIGN LIMITS ARE NOT EXCEEDED DURING ANY CONDITION OF NORMAL OPERATION, INCLUDING THE EFFECTS OF ANTICIPATED OPERATIONAL OCCURRENCES."

SPECIFIED ACCEPTABLE FUEL DESIGN LIMITS

1. LHR

CORRESPONDING TO CENTERLINE MELT

2. DNBR

EQUAL TO 1.3 (W-3 CORRELATION)

CRITERION NUMBER 20
(10CFR50, APPENDIX A):

"THE PROTECTION SYSTEM SHALL BE DESIGNED 1) TO INITIATE AUTOMATICALLY THE OPERATION OF APPROPRIATE SYSTEMS INCLUDING THE REACTIVITY CONTROL SYSTEMS, TO ASSURE THAT SPECIFIED ACCEPTABLE FUEL DESIGN LIMITS ARE NOT EXCEEDED AS A RESULT OF ANTICIPATED OPERATIONAL OCCURRENCES AND 2) TO SENSE ACCIDENT CONDITIONS AND TO INITIATE THE OPERATION OF SYSTEMS AND COMPONENTS IMPORTANT TO SAFETY."

CRITERION NUMBER 25
(10CFR50, APPENDIX A)

"THE PROTECTION SYSTEM SHALL BE DESIGNED TO ASSURE THAT SPECIFIED ACCEPTABLE FUEL DESIGN LIMITS ARE NOT EXCEEDED FOR SINGLE MALFUNCTION OF THE REACTIVITY CONTROL SYSTEMS, SUCH AS ACCIDENTAL WITHDRAWAL (NOT EJECTION OR DROP-OUT) OF CONTROL RODS."

EVOLUTION OF LICENSING CRITERIA

NRC INTERPRETATION OF CRITERIA AND INDUSTRY KNOWLEDGE AND VIEWS IN REACTOR PROTECTION DEVELOPED AND CHANGED IN THE EARLY 1970's.

1. IN GENERAL SINGLE FAILURES OF AN ACTIVE COMPONENT SHOULD BE CONSIDERED AS A POSSIBLE INITIATING MECHANISM FOR AN AOO.

ROD MISOPERATION EVENTS

- SINGLE ROD WITHDRAWAL
 - OUT OF SEQUENCE INSERTION AND WITHDRAWAL
2. IN MOST CASES, OPERATOR ACTION SHOULD NOT BE RELIED UPON TO PREVENT THE SPECIFIED ACCEPTABLE FUEL DESIGN LIMITS FROM BEING EXCEEDED.
 - AXIAL FLUX PERTURBATIONS

BASED ON THESE CONSIDERATIONS AND THE POTENTIAL IMPACT OF THE RESTRICTIONS IN TERMS OF OPERATION, IT WAS CONCLUDED THAT THE PROTECTIVE SYSTEM MUST:


1. SENSE THE POWER DISTRIBUTION WITH INCREASED ACCURACY.
2. INCLUDE MEASURED CONTROL ROD POSITION AS INPUT.
3. PROVIDE INCREASED ACCURACY IN DNBR THERMAL MARGIN BY ON-LINE INTERPRETATION OF RELEVANT COOLANT SYSTEM PARAMETERS.

TO EFFECTIVELY IMPLEMENT THE ABOVE REQUIREMENTS, DIGITAL PROCESSING TECHNOLOGY WAS INCORPORATED INTO THE PPS.

THE SONGS PLANT PROTECTION SYSTEM (PPS) IS COMPOSED OF TWO SUBSYSTEMS:

1. AN ENGINEERED SAFETY FEATURES ACTUATION SYSTEM (ESFAS), AND
2. A REACTOR PROTECTION SYSTEM (RPS)

THE CORE PROTECTION CALCULATOR INITIATES TWO OF THE TWELVE TRIPS IN THE REACTOR PROTECTION SYSTEM, THE LOW DNBR TRIP AND THE HIGH LOCAL POWER DENSITY TRIP.



BACK-UP TRIP FUNCTIONS FOR
CPC DESIGN BASIS EVENTS

FAILURE OF CPC WITH CONCURRENT AOO IS NOT A DESIGN BASIS
EVENT FOR THE SONGS PLANT.



AN EVALUATION HAS BEEN PERFORMED TO DETERMINE BACK-UP
TRIP FUNCTIONS.

RESULT:





<u>EVENT</u>	<u>BACK-UP TRIP</u>
UNCONTROLLED CEA WITHDRAWAL FROM A CRITICAL CONDITION	HIGH PRESSURIZER PRESSURE
UNCONTROLLED BORON DILUTION	HIGH PRESSURIZER PRESSURE
TOTAL AND PARTIAL LOSS OF REACTOR COOLANT FORCED FLOW	HIGH PRESSURIZER PRESSURE
EXCESS HEAT REMOVAL DUE TO SECONDARY SYSTEM MALFUNCTION	LOW STEAM GENERATOR WATER LEVEL
STEAM GENERATOR TUBE RUPTURE	LOW PRESSURIZER PRESSURE
CEA MISOPERATION	MANUAL TRIP



CPC SCOPE

1. SIGNALS FROM SENSORS THAT MONITOR SPECIFIED CORE VARIABLES
2. DEDICATED COMPUTERS (6) TO IMPLEMENT ALGORITHMS THAT WILL PROCESS THE SENSOR INFORMATION
3. OPERATORS MODULES
4. OUTPUTS FOR DISPLAYS, ALARMS AND REACTOR TRIPS







**IMAGE EVALUATION
TEST TARGET (MT-3)**





**IMAGE EVALUATION
TEST TARGET (MT-3)**



CPC

THE CORE PROTECTION CALCULATORS ARE DESIGNED TO PROVIDE THE FOLLOWING PROTECTIVE FUNCTIONS:

- A. INITIATE AUTOMATIC PROTECTIVE ACTION SUCH THAT THE SPECIFIED FUEL DESIGN LIMITS ON DNBR AND LOCAL POWER DENSITY ARE NOT EXCEEDED DURING ANTICIPATED OPERATIONAL OCCURRENCES, AND
- B. INITIATE AUTOMATIC PROTECTIVE ACTION DURING CERTAIN ACCIDENT CONDITIONS TO AID THE ENGINEERED SAFETY FEATURES SYSTEM IN LIMITING THE CONSEQUENCES OF THE ACCIDENTS.

CPC DESIGN FEATURES

- AN ON-LINE PROTECTION SYSTEM USING 3 LEVELS OF EX-CORE DETECTOR INFORMATION
- A COMPLETE SYSTEM OF DEDICATED DIGITAL CALCULATORS TO PROVIDE FOUR CHANNEL REDUNDANCY
- USES AN AXIAL/RADIAL SYNTHESIS TO CONSTRUCT POWER DISTRIBUTIONS
- USES MEASURED CEA POSITION INPUT
- FLOW DETERMINATION BASED ON RCP SPEED MEASUREMENTS
- LINEAR HEAT RATE AND DNBR CALCULATED ON-LINE
- OPERATOR'S CONSOLE PROVIDES COMPREHENSIVE DATA DISPLAY


CPC DESIGN BASES EVENTS

MAJOR ANTICIPATED OPERATIONAL OCCURRENCES

1. UNCONTROLLED AXIAL XENON OSCILLATIONS
2. CEA RELATED EVENTS INCLUDING SINGLE ROD WITHDRAWAL, SINGLE DROPPED ROD, SUB-GROUP DEVIATION AND OUT-OF-SEQUENCE WITHDRAWAL AND INSERTION
3. EXCESS LOAD
4. LOSS OF LOAD
5. LOSS OF FORCED REACTOR COOLANT FLOW
6. UNCONTROLLED BORON DILUTION
7. ASYMMETRIC STEAM GENERATOR TRANSIENT DUE TO AN INSTANTANEOUS CLOSURE OF AN MSIV

POSTULATED ACCIDENTS

1. STEAM GENERATOR TUBE RUPTURE
2. REACTOR COOLANT PUMP SHAFT SEIZURE



CPC PROCESS INPUT SIGNALS

<u>SIGNAL</u>	<u>NUMBER PER CHANNEL</u>	<u>RANGE</u>	<u>SIGNAL TYPE</u>
REACTOR COOLANT PUMP SPEED	4	10%-100% RATED SPEED	DIGITAL
COLD LEG TEMPERATURE	2	465-615°F	ANALOG
HOT LEG TEMPERATURE	2	525-675°F	ANALOG
PRESSURIZER PRESSURE	1	1500-2500 PSIA	ANALOG
EX-CORE NEUTRON FLUX	3	0-200 %	ANALOG
CEAC DEVIATION PENALTY FACTOR	2	0-4.0	DIGITAL
TARGET CEA POSITION	23	0-100% WITHDRAWAL	ANALOG

CPC PROTECTION ALGORITHM STRUCTURE

THE CORE PROTECTION SOFTWARE CONSISTS OF FOUR INTERDEPENDENT PROGRAMS AND A TRIP PROGRAM MODULE THAT IS ACCESSIBLE TO ALL FOUR PROGRAMS:

1. COOLANT MASS FLOW PROGRAM (FLOW)
2. DNBR AND POWER DENSITY UPDATE PROGRAM (UPDATE)
3. POWER DISTRIBUTION PROGRAM (POWER)
4. STATIC DNBR AND POWER DENSITY PROGRAM (STATIC)
5. TRIP SEQUENCE PROGRAM (TRIPSEQ)

SAMPLING OF THE INPUT SIGNALS IS INITIATED WITHIN THE PROTECTION PROGRAMS AND IS CONSISTENT WITH THE FREQUENCY OF EXECUTION OF THE CALLING PROGRAM.

MAJOR CALCULATIONS

A. CPC "FLOW" PROGRAM

1. PRIMARY CORE COOLANT MASS FLOW RATE
2. PROJECTED DNBR BASED ON RATE OF DECREASE OF CORE COOLANT MASS FLOW RATE

B. CPC "UPDATE" PROGRAM

1. CORE AVERAGE POWER BASED ON NEUTRON FLUX
2. CORE AVERAGE POWER BASED ON CORE ENTHALPY RISE
3. CORE AVERAGE HEAT FLUX
4. HOT PIN HEAT FLUX DISTRIBUTION
5. DNBR UPDATED FOR CHANGES IN CPC INPUT PARAMETERS
6. PEAK LOCAL POWER DENSITY

MAJOR CALCULATIONS (CONTINUED)

C. CPC "POWER" PROGRAM

1. CORE AVERAGE AXIAL POWER DISTRIBUTION
2. HOT PIN AXIAL POWER DISTRIBUTION

D. CPC "STATIC" PROGRAM

1. STATIC DNBR
2. STATIC HOT CHANNEL QUALITY
3. CORE INLET AND EXIT ENTHALPY

CPC OUTPUT SIGNALS

<u>SIGNAL</u>	<u>TYPE</u>	<u>SEIPOINT</u>	<u>RANGE</u>
LOW DNBR TRIP	CONTACT	1.19	—
LOW DNBR PRE-TRIP	CONTACT	1.30	—
HIGH LPD TRIP	CONTACT	393.2*	—
HIGH LPD PRE-TRIP	CONTACT	374.5*	—
SENSOR FAILURE	CONTACT	—	—
DNBR MARGIN TO TRIP	ANALOG	—	0 - 10
LPD MARGIN TO TRIP	ANALOG	—	0 - 25 KW/FT
CALIBRATED NEUTRON FLUX POWER	ANALOG	—	0 - 200 (% OF RATED PC)
CORE COOLANT MASS FLOW RATE	ANALOG	—	0 - 2 (FRACTION OF REF. REFERENCE FLOW)

* % OF RATED AVERAGE POWER DENSITY (RATED AVERAGE POWER DENSITY IS 5.34 KW/FT)

CPC PROGRAM EXECUTION INTERVALS
AND
INPUT SAMPLING RATES

<u>PROGRAM</u>	<u>INPUTS SAMPLED</u>	<u>EXECUTION /SAMPLING INTERVAL</u>
FLOW	1. RC PUMP SHAFT SPEED	50 MILLISECONDS (MS)
UPDATE	1. COLD LEG TEMPERATURES 2. HOT LEG TEMPERATURES 3. PRESSURE 4. CEAC DEVIATION PENALTY FACTORS 5. EXCORE SIGNALS CEA POSITIONS	100 MILLISECONDS (MS)
POWER		1 SECOND
STATIC	NONE	2 SECONDS

NOTE THAT OPERATORS MODULE DIGITAL DISPLAY IS UPDATED EVERY 0.5 SECOND, SO DISPLAYED VARIABLES FROM "FLOW" WILL BE THOSE FROM EVERY TENTH CALCULATION OF "FLOW"; DISPLAYED VARIABLES FROM "UPDATE" WILL BE THOSE OCCURRING DURING EVERY FIFTH CALCULATION OF "UPDATE".

CORE PROTECTION CALCULATOR SYSTEM
DISPLAY AND INDICATION

OPERATORS MODULE

SYSTEM STATUS INDICATION

OPERATOR DISPLAY OF SETPOINT AND CALCULATED VARIABLES

OPERATING BYPASS CONTROL AND INDICATION

KEYLOCK ADMINISTRATIVE CONTROL FOR CALCULATOR SECURITY

ADDRESSABLE CONSTANT ENTRY FOR CALIBRATION

CPC ANALOG INDICATORS

DEDICATED ANALOG METERS FOR

DNBR MARGIN TO TRIP SETPOINT

LPD MARGIN TO TRIP SETPOINT

CALIBRATED NEUTRON FLUX POWER

ALARM ANNUNCIATORS

STATION ANNUNCIATORS ARE PROVIDED TO INDICATE TRIP STATUS AND
OPERABILITY OF THE CPC SYSTEM

ANALOG PROCESS INDICATION

DEDICATED ANALOG METERS DISPLAY EACH CPC SENSOR INPUT VALUES EXCEPT
CEA POSITION AND REACTOR COOLANT PUMP SPEED

CEA POSITION DISPLAY

A CRT DISPLAYS THE POSITION OF ALL 81 CONTROL ELEMENT ASSEMBLIES
THE DISPLAY IS SWITCH SELECTABLE TO EITHER OF TWO REDUNDANT SIGNAL
CHANNELS.

CPCS

2. COMPARISON OF SAN ONOFRE 2 AND 3 AND ANO-2 DESIGNS

- A. HARDWARE
- B. EXECUTIVE SYSTEM SOFTWARE
- C. APPLICATION PROGRAMS SOFTWARE

CPC HARDWARE COMPARISON
ANO-2 / SONGS

THERE ARE NO DIFFERENCES IN FUNCTIONAL DESIGN OR CRITERIA BETWEEN THE SAN ONOFRE CORE PROTECTION CALCULATOR SYSTEM (CPCS) HARDWARE AND THE ANO-2 CPCS HARDWARE.

THE SAN ONOFRE CPCS HARDWARE IS IDENTICAL TO THE ANO-2 CPCS HARDWARE WITH THE EXCEPTION OF CABLE LENGTHS TO THE OPERATOR'S MODULES AND DISPLAY GENERATOR.

THE TWO PLANTS HAVE DIFFERENT QUANTITIES OF CONTROL ELEMENT ASSEMBLIES (CEAs). THE TWO CPC SYSTEMS, HOWEVER, HAVE THE SAME NUMBER OF ANALOG INPUT MULTIPLEXER CARDS FOR THESE CEAs. THE ANO-2 CPCS JUST HAS MORE SPARE CAPACITY.

CPC/CEAC EXECUTIVE SYSTEM SOFTWARE

COMPARISON ANO-2 / SONGS

THERE ARE NO DIFFERENCES IN THE SOFTWARE DESIGN BETWEEN THE SAN ONOFRE CORE PROTECTION CALCULATOR SYSTEM (CPCS) AND THE ANO-2 CPCS FOR THE FOLLOWING EXECUTIVE SYSTEM FUNCTIONS:

- TASK SCHEDULING
- PRIORITY
- SOFTWARE STRUCTURE

SINCE THE TWO PLANTS HAVE DIFFERENT QUANTITIES OF CONTROL ELEMENT ASSEMBLIES (CEA), DIFFERENCES EXIST IN THE FOLLOWING INPUT/OUTPUT SERVICE ROUTINES:

- READ ALL CEA POSITIONS FROM ANALOG INPUTS
- READ TARGET CEA POSITIONS FROM ANALOG INPUTS
- OUTPUT CEAC BUFFER TO PLANT COMPUTER
- OUTPUT CPC BUFFER TO PLANT COMPUTER

CPC APPLICATION SOFTWARE COMPARISON
ANO-2 / SONGS

DIFFERENCES IN APPLICATION PROGRAMS BETWEEN THE
SAN ONOFRE CORE PROTECTION CALCULATOR SYSTEM (CPCS)
AND THE ANO-2 CPCS ARE IN THE FOLLOWING MAJOR
CATAGORIES:

- DNEC ALGORITHM CHANGES
- DATA BASE CHANGES
- CEA RELATED CHANGES

3. DESIGN, QUALIFICATION AND FIELD STATUS

<u>ITEM</u>	<u>STATUS</u>
1. HARDWARE DESIGN	COMPLETE - 8/76
2. INSTALLED AT SITE	COMPLETE - 6/78
3. FIELD HARDWARE ACCEPTANCE TEST	COMPLETE - 10/80
4. FIELD PREOPERATIONAL TEST	IN PROGRESS, EST. COMPLETION - 4/81
5. CPC/CEAC FUNCTIONAL DESIGN	COMPLETE - 2/81
6. CPC/CEAC DATA BASE	90% COMPLETE: EST. COMPLETION - 3/81
7. SOFTWARE DESIGN	50% COMPLETE, EST. COMPLETION - 3/81
8. SOFTWARE TESTING	5% COMPLETE, EST. COMPLETION 4/81

4. LICENSING STATUS

- A. EXTENT OF COMPLIANCE WITH 27 NRC STAFF POSITIONS
- B. SER OPEN ITEM
- C. OTHER RELEVANT ISSUES

27 NRC STAFF POSITIONS

SAN ONOFRE UNITS ²1 AND ³2 DESIGN IS IN FULL COMPLIANCE WITH EXCEPTION OF POSITION 20 CLARIFICATION REQUIRING REMOVAL OF DATA LINKS BETWEEN THE CPCS/CEAC TO PLANT MONITORING SYSTEM (PMS).

SCE POSITION:

THE USE OF DATA LINKS OUTWEIGHS ANY CONCERNS REGARDING HYPOTHETICAL ELECTRICAL OR FUNCTIONAL INTERACTIONS BETWEEN THE CPCS AND PMS.

CPCS - SER OPEN ITEM

ITEM

CPC/CEAC CHANGES ASSOCIATED
WITH ADDITIONAL CEAs.

SOFTWARE CHANGES IN-
CLUDED IN CPC/CEAC
FUNCTIONAL DESCRIPTIONS
CEN-35, CEN-147, AND
CEN-148.

DATA BASE CONSTANTS-UPDATE
TO INCLUDE SPECIFIC CORE AND
COOLANT SYSTEM DATA.

MAJORITY (60%) IN-
CLUDED IN CEN-149
WORK (90%) COMPLETE NOW.

CHANGES RELATED IMPROVEMENTS
IN THERMAL-HYDRAULIC METHODS

SOFTWARE CHANGES INCLUDED
IN CPC/CEAC FUNCTIONAL
DESCRIPTIONS CEN-135,
CEN-147, AND CEN-148.

MX Bill Gill - PIAC SHIRT

PROPOSED AGENDA
24-25 Feb 1981

ELECTRICAL SYSTEMS SUBCOMMITTEE

STARTED 9 AM PROMPT.

FEBRUARY 24, 1981

- | | |
|---|--------------|
| 1. EXECUTIVE SESSION | 9:00 - 9:15 |
| 2. Description of the CE Core Protection Calculator and Comparison of the ANO-2 and San Onofre 2&3 Designs (2 hrs) - CE | 9:15 - 11:15 |
| 3. Discussion of ANO-2 Experience (2 hrs) - Arkansas Power & Light | 11:15 - 1:15 |
| LUNCH | 1:15 - 2:15 |
| 4. San Onofre 2&3 Core Protection Calculator (1 hr) - SCE and CE | 2:15 - 3:15 |
| a) Summary of San Onofre Design and Test and Verification Program | |
| b) System modifications Use of ANO-2 Experience, and Bases | |
| 5. NRC Review of the San Onofre Core Protection Calculator (1 hr) - NRC | 3:15 - 4:15 |
| 6. Comment by Southern California Edison Company, Arkansas Power and Light Company, and Combustion Engineering | 4:15 - 4:45 |
| 7. GENERAL DISCUSSION | 4:45 - 5:15 |

FEBRUARY 25, 1981

DISCUSSIONS RELATING TO THE USE OF COMPUTER PROTECTION SYSTEMS AND CANADIAN
REGULATORY REQUIREMENTS FOR REACTOR CONTROL SYSTEMS 9:00 - COB

Specific questions to be addressed by the NRC Staff as per Dr. Kerr's 12 Feb 81
request:

- 1) What has been the experience with the use of the data link between the CPC and the plant computer and how would the NRC relate this experience to the NRC's current position on the use of this device?
- 2) What is the status of the NRC actions on Arkansas Power and Light request for the continued use of the data link between the CPC and the plant computer?
- 3) How did the review procedures used for the ANO-2 review differ from the San Onofre 2&3 review? Were features of the San Onofre 2&3 design addressed which were not addressed in the ANO-2 review?
- 4) Will a FMEA be performed for the San Onofre 2&3 Core Protection Calculator? If not, what is the basis for the decision?

OTHER RELEVANT LICENSING ITEMS

1. SOFTWARE CHANGE PROCEDURE - METHODOLOGY
 - A. CEN-39(A)-P, REVISION 2 AND SUPPLEMENT
 - B. APPROVED BY NRC
 - C. SCE COMMITTED TO USE APPROVED METHOD VIA RESPONSE NRC Q 221.18.
 - D. FRAME WORK FOR EXISTING FUNCTIONAL DESCRIPTION AND TEST PROGRAM DOCUMENTATION

2. SOFTWARE TESTING PROGRAM
 - A. BEING PERFORMED IN ACCORDANCE WITH CEN-39
 - B. RESULTS TO BE PROVIDED TO NRC BY 4/81

Fuzek

CPC SOFTWARE MODIFICATIONS

1. MODIFICATIONS DURING ANO-2 CYCLE 1
2. MODIFICATIONS FOR SONGS

ACRONYMS

ASGT - ASYMMETRIC STEAM GENERATOR TRANSIENT

CEA - CONTROL ELEMENT ASSEMBLY

CEAC - CONTROL ELEMENT ASSEMBLY CALCULATOR

CPC - CORE PROTECTION CALCULATOR

CRT - CATHODE RAY TUBE

ID - IDENTIFICATION

LPD - LOCAL POWER DENSITY

PF - PENALTY FACTOR

RSPT - REED SWITCH POSITION TRANSMITTER


ANO-2 CYCLE 1 CPC SOFTWARE CHANGES

1. ANO-2 FIRST PLANT WITH CPC SYSTEM
 - A. ORIGINAL SOFTWARE CONSERVATIVE
 - B. CONSERVATISM IMPACTED PLANT PERFORMANCE

2. TWO SETS OF SOFTWARE MODIFICATIONS IMPLEMENTED
 - A. MOD 1/2A
 - I. IMPLEMENTED JUNE 24, 1979
 - II. CHANGES BASED ON SOFTWARE QUALIFICATION TESTING AND EARLY ANO-2 OPERATION.

 - B. MOD 2B/3
 - I. IMPLEMENTED MAY 24, 1980
 - II. CHANGES BASED ON LATER ANO-2 OPERATION.

3. BOTH SETS OF MODIFICATIONS MADE IN ACCORDANCE WITH THE NRC-APPROVED SOFTWARE CHANGE PROCEDURE, CEN-39(A).



ANO-2 CYCLE 1 SOFTWARE MODIFICATIONS

- LOW POWER FIXED EXCORE SHAPE
- CPC AND CEAC CEA POSITION DEADBANDS
- DYNAMIC THERMAL POWER
- HEAT FLUX AND LPD FILTERS
- FIXED POINT TO FLOATING POINT ARITHMETIC
- CPC AND CEAC INITIALIZATION
- ASGT MODIFICATION
- HEAT FLUX CALCULATION
- *• CEAC PENALTY FACTOR CHANGES
- *• CPC/CEAC DIAGNOSTICS

*DESCRIBED IN FURTHER DETAIL

CEAC PF CHANGES

OBJECTIVE:


REDUCE THE NUMBER OF UNNECESSARY CPC TRIPS AS A RESULT OF CEA DEVIATION LOGIC.

PREVIOUS DESIGN:

1. THE CEAC CALCULATED ONE "WORST CASE" PENALTY FACTOR WHICH WAS APPLIED TO DNBR AND LPD.
2. THE PF WAS APPLIED TO THE ONE PIN RADIAL PEAK.
3. THE CEAC/RSPT INOPERABLE MODE LOGIC LEAVES BOTH CEACS IN-SERVICE OR TAKES BOTH CEACS OUT-OF-SERVICE.

CHANGES:


1. SEPARATE DNBR AND LPD PENALTY FACTORS.
2. PENALTY FACTORS DEPENDENT ON:
 - A. MAGNITUDE OF DEVIATION
 - B. DIRECTION OF DEVIATION
 - C. SUBGROUP WITH DEVIATION
 - D. CEA CONFIGURATION
 - E. TIME
3. DATA TRANSMITTED TO CPC FROM CEAC
 - A. FAIL FLAG
 - B. BIG PENALTY FACTOR FLAG
 - C. DNBR AND LPD PENALTY FACTOR
4. APPLY PF TO HEAT FLUX IN STATIC DNBR LOGIC.
5. MODIFY THE CEAC/RSPT INOPERABLE MODE LOGIC SUCH THAT ONE CEAC CAN BE LEFT IN-SERVICE.
6. MODIFY CEAC CRT DISPLAY.



CEA POSITION DISPLAY

1	2	3	4	5	6	P	A	B	1
10 11	2 19	16 17	3	15	12	6 7	13 14 18 20	1 4 5 8 9	
38 39	6 71	62 63	10	58	46	22 26	50 51 70 72	2 14 15 30 31	
40 41	7 74	64 65	11	59	47	23 27	52 53 73 75	3 16 17 32 33	
44 45	9 80	68 69	13	61	49	25 29	56 57 79 81	5 20 21 36 37	
42 43	8 77	66 67	12	60	48	24 28	54 55 76 78	4 18 19 34 35	

PFLPD=1.000 PFDNB=1.000



CEAC DISPLAY

1

B

A

P

6

5

4

3


2

1

10 11	2 14	16 17	3	15	12	6 7	13 14 18 20	1 9 5 8 9
23 29	6 71	62 63	10	50	46	22 25	50 51 70 72	2 14 15 30 31
40 41	7 74	64 65	11	59	47	23 27	52 53 73 75	3 16 17 32 33
44 45	9 80	66 67	13	61	49	25 29	56 57 79 81	5 20 21 36 37
42 43	8 77	68 69	12	60	40	24 28	54 55 76 78	4 18 19 34 35

PFDNB=1.169

PFLPD=1.144



CEAC DISPLAY

CPC/CEAC DIAGNOSTICS

OBJECTIVE:

PROVIDE ADDITIONAL CPC AND CEAC DIAGNOSTICS TO IDENTIFY THE CAUSE OF SPURIOUS CPC TRIPS.

PREVIOUS DESIGN:

SENSOR STATUS WORDS PROVIDED INFORMATION THAT A CPC SENSOR HAD FAILED.

CHANGES:

1. FAILED SENSOR STACKS IN CPCs AND CEACs
 - A. STORES UP TO 6 ENTRIES
 - B. CONTAINS SENSOR ID, STATUS, AND TIME OF ENTRY
 - C. ACCESSED FROM:
 - I. OPERATOR'S MODULE
 - II. TELETYPE WHEN CALCULATOR IN-TEST
2. SNAPSHOT OF DATA
 - A. CONTAINS INPUTS, ADDRESSABLE CONSTANTS, INTERMEDIATE VARIABLES AND OUTPUTS.
 - B. BUFFER FILLED:
 - I. IN CEAC, FOR AN OFF-NORMAL PF OUTPUT
 - II. IN CPC, FOR A CHANNEL TRIP.
 - C. ACCESSED FROM TELETYPE WHEN CALCULATOR IS IN-TEST.
3. LOGIC ADDED TO PREVENT SPURIOUS PENALTIES AS A RESULT OF RSPT ASSOCIATED INSTRUMENTATION ANOMALIES.

SONGS CPC SOFTWARE MODIFICATIONS

- DNBR CALCULATION
- ADDRESSABLE CONSTANTS
- POWER DISTRIBUTION CALCULATION
- DIAGNOSTIC CHANGES
- PLANT SPECIFIC DATA

DNBR CALCULATION

1. STATIC DNBR BASED ON CE-1 CRITICAL HEAT FLUX CORRELATION.
2. UPDATED DNBR BASED ON CE-1 CRITICAL HEAT FLUX CORRELATION.

CPC STATIC DNBR ALGORITHM

OBJECTIVE:

TO INCLUDE A DNBR ALGORITHM WHICH IS CONSISTENT WITH THE DESIGN BASIS THERMAL-HYDRAULIC CODE (TORC).

PREVIOUS DESIGN:

CPC STATIC DNBR BASED ON THE W-3/BULL METHODOLOGY.

CHANGE:

THE STATIC DNBR ALGORITHM BASED ON CE-1/TORC METHODOLOGY.

THE ALGORITHM IS DESCRIBED IN:

CEN-135(S), APPENDIX A, SUBMITTED AUGUST 1980

CEN-147(S), SECTION 4.4, JANUARY 1981

ADDRESSABLE CONSTANTS

1. POWER DISTRIBUTION-RELATED ADDRESSABLE CONSTANTS
 - A. CEA SHADOWING FACTOR ADJUSTMENT
 - B. PLANAR RADIAL PEAKING FACTOR ADJUSTMENT
 - C. BOUNDARY POINT POWER CORRELATION COEFFICIENTS
 - D. COOLANT TEMPERATURE SHADOWING FACTOR
2. DNBR AND LPD PRE-TRIP SETPOINTS.
3. AUTOMATED REENTRY OF CERTAIN ADDRESSABLE CONSTANTS.

POWER DISTRIBUTION CALCULATION

1. CHANGE FIXED NUMBERS IN CALCULATION TO DATA BASE CONSTANTS.
2. DENSITY-DEPENDENT RADIAL CORRECTION FACTOR.

DIAGNOSTIC CHANGES

OBJECTIVE:

TO IMPROVE CPC DIAGNOSTICS BASED ON ANO-2 OPERATING EXPERIENCE.

CHANGES:

1. CEAC SNAPSHOT BUFFER
2. FAILED SENSOR STACK ID NUMBERS
3. CEAC CRT REWRITE

Star

CPC/CEAC
SOFTWARE CHANGE PROCESS

PURPOSE OF PRESENTATION

PRIOR TO THE PRESENTATION ON SOFTWARE MODIFICATIONS TO THE ANO-2 AND SONGS CPC/CEAC SYSTEMS, WE WILL PRESENT THE SOFTWARE CHANGE PROCESS THAT OCCURS WHEN SUCH MODIFICATIONS ARE PERFORMED.

CPC/CEAC
SOFTWARE CHANGE PROCESS

- o C-E HAS DEVELOPED A HIGHLY STRUCTURED AND DETAILED CPC/CEAC SOFTWARE CHANGE PROCESS.
- o THIS PROCESS IS DOCUMENTED IN THE SOFTWARE CHANGE PROCEDURE CEN-39.
- o CEN-39 HAS BEEN APPROVED BY THE NRC STAFF DURING THE RESOLUTION OF STAFF POSITION NO. 19 ON ANO-2.
- o CEN-39 HAS BEEN FOLLOWED FOR ALL ANO-2 AND SONGS SOFTWARE CHANGES.
- o THE FOLLOWING DISCUSSION COVERS SEVERAL IMPORTANT FEATURES OF THE SOFTWARE DESIGN PROCESS. *

CEN-39
SOFTWARE CHANGE PROCEDURE

PURPOSE

TO ENSURE THAT THE PROCESS OF SPECIFYING AND IMPLEMENTING SOFTWARE MODIFICATIONS IS DONE IN A MANNER THAT MAINTAINS THE INTEGRITY AND RELIABILITY OF THE SOFTWARE.

SCOPE

- o FUNCTIONAL DESIGN, SOFTWARE CODING AND IMPLEMENTATION, AND SOFTWARE TESTING ARE COVERED.
- o ALL DOCUMENTS ARE ADDRESSED.
- o WIDE SPECTRUM OF DETAIL IS INCLUDED, FROM RELATIVELY HIGH LEVEL REQUIREMENTS DOWN TO PRECISE, SPECIFIC INSTRUCTIONS FOR DISC GENERATION.

APPLICABILITY

CEN-39 IS APPLICABLE TO ALL SOFTWARE CHANGES.

SOFTWARE DESIGN DOCUMENTATION

DESIGN SPECIFICATION


RECORDED CALCULATIONS
CPC FUNCTIONAL DESIGN SPECIFICATION
CEAC FUNCTIONAL DESIGN SPECIFICATION
CPC/CEAC FORTRAN CERTIFICATION
DATA BASE DOCUMENT

DESIGN IMPLEMENTATION

CPC SOFTWARE SPECIFICATION
CEAC SOFTWARE SPECIFICATION
EXECUTIVE SOFTWARE SPECIFICATION

TESTING

PHASE I TEST PROCEDURE
PHASE II TEST PROCEDURE
FLOW TEST CASES
UPDATE TEST CASES
POWER TEST CASES
STATIC TEST CASES
TRIP SEQUENCE TEST CASES
COMMON SUBROUTINE TEST CASES
PENALTY FACTOR TEST CASES
POSITION DISPLAY TEST CASES
PHASE I TEST REPORT
PHASE II TEST REPORT
TEST AND CERTIFICATION ANALYSIS



CPC/CEAC SOFTWARE DESIGN
MODIFICATION BLOCK DIAGRAM

PHASE I TESTING

- o VERIFIES THE IMPLEMENTATION OF MODIFICATIONS TO THE CPC/CEAC SOFTWARE.

- o IMPLEMENTATION IS THE TRANSLATION OF SYSTEM FUNCTIONAL REQUIREMENTS INTO MODULES OF MACHINE EXECUTABLE CODE, AND THE INTEGRATION OF THESE MODULES INTO A REAL-TIME SOFTWARE SYSTEM.

- o ALL MODIFIED MODULES ARE TESTED.

- o ALL MODULES THAT ACCESS UPDATED CONSTANTS ARE TESTED.

- o TEST CASES ARE SELECTED TO EXERCISE ALL BRANCHES OF ANY MODULE THAT WAS MODIFIED.

PHASE II TESTING

1. PERFORMED ON A SINGLE CHANNEL CPC/CEAC SYSTEM
2. OBJECTIVES:
 - A. VERIFY SOFTWARE MODIFICATIONS HAVE BEEN PROPERLY INTEGRATED WITH CPC AND CEAC SOFTWARE AND SYSTEM HARDWARE.
 - B. CONFIRM THAT STATIC AND DYNAMIC OPERATION OF THE INTEGRATED SYSTEM IS AS PREDICTED.
3. BASIS FOR COMPARISON IS THE CERTIFIED CPC/CEAC SIMULATION CODE.
4. TESTS PERFORMED
 - A. INPUT SWEEP TEST
 - B. DYNAMIC SOFTWARE VERIFICATION TEST (DSVT)
 - C. LIVE INPUT SINGLE PARAMETER (LISP) TEST

INPUT SWEEP TEST

1. OBJECTIVES:
 - A. DETERMINE PROCESSING UNCERTAINTIES
 - B. VERIFY INITIALIZATION OVER OPERATING SPACE

2. MINIMUM OF 500 TEST CASES REQUIRED

3. TEST CASES EXECUTED FOR ANO-2 CYCLE 1
 - A. CPC - 2000 CASES
 - B. CEAC - 1200 CASES

DYNAMIC SOFTWARE VERIFICATION TEST (DSVT)

1. OBJECTIVES
 - A. VERIFY DYNAMIC RESPONSE
 - B. FURTHER ASSURE CORRECT SOFTWARE IMPLEMENTATION
2. MINIMUM OF FIVE TEST CASES REQUIRED.
3. EXAMPLE CASES
 - o 4 PUMP LOSS OF FLOW
 - o SINGLE CEA DROP
 - o UNCONTROLLED BANK WITHDRAWAL
 - o RAPID DEPRESSURIZATION
 - o INCREASING POWER RAMP

LIVE INPUT SINGLE PARAMETER (LISP) TEST

1. OBJECTIVES:
 - A. VERIFY DYNAMIC RESPONSE
 - B. FURTHER ASSURE CORRECT IMPLEMENTATION OF SOFTWARE
 - C. EVALUATE HARDWARE/SOFTWARE SYSTEM
2. MINIMUM OF FIVE TEST CASES REQUIRED
3. EXAMPLE CASES
 - o PUMP SPEED SIGNAL RAMP
 - o EXCORE DETECTOR SIGNAL RAMP
 - o TEMPERATURE SIGNAL RAMP
 - o PRESSURE SIGNAL RAMP
 - o SINGLE CEA SIGNAL RAMP

SUMMARY

- o A HIGHLY DETAILED AND STRUCTURED PROCESS IS USED FOR SOFTWARE CHANGES.

- o THE PROCESS WAS REVIEWED AND APPROVED BY THE NRC STAFF (CEN-39).

- o CEN-39 WAS APPLIED TO ANO-2 AND SONGS SOFTWARE CHANGES.