



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

March 3, 1981

Charles Bechhoefer, Esq., Chairman
Atomic Safety & Licensing Board
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Dr. George C. Anderson
Department of Oceanography
University of Washington
Seattle, Washington 98195

Mr. Ralph S. Decker
Route 4, Box 190D
Cambridge, Maryland 21613



In the Matter of
DAIRYLAND POWER COOPERATIVE
(La Crosse Boiling Water Reactor)
Docket No. 50-409-SC (Order to Show Cause)

Dear Members of the Board:

Attached for your information is a copy of Amendment No. 24 to Provisional Operating License No. DPR-45 for the La Crosse Boiling Water Reactor. This amendment includes the requirements for the dedicated safe shutdown system which the NRC staff found necessary to preclude reliance on the crib house and underground piping at the site. See Letter from H. R. Denton to F. Linder, enclosing Safety Evaluation by the Office of Nuclear Reactor Regulation Relating to Liquefaction Potential at the La Crosse Site (Aug. 29, 1980).

Respectfully submitted,

Stephen G. Burns

Stephen G. Burns
Counsel for NRC Staff

Attachment:
As Stated

cc: Ann Morse
Frederick M. Olsen, III
O. S. Hiestand, Esq.
F. Schubert (w/o attachment)
F. Linder (w/o attachment)
ASLBP
ASLAP
Docketing & Service

G

8108060271