

TELA



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

February 17, 1981

Docket No. 50-409  
LS05-81-02-035



Mr. Frank Linder  
General Manager  
Dairyland Power Cooperative  
2615 East Avenue South  
LaCrosse, Wisconsin 54601

Dear Mr. Linder:

SUBJECT: ENVIRONMENTAL QUALIFICATION OF SAFETY-RELATED ELECTRICAL EQUIPMENT

RE: LACROSSE BOILING WATER REACTOR

Reference: Order for Modification of License Concerning the Environmental Qualification of Safety-Related Electrical Equipment, October 24, 1980.

This letter transmits the preliminary results of our review of environmental qualifications of safety-related electrical equipment at your facility. This evaluation was based on your submittals received over the past months.

The facility license was modified by the referenced Order of October 24, 1980, to require that all safety-related electrical equipment be qualified to specified requirements not later than June 30, 1982. In addition, the Order noted that a licensee is obligated to modify or replace inadequate equipment promptly.

The staff's review of your submittals has resulted in our identifying a number of potential equipment deficiencies involving a lack of proper documentation, inadequate justification of assumed environmental conditions following an accident, and/or inadequate environmental testing of equipment, such that conformance to the DOR guidelines, as required by the Order, cannot be demonstrated. You are requested to review our identified deficiencies, and their ramifications, and provide us your overall finding regarding continued safe operation of your facility. Accordingly, in order to determine whether your license should be modified or suspended, you are required pursuant to 10 CFR 50.54(f), to provide within 10 days of receipt of this letter, a written statement, signed under oath or affirmation supporting the safe operation of your facility, that takes into account the NRC staff's preliminary list of deficiencies.

8108060 419

Mr. Frank Linder


- 2 -

February 17, 1981

The purpose of this statement is to provide the NRC with needed assurance, by the licensee, regarding the continued safety of the facility until you can provide an item-by-item reevaluation in a detailed documented manner at a later date. A negative finding on your part concerning the safety of continued operation would result in a unit shutdown, and should be reported as a Licensee Event Report (LER) within twenty-four (24) hours of the determination to the appropriate NRC Regional Office. Include in the LER the actions you have taken for the immediate resolution of the matter. A copy of any such LER should be sent to the Director, Division of Licensing, Office of Nuclear Reactor Regulation.

Please submit a copy of your reply to us via telecopy.

Sincerely,



Gus C. Lainas, Assistant Director  
for Safety Assessment  
Division of Licensing

Enclosure:  
Equipment Evaluation  
Report

cc w/enclosure:  
See next page

Mr. Frank Linder

- 3 -

February 17, 1981

cc w/enclosure:

Fritz Schubert, Esquire  
Staff Attorney  
Dairyland Power Cooperative  
2615 East Avenue South  
La Crosse, Wisconsin 54601

O. S. Heistand, Jr., Esquire  
Morgan, Lewis & Bockius  
1800 M Street, N. W.  
Washington, D. C. 20036

Mr. R. E. Shimshak  
La Crosse Boiling Water Reactor  
Dairyland Power Cooperative  
P. O. Box 135  
Genoa, Wisconsin 54632

Coulee Region Energy Coalition  
ATTN: George R. Nygaard  
P. O. Box 1583  
La Crosse, Wisconsin 54601

La Crosse Public Library  
800 Main Street  
La Crosse, Wisconsin 54601

U. S. Nuclear Regulatory Commission  
Resident Inspectors Office  
Rural Route #1, Box 225  
Genoa, Wisconsin 54632

Town Chairman  
Town of Genoa  
Route 1  
Genoa, Wisconsin 54632

Chairman, Public Service Commission  
of Wisconsin  
Hill Farms State Office Building  
Madison, Wisconsin 53702

Alan S. Rosenthal, Esq., Chairman  
Atomic Safety and Licensing Appeal Board  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Mr. Frederick Milton Olsen, III  
609 North 11th Street  
LaCrosse, Wisconsin

Director, Standards and Criteria  
Division  
Office of Radiation Programs  
(ANR-460)  
U. S. Environmental Protection  
Agency  
Washington, D. C. 20460

U. S. Environmental Protection  
Agency  
Federal Activities Branch  
Region V Office  
ATTN: EIS COORDINATOR  
230 South Dearborn Street  
Chicago, Illinois 60604

Charles Bechhoefer, Esq., Chairman  
Atomic Safety and Licensing Board  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Dr. George C. Anderson  
Department of Oceanography  
University of Washington  
Seattle, Washington 98195

Mr. Ralph S. Decker  
Route 4, Box 190D  
Cambridge, Maryland 21613

Dr. Lawrence R. Quarles  
Kendal at Longwood, Apt. 51  
Kenneth Square, Pennsylvania 19348

Thomas S. Moore  
Atomic Safety and Licensing Appeal Board  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Ms. Anne K. Morse  
Coulee Region Energy Coalition  
Post Office Box 1583  
LaCrosse, Wisconsin 54601

U. S. Nuclear Regulatory Commission  
Resident Inspectors Office  
Rural Route #1, Box 225  
Genoa, Wisconsin 54632