NRC FORM 366 (7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 LICENSEE CODE: C T H N P 1 (2) LICENSE NUMBER: 0 0 - 0 0 0 0 0 - 0 0 (3) LICENSE TYPE: 4 1 1 1 1 (4) CAT (5)

CON'T 01 REPORT SOURCE: (6) DOCKET NUMBER: 0 5 0 - 0 2 1 3 (7) EVENT DATE: 0 2 0 5 8 1 (8) REPORT DATE: 0 3 0 2 8 1 (9)

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 During monthly containment air recirculation fan damper tests the top section
03 of bypass dampers, on one of the four fans, did not close when it was supposed to.
04 Failure of the bypass damper to close when called upon to do so in accident
05 conditions would reduce the efficiency of that fan for removal of particulates
06 and iodine.
07
08

SYSTEM CODE	CAUSE CODE	CAUSE SUBCODE	COMPONENT CODE	COMP. SUBCODE	VALVE SUBCODE
S C (11)	E (12)	X (13)	M O T O R X (14)	Z (15)	Z (16)

(17) LER/RO REPORT NUMBER

EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE	REPORT TYPE		REVISION NO.
8 1	—	0 0 1	/	0 3	L	—	0

ACTION TAKEN	FUTURE ACTION	EFFECT ON PLANT	SHUTDOWN METHOD	HOURS (22)	ATTACHMENT SUBMITTED	NPRD-4 FORM SUB.	PRIME COMP. SUPPLIER	COMPONENT MANUFACTURER
B (18)	Z (19)	Z (20)	Z (21)	0 0 0 0	N (23)	Y (24)	X (25)	X 9 9 9 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 The air motor used to position the damper was found inoperable. The motor
11 was dismantled, cleaned of foreign objects, replaced and tested for proper
12 operation.
13
14

15 FACILITY STATUS: E (28) % POWER: 1 0 0 (29) OTHER STATUS (30): N/A METHOD OF DISCOVERY: B (31) DISCOVERY DESCRIPTION (32): Operator Observation

16 ACTIVITY RELEASED: Z (33) CONTENT OF RELEASE: Z (34) AMOUNT OF ACTIVITY (35): N/A LOCATION OF RELEASE (36): N/A

PERSONNEL EXPOSURES

17 NUMBER: 0 0 0 (37) TYPE: Z (38) DESCRIPTION (39): N/A

PERSONNEL INJURIES

18 NUMBER: 0 0 0 (40) DESCRIPTION (41): N/A

LOSS OF OR DAMAGE TO FACILITY (43)

19 TYPE: Z (42) DESCRIPTION: N/A

PUBLICITY

20 ISSUED: N (44) DESCRIPTION (45): N/A NRC USE ONLY

8103090544

NAME OF PREPARER: S. T. Fleming PHONE: (203) 267-2556

GPO 917-926