


71c



SACRAMENTO MUNICIPAL UTILITY DISTRICT □ 6201 S Street, Box 15830, Sacramento, California 95813; (916) 452-3211

March 6, 1981

Mr. R. H. Engelken, Director
Region V, Office of Inspection
and Enforcement
U.S. Nuclear Regulatory Commission
Suite 202, Walnut Creek Plaza
1990 North California Boulevard
Walnut Creek, CA 94596



Docket 50-312
Rancho Seco Nuclear Generating
Station, Unit No. 1
IE Bulletin 81-01



Dear Mr. Engelken:

The Sacramento Municipal Utility District has reviewed IE Bulletin No. 81-01, Surveillance of Mechanical Snubbers, dated January 27, 1981. We have determined that we do not have any mechanical snubbers installed on safety related systems at Rancho Seco Unit 1 and, therefore, do not intend to pursue any of the actions requested in this bulletin.

Sincerely,

John J. Mattimoe
Assistant General Manager
and Chief Engineer

8103260108

Q

81-47