

APPENDIX A
NOTICE OF VIOLATION

Georgia Power Company
Vogtle

Docket Nos. 50-424 & 50-425
License Nos. CPPR-108 & CPPR-109

As a result of the inspection conducted on February 18-20, 1981, and in accordance with the Interim Enforcement Policy, 45 FR 66754 (October 7, 1980), the following violation was identified.

10 CFR 50, Appendix B, Criterion V, implemented by paragraph 17.1.5 of the PSAR, requires in part that, activities affecting quality shall be prescribed by documented instructions, procedures, and drawings and shall be accomplished in accordance with these instructions, procedures and drawings. Paragraphs VIII.A and VIII.E.3.b of procedure GD-T-01, the procedure for controlling nonconforming items, require that a nonconforming report be issued and the nonconforming item be placed on hold when incorrect or deficient documentation is identified.

Contrary to the above, a significant documentation deficiency, was identified by QA with the material test report for Heat 97401 E70S-2 welding wire and a nonconformance report was not issued and the material was not placed on hold.

This is a Severity Level V Violation (Supplement II.F.).

Pursuant to the provisions of 10 CFR 2.201, you are hereby required to submit to this office within twenty-five days of the date of this Notice, a written statement or explanation in reply, including: (1) admission or denial of the alleged violation; (2) the reasons for the violation if admitted; (3) the corrective steps which have been taken and the results achieved; (4) corrective steps which will be taken to avoid further violations; and (5) the date when full compliance will be achieved. Under the authority of Section 182 of the Atomic Energy Act of 1954, as amended, this response shall be submitted under oath or affirmation.

MAR 13 1981

Date: _____

B108270 145