

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (1)

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 I L Z I S 1 2 0 0 - 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5
7 8 9 LICENSE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 31 CAT 36

CONT
0 1 REPORT SOURCE L 6 0 5 0 0 0 2 9 5 7 0 2 2 8 8 1 8 0 3 2 0 9 1 9
7 8 9 DOCKET NUMBER 19 20 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (19)

0 2 With Unit 1 in Cold Shutdown and Unit 2 in power operation, Fire Sump
0 3 Radiation Monitor ORT-PR25 high alarmed. A grab sample was taken indica-
0 4 ting only background levels of activity. The monitor was taken O.O.S.
0 5 and shiftly grab samples were taken as required by T.S. 3.14.1.C. There
0 6 were no safety implications and the health and safety of the general pub-
0 7 lic was not affected.

0 8 _____
7 8 9

0 9 SYSTEM CODE M A (11) CAUSE CODE E (12) CAUSE SUBCODE A (13) COMPONENT CODE I N S T R U (14) COMP. SUBCODE X (15) VALVE SUBCODE Z (16)
7 8 9 10 11 12 13 18 19 20
17 LER NO. REPORT NUMBER 8 1 (21) _____ (23) SEQUENTIAL REPORT NO. 0 0 6 (24) _____ (27) OCCURRENCE CODE 0 3 (28) REPORT TYPE L (30) REVISION NO. 0 (32)
8 9 21 22 23 24 26 27 28 29 30 31 32
ACTION TAKEN B (18) FUTURE ACTION Z (19) EFFECT ON PLANT Z (20) SHUTDOWN METHOD Z (21) HOURS 0 0 0 0 (22) ATTACHMENT SUBMITTED N (23) NRR-4 FORM SUB. N (24) PRIME COMP. SUPPLIER A (25) COMPONENT MANUFACTURER G 0 6 3 (26)
33 34 35 36 37 40 41 42 43 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 The false high alarm was caused by a break in a solder joint in the high
1 1 voltage circuit of the monitor. No other cause of failure was noted.
1 2 The joint was repaired, the monitor functionally tested, and returned to
1 3 service. This is not a recurring problem and no further action is neces-
1 4 sary.
7 8 9

1 5 FACILITY STATUS E (28) % POWER 0 9 0 (29) OTHER STATUS NA (30) METHOD OF DISCOVERY A (31) DISCOVERY DESCRIPTION Operator Observation (32)
7 8 9 10 12 13 44 45 46 80

1 6 ACTIVITY CONTENT RELEASED OF RELEASE Z (33) Z (34) AMOUNT OF ACTIVITY NA (35) LOCATION OF RELEASE NA (36)
7 8 9 10 11 44 45 80

1 7 PERSONNEL EXPOSURES NUMBER 0 0 0 (37) TYPE Z (38) DESCRIPTION NA (39)
7 8 9 11 12 13 80

1 8 PERSONNEL INJURIES NUMBER 0 0 0 (40) DESCRIPTION NA (41)
7 8 9 11 12 80

1 9 LOSS OF OH DAMAGE TO FACILITY TYPE Z (42) DESCRIPTION NA (43)
7 8 9 10 80

2 0 PUBLICITY ISSUED N (44) DESCRIPTION NA (45) 8108310558
7 8 9 10 80
NRC USE ONLY