



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

March 27, 1981

Docket No. 50-298

Mr. J. M. Pilant, Director
Licensing & Quality Assurance
Nebraska Public Power District
P. O. Box 499
Columbus, Nebraska 68601



Dear Mr. Pilant:

SUBJECT: ENVIRONMENTAL QUALIFICATION OF SAFETY-RELATED ELECTRICAL EQUIPMENT
RE: COOPER NUCLEAR POWER STATION

Reference: Order for Modification of License Concerning the Environmental Qualification of Safety-Related Electrical Equipment, October 24, 1980.

This letter transmits the preliminary results of our review of environmental qualifications of safety-related electrical equipment at your facility. This evaluation was based on your submittals received over the past months.

The facility license was modified by the referenced Order of October 24, 1980, to require that all safety-related electrical equipment be qualified to specified requirements not later than June 30, 1982. In addition, the Order noted that a licensee is obligated to modify or replace inadequate equipment promptly.


The staff's review of your submittals has resulted in our identifying a number of potential equipment deficiencies involving a lack of proper documentation, inadequate justification of assumed environmental conditions following an accident, and/or inadequate environmental testing of equipment, such that conformance to the DOR guidelines, as required by the Order, cannot be demonstrated. You are requested to review our identified deficiencies, and their ramifications, and provide us your overall finding regarding continued safe operation of your facility. Accordingly, in order to determine whether your license should be modified or suspended, you are required pursuant to 10 CFR 50.54(f), to provide within 10 days of receipt of this letter, a written statement, signed under oath or affirmation supporting the safe operation of your facility, that takes into account the NRC staff's preliminary list of deficiencies.

P 8104020268

The purpose of this statement is to provide the NRC with needed assurance, by the licensee, regarding the continued safety of the facility until you can provide an item-by-item reevaluation in a detailed documented manner at a later date. A negative finding on your part concerning the safety of continued operation would result in a unit shutdown, and should be reported as a Licensee Event Report (LER) within twenty-four (24) hours of the determination to the appropriate NRC Regional Office. Include in the LER the actions you have taken for the immediate resolution of the matter. A copy of any such LER should be sent to the Director, Division of Licensing, Office of Nuclear Reactor Regulation.

Please submit a copy of your reply to us via telecopy.

Sincerely,



Thomas M. Novak, Assistant Director
for Operating Reactors
Division of Licensing

Enclosure:
Evaluation Report

cc w/enclosure:
See next page

Mr. J. M. Pilant
Nebraska Public Power District

cc:

Mr. G. D. Watson, General Counsel
Nebraska Public Power District
P. O. Box 499
Columbus, Nebraska 68601

Mr. Arthur C. Gehr, Attorney
Snell & Wilmer
3100 Valley Center
Phoenix, Arizona 85073

Cooper Nuclear Station
ATTN: Mr. L. Lessor
Station Superintendent
P. O. Box 98
Brownville, Nebraska 68321

Auburn Public Library
118 - 15th Street
Auburn, Nebraska 68305

Director
Nebraska Dept. of Environmental Control
P. O. Box 94877, State House Station
Lincoln, Nebraska 68509

Mr. William Siebert, Commissioner
Nemaha County Board of Commissioners
Nemaha County Courthouse
Auburn, Nebraska 68305

Director, Criteria and Standards
Division
Office of Radiation Programs (ANR-460)
U. S. Environmental Protection Agency
Washington, D. C. 20460

U. S. Environmental Protection Agency
Region VII Office
ATTN: EIS COORDINATOR
324 East 11th Street
Kansas City, MO 64106

Mr. Dennis Dubois
USNRC
Resident Inspector
P. O. Box 446
Nebraska City, NE 68410