

U. S. NUCLEAR REGULATORY COMMISSION  
OFFICE OF INSPECTION AND ENFORCEMENT  
REGION II

JAN 12 1981

Report No. 50-348/80-39

Docket No. 50-348

License No. NPF-2

Licensee: Alabama Power Company  
600 North 18th Street  
Birmingham, AL 35202

Facility Name: Farley 1

Inspection at: Ashford, Alabama

Inspection conducted: November 24-26, 1980

Type of Inspection: Unannounced Physical Security

Inspectors: LE Moore  
D. E. Moore, Physical Security Inspector

1/5/81  
Date

J. C. Howell  
J. C. Howell, Physical Security Inspector

1/5/81  
Date

Approved by: DR McGuire  
D. R. McGuire, Chief, Security Section  
Safeguards Branch

1/6/81  
Date

SUMMARY

Inspection Summary

Areas Inspected: Included review of lighting; security organization; protected and vital area physical barriers and communications.

The inspection involved 40 inspector-hours on site by two NRC inspectors. The inspection was begun during an offshift period; six inspection hours were accomplished during offshift periods.

Results: Of the five areas examined during the inspection, one apparent violation of regulatory requirements was identified in one area. Physical Barriers (Vital Areas) - Temporary door not alarmed.

8104060041

RESTRICTED INFORMATION  
CONTAINS SENSITIVE INFORMATION

S-F2 21 - 4  
Copy \_\_\_\_\_ of \_\_\_\_\_ Copies  
\_\_\_\_\_ Pages

This Document is not to be  
reproduced without specific  
approval of IE:II