

CONTROL BLOCK

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

CON'T

0	1	L	6	0	5	0	-	0	3	2	4	7	0	2	2	5	8	1	3	0	3	2	7	8	1	9		
7	8	60	61	POCKET NUMBER										68	69	EVENT DATE					74	75	REPORT DATE					80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)
During a normal plant startup while moving control rods, a "rod overtravel" annunciator was received during the verification of rod-drive coupling for rod 30-23. This rod and the other rods symmetric to it were then inserted and deactivated in accordance with plant procedures and technical specifications. This event did not affect the health or safety of the public.

Technical Specifications 3.1.3.6, 6.9.1.9b

SYSTEM CODE R B 11		CAUSE CODE X 12		CAUSE SUBCODE Z 13		COMPONENT CODE Z Z Z Z Z Z 14		COMP SUBCODE Z 15		VALVE SUBCODE Z 16	
LER NO REPORT NUMBER 8 1 17		EVENT YEAR 8 1 21		SEQUENTIAL REPORT NO. 0 3 5 24		OCCURRENCE CODE 0 3 28		REPORT TYPE L 30		REVISION NO. 0 32	
ACTION TAKEN X 18		FUTURE ACTION X 19		EFFECT ON PLANT Z 20		SHUTDOWN METHOD Z 21		HOURS 0 0 0 0 22		ATTACHMENT SUBMITTED N 23	
CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27		NPRD-4 FORM SUB Y 24		PRIME COMP SUPPLIER N 25		COMPONENT MANUFACTURER G 0 8 0 26					

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS

During subsequent unit load changes while above the preset power level of the RSCS, this rod was verified coupled to its drive and was declared operable and returned to service in accordance with Technical Specification 3.1.3.6a. During the next scheduled CRD rebuilding outage, this rod will be inspected to determine if any irregularities exist which could have caused the "rod overtravel" annunciator.

FACILITY STATUS		POWER		OTHER STATUS		METHOD OF DISCOVERY		DISCOVERY DESCRIPTION	
1	5	C	28	0	0	4	29	NA	NA
ACTIVITY CONTENT		RELEASED OF RELEASE		AMOUNT OF ACTIVITY		LOCATION OF RELEASE			
1	6	Z	33	Z	34	NA	35	NA	36
PERSONNEL EXPOSURES		NUMBER		TYPE		DESCRIPTION			
1	7	0	0	0	37	Z	38	NA	
PERSONNEL INJURIES		NUMBER		DESCRIPTION					
1	8	0	0	0	40			NA	
LOSS OF OR DAMAGE TO FACILITY		TYPE		DESCRIPTION					
1	9	Z	42					NA	
PUBLICITY		ISSUED		DESCRIPTION				NRC USE ONLY	
2	0	N	44					NA	

NAME OF PREPARER M. J. Pastva, Jr.

PHONE (919) 457-9521

810 4060 604