

BIG ROCK POINT PRA EXECUTIVE SUMMARY

MOTIVATION FOR THE STUDY

STUDY OBJECTIVES

RESULTS


CPCo CONCLUSIONS AND PLAN OF ACTION

18104100 315

FWBUCKMAN
7/17/01

MOTIVATION FOR STUDY

- CPGO IS CONCERNED ABOUT PROJECTED CAPITAL EXPENDITURES
- BIG ROCK POINT HAS PERFORMED WELL IN TERMS OF SAFETY AND AVAILABILITY OVER THE YEARS
- A BASIS FOR A CORPORATE DECISION ON FUTURE OPERATION OF BIG ROCK POINT IS NEEDED




FWBUCKMAN
3/17/81


STUDY OBJECTIVES

- PERFORM A COMPREHENSIVE AND SYSTEMATIC EVALUATION OF PLANT SAFETY
- MAINTAIN TECHNICAL OBJECTIVITY IN THIS EFFORT
- EXPLORE MEANS OF REDUCING PLANT RISK
- EVALUATE EFFECTIVENESS OF REGULATORY ISSUES USING PRA
- DEVELOP A COST EFFECTIVE RISK MANAGEMENT PROGRAM FOR BIG ROCK POINT

PROBABILISTIC RISK ASSESSMENT
OF
BIG ROCK POINT

OBJECTIVE:
TO ACHIEVE
COST EFFECTIVE
RISK REDUCTION





COMPARISON OF CCDF FOR LATENT FATALITIES PER YEAR
BETWEEN BIG ROCK POINT (BASE CASE)
AND THE AVERAGE CURVE FROM WASH-1400

SUMMARY OF DOMINANT SEQUENCES

<u>Sequence Class (No. of Sequences)</u>	<u>Core Damage Frequency (yr⁻¹)</u>	
Turbine Trip (3)	8.5 x 10 ⁻⁷	8.7 x 10 ⁻⁷
Loss of Feedwater (1)	4 x 10 ⁻⁷	
Loss of Main Condenser (6)	3.7 x 10 ⁻⁶	
Loss of Offsite Power (15)	4.5 x 10 ⁻⁵	4.7
LOCA (5)	4.3 x 10 ⁻⁵	4.5
Steam Line Break Inside Containment (3)	1.1 x 10 ⁻⁴	✓
Loss of Instrument Air (6)	3.3 x 10 ⁻⁵	3.5
Spurious Closure of MSIV (4)	3.2 x 10 ⁻⁶	
Spurious Opening of Turbine Bypass Valve (5)	7.1 x 10 ⁻⁵	
ATWS (18)	4.7 x 10 ⁻⁵	revised? 2.7 x 10 ⁻⁵
Spurious Opening of RDS Isolation Valve (2)	1.7 x 10 ⁻⁵	
High Energy Line Break (2)	1.5 x 10 ⁻⁶	
Interfacing LOCA (2)	8.7 x 10 ⁻⁵	9.1
Fire (6)	2.3 x 10 ⁻⁴	
Stuck Open Safety Valve (8)	2.9 x 10 ⁻⁴	
TOTAL (86 sequences)	9.82 x 10 ⁻⁴	

8

RISK REDUCTION ACTION PLAN

• PLANT MODIFICATIONS

• CONTINUING RISK MANAGEMENT PROGRAM

SHORT TERM PLAN

1. CPCo WILL SUBMIT PRA DOCUMENT 3/31
2. CPCo WILL SUBMIT PRA-BASED DOCUMENTATION FOR DEFERRAL ITEMS ON 3/31
3. CPCo WILL INITIATE DETAILED DESIGN ACTIVITIES ON PRA - RECOMMENDED MODIFICATIONS AS SOON AS THE NRC ISSUES A PROVISIONAL ACCEPTANCE OF THE CPCo POSITION STATED IN ITEM 2 ABOVE. THIS PROVISIONAL ACCEPTANCE INVOLVES DEFERRAL OF IMPLEMENTATION DATES FOR THESE ITEMS PENDING COMPLETION OF DETAILED REVIEW
4. CPCo WILL COMPLETE IMPLEMENTATION OF THE PRA-RECOMMENDED MODIFICATIONS SUBSEQUENT TO COMPLETION OF NRC REVIEW GIVEN NRC ACCEPTANCE OF PRA AS AN EVALUATION BASIS FOR FUTURE REGULATORY ISSUES

CONCLUSIONS

- . BRP CAN BE OPERATED AT AN ACCEPTABLY LOW LEVEL OF RISK TODAY.

- . PRA INDICATES THAT THERE ARE SOME HIGHLY COST EFFECTIVE ACTIONS THAT CAN BE TAKEN TO REDUCE RISK.

- . BASED UPON PROJECTED CAPITAL EXPENDITURES CPCo NEEDS SOME ASSURANCES THAT PRA WILL SERVE AS AN EFFECTIVE TOOL IN DECIDING UPON PLANT MODIFICATIONS.

SCOPE OF STUDY .

- o COMPLETE BASELINE PRA
- o SEQUENCE DEVELOPMENT AND PROBABILISTIC QUANTIFICATION
- o IN-PLANT AND EX-PLANT CONSEQUENCES ANALYZED
- o THOROUGH CONSIDERATION OF POTENTIAL PLANT MODIFICATIONS
- o ON-GOING DEFINITION OF RISK MINIMIZATION PROGRAM

STUDY PURPOSE .

EMPLOY THE TECHNIQUES OF PROBABILISTIC RISK ASSESSMENT
(PRA) TO SUPPORT THE CONTINUED SAFE OPERATION OF THE
BIG ROCK POINT NUCLEAR PLANT

APPROACH EMPLOYED


- o COMPLETE BASELINE PRA
 - + INITIATOR SPECIFIC TO PLANT
 - + ACCIDENT SEQUENCES (EVENT TREES AND FAULT TREES)
 - + PLANT SPECIFIC DATA
 - + IN-PLANT AND EX-PLANT CONSEQUENCES

- o DIFFICULT ISSUES TREATED DIRECTLY
 - + COMMON CAUSE FAILURES
 - + INTERNAL EVENTS (E.G., FIRES AND HIGH ENERGY LINE BREAKS)
 - + EXTERNAL EVENTS (E.G., SEISMIC AND WIND LOADINGS)
 - + EQUIPMENT ENVIRONMENTAL QUALIFICATION

- o INCLUDED IN SCOPE
 - + UNIQUE APPROACHES TO ASSURING COMPLETENESS
 - + FORMULATION AND INVESTIGATION OF EFFECT OF VARIOUS PLANT MODIFICATIONS
 - + SIGNIFICANT CPCo PARTICIPATION

- o EXCLUDED FROM SCOPE
 - + SABOTAGE
 - + DETAILED QUANTIFICATION OF PROBABILITY OF FAILURE TO SCRAM

CORE DAMAGE AND RADIONUCLIDE RELEASE EVALUATION



COMPARISONS OF CONTAINMENT PHYSICAL PARAMETERS

	<u>BIG ROCK POINT</u>	<u>SURRY</u>
POWER LEVEL (MW _t)	240	2,400
CONTAINMENT VOLUME (CUBIC FEET)	9.4x10 ⁵	1.8x10 ⁶
CONTAINMENT DESIGN PRESSURE (PSIG)	27.0	45.0
ENERGY RELEASES IN LARGE LOCA		
INFORMATION REQUIRED		
o PRIMARY VOLUME (CUBIC FEET)	3,639 (2,718 cu. FT. OF WATER)	8,387
o PRIMARY TEMPERATURE (°F)	566°F	572°F
o PRIMARY PRESSURE (PSIA)	1,350	2,295
PRESSURE IN CONTAINMENT FOLLOWING A LARGE LOCA ASSUMING NO CONTAINMENT SPRAY (PSIG)	PEAK PRESS. 20 PSIG	39.3 PSIG
VOLUME OF STEAM PRODUCED AT ATMOSPHERIC PRESSURE BY 1% DECAY POWER (CUBIC FEET PER MINUTE)	3.82x10 ³ (@ 100°C)	3.88x10 ⁴ (@ 100°C)
DIVIDED BY CONT. VOLUME	4.1x10 ⁻³	2.2x10 ⁻²
MASS OF UO ₂ (POUNDS)	27,500 LBS.	175,600 LBS.
MASS OF ZIRCONIUM IN CORE (POUNDS)	11,270 LBS.	36,300 LBS.
PERCENT OF H ₂ IN CONTAINMENT (ASSUMING ALL ZIRCONIUM REACTS)	7 TO 8% H ₂	12 TO 14% H ₂
REMOVAL RATE CONSTANT (HR ⁻¹)		
o IODINE (NATURAL)	1.5	1.4
o PARTICULATE (NATURAL)	0.9	0.6
o IODINE (SPRAY)	0.1	3.0 (BORIC ACID), (IF HYDROXIDE IN SPRAY, 30)
o PARTICULATE (SPRAY)	0.6	20.0

Table 7.1

LIST OF RISK OUTLIERS AND SEQUENCE CLASSES AFFECTED


RISK OUTLIER	SEQUENCE CLASSES														
	Turbine Trip	Loss of Feedwater	Loss of Main Condenser	Loss of Offsite Power	LOCA	Steam Line Break Inside Containment	Loss of Instrument Air	Spurious Closure of MSIV	Spurious Opening of Turbine Bypass Valve	ATWS	Spurious Opening of RDS Isolation Valve	High Energy Line Break	Interfac ^g LOCA	Fire	Stuck Open Safety Valve
Emergency Condenser Makeup Failure	X		X	X		X	X	X		X					X
Environmental Qualification	X	X	X	X	X	X	X	X	X	X		X			X
Limited FM During ATWS									X						
MSIV Backup Failure				X											
Post Incident System Reliability	X	X	X	X	X	X	X	X		X		X			X
RDS/CS Reliability	X		X	X	X	X	X	X		X		X			X
Standby Diesel Reliability				X											
Instrument Air System Repair						X									
Leaking RDS Valves										X					
Single Valve Isolation of Primary System												X			
Proximity of Safety System Piping to High Energy Lines											X				
Concentration of Safety System Electrical Cables in Single Locations															X
Late Automatic Isolation of Main Steam Line on Loss of Coolant										X					
Secondary System Instabilities	X		X						X			X			

TABLE 1.1
SUMMARY OF DOMINANT SEQUENCES

<u>SEQUENCE CLASS (NO OF SEQUENCES)</u>	<u>FREQUENCY (YR⁻¹)</u>	<u>UNCERTAINTY*</u>
TURBINE TRIP (3)	8.7×10^{-7}	20
LOSS OF FEEDWATER (1)	4×10^{-7}	98
LOSS OF MAIN CONDENSER (6)	4.0×10^{-6}	35
LOSS OF OFFSITE POWER (15)	4.7×10^{-5}	29
LOCA (5)	4.5×10^{-5}	19
STEAM LINE BREAK INSIDE CONTAINMENT (3)	1.1×10^{-4}	49
LOSS OF INSTRUMENT AIR (6)	3.5×10^{-5}	18
SPURIOUS CLOSURE OF MSIV (4)	3.2×10^{-6}	40
SPURIOUS OPENING OF TURBINE BYPASS VALVE (5)	7.1×10^{-5}	22
ATWS (13)	2.7×10^{-5}	11
SPURIOUS OPENING OF RDS ISOLATION VALVE (2)	1.7×10^{-5}	9
HIGH ENERGY LINE BREAK (2)	1.5×10^{-6}	10
INTERFACING LOCA (2)	9.1×10^{-5}	4
FIRE (6)	2.3×10^{-4}	13
STUCK OPEN SAFETY VALVE (8)	2.9×10^{-4}	45
TOTAL (81 SEQUENCES)	9.75×10^{-4}	15


* UNCERTAINTY TAKEN TO BE 95% CONFIDENCE LIMIT \pm MEAN

TOTAL CORE DAMAGE FREQUENCY (YR⁻¹)




GROUP 1 MODIFICATIONS VS TOTAL
CORE DAMAGE FREQUENCY (YR⁻¹) WITH
MARGINAL COST BENEFIT RATIO (\$/MAN - REM)

GROUP 1 MODIFICATIONS (INCLUDING ENVIRONMENTAL
 QUALIFICATION) VS TOTAL CORE DAMAGE FREQUENCY (YR⁻¹)
 WITH MARGINAL COST - BENEFIT RATES (\$/MAN-REM)




TOTAL CORE DAMAGE FREQUENCY (YR⁻¹)



GROUP 2 MODIFICATIONS VS TOTAL
 CORE DAMAGE FREQUENCY (YR⁻¹) WITH
 MARGINAL COST BENEFIT RATIO (\$/MAN-REM)

STEPS OF PROCESS FOR DEFINING
PLANT MODIFICATIONS RESULTING FROM PRA



SAFE SHUTDOWN AREA
RECOMMENDATIONS
FOR FIRE PROTECTION

10CFR 50 APPENDIX R

BIG ROCK PRA

EQUIPMENT ON PANEL FOR SHORT TERM COOLING

MSIV CONTROL AND POWER

MSIV CONTROL AND POWER

EMERGENCY CONDENSER OUTLET
VALVE CONTROL AND POWER (1 LOOP)

EMERGENCY CONDENSER OUTLET
VALVE CONTROL AND POWER
(2 LOOPS)

EMERGENCY CONDENSER MAKEUP
VALVE FROM FIRE SYSTEM CONTROL
AND POWER

EMERGENCY CONDENSER MAKEUP
VALVE FROM FIRE SYSTEM
CONTROL AND POWER

MANUAL REACTOR TRIP CAPABILITY

INSTRUMENTATION

DRUM LEVEL

DRUM LEVEL

EMERGENCY CONDENSER LEVEL
(ANNUNCIATOR)

EMERGENCY CONDENSER LEVEL
(ANNUNCIATOR)

EMERGENCY CONDENSER VALVE POSITION
INDICATION MAKEUP & OUTLET VALVE

EMERGENCY CONDENSER VALVE
POSITION MAKEUP & OUTLET
VALVE

MSIV POSITION INDICATION

MSIV POSITION

LONG TERM COOLING EQUIPMENT

SHUTDOWN PUMP AND MOTOR
OPERATED VALVES

REACTOR COOLING WATER PUMP

SERVICE WATER PUMP

& CAPABILITY TO POWER THIS
EQUIPMENT THROUGH SHUTDOWN
AREA WITH EMERGENCY DIESEL


EMERGENCY CONDENSER
MAKEUP VALVE CAPABLE
OF REMOTE AND LOCAL
HAND OPERATION

OTHER MISCELLANEOUS REQUIREMENTS

PREVENT EMERGENCY CONDENSER
INLET VALVES FROM CLOSING
ON HOT SHORTS

PREVENT EMERGENCY CONDENSER
INLET VALVES FROM CLOSING ON
HOT SHORTS

PROVIDE POWER AND CONTROL
FOR A CRD PUMP FROM THE SAFE
SHUTDOWN AREA



APPROVED
FOR CONSTRUCTION


BIG BROTHERS PLANT EQUIPMENT LOCATION PLAN ABOVE OPERATING FLOOR	3159 M-101
--	------------

PLAN BEING RELEASED
 BY THE BUREAU OF RESEARCH
 ON 11/15/54

RELEASED
 IN FULL
 ON 08/08/01

U.S. GOVERNMENT PRINTING OFFICE: 1954 O-3159






AS-10017

PIPING & INSTRUMENT DIAGRAM NUCLEAR STEAM SUPPLY SYSTEM	
SHEET NO. 3159	DATE 11-13-57
DRAWING ROOM	
CHECKED BY	
DESIGNED BY	
APPROVED BY	

**APPROVED
FOR CONSTRUCTION**

POOR ORIGINAL

EMERGENCY CONDENSER MAKEUP FAILURE MODIFICATIONS



MOD 1

REPLACE VEC-1 WITH REMOTE MANUAL D.C. POWERED VALVE

MOV FAILS TO OPEN	7.1E-3
OPERATOR FAILS TO ACTUATE	<u>1.0E-3</u>
	8.1E-3

MOD 2

REPLACE VEC-1 WITH AUTOMATIC D.C. POWERED VALVE

MOV FAILS TO OPEN	7.1E-3
-------------------	--------

MOD 3

PLACE DEMIN. PUMP AND AN AIR COMPRESSOR ON THE EMERGENCY BUS

1.0E-2

CHECK VALVES FAIL TO OPEN	2.0E-3
DEMIN. PUMP OUT FOR MAINT.	7.3E-3
DEMIN. PUMP FAIL TO RUN	2.7E-4
LOSS OF AIR	<u>2.7E-5</u>
	1.0E-2

RESULTS OF EMERGENCY CONDENSER MAKEUP SENSITIVITY STUDY

MODIFICATION	LOSS OF OFFSITE POWER SEQUENCES		STICK OPEN SAFETY VALVE SEQUENCES		ALL AFFECTED SEQUENCES		TOTAL CORE DAMAGE FREQUENCY	
	W/O MOD	W. MOD	W/O MOD	W. MOD	W/O MOD	W. MOD	W/O MOD	W. MOD
1. REPLACE VEC-1 WITH REMOTE MANUAL D.C. POWERED VALVE	4.7E-5	1.11E-5	2.9E-4	6.8E-5	4.5E-4	1.6E-4	9.75E-4	6.76E-4
2. REPLACE VEC-1 WITH AUTOMATIC D.C. POWERED VALVE	4.7E-5	1.10E-5	2.9E-4	6.7E-5	4.5E-4	1.59E-4	9.75E-4	6.75E-4
3. PLACE DEMIN. PUMP AND AN AIR COMPRESSER ON EMERGENCY BUIS	4.7E-5	1.6E-5	2.9E-4	1.9E-4	4.5E-4	3.2E-4	9.75E-4	8.36E-4

THE NEED FOR SHIELDING AT BIG ROCK POINT

NEED MAY COME FROM REQUIREMENTS IN NUREG-0737

OR

COMPARISON BETWEEN THE PLACEMENT OF SHIELDING VS
AFFECT ON CORE MELT PROBABILITY

RMMARUSICH
3/17/81

NUREG-0737 ACTION GUIDANCE

1. REVIEW VITAL AREAS WHICH MAY REQUIRE OCCUPANCY.
2. REVIEW SYSTEMS WHICH MAY CONTAIN LARGE QUANTITIES OF RADIO NUCLIDES.
3. DETERMINE WHICH OF THESE SYSTEMS AFFECT THE VITAL AREAS.
4. DETERMINE THE MAGNITUDE OF THE SOURCE AT THE TIME OF THE ACTION (NO SOURCE, GAP RELEASE, MELT RELEASE, ETC).
5. DETERMINE DOSE.

CRITERIA - 15 MR/HR AVERAGE OVER 30 DAYS FOR CONTINUOUS OCCUPANCY AREAS.

5 REM TOTAL EXPOSURE FOR ACCESS INTO AREAS INFREQUENTLY.

METHODOLOGY AND ASSUMPTIONS

1. RADIOACTIVITY

WORST CASE FOR DIRECT SHINE - LARGE LOCA

WORST CASE FOR AIRBORNE - LOSS OF STATION POWER WITH FAILURE OF THE PCS TO ISOLATE RELEASES NOT AT T=0 BUT OVER TIME OBTAINED FROM INCOR CODES.

2. CALCULATIONAL METHODOLOGY

SHINE - USE EQUATION CONCERNING DOSE TO A POINT FROM A FINITE SPHERICAL SOURCE.

INHALATION - RISK ASSESSMENT METHODOLOGY PROVIDED RELEASE FRACTIONS VS TIME; X/Q CALCULATED FOR OUR CASE; VENTILATION CHARACTERISTICS USED; FACTOR OF 10^{-3} USED TO DETERMINE IODINE CONCENTRATIONS CHEMICALLY REDUCING ENVIRONMENT (ALWAYS WATER PRESENT AS STEAM OR WATER) NO OXIDIZING ENVIRONMENT (CONTAINMENT P > TB P).

3. DOSES

25 REM FOR ACCIDENT CONDITIONS FROM NCRP REPORT 39 & DOE IN EP
FACTOR OF 20 REDUCTION IN THYROID DOSE WHEN KI PILLS TAKEN,
NCRP REPORT 55.

5 REM WHOLE BODY, 30 REM THYROID FOR CONTINUOUS OCCUPIED AREAS.

4. SCENERIO

LARGE LOCA

T=0 INITIATION
T=15M MELT STARTS
T=1HR MELT PHASE ENDS
(90% XE, KR)
T=4.4HR REMAINING NUCLIDES
RELEASED

LOSS OF POWER

T=0 INITIATION
T=15M MELT STARTS
T=1.5HR MELT PHASE ENDS
T=3HRS VESSEL MELT THROUGH
T=5HRS REMAINING NUCLIDES
RELEASED

REVIEW CONSIDERED

VITAL AREAS

1. ALL OPERATOR ACTIONS SPECIFIED BY THE PROCEDURE.
2. FUEL OIL DELIVERY, STANDBY EDG SET-UP, INGRESS AND EGRESS.
3. AREAS OF POSSIBLE MAINTENANCE (CORE SPRAY, HX ROOM, SCREEN HOUSE).
4. INHABITED AREAS (CONTROL ROOM, TECHNICAL SUPPORT CENTER, ELECTRIC EQUIPMENT ROOM, SAMPLE ANALYSIS AREA).

SOURCES

1. CONTAINMENT.
2. POST INCIDENT RECIRCULATION PIPING.

MAGNITUDES OF RADIOACTIVITY

1. NORMAL OPERATION LEVELS.
2. GAP RELEASE (APPROXIMATELY 2% MELT RELEASE).
3. MELT RELEASE.

OPERATOR ACTIONS

REVIEWED THE PROCEDURES AND DETERMINED THE ACTIONS AND WHERE THEY TAKE PLACE.

THE VAST MAJORITY OF THE ACTIONS TAKE PLACE BEFORE RDS.

AFTER MELT ACTIONS -

OCCUPY CONTROL ROOM, TSC

GET TO SAMPLE ANALYSIS AREA, ELECTRIC EQUIPMENT ROOM

FILL FUEL OIL TANKS (HEATING BOILER, EDG, DIESEL FIRE PUMP, STANDBY EDG)

INGRESS AND EGRESS

SWITCH TO RECIRCULATION (MANUAL VALVES)

OTHER POSSIBLE ACTIONS -

REPAIR CORE SPRAY SYSTEM COMPONENTS IN SCREENHOUSE.

REPAIR POST INCIDENT SYSTEM COMPONENTS IN CORE SPRAY HEAT EXCHANGER ROOM.

OPEN MANUAL VALVE IN CORE SPRAY HEAT EXCHANGER ROOM SHOULD MOV FAIL.

SWITCH STRAINER IN B/A T STRAINERS

SWITCH LOADS SHOULD O. POWER BE LOST AND

CONNECT STANDBY EDG

SUMMARY OF SHIELDING ISSUE

- NO ADDITIONAL SHIELDING IS REQUIRED TO SATISFY NUREG-0737
- RESULTS OF BASELINE PRA WILL NOT BE SIGNIFICANTLY AFFECTED BY ADDTION OF SHIELD WALL OR LOCAL SHIELDING
- POTENTIAL LOCAL SHIELDING REQUIRED FOR PLANT MODIFICATION WILL BE ADDRESSED IN THE DETAILED MODIFICATION DESIGN PACKAGE
- POTENTIAL FOR FURTHER REDUCTION IN THE DOSE OBTAINED FROM INGRESS OR EGRESS WILL BE CONSIDERED

RESULTS

ALL AREAS CONTINUOUSLY OCCUPIED; < 5 REM.

ALL AREA INFREQUENTLY OCCUPIED
(INCLUDES SHORT AND LONG ACTION); < 25 REM.

INHALATION DOSES IN CONTINUOUSLY OCCUPIED
AREA; < 0.1 REM TO THE THYROID
(POTASSIUM IODINE PILLS TAKEN, REALISTIC IODINE
RELEASE-A FACTOR OF 1000 LESS THAN NOBLE GAS RELEASE)

FILL OIL TANKS; < 25 REM

INGRESS AND EGRESS; < 12 REM WORST CASE - 0-7 REM TYPICAL

INVOLVE ONLY LONG TERM MAINTENANCE ACTIVITIES AND ARE NOT
REQUIRED TO BE PERFORMED.

SCREENHOUSE - TO FIX COMPONENTS OF CORE SPRAY SYSTEM (FIRE
PROTECTION SYSTEM) PRIOR TO RDS IF THE NEED ARISES;
DOSE > 25 REM (MORE DETAILS FURTHER BACK)

CORE SPRAY HEAT EXCHANGER ROOM - TO FIX COMPONENTS OF THE
POST INCIDENT SYSTEM PRIOR TO RECIRCULATION, IF THE NEED
ARISES; DOSE > 25 REM (MORE DETAILS FURTHER BACK)

ACTION

REVIEWED RISK ASSESSMENT DOMINANT SEQUENCES

REVIEWED TIME TO CORE MELT VS CORE SPRAY FAILURE
AND PIS FAILURE

CORE SRPAY FAILURES - CANNOT SIGNIFICANTLY AFFECT
SYSTEM FAILURE PROBABILITY PRIOR TO CORE MELT

PIS FAILURE - CAN SIGNIFICANTLY AFFECT SYSTEM FAILURE
PROBABILITY PRIOR TO CORE MELT FOR NON-BREAK SCENERIOS
(17 HOURS UNTIL CORE MELT FROM INITIAL LTC ACTION)

HOWEVER DOMINANT SEQUENCES WITH PIS FAILURE MAKE UP ONLY
 $2.4E-4$ OF THE $9.8E-4$ MELT PROBABILITY

SO FIXING PIS WOULD NOT SIGNIFICANTLY AFFECT TOTAL CORE
MELT PROBABILITY

AS A RESULT SHIELDING WILL NOT BE PLACED IN THESE AREAS
UNLESS AS A RESULT OF THE REVIEW OTHER ISSUES ARE RAISED

RMMARUSICH
3/17/81

TYPICAL ACCIDENT SCENERIO

LOSS OF OFFSITE POWER

SCRAM

EMERGENCY POWER ACTIVATION

MSIV'S CLOSE (ON LOSS OF AC)

EMERGENCY CONDENSER TRIED TO REMOVE DECAY HEAT BUT IT FAILS
RESULTS IN RAPID PRESSURIZATION.

PRESSURE CONTINUES TO RISE UNTIL SAFETY VALVE SETPOINT IS
REACHED.

SAFETIES OPEN PLANT COOLING WITH FEED AND BLEED BUT SPHERE IS
FILLING WITH WATER.

MUST USE CORE SPRAY/RDS, IF THIS FAILS, NO COOLING AND CORE
MELTS.

IF RDS/CORE SPRAY GOES, NEED LONG TERM COOLING.

IF LONG TERM COOLING FAILS, CORE WILL MELT LATER.

	<u>RDS/CORE SPRAY FAILURE</u>	<u>LTC FAILURE</u>
CORE GAP RELEASED (RDS)	5.9 HRS	5.9 HRS
CORE MELT STARTED	6.3 HRS	40 HRS
MELT 80%	11.5 HRS	46 HRS

RMMARUSICH
3/17/81

CALCULATIONS

CONTROL ROOM, TSC ELECTRICAL EQUIPMENT ROOM (720 HRS CONTINUOUS)

DAMPER CLOSED BY PROCEDURE ON HIGH AREA MONITOR ALARM AT 0.09 MR/HR
(5CFM LEAK)

SHINE FROM CONTAINMENT < 5 REM FOR ISOLATED CONTAINMENT CASE.

SHINE FROM AIRBORNE CLOUD < 1 REM FOR NONISOLATED CASE.

SAMPLE ANALYSIS AREA

SHINE FROM T=1 HR 27 R/HR

CONTAINMENT 5HR 6.3 R/HR

(ISOLATED) 24 HR 0.7 R/HR

SHINE FROM AIRBORNE RELEASE < 5 REM OVER 720 HOURS

FILL OIL TANKS, START STANDBY EDG < 25 REM

INGRESS & EGRESS

(WORST CASE - LARGE LOCA)

<u>TIME (FROM INITIATION</u>	<u>DOSE RATE R/HR</u>	<u>DOSE RECEIVED (USING 36 SECOND ENTRY TIME)</u>
0	0	0
15 MIN	30 R/HR	0.3 REM
1 HR	1275 R/HR	12.75 REM
2 HR	1087 R/HR	10.87 REM
8 HR	435 R/HR	4.35 REM
24 HR	120 R/HR	1.20 REM

TYPICAL CASE - LOSS OF OFFSITE POWER - CS FAILS

0	0	0
1.75 HR	0	0
2.25 HR	11.25 R/HR	0.11 REM
4.24 HR	675 R/HR	6.75 REM
8 HR	405 R/HR	4.05 REM
24 HR	108 R/HR	1.08 REM

TYPICAL CASE - LOSS OF OFFSITE POWER - PIS FAILS

0	0	0
5.9 HR	0	0
8 HR	4.05 R/HR	0.04 REM
24 HR	1.5 R/HR	0.015 REM
46 HR	67.5 R/HR	0.675 REM

RMMARUSICH
3/17/81

PROBLEM AREAS

SCREEN HOUSE

<u>TIME AFTER TRIP, HR</u>	<u>MELT RELEASE</u>
T=1	2834 R/HR
5	667
24	77.5
720	16.2

CORE SPRAY HEAT EXCHANGER ROOM

<u>TIME (AFTER TRIP, HR)</u>	<u>SHINE FROM CONTAINMENT</u>		<u>INSIDE ROOM</u>
	<u>ROOM DOSE RATE R/HR</u>	<u>NEAR PUMP DOSE RATE R/HR</u>	<u>GENERAL FIELD R/HR</u>
T=1	426	4260	1239
5	46.8	468	771
24	4.9	48.8	161
720	1.8	18.1	6.2

NUREG 0737 ITEMS

AFFECTED BY PRA

DIRECT AFFECT

POTENTIAL AFFECT

II.B.2 ^{1/1/82} DESIGN REVIEW OF PLANT SHIELDING AND ENVIRONMENTAL QUALIFICATION OF ELECTRICAL EQUIPMENT FOR SPACES/SYSTEMS WHICH MAY BE USED IN POST-ACCIDENT OPERATIONS

II.B.3 ^{1/1/82} POST-ACCIDENT SAMPLING CAPABILITY

II.F.2 ^{1/1/82} INSTRUMENTATION FOR DETECTION OF INADEQUATE CORE COOLING

II.K.3.14 ^{1/1/82} ISOLATION OF ISOLATION CONDENSERS ON HIGH RADIATION

II.K.3.19 ^{7/1/81} INTERLOCK ON RECIRCULATION PUMPS LOOPS

III.A.1.2 ^{7/80} UPGRADE EMERGENCY SUPPORT FACILITIES (NUREG-0696)

III.D.3.4 ^{1/82} CONTROL ROOM HABITABILITY

I.A.1.3 SHIFT MANNING

I.C.1 ^{7/1/82} ^{1/1/82} GUIDE FOR EVALUATION AND DEVELOPMENT OF PROCEDURES FOR TRANSIENTS AND ACCIDENTS

I.D.1 ^{7/80} CONTROL ROOM DESIGN REVIEWS

I.D.2 ^{7/80} SAFETY PARAMETER DISPLAY

II.B.1 ^{7/1/82} REACTOR COOLANT SYSTEM VENTS

II.D.1 ^{7/1/81} PERFORMANCE TESTING OF BWR AND PWR RELIEF AND SAFETY VALVES

II.F.1 ^{1/1/82} ATT.5 CONTAINMENT WATER LEVEL MONITOR

II.K.3.20 ^{7/1/81} LOSS OF SERVICE WATER FOR BIG ROCK POINT


II.K.3.25 ^{1/1/82} EFFECT OF LOSS OF ALTERNATING CURRENT POWER ON PUMP SEALS

II.K.3.44 ^{1/1/81} EVALUATION OF ANTICIPATED TRANSIENTS WITH SINGLE FAILURE TO VERIFY NO FUEL FAILURE

III.A.2 ^{1/1/82} IMPROVING LICENSEE EMERGENCY PREPAREDNESS LONG TERM (NUREG-0654/FEMA-REP-1)

ACCIDENT CONSEQUENCE ANALYSIS

RACAP CODE NETWORK



CUMULATIVE NUMBER OF PEOPLE

4000

3000

2000

1000

0

BIG ROCK POINT
POPULATION IN TWO
MOST POPULOUS SECTORS

0

2


4


6

8

10

DISTANCE FROM THE SITE (MILES)






TURBINE BUILDING


REACTOR BUILDING

Section 4



REACTOR VESSEL SCHEMATIC

POOR ORIGINAL



APPI
FOR COA

EMERGENCY CONDENSER SYSTEM

POOR ORIGINAL

SEE FIG. II
for Details





FIG. 6J


POOR ORIGINAL




SODIUM PENTABORATE IN SOLUTION:
MIN. 19% - MAX. 30% (WT.)

INJECTION GAS PRESSURE:
HEAD OFF = 500 PSIG
HEAD ON PSIG @ 1350 PSIG


POISON WORTH:
5-MIN INJECTION, 1300 ppm = 16% ΔK_{eff}
TOTAL INJECTION, 2000 ppm = 25% ΔK_{eff}



AUTO-CONTROL FROM REACTOR PUMPS. CONTROL UPON WHEN SUITS P.I.E. ON.




SCALE	DESIGN	LOGGED
NONE	RES.	DRM
SIB ROCK POINT PLANT CONSTRUCTION DEPT. 441 CONSTRUCTION POWER DIVISION		
LIQUID POISON SYSTEM		
REF. DWG. NO.		
0740640107		REV. C.
0740640121		REV. C.



(LS) - LEVEL SENSING SCHEME


POOR ORIGINAL

POOR ORIGINAL



POOR ORIGINAL

EMERGENCY CORE SPRAY AND REDUNDANT CORE SPRAY SYSTEMS



C-6: MATERIAL SS 304
PRIMARY RATING 1500 psig @ 1000° F

E-11: MATERIAL CARBON STEEL
PRIMARY RATING 150 psig @ 500° F

A-7: MATERIAL CARBON STEEL
PRIMARY RATING 1500 psig @ 850° F




FIGURE QUALITATIVE COMPARISON OF BIG ROCK POINT
RISK WITH DECISION RULES PROPOSED IN NUREG-0739

LIMITS ON OCCURRENCE OF HAZARD STATE				
HAZARD STATE	DECISION RULE ON MEAN FREQUENCY		BIG ROCK POINT PRE-MOD. STATUS	BIG ROCK POINT POTENTIAL POST MOD. STATUS
	GOAL LEVEL	UPPER LIMIT		
SIGNIFICANT CORE DAMAGE	$<3 \times 10^{-4}/\text{RY}$	$<1 \times 10^{-3}/\text{RY}$	BELOW GOAL $1 \times 10^{-3}/\text{YR}$ AT LIMIT	BELOW GOAL 8.4×10^{-5} BELOW GOAL
LARGE SCALE FUEL MELT (LSFM)	$<1 \times 10^{-4}/\text{RY}$	$<5 \times 10^{-4}/\text{RY}$	ABOVE ABOVE LIMIT $1 \times 10^{-3}/\text{YR}$	BELOW GOAL 8.4×10^{-5}
LARGE SCALE UNCON- TROLLED RELEASE FROM CONTAINMENT (GIVEN LSFM) (1)	<0.01	<0.1	ABOVE LIMIT ~ 0.4	BETWEEN GOAL AND LIMIT FOR MOST SEQUENCES (1) ABOVE LIMIT ~ 0.3 (INCLUDING LEAKAGE)

(1) THIS DECISION SEEMS TO BE ARBITRARY, OPEN TO INTERPRETATION, AND LIKELY UNACCEPTABLE BECAUSE IT IS SO STRONGLY RELATED TO THE SEQUENCE CHARACTERISTICS AND INDEPENDENT OF THE SEQUENCE PROBABILITY.

FIGURE QUALITATIVE COMPARISON OF BIG ROCK POINT
RISK WITH DECISION RULES PROPOSED IN NUREG-0739

LIMITS ON RISK TO MOST EXPOSED INDIVIDUAL (1)

<u>PROBABILITY GOAL</u>	<u>DECISION RULE ON MEAN FREQUENCY PER SITE-YEAR</u>		<u>BIG ROCK POINT PRE-MOD. STATUS</u>	<u>BIG ROCK POINT POTENTIAL POST-MOD. STATUS</u>
	<u>GOAL LEVEL</u>	<u>UPPER LIMIT</u>		
INDIVIDUAL PROBABILITY OF DELAYED CANCER DEATH (MOST EXPOSED PERSON)	$<5 \times 10^{-6} / \text{SITE-YEAR}$	$<2.5 \times 10^{-5} / \text{SITE-YEAR}$		
PROBABILITY OF EARLY DEATH (MOST EXPOSED PERSON)	$<1 \times 10^{-6} / \text{SITE-YEAR}$	$<5 \times 10^{-6} / \text{SITE-YEAR}$	BELOW GOAL	BELOW GOAL

(1) DECISION RULES ON MEAN FREQUENCY PER LARGE SCALE FUEL MELT HAVE NOT YET BEEN ESTIMATED.

(FIGURE QUALITATIVE COMPARISON OF BIG ROCK POINT
RISK WITH DECISION RULES PROPOSED IN NUREG-0739

<u>SOCIETAL HEALTH RISK LIMITS</u>				
<u>MEASURE OF RISK</u>	<u>DECISION RULES</u>		<u>BIG ROCK POINT PRE-MOD. STATUS</u>	
	<u>GOAL LEVEL</u>	<u>UPPER LIMIT</u>		<u>BIG ROCK POINT POTENTIAL POST- MOD. STATUS</u>
EXPECTED VALUE OF DELAYED CANCER DEATHS	<2 PER 10^{10} kWh	<10 PER 10^{10} kWh	BELOW GOAL	BELOW GOAL
EXPECTED FREQUENCY OF EARLY DEATHS (RAISED TO THE 1.2 POWER)	<0.4 PER 10^{10} kWh	<2 PER 10^{10} kWh	BELOW GOAL	BELOW GOAL

DATA COLLECTION FOR THE
BIG ROCK POINT NUCLEAR PLANT RISK ASSESSMENT

- PLANT SPECIFIC DATA COLLECTED FOR USE IN BIG ROCK POINT FAULT TREE QUANTIFICATION
- DATA USED TO DETERMINE COMPONENT FAILURE RATES, MAINTENANCE AND TEST UNAVAILABILITIES, REPAIR AND RESTORATION TIMES, AND OPERATOR ERROR PROBABILITIES
- SOURCES OF PLANT SPECIFIC DATA
 - (1) Plant Maintenance Orders - plant MO's provided information on the cause of component failure and the time to accomplish repairs. The data was used to compute failure rates, failure modes and repair times.
 - (2) Control Room Log Books - CRLB's are the daily operating history of the plant. They provide a history of the operation of equipment and actions taken by the operator during plant operations. From this source, data on equipment operation and outages, failure modes and failure rates can be obtained
 - (3) Surveillance Tests- SRVT's are procedures by which safety related components and instrumentation can be tested against standards of normal operation. Information on failure rates, component operating history and test and maintenance unavailabilities can be obtained.
 - (4) Licensee Event Reports, Event Reports, Deviation Reports, Plant Review Committee Meeting Minutes and NRC Correspondence - from these documents additional component failure information was obtained. They also provided additional insight on failures found in other sources which did not elaborate on the causes.
- DATA GATHERED FOR TEN-YEAR PERIOD 1970-1979

DETERMINATION OF COMPONENT FAILURE RATES

- COMPONENT FAILURE MODES SUMMARIZED FROM DATA
- COMPONENT DEMANDS AND OPERATING TIMES DETERMINED FROM DATA SOURCES
- ABOVE INFORMATION COMBINED TO DETERMINE COMPONENT FAILURE RATES

SUMMARY OF BIG ROCK POINT COMPONENT FAILURES AND OUTAGES
EMERGENCY DIESEL GENERATOR

<u>DATE</u>	<u>COMPONENT</u>	<u>DESCRIPTION</u>	<u>SOURCE</u>	<u>FAILURE MODE</u>
11/15/74	Emergency diesel generator	Tagged out; 1 hour	CRLB155	
11/22/74	Emergency diesel generator	Replaced fuel transfer pump; outage 2 hours	M074EPS527 M074EPS32413 CRLB151	
12/5/74	Emergency diesel generator	Selector switch to off; 15 minutes	CRLB156	
4/10/75	Emergency diesel generator	Failed to start; started after hand priming; approximately 30 minutes	A0-9-75	[1]
7/17/75	Emergency diesel generator	Tagged out; 1 hour	CRLB163	
3/24/76	Emergency diesel generator	Tripped on high temperature; inlet screen plugged; estimated outage 9 hours	BRP1-050155-032476	FT0
5/13/76	Emergency diesel generator	Tripped after running 1 hour and 15 minutes on high temperature; cleaned suction screen; outage 9 hours	BRP1-050155-051676 M076EPS12806	FT0
5/17/76	Emergency diesel generator	No indication of cooling water flow after start; diesel shutdown; repacked coolant pump; cleaned suction screen; outage 12.5 hours	CRLB173 BRP1-050155-057877 M076EPS13806 M076EPS13901	FT0
6/5/76	Emergency diesel generator	No voltage indication; outage 6.5 hours	CRLB173 M076EPS1009	FTS
8/5/76	Emergency diesel generator	Did not start within 15 seconds; not retested to see if it would start	ER-B-76-22	FTS
8/12/76	Emergency diesel generator	Failed to start; battery cable burned off; outage 1 hour	ER-B-76-22 M076EPS22508	FTS

SUMMARY OF BIG ROCK POINT COMPONENT FAILURES AND OUTAGES
PUMPS

<u>DATE</u>	<u>COMPONENT</u>	<u>DESCRIPTION</u>	<u>SOURCE</u>	<u>FAILURE MODE</u>
7/6/73	#1 Control rod drive pump	Replaced relief valve; outage 1 hour	M073CRD408 CRLB137	
9/21/73	#1 Control rod drive pump	Tagged out; reason unknown; outage 4 hours	CRLB140	
9/24/73	#1 Control rod drive pump	Tagged out; 6.5 hours	CRLB140	
9/25/73	#1 Control rod drive pump	Tagged out; 11.5 hours	CRLB140	
9/27/73	#1 Control rod drive pump	Tagged out; 16.5 hours	CRLB140	
11/5/73	#1 Control rod drive pump	Relief valve lifting; valve replaced; outage 1 hour	CRLB414 M073CRD692	FT0
1/14/75	#1 Control rod drive pump	Leak in discharge elbow; outage 25 hours	M074CRD029 CRLB144	FT0
1/26/74	#1 Control rod drive pump	Repacked pistons; outage 4 hours	M074CRD058 CRLB144	
5/31/74	#1 Control rod drive pump	Pump packing blown; est. outage 1 hour	M074CRD33006	FT0
7/31/74	#1 Control rod drive pump	Packing leak; outage 3 hours	M074CRD419 CRLB152	
8/15/74	#1 Control rod drive pump	Broken valve spring replaced; outage 2.5 hours	M074CRD447	FT0

SUMMARY OF BIG ROCK POINT COMPONENT FAILURES AND OUTAGES
CONTROL VALVES

<u>DATE</u>	<u>COMPONENT</u>	<u>DESCRIPTION</u>	<u>SOURCE</u>	<u>FAILURE MODE</u>
5/27/77	CV4094	Failed to close during test	CRLB190	FTC
5/27/77	CV4095	Failed to close during test	CRLB190	FTC
10/10/79	CV4094 & CV4095	Failed leak rate test	Surv. test T180.01 part A	IL
3/31/75	CV4096	Failed to seat properly; packing misadjusted	AØ -8-75	IL
6/8/77	CV4096	Replaced limit switch	MØ77CIS15802	
1/5/78	CV4096 & CV4097	Failed pressure test	CRLB202	IL
1/26/74	CV4097	Flange leak; bolts tightened	BRP1-050155-042674	XL
3/21/75	CV4097	Failed to seat during test	MØ75CIS07901	IL
5/26/75	CV4097	Failed pressure test	AØ-14-75	IL
5/17/75	CV4097	Failed leak rate test	BRP1-050155-04177	IL
3/19/76	CV4097	Failed leak rate test	BRP1-050155-06197	IL
1/20/78	CV4097	Failed leak rate test	BRP1-050155-012078	IL
1/21/79	CV4097	Failed to open on first attempt; opened on second	MØ78CIS02303 D-BRP-78-09	FTØ
1/25/79	CV4097	Spurious closure; failed to reopen	MØ78CIS02506	FTRØ

SUMMARY OF BIG ROCK POINT COMPONENT FAILURES AND OUTAGES

MOTOR OPERATED VALVES

<u>DATE</u>	<u>COMPONENT</u>	<u>DESCRIPTION</u>	<u>SOURCE</u>	<u>FAILURE MODE</u>
10/30/78	MØV7062 (Emergency Condenser Inlet Valve)	Failed to close by remote manual controller; valve stem cleaned	MØ78ECS30303	FTC
12/10/79	MØ7062	Valve failed to open after hand tightened against backseat; estimated outage 93 hours	E-BRP-79-41	FTØ
11/11/73	MØ7053 (Emergency Condenser Outlet Valve)	Emergency condenser outlet valve would not close	CRLB141	FTC
11/14/73	MØ7053	Would not close	CRLB141	FTC
4/5/73	MØ7053	Failed to open; adjusted packing	AØ-8-73	FTØ
6/5/78	MØ7053	Was inoperable after hand tightened against backseat; estimated outage 2184 hours	BRP1-050155-060578	
1/25/72	MØ7063 (Emergency Condenser outlet valve)	Failed to close; motor burned out after improperly set torque switch, motor replaced	March 3, 1972 letter to AEC CRLB117	FTC
10/23/75	MØ7063	Control pulled to stop for work on RE07B; 15 minutes	CRLB165	
11/11/75	MØ7056, 7057, 7058, 7059 (Shutdown cooling system primary and secondary valves)	Shutdown inlet and outlet valves control placed in pull to stop position; 3 hours	CRLB166	
8/27/77	MØ7051 (Core Spray Valve)	Failed to close	D-BRP-77-104	FTC

TABLE III-3

FAILURE RATES COMPUTED FROM BIG ROCK POINT SPECIFIC DATA

COMPONENT	FAILURE MODE	TOTAL FAILURES	TOTAL DEMANDS	TOTAL OPERATION	FAILURE RATE
Emergency Diesel Generator	failure to start	12	669	355	$1.79 \times 10^{-2}/d$
	failure to run	7			$1.97 \times 10^{-2}/hr$
CRD Pump	failure to run	13		67894	$1.91 \times 10^{-4}/hr$
Feedwater Pump	failure to start	4	297	119520	$1.34 \times 10^{-2}/d$
	failure to run	8			$6.69 \times 10^{-2}/hr$
Service Water Pump				87648	
Condenser Circulating Water Pump	failure to start	3	209	119520	$1.43 \times 10^{-2}/d$
	failure to run	3			$2.5 \times 10^{-2}/hr$
Demineralized Water Pump	failure to run	3		44820	$6.69 \times 10^{-2}/hr$
Reactor Cleanup Pump	failure to run	18		59760	$3.01 \times 10^{-2}/hr$
Shutdown Cooling Pump	failure to run	1		27888	$3.58 \times 10^{-2}/hr$
Condensate Pump	failure to start	1	462	119520	$2.16 \times 10^{-3}/d$
	failure to run	2			$1.67 \times 10^{-2}/hr$
Reactor Cooling Water Pump	failure to run	1		87648	$1.14 \times 10^{-2}/hr$
Fuel Pit Pump	failure to start	1	572	87648	$1.74 \times 10^{-3}/d$
	failure to run	11			$1.25 \times 10^{-2}/hr$
Electric Fire Pump	failure to start	2	355	399	$5.63 \times 10^{-3}/d$
Diesel Fire Pump	failure to start	1	326	146	$3.06 \times 10^{-3}/d$

TABLE III-3

FAILURE RATES COMPUTED FROM BIG ROCK POINT SPECIFIC DATA

COMPONENT	FAILURE MODE	TOTAL FAILURES	TOTAL DEMANDS	TOTAL OPERATION	FAILURE RATE
14. MSIV (M27050)	failure to close	2	52		$3.84 \times 10^{-2}/d$
15. CV4014 (Turbine Bypass Valve)	failure to open	4	28		$1.42 \times 10^{-1}/d$
16. Control Valves	failure to open	16	750		$2.13 \times 10^{-2}/d$
	failure to close	16	671		$2.57 \times 10^{-2}/d$
	failure to remain open	4		66 @ 59760	$1.01 \times 10^{-6}/hr$
	failure to remain closed	3		66 @ 59760	$7.6 \times 10^{-7}/hr$
17. Motor Operated Valves	failure to open	7	989	21 @ 59760	$7.07 \times 10^{-3}/d$
	failure to close	10	639		$1.56 \times 10^{-2}/d$
	failure to remain closed	1		<u>1254970</u>	$8.81 \times 10^{-7}/hr$
18. Core Spray Valves (M27051, 7061, 7070, & 7071)	failure to open	3	230	4 @ 59760	$1.3 \times 10^{-2}/d$
				<u>158832</u>	
19. Emergency Condenser Valves	failure to open	2	125		$1.6 \times 10^{-2}/d$
20. Isolation Valves (CV4025, 4027, 4031, 4091, 4092, 4093, 4094, 4095, 4096, 4097, 4102, 4103, 4117, 4200, M27080, 7065, 7067, VFW9, VRW304)	failure to isolate	19	227		$8.37 \times 10^{-2}/d$
	failure of leak test	16	160		.10/d
21. RDS Isolation Valve	failure to open	1	215	15240	$4.65 \times 10^{-3}/d$

GENERIC DATA USED IN
BIG ROCK POINT RISK ASSESSMENT

- GENERIC DATA WAS USED WHERE PLANT SPECIFIC DATA WAS EITHER UNAVAILABLE OR CONSIDERED INAPPROPRIATE
- SOURCES OF GENERIC DATA
 - (1) WASH-1400, REACTOR SAFETY STUDY, AUGUST 1974
 - (2) GE RECOMMENDED FAILURE RATES, GE-22A2589, MAY 1974
 - (3) IEEE-500, COMPONENT RELIABILITY DATA, 1977
 - (4) NUREG/CR-1363, DATA SUMMARIES OF LER's, JUNE 1980
 - (5) NUREG/CR-1205, DATA SUMMARIES OF LER's OF PUMPS, JANUARY 1980
- ENGINEERING JUDGEMENT USED TO DETERMINE RECOMMENDED VALUE FOR A PARTICULAR COMPONENT

Table III-4a
GENERIC DATA - VALVES

EVENT IDENTIFICATION	1. WASH 1400		2. GE	3. IEEE-500 ⁽¹⁾	4. CRNL-704 ⁽²⁾	5. AI ⁽³⁾	6. EGG		* Recommended	
	λ ⁽⁴⁾	Q ⁽⁵⁾					λ	λ	Q	λ
VALVES										
Motor Operated(MOV)										
FTO	-	1.0	1.5	2.5			1.0	-	1.5	1.0
FTC	-	1.0	1.6	2.5	[L=0.5]	[3.4]	0.8	-	1.6	1.0
FTRO	-	0.1	0.15	0.124	[U=30]		-	-	0.15	0.1
FTRC	-	0.1	0.16	0.124			-	-	0.16	0.1
Safety										
FTO	-	0.01	1.1	-	[L=1]	[11.4]	-	8/d ⁽⁶⁾	1.1	8
FTC	-	-	2.7	-	[U=10]		3.0	-	2.7	1.2 ⁽⁷⁾
FTRC	10	-	0.42	-			-	3/d	0.42	-
Check										
FTO	-	0.1	0.16	-	[L=0.7]	[2.3]	0.08	0.1	0.08	0.1
FTC	-	-	-	-	[U=10]		0.3	0.5	0.3	0.5
Reverse Leak	0.3	-	1.6	-			0.5	-	0.5	-
Diaphragm										
FTO	-	0.3	2.1	-	-	[2.0]	1.0	-	2.1	0.3
FTC	-	0.3	2.1	-	-		0.8	-	2.1	0.3
FTRO	-	0.1	-	-	-		-	-	(0.15)	0.1
FTRC	-	0.1	-	-	-		-	-	(0.16)	0.1
Solenoid(SOV)										
FTO	-	1.0	-	3.9			1.0	-	3.9	1.0
FTC	-	1.0	-	3.9	[L=1]		0.8	-	3.9	1.0
FTRO	-	-	0.15	0.14	[U=40]		-	-	0.15	(0.1)
FTRC	-	-	0.15	0.14			-	-	0.15	(0.1)

- (1) IEEE-500 data applies to actuation only
 (2) CRNL-704 data includes upper(U) and lower(L) bounds; brackets indicate rate is for all failure modes
 (3) AI data rates are for all failure modes (hence brackets)
 (4) λ is hourly failure rate, number indicates failures per million hours
 (5) Q is demand failure rate, number indicates failures per thousand demands
 (6) Value for BWR relief valves
 (7) From CE data

* Recommended if the data were to be applied to BWR; out, in most cases, actual BWR data were used.

MAINTENANCE AND TEST UNAVAILABILITIES
USED IN BIG ROCK POINT RISK ASSESSMENT

- MAINTENANCE PHILOSOPHY AT BIG ROCK POINT IS TO REPAIR PROBLEMS AS THEY OCCUR
- ONLY MAINTENANCE OUTAGES WHICH OCCURRED WHILE THE PLANT WAS AT FULL POWER WERE CONSIDERED
- NO TEST UNAVAILABILITIES OF SAFETY SYSTEMS DURING FULL POWER OPERATION

TABLE III-5

MAINTENANCE UNAVAILABILITIES
COMPUTED FROM THE BIG ROCK POINT SPECIFIC DATA


COMPONENT	NUMBER OF COMPONENTS	TOTAL OUTAGE	MAINTENANCE UNAVAILABILITY
1. Emergency Diesel Generator	1	180	3.01×10^{-3}
2. CRD Pump	2	380	3.17×10^{-3}
3. Feedwater Pump	2	127	1.06×10^{-3}
4. Service Water Pump	2	24	2.0×10^{-4}
5. Condenser Circulating Water Pump	2	285	2.4×10^{-3}
6. Demineralized Water Pump	1	434	7.26×10^{-3}
7. Reactor Cleanup Pump	1	117	1.95×10^{-3}
8. Shutdown Cooling Pump	2	61	5.1×10^{-4}
9. Condensate Pump	2	58	4.85×10^{-4}
10. Reactor Cooling Water Pump	2	192	1.60×10^{-3}
11. Fuel Pit Pump	2	4.5	3.76×10^{-5}
12. Electric Fire Pump	1	48	8.03×10^{-4}
13. Diesel Fire Pump	1	8	1.33×10^{-4}
14. CV4014 (Turbine Bypass Valve)	1	151	2.52×10^{-3}
15. Motor Operated Valves	21	85	7.49×10^{-5}
16. Core Spray Valves (M070F., 7061, 7070 & 7071)	4	10	$6.2 \times 10^{-5}/\text{valve}$
17. Emergency Condenser Valves	4	2277	9.5×10^{-3}

HUMAN ERROR PROBABILITIES
USED IN BIG ROCK POINT RISK ASSESSMENT

- MANY BACKUP SYSTEMS REQUIRE OPERATOR ACTION TO FUNCTION
- USED SWAIN AND GUTTMANN'S "HANDBOOK OF HUMAN RELIABILITY WITH EMPHASIS ON NUCLEAR POWER PLANT APPLICATIONS" AS FOUNDATION
- FACTORS WHICH DETERMINE HUMAN ERROR PROBABILITIES
 - (1) EXPERIENCE
 - (2) TRAINING
 - (3) ADEQUATE PROCEDURES
 - (4) STRESS
- MANY HUMAN ERROR PROBABILITIES USED IN BRP RISK ASSESSMENT HAD TO BE EVALUATED AS A FUNCTION OF TIME

Figure III. 2

Probability of failure to enter containment to open valve VEC-1 vs. time prior to safety valve actuation (in hours) at which possible need to open VEC-1 is recognized






Figure III-3 Estimation of Failure to Initiate Liquid Poison Given an ATWS

TABLE III-7
 SUMMARY OF HUMAN ERROR PROBABILITIES FOR BIG ROCK POINT

1. Operator performs an action for which there is no reason, i.e., closing a normally open valve necessary for flow or opening a normally closed circuit breaker necessary for power
 1×10^{-4}
2. Operator fails to open an MOV or start a pump when this action is necessary for successful system operation, a procedure is available, and location is familiar
 1×10^{-3} (low stress)
 2×10^{-3} (moderate stress)
3. Operator fails to return valves or components to service following maintenance or test
 1×10^{-3}
4. Operator fails to open an MOV, start a pump or close a circuit breaker when location is unfamiliar or not frequently used
 3×10^{-3} (low stress)
 6×10^{-3} (moderate stress)
5. Operator fails to close circuit breaker after LOSP when procedure is available but vague but sufficient indicators are available to alert him to action
 1×10^{-2}
6. Operator fails to shed loads and place demin. pump in operation when procedure is vague following LOSP.
 0.25
7. Operator fails to enter containment and open fire water valve for emergency condenser makeup
 See Figure III.2
8. Operator fails to place standby diesel generator in service before RDS operation takes place following a failure of the emergency diesel generator
 See Figure III.5
9. Operator fails to shed loads and place control rod drive pump on diesel generator with defined procedures following LOSP

REPAIR AND RESTORATION TIMES
USED IN BIG ROCK POINT RISK ASSESSMENT

- CUMULATIVE REPAIR DISTRIBUTIONS FORMULATED FROM BRP MAINTENANCE DATA
- REPAIR DATA FOR EMERGENCY DIESEL GENERATOR USED IN EVENT TREE QUANTIFICATION
- RESTORATION OF OFFSITE POWER USED IN EVENT TREE QUANTIFICATION



Figure III-6. Log Normal Distribution Fit to the Emergency Diesel Generator Data.




Figure III-7. Log Normal Distribution Fit to the Pump Repair Data

Table III-11

RAW DATA FOR LOSS OF OFFSITE POWER AT
THE BIG ROCK POINT SITE

DATE	DURATION (MINUTES)	
	46 KV LINE	138 KV LINE
5/2/69	< 5	
6/26/69	< 5	
8/4/69	< 5	
10/19/69	619	
7/8/70	< 5	
9/11/70	< 5	
10/2/70	< 5	
11/19/70	< 5	
12/3/70		(1)
8/22/71	187	
9/28/71	< 5	< 5
1/25/72	119	20
6/1/72	61	
11/3/72	< 5	
11/7/72		< 5
5/21/74	< 5	
7/22/75	< 5	
12/8/75	< 5	
2/2/76	596	
3/12/76	10	
5/5/76		< 5
10/21/76	< 5	
8/31/77		201
4/6/78		63
4/17/78		142
5/31/78		8
4/6/79		1329
4/12/79	75	
5/8/79	817	
9/26/79		< 5
10/10/79	94	

(1) Nine power interruptions occurred on this date.




Figure III-8. Gamma Distribution Fit to the Restoration of Offsite Power Data.

COMMON CAUSE FAILURE ANALYSIS: METHODOLOGY

I. IDENTIFICATION OF COMMON MODE MECHANISM

- A. "LIKE" VS. "UNLIKE" COMPONENTS
- B. SUSCEPTIBILITY TO COMMON CAUSE
- C. OPPORTUNITY FOR COMMON CAUSE FAILURE

II. QUANTIFICATION

A. "LIKE" COMPONENTS

- 1. CONSERVATIVE FILTER - 10% COUPLING FOR ALL REDUNDANT COMPONENTS, SUBSYSTEMS, OR SYSTEMS

[NUCLEAR TECHNOLOGY, VOL. 46, DECEMBER 1979]

2. EXTERNAL EVENTS

B. "UNLIKE" COMPONENTS

- 1. EXTERNAL EVENTS

III. INTEGRATION INTO FAULT TREE AND EVENT TREE MODELS

EXAMPLES OF
COMMON CAUSE FAILURE MECHANISMS

● INTERNAL - MANUFACTURER

LOCATION

TEST

MAINTENANCE

● EXTERNAL - FIRE

EARTHQUAKE

TORNADO

FLOOD

HIGH ENERGY LINE BREAK

CONTROL ROOM HABITABILITY (SMOKE, RADIATION)

AIRPLANE CRASH

HUMAN ERROR

DOMINANT COMMON MODE FAILURE MECHANISMS

- INTERNAL - MANUFACTURER

LOCATION

- EXTERNAL - FIRE

HIGH ENERGY LINE BREAK

UNCERTAINTY ANALYSIS

I. METHODOLOGY

A. DOMINANT SEQUENCES ANALYZED

1. DETERMINE ALL COMPONENTS OR EVENTS INCLUDED IN DOMINANT ACCIDENT SEQUENCES
2. DEVELOP A DOMINANT ACCIDENT SEQUENCE "FAULT TREE"

B. ASSUME PROBABILITY DENSITY FUNCTIONS (PDFs) FOR ALL EVENTS

C. PROPAGATE EVENT UNCERTAINTIES TO ARRIVE AT SEQUENCE (AND CDF) UNCERTAINTY

D. PERFORM PDF SENSITIVITY STUDY

II. PDFs

A. ENGINEERING JUDGEMENT, BASED UPON DATA SOURCE (I.E. WASH-1400, EG&G, OR PLANT), AND/OR DATA POPULATION SIZE (SEVERAL TRIALS VS. FEW TRIALS)

B. PDFs CHOSEN FOR:

1. COMPONENTS - GENERIC (LOG-NORMAL, POISSON)
- PLANT SPECIFIC (BINOMIAL, POISSON, GAMMA, F)
2. HUMAN ERRORS OR ACTIONS - (NORMAL, LOG-NORMAL)
3. INITIATORS (LOG-NORMAL, POISSON, GAMMA)

III. PROPAGATION

A. USE METHOD OF MOMENT PROPAGATION

1. FIRST AND SECOND MOMENTS ABOUT THE ORIGIN
2. FASTER COMPUTER RUNNING TIME THAN MONTE CARLO METHOD, WITH SMALL ACCURACY LOSS
3. 95% CHEBYCHEV CONFIDENCE LIMIT IS CONSERVATIVE

- B. RESULTS ARE: MEAN, STANDARD DEVIATION, 95% CHEBYCHEV CONFIDENCE LIMIT (FOR NORMAL DISTRIBUTION)

IV. SENSITIVITY STUDY

- A. CHOOSE DIFFERENT PDFs FOR
 - 1. COMPONENTS OR EVENTS
 - 2. INITIATORS
- B. RESULTS INDICATE SENSITIVITY TO INITIATOR PDFs

PDF EXAMPLES

INITIATORS:

LOCA	LOG-NORMAL, EF = 20
LOSS OF FEEDWATER	LOG-NORMAL, EF = 10
FIRES	GAMMA

HUMAN ERRORS:

FAILURE TO TRANSFER DEMIN. PUMP TO 2B BUS	LOG-NORMAL, EF = 3
INADVERTANT OPENING/ CLOSING OF VALVE	LOG-NORMAL, EF = 10
FAILURE TO ENTER CONTAINMENT FOLLOWING DEMIN. PUMP FAILURE	NORMAL

COMPONENTS:

GENERIC - MOVs	LOG-NORMAL, EF = 3
SOLENOIDS	LOG-NORMAL, EF = 3
CHECK VALVES	POISSON

PDF EXAMPLES (CONTINUED)

COMPONENTS: (CONTINUED)

PLANT SPECIFIC - PUMP FAILS TO START	BINOMIAL
PUMP FAILS TO RUN	POISSON
VALVE FAILS TO REMAIN OPEN	GAMMA
MSIV FAILS TO CLOSE	F

RESULTS OF BRP PRA UNCERTAINTY ANALYSIS

CASE*	<u>MEAN</u>	<u>STANDARD DEVIATION</u>	<u>95% (CHEBYCHEV) CONFIDENCE LIMIT</u>	<u>EF ($\frac{95\%}{\text{MEAN}}$)</u>	
A	$9.85 \times 10^{-4} / \text{YR}$	4.4×10^{-3}	1.5×10^{-2}	15	BASE CASE
B	"	3.1×10^{-3}	1.1×10^{-2}	11	
C	"	1.8×10^{-3}	6.6×10^{-3}	6	
D	"	2.2×10^{-3}	7.9×10^{-3}	8	
E	"	1.5×10^{-2}	4.9×10^{-2}	49	
F	"	1.6×10^{-2}	5.3×10^{-2}	53	

*CASE A = LOG-NORMAL INITIATING FREQUENCIES (IFs) EXCEPT FIRE (GAMMA), EFs = 10, 20.
MIXED SPECTRUM FOR COMPONENT DISTRIBUTIONS

B = CASE A IFs, LOG-NORMAL COMPONENTS

C = LOG-NORMAL IFs (EXCEPT FIRE), EFs = 3, 10. CASE B COMPONENTS

D = LOG-NORMAL IFs (EXCEPT FIRE), LOCA EFs = 20, OTHERS ESTIMATED WITH $\chi^2_{0.95}$
CASE B COMPONENTS

E = χ^2 IFs (EXCEPT FIRE), CASE B COMPONENTS

F = CASE E IFs, CASE A COMPONENTS