



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

JRA

March 31, 1981

Docket No. 50-346

Mr. Richard P. Crouse
Vice President, Nuclear
Toledo Edison Company
Edison Plaza
300 Madison Avenue
Toledo, Ohio 43652



- References: (1) NRC letter dated January 7, 1980, To All Power Reactor Licensees Concerning Diesel Generator Fuel Oil
- (2) Toledo Edison Company letter Serial No. 611 dated April 18, 1980.

Dear Mr. Crouse:

In Reference (1), we requested that you include diesel generator (DG) fuel oil within your Quality Assurance Program or provide a justification for not doing so. In Reference (2) you responded to our request by stating that DG fuel oil was not covered within the Davis-Besse Quality Assurance Program, but that measures were in effect at the plant that meet the intent of Regulatory Guide 1.137, "Fuel Oil Systems for Standby Diesel Generators". You concluded, therefore, that it was not necessary to include DG fuel oil within the Quality Assurance Program.

We have reviewed your response and do not consider that you have proposed an acceptable alternative to our position stated in Reference (1). If you do not intend to include the DG fuel oil within your Quality Assurance Program, we consider that your current Technical Specifications regarding DG fuel oil should be revised to include the following requirements:

1. At least once per 92 days a sample of diesel fuel from each Emergency Diesel Generator Fuel Oil Storage Tanks be obtained in accordance with ASTM D270-65 and be within the acceptable limits specified in Table 1 of ASTM D975-74 when checked for viscosity, water, and sediment.
2. Immediately prior to transfer of the diesel fuel oil to an Emergency Diesel Generator Fuel Oil Storage Tank, a sample of fuel being transferred be obtained in accordance with ASTM D270-65 and be within the acceptable limits specified in Table 1 of ASTM D975-74 when checked for viscosity, water, and sediment.

8104100471


P

Mr. Richard P. Crouse

-2-

You are requested to comply with our position of Reference (1) or, in the alternative, propose a Technical Specification change to reflect the requirements stated above. You are requested to reply within 45 days of receipt of this letter.

Sincerely,

A handwritten signature in cursive script, reading "John F. Stolz". The signature is written in dark ink and is positioned above the typed name and title.

John F. Stolz, Chief
Operating Reactors Branch #4
Division of Licensing

cc:
See next page

Toledo Edison Company

cc w/enclosure(s):

Mr. Donald H. Hauser, Esq.
The Cleveland Electric
Illuminating Company
P. O. Box 5000
Cleveland, Ohio 44101

Gerald Charnoff, Esq.
Shaw, Pittman, Potts
and Trowbridge
1800 M Street, N.W.
Washington, D. C. 20036

Leslie Henry, Esq.
Fuller, Seney, Henry and Hodge
300 Madison Avenue
Toledo, Ohio 43604

Mr. Robert B. Borsum
Babcock & Wilcox
Nuclear Power Generation Division
Suite 420, 7735 Old Georgetown Road
Bethesda, Maryland 20014

Ida Rupp Public Library
310 Madison Street
Port Clinton, Ohio 43452

President, Board of County
Commissioners of Ottawa County
Port Clinton, Ohio 43452

Attorney General
Department of Attorney General
30 East Broad Street
Columbus, Ohio 43215

Harold Kahn, Staff Scientist
Power Siting Commission
361 East Broad Street
Columbus, Ohio 43216

Mr. Rick Jagger
Industrial Commission
State of Ohio
2323 West 5th Avenue
Columbus, Ohio 43216

Mr. Ted Myers
Manager, Nuclear Licensing
Toledo Edison Company
Edison Plaza
300 Madison Avenue
Toledo, Ohio 43652

U.S. Nuclear Regulatory Commission
Resident Inspector's Office
5503 N. State Route 2
Oak Harbor, Ohio 43449

Director, Criteria and Standards
Division
Office of Radiation Programs (ANR-460)
U. S. Environmental Protection Agency
Washington, D. C. 20460

U. S. Environmental Protection Agency
Federal Activities Branch
Region V Office
ATTN: EIS COORDINATOR
230 South Dearborn Street
Chicago, Illinois 60604

Ohio Department of Health
ATTN: Director of Health
450 East Town Street
Columbus, Ohio 43216