



Mr. Lester L. Kintner U. S. Nuclear Regulatory Commission 7920 Norfolk Avenue Bethseda, MD. 20014

Reference: Enrico Fermi Atomic Power Plant - Unit 2

NRC Docket Number 50-341

Subject: Supplemental Response to Item 110.17

Dear Mr. Kintner:

Detroit Edison will provide a supplemental response to item 110.17 in the next FSAR amendment as you requested. The supplemental response will be as follows:

"If a crack is detected in a jet pump hold-down beam, that beam will be replaced by one of a suitable material and design before returning to power operation."

Very truly yours,

W. F. Colbert Project Engineer Enrico Fermi 2

WFC:LES:ca

cc: L. E. Schuerman

M. L. Batch

E. Lusis

J. W. Honkala

J. E. Slyder (NUS, Rockville, MD.)

C. M. Johnson (GE, San Jose, CA.)

3001