

LICENSEE EVENT REPORT

CONTROL BLOCK: [] [] [] [] [] [] [] [] [] []

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | C | T | M | N | S | 2 | ⑦ | 0 | 0 | - | 0 | 0 | 0 | 0 | 0 | - | 0 | 0 | ③ | 4 | 1 | 1 | 1 | 1 | 1 | ④ | | | ⑤

7 8 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 31 32 33 34 35 36 37 CAT 58

CON'T

REPORT SOURCE L 6 0 5 0 0 0 3 3 6 7 0 3 1 2 8 1 6 0 4 0 2 0 1 1

60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | During routine operations, the A Safety Injection Tank (SIT) level transmitter was

0 3 | indicating normal level with the presence of a low level alarm. Subsequent investigation

0 4 | indicated that the transmitter was giving a false reading. Action Statement 3.5.1a

0 5 | was entered to allow repair. When re-energized the SIT level was found to be low at

0 6 | 53.8 per-cent. Operation continued under the Action Statement until level was restored

0 7 | to the 55 per-cent minimum. Total time in Action Statement- 48 m.n. Similar LERs

0 8 | 77-48, 79-26

SYSTEM CODE S F 11		CAUSE CODE E 12		CAUSE SUBCODE A 13		COMPONENT CODE I N S T R U 18		COMP. SUBCODE T 15		VALVE SUBCODE Z 16	
EVENT YEAR 8 1 21 22		SEQUENTIAL REPORT NO. 0 1 3 24 26		OCCURRENCE CODE 0 3 28 29		REPORT TYPE L 30		REVISION NO. 0 32		COMPONENT MANUFACTURER G 0 8 0 26	
ACTION TAKEN C 18 33		FUTURE ACTION Z 19 34		EFFECT ON PLANT Z 20 35		SHUTDOWN METHOD Z 21 36		HOURS 0 0 0 0 22 37 40		ATTACHMENT SUBMITTED N 23 41	
CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27		PRIME COMP. SUPPLIER N 25 43		NPRD-4 FORM SUB. Y 24 42		CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27		CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27		CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27	

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS	
1 0	The cause of the erroneous level indication was traced to a bad amplifier card
1 1	in the transmitter. The entire transmitter was replaced. The transmitter is a
1 2	GEMAC Model 555 D/P level transmitter with a 0-800 inch H ₂ O measurement range.
1 3	

1 4 7 8 9
FACILITY STATUS 28
POWER 1 0 0 29
OTHER STATUS 30 N/A
METHOD OF DISCOVERY 31 A
DISCOVERY DESCRIPTION 32 Operator Observation

ACTIVITY CONTENT
RELEASED OF RELEASE AMOUNT OF ACTIVITY (35)
1 6 2 33 4 34 N/A 44

LOCATION OF RELEASE (36)
N/A 45 80

PERSONNEL EXPOSURES									
NUMBER			TYPE	DESCRIPTION					
1	7	0	0	0	71	Z	3R	NA	

PERSONNEL INJURIES									
NUMBER				DESCRIPTION					
1	8	0	0	0	40	NA			

LOSS OF OR DAMAGE TO FACILITY					
TYPE		DESCRIPTION			
1	9	Z	(42)	NA	

80

NRC USE ONLY

PUBLICITY
 ISSUED DESCRIPTION (45) 8104170545
 2 0 [N] 11 NA 68 69 70

NRC USE ONLY