

WM. H. ZIMMER - UNIT 1
4130-00

SUMMARY OF EQUIPMENT
QUALIFICATION

8 104230512

TABLE OF CONTENTS

- TAB 1) ZIMMER EQUIPMENT QUALIFICATION PROGRAM
- A) INTRODUCTION
 - B) BACKGROUND
 - C) ASSESSMENT AND REQUALIFICATION PROCEDURES
 - D) VERIFICATION TEST PROGRAM
 - E) CONSERVATISMS
- TAB 2) OPERATING PROCEDURE SCENARIOS
- A) SCENARIO FOR MAINTAINING COLD SHUTDOWN
 - B) SCENARIO FOR MAINTAINING HOT STANDBY
 - C) TABLE IDENTIFYING EQUIPMENT REQUIRED FOR COLD SHUTDOWN, HOT STANDBY, AND POST LOCA
- TAB 3) COMPLETION SCHEDULE
- TAB 4) SUMMARY OF HARDWARE MODIFICATIONS RESULTING FROM REQUALIFICATION PROGRAM
- TAB 5) SUMMARY OF EQUIPMENT QUALIFICATION
- A) EQUIPMENT
 - B) HVAC DAMPERS
 - C) VALVES
 - D) INSTRUMENTATION

Introduction

The purpose of this report is to briefly summarize the philosophy, methodology, and procedures used in the dynamic qualification of the Zimmer balance of plant safety-related equipment. A more detailed presentation may be found in the Zimmer Formal Safety Analysis Report (FSAR) and in the Zimmer Design Assessment Report (DAR).

Background

The present Zimmer equipment qualification program has evolved through a period of eight years. The evolution has involved advancements in dynamic analysis and test methods, identification and refinement of additional dynamic loads to be considered, improvements in industry standards, and increased regulatory requirements. The definition of the dynamic loads, having the greatest impact on equipment qualification, has evolved through four stages to its present level.

Initially the dynamic load definition included only seismic loads, however in late 1974 the existence of additional dynamic loads began to be recognized. These new loads were associated with extended SRV discharge into the suppression pool. In late 1975, as a result of the efforts of the Mark II owners group and the NRC staff, the loads associated with a postulated SRV discharge event were defined, and subsequently the Zimmer equipment qualification program was revised to incorporate these new loads.

The next development occurred as a result of changing the type of SRV discharge device used from the ramshead to the T-quencher. This change was made in order to accomplish better heat transfer and thermal mixing in the suppression pool, but also resulted in changing the structural response of the Containment. In order to accommodate this change, the dynamic load definition for the Zimmer equipment qualification program was again revised to include this new SRV load definition. Also at this time the dynamic loads associated with a Loss Of Coolant Accident (LOCA) were incorporated into the load definition.

The final state in the evolution of the dynamic load definition occurred in mid 1980 when the spectra defining the dynamic loads were regenerated to incorporate refinements made by General Electric in their definition of the Mark II hydrodynamic loads.

As each new generation dynamic load definition was incorporated into the Zimmer equipment qualification program, an assessment

SARGENT & LUNDY
ENGINEERS
CHICAGO

was made of the equipment previously qualified. Where the assessment determined there were inadequacies the equipment was requalified and hardware modifications were made as required. For new equipment or equipment where the qualification had not been completed, the qualification was performed using the latest load definition. In addition, each stage of this assessment and qualification effort was performed using the latest industry standards and regulatory requirements.

Design Load Combinations

Itemized below are the load combinations used in the Zimmer equipment qualification program. Also identified are the appropriate damping values, service levels and the method used to combine the individual loads.

Load Combination	Damping Value	Service Level	Combination Method
1) N + OBE	1/2%	B*	ABS
2) N + SSE	1%	C*	ABS
3) N + OBE + Envelope (SRV _{ASY-TQ} SRV _{ALL-TQ})	1%	B	ABS
4) N + Envelope(OBE & SSE) + Envelope (SRV _{ASY-TQ} + SRV _{ALL-TQ}) + CHG	2%	C	ABS
5) N + Envelope(OBE & SSE) + Envelope (SRV _{ASY-TQ} + 0.6 SRV _{ALL-TQ}) + CO1	2%	C	ABS
6) N + Envelope(OBE & SSE) + Envelope (SRV _{ASY-TQ} + SRV _{ALL-TQ}) + CO2	2%	C	ABS
7) N + SQRT (SSE ² + AP ²)	2%	C	ABS

* these service levels reflect that combinations 1 and 2 are used for equipment not affected by the SRV and LOCA loads (equipment located outside of reactor building). Combinations 3 through 7 are used for equipment located in the primary containment and reactor building.

Assessment and Requalification Procedures

1) General Approach

The procedure used to assess the existing qualification documentation to determine the equipment adequacy for the additional hydrodynamic loads, consists of three steps.

- Step 1: Check the original qualification method to insure that all important issues have been addressed and that the original qualification is still in accordance with the latest applicable codes and standards.
- Step 2: Determine if the input used in the original qualification is sufficient to properly include the additional hydrodynamic loads. This includes both the increased frequency content and amplitude.
- Step 3: If the frequency range considered in the original qualification is less than the frequency content of the additional hydrodynamic loads, determine if there is sufficient margin in the input acceleration to account for the effect of the higher frequencies.

If the assessment demonstrated that the equipment is adequate for the additional hydrodynamic loads and that the qualification documentation is in proper order, then the component was considered qualified. If the assessment determined deficiencies or that further investigation was required, then the component was requalified. The method of requalification was generally dictated by the original qualification method. In most cases this involved simply supplementing the original qualification. However, a significant number of cases required complete re-analysis or retesting.

2) Procedure for Equipment Originally Qualified by Test

Basically there were four major concerns involving qualification by testing that have been addressed by the Zimmer equipment qualification program. These concerns are:

SARGENT & LUNDY
ENGINEERS
CHICAGO

- a) the increased frequency content and
- b) increased acceleration levels associated with the hydrodynamic loads
- c) the effect of cross-coupling and
- d) multimode response when the original qualification was single axis or single frequency.

A brief summary describing how these concerns have been addressed is provided below.

- a) For multiple frequency tests the increased frequency content was addressed by first determining whether the test response spectra (TRS) enveloped the required response spectra (RRS). In cases where the TRS did not envelope the RRS, the natural frequencies were compared against the exceedances. If no natural frequencies were found in the areas not enveloped, the component was considered qualified. However, in some cases the TRS was not plotted after 33 Hz or natural frequencies greater than 33 Hz were not determined. For these cases, the criterion for determining adequacy was: did the test input include sufficiently high acceleration levels to account for possible high frequency effects, or, based upon qualification of similar equipment, is this component sensitive to high frequencies. This criterion is to be verified by the Zimmer verification test program.

For single frequency tests the increased frequency content concern was addressed by determining if the test input included sufficiently high acceleration levels to account for possible high frequency effects, or by determining the sensitivity of the equipment to high frequencies. This determination was generally based upon the qualification results of similar equipment. The basis for making these determinations will be confirmed by the Zimmer verification test program.

- b) The increased acceleration levels associated with the hydrodynamic loads were addressed by determining if the test input acceleration bounded the increased acceleration levels.
- c) The cross-coupling concern for equipment qualified by single axis testing was addressed by determining whether the test input included sufficient margin to account for cross-coupling effects. The amount of margin required was based upon previous testing

SARGENT & LUNDY
ENGINEERS
CHICAGO

experience and found to be dependent upon:

- the relative rigidity of the equipment
- eccentricity of the center of gravity from the centroid of the mounting. This includes the eccentricity of locally mounted devices in the equipment as well as overall equipment eccentricity
- the sensitivity of mechanical linkages to cross-coupling

d) The effects of multi-mode response for single frequency testing was addressed by determining if there was sufficient margin in the test input acceleration to account for the participation of multiple modes. The amount of margin required was determined by examining the modal participation factors of similar equipment.

) Procedure for Equipment Originally Qualified by Analysis

For equipment originally qualified by analysis there were two major concerns, the increased frequency content and the increased acceleration levels associated with the hydrodynamic loads. These concerns were addressed by extending the analysis to include the effect of the higher frequencies, and when the additional hydrodynamic loads resulted in combined loads exceeding the design basis loads, the analysis was repeated using the new combined loads.

4) Use of SRSS

The above discussion summarizes the supplemental qualification efforts implemented on equipment identified by the assessment as either having qualification deficiencies or as requiring further investigation. As a result of these efforts one of the following actions has been or will be implemented:

- a) equipment classified as qualified
- b) equipment retested or reanalyzed
- c) hardware modifications made
- d) equipment replaced

However before hardware modifications were made or replacement was initiated the combining of the seismic and hydrodynamic loads by the square root of the sum of the squares (SRSS) method was considered. If sufficient load reduction

SARGENT & LUNDY
ENGINEERS
CHICAGO

was obtained, then modifications or replacement were not necessary. If the load reduction was not sufficient then the modifications made were based upon loads combined by the absolute sum (ABS) method.

VERIFICATION TEST PROGRAMS

I. In-situ Test Programs

A. In-situ Impedance Test Program

The purpose of this test program is to obtain the equipment natural frequencies in the range of 1-100 Hz, associated mode shapes and modal participation factors as well as damping and cross coupling parameters. It is intended to use these results to verify analytical techniques used for the equipment qualification and to supplement existing test qualification as needed. Nine pieces of equipment were chosen for the test program with the concurrence of the NRC-SQRT. These nine pieces comprise a representative sample of the types of equipment used in the Zimmer plant.

These pieces of equipment are:

- 1) 1E51C001 Reactor Core Isolation Cooling Pump
- 2) 1E51C002 Reactor Core Isolation Cooling Steam Turbine Assembly
- 3) 1H22P017 Reactor Core Isolation Cooling Instrument Panel
- 4) 1E51F010 6" Motor Operated Reactor Core Isolation Cooling Gate Valve
- 5) 1E12B001 Residual Heat Removal Heat Exchanger
- 6) 1E12F014A 16" Motor Operated Residual Heat Removal Butterfly Valve
- 7) 1VG05SA Standby Gas Treatment System Equipment Train
- 8) 1AP15EA 480 volt Reactor Building Motor Control Center 1A
- 9) 1WR01PA Reactor Building Closed Cooling Water Pump

The test was completed using different methods of excitations such as a hydraulic shaker, electromagnetic shaker

and calibrated hammers. The dynamic input was in the form of white noise (flat spectra), shaped spectra and impact. The points of measuring response were selected to construct a test model capable of detecting global and local modes.

B. In-Plant SRV Test Program

The purpose of this test program is to verify the predicted forcing function, structural response, the nature of the input to equipment and the accuracy of predicted equipment response during a safety relief valve discharge event.

Seven pieces of equipment have been chosen to be monitored during the test. They are:

- 1) 1E22C001 High Pressure Core Spray Pump
- 2) 1H22P017 Reactor Core Isolation Cooling Instrument Rack
- 3) 1E22F015 20" Motor Operated High Pressure Core Spray Gate Valve
- 4) 1AP1SEE 480 Volt Reactor Building Motor Control Center 1E
- 5) 1B33C001B Reactor Recirculation Pump
- 6) 1H22P027 Reactor Vessel Level and Pressure Instrument Rack
- 7) 1C41F001 3" Motor Operated Standby Liquid Control Globe Valve

II. Fatigue Evaluation

The impact of the extended duration of the hydrodynamic SRV and LOCA loads is assessed by analytical and testing techniques.

A. Analytical Approach

Two pieces of mechanical equipment which have been qualified by analysis will be selected and a detailed

fatigue analysis will be performed to calculate the cumulative usage factor.

B. Testing Approach

Selected pieces of equipment and instrumentation which are scheduled to be requalified by test are to be fatigue tested. This test will be conducted after the completion of qualification testing and will consist of extended duration segments designed to represent the hydrodynamic loads associated with the S/R valve actuation and LOCA events. The test duration is conservatively estimated from the equivalent number of cycles for each event, and the test input is taken as the envelope of the combined loads associated with each postulated loading combination. These tests are being performed by Southwest Research, and when completed the results will be summarized and presented to the NRC. It is intended to use these results to draw generic conclusions about the impact of the extended nature of the hydrodynamic loads on equipment and instrumentation.

III. Sensitivity Testing of Relays

The purpose of this testing program is to determine the sensitivity of relays and similar electrical devices and instrumentation to the input frequency of the dynamic loads. The test will be conducted in three phases using four relays. In the phase one the relays will be tested using a dynamic input consisting of frequencies from 51 to 100 Hz only, and amplitude which shall be incrementally increased until failure occurs. Phase two will be identical to phase one except the dynamic input will consist of frequencies from 1 to 50 Hz. Finally, in phase three the dynamic input will consist of frequencies from 1 to 100 Hz. The results will be used to draw generic conclusions about the effect of frequency upon performance of relays and similar type devices.

Conservatism

The following conservatisms have been incorporated into the Zimmer equipment qualification programs:

- 1) Lower damping values than those recommended in Regulatory Guide 1.61 were used.
- 2) The loads were combined by the absolute sum (ABS) method rather than the square root of the sum of the squares, (SRSS) method.
- 3) The response spectrum method was used rather than the time history method.
- 4) Peaks of the hydrodynamic load response spectra have been widened by 20%.
- 5) The primary containment and reactor building response spectra consist of a resultant (radial) horizontal and a vertical curve. However, this resultant horizontal was applied in each individual (N-S and E-W) horizontal direction simultaneously with the vertical direction.
- 6) The load combinations use the envelope of SRV_{ALL} and SRV_{ASY} in all directions while SRV_{ALL} is maximum in the vertical direction while SRV_{ASY} is maximum in the horizontal direction.

ZIMMER NUCLEAR STATION
UNIT 1

BOP EQUIPMENT QUALIFICATION SUMMARY
USING T-QUENCHER HYDRODYNAMIC LOADS

EQUIPMENT NAME:

EQUIPMENT NO.:

SPEC. NO.:

LOCATION:

EQUIPMENT CLASSIFICATION: ACTIVE PASSIVE

QUALIFICATION METHOD:

QUALIFICATION DOCUMENT REFERENCES:

LOAD COMBINATIONS CONSIDERED IN QUALIFICATION:

1. $N + OBE + ENV [SRV_{ASY-TQ} + SRV_{ALL-TQ}]$
2. $N + ENV (OBE \& SSE) + ENV [SRV_{ASY-TQ} \& SRV_{ADS-TQ}] + CHG$
3. $N + ENV (OBE \& SSE) + ENV [SRV_{ASY-TQ} \& 0.6 SRV_{ADS-TQ}] + CO1$
4. $N + ENV (OBE + SSE) + ENV [SRV_{ASY-TQ} \& SRV_{ADS-TQ}] + CO2$
5. $N + \sqrt{SSE^2 + AP^2}$

QUALIFICATION:

PREPARED BY:

DATE:

REVIEWED BY:

DATE:

PROJECT NO. 4130-15

APPROVED BY:

DATE:

EMD FILE NO.

QUALIFICATION SUMMARY

SEISMIC QUALIFICATION METHOD:

T-QUENCHER REQUALIFICATION METHOD:

Reference: EMD File No. _____

-2-

SARGENT & LUNDY
ENGINEERS
CHICAGO

QUALIFICATION SUMMARY OF EQUIPMENT

- I. PLANT NAME: ZIMMER - Unit 1 TYPE: _____
1. Utility: Cincinnati Gas & Electric PWR
2. NSSS: General Electric BWR
3. A-E: Sargent & Lundy

- II. COMPONENT NAME: _____
1. Scope: NSSS BOP
2. Model Number: _____ Quantity: _____
3. Vendor: _____
4. If the component is a cabinet or panel, name and model No. of the devices included: _____
5. Physical Description _____ Appearance: _____
- Dimensions: _____ Weight: _____
6. Location: Building: _____ Elev.: _____
7. Field Mounting Conditions:
- Bolting: Number: _____ Size: _____
- Welding: Weld Type: _____
- Leg: _____ Length: _____ Pitch: _____
8. Natural Frequencies in Each Direction:
- H1: _____
- H2: _____
- V: _____
9. (a) Functional Description _____
- (b) Equipment required for:
- Hot Standby Cold Shutdown Both
10. Pertinent Reference Design Specifications: _____

III. IS EQUIPMENT AVAILABLE FOR INSPECTION IN THE PLANT: Yes No

Comments: _____



- IV. EQUIPMENT QUALIFICATION METHOD: Test
 Analysis
 Combination of Test and Analysis

1. Test and/or Analysis by _____
(Name of Company or Laboratory & Report No.)

2. If Qualification by combination of test and analysis state which components were tested and which were analyzed: _____

V. VIBRATION INPUT:

1. Loads considered: Seismic
 Hydrodynamic
 Explosive
 Other (Specify): _____

2. Required Response Spectra (attach the graphs):

3. Method of combining Requiring Response Spectra:

Absolute Sum

SRSS

4. Required Acceleration in Each Direction (if Required):

H1 _____ H2 _____ V _____

5. Damping OBE: _____ Basis for damping: _____
SSE: _____

VI. IF QUALIFICATION BY TEST, THEN COMPLETE:

1. Test Method: Single Frequency
 Multiple Frequency
 Random Motion
 Sine Beat

2. Input Motion: Single Axis
 Multi Axis

3. No. of Qualification Tests: OBE _____ SSE _____ Other _____

4. Frequency Range: _____

6. Deflection Evaluation at Critical Structural Elements
(Active Equipment Only)

Element	Calc Deflec.	Allow Deflec.

VIII. ADDITIONAL COMMENTS:

Reference: EMD File No. _____

ZIMMER NUCLEAR STATION

UNIT-1

4130-00/4130-15

BOP VALVE QUALIFICATION SUMMARY

UTILITY : CINCINNATI GAS & ELECTRIC CO.

NSSS : GENERAL ELECTRIC CO.

TYPE: BWR

AE : SARGENT & LUNDY

SPEC NO.:

VALVE MANUFACTURER:

VALVE SIZE(S) & RATING(S):

VALVE QJAL. METHOD:

QUALIFICATION DOCUMENT REFERENCES:

- 1.
- 2.
- 3.
- 4.
- 5.

PREPARED BY:

DATE:

REVIEWED BY:

DATE:

II. MOUNTING:

On pipe Weld Type Flange Type

Any other support? (describe briefly) _____

III. IF QUALIFICATION BY ANALYSIS:

1. Method of analysis:

Finite element Computer aided _____ (Program)

Closed form Hand calculations

Other _____

2. For active valves, operability of the valve was addressed by:

Limiting deflections

Limiting stress to within design allowables

Both

3. Stress in the critical elements:

Element	G-Level in axis*			Calculated Stress (ksi)	Allowable stress (ksi)	
	a	b	c		Upset	Emergency

4. Deflections, for active valves only:

Element	G-Level in axis*			Calculated Deflection in	Allowable Deflection in
	a	b	c		

*Axis a - Along outlet pipe run

b - Perpendicular to axis 'a' and in the plane of axis 'a' and valve stem axis

c - Perpendicular to both 'a' and 'b'



IV. IF THE QUALIFICATION IS BY TEST:

1. Laboratory mounting: _____
2. Normal operating loads input by: _____

3. Resonance search test:
 - a) Input axes: Single Biaxial
 - b) Frequency range _____ to _____ Hz.
 - c) Sweep rate _____ octaves/min.
 - d) Input acceleration: _____
4. Qualification test:
 - a) Input axes: Single Biaxial Pseudo-biaxial
 - b) Frequency range: _____ Hz.
 - c) No. of tests in each orientation:
Upset: _____ Emergency: _____
 - d) Test method
 - Sine beat (single frequency):
No. of beats _____, No. of cycles/beat _____
Beats at _____
Input acceleration Upset: a _____, b _____, c _____
Emergency: a _____, b _____, c _____
 - Sine Dwell (single frequency): Duration: _____
Dwells at _____
Input acceleration Upset: a _____, b _____, c _____
Emergency: a _____, b _____, c _____
 - Random motion (multi frequency): Duration: _____
Damping: Upset: _____ Emergency: _____
TRS envelop RRS? _____
 - e) Other tests performed and comments: _____

V. RESULTS OF QUALIFICATION:

RESONANT FREQUENCIES			MAXIMUM ALLOWABLE 'G' VALUE APPLIED SIMULTANEOUSLY					
a	b	c	UPSET			EMERGENCY		
			a	b	c	a	b	c

VI. LOADS FROM PIPING ANALYSIS:

VALVE TAG NO.	PIPING SUBSYSTEM ANAL. DATE & EMD FILE	VALVE NOZZLE LOADS WITHIN VALVE ALLOW.	ACCELERATION IN 'G'S'					
			UPSET			EMERGENCY		
			a	b	c	a	b	c

ADDITIONAL CONSIDERATIONS:

THE CINCINNATI GAS & ELECTRIC COMPANY
WM. H. ZIMMER NUCLEAR POWER STATION - UNIT 1

SCENARIO FOR ACCOMPLISHING HOT OR COLD SHUTDOWN

Several success paths are available for safely shutting the reactor to a cold shutdown condition or maintaining an interim condition, assuming the following initiating events:

- 1) Safe Shutdown Earthquake (SSE)
- 2) Loss of Off-Site Power
- 3) Single Failure

For purposes of selecting one success path for accomplishing cold shutdown, RHR 1A pump, 1E12C002A, is assumed as the single failure. The following seismic Category I equipment are available for reactor scram, RPV depressurization and decay heat removal:

1. ESS Relay Panel senses loss of off-site power and initiates diesel generators and load sequencing.
2. CRD Hydraulic Units insert the control rods and shutdown the core (SCRAM).
3. Diesel Generators are started and reach rated speed and accept auxiliary load.
4. RHR 1B and 1C pumps are started and operate on minimum flow recirculation.
5. The following electrical equipment is energized during and following load sequencing:
 - a. 4.16 kV Switchgear
 - b. 480-V ESS Substation

- c. 480-V MCC's
 - d. Batteries
 - e. 24-V, 125-V, 250-V DC Distribution Panels/Cubicles
 - f. 120-V AC Distribution Panels
 - g. Electrical Penetration Assemblies
6. The following equipment is automatically started during load sequencing:
- a. RBCCW Pumps (LWR System)
 - b. Service Water Pumps (LWS System)
 - c. Control Room Air Conditioning (LVC System)
 - d. Switchgear Heat Removal (LVX System)
 - e. CSCS Room Coolers (LVY System)
 - f. SW Pump Structure Room Coolers (LVH System)
 - g. CSCS Water Leg Pumps
7. Cooling Water becomes available for the following heat exchangers:
- a. DG Hx
 - b. RBCCW Hx
 - c. RHR Hx (GE Furnished)
8. RBCCW Expansion Tank provides suction head on RBCCW pumps.
9. Safety Relief Valves provide RPV pressure control for depressurizing RPV to permit RHR initiation. Once the RHR System begins operation (below 135 psig vessel pressure), the reactor can be maintained at any desired temperature or pressure, or cooldown may be continued.

10. Miscellaneous Section III tanks provide high pressure air for closing the MSIV's and opening the SRV's from the main control room.
11. The following valves are cycled to line up piping to permit DG cooling and decay heat removal:

1E12F003B	1WS037A/D
1E12F004B	1WS033
1E12F047B	1E12F042C
1E12F048B	
1E12F006B	<u>See attached table</u>
1E12F008	<u>for valve functions</u>
1E12F009	
1E12F053B	
1E12F068B	
1E12F014B	
1B21F013A-D, E-H, K, L, P, R, S	(GE Furnished)
1B21F022A/D	(GE Furnished)
1B21F028A/D	(GE Furnished)

The above equipment therefore provides on-site power, instrumentation, decay heat removal, auxiliary equipment cooling and main control room habitability to safely shut down the reactor from power operation to cold shutdown.

The attached list of BOP and NSSS equipment noted by an asterick denotes in detail the equipment required for accomplishing the above success path.

RJPruski/mw

VALVE DESCRIPTION & FUNCTION

1E12F003B	RHR HX(B) Disch. to RPV
1E12F047B	Inlet to RHR HX(B)
1E12F048B	Bypass RHR HX(B)
1E12F006B)] Suction to RHR(B) From Recirc. Suction Pipe
1E12F008)	
1E12F009)	
1E12F053B	Return to RPV from RHR HX(B)
1E12F068B	Service Water Discharge from RHR HX(B)
1E12F014B	Service Water Inlet to RHR HX(B)
1E12F004B	Suction to RHR Pump (B) from Suppression Pool
1E12F042C	Discharge from RHR Pump (C) to RPV
1E12F004C	Suction to RHR Pump (C) from Suppression Pool (Not required to stroke - normally open)
1B21F013A-D,E-H, K,L,P,R,S	Safety Valve Main Steam System
1B21F022A/D	Inboard MSIV
1B21F028A/D	Outboard MSIV
1WS037A/D	Service Water Dish from D.G. HX
1WS033)] Service Water Essential - Loop Iso. Valves
1WS034)	

TABLE 110.6

SEISMIC QUALIFICATION SUMMARY OF CATEGORY I MECHANICAL AND ELECTRICAL EQUIPMENT

Equipment Number	Equipment Name	Method of Qualification**	Equipment Function**	Inspection Availability	Equipment Number	Equipment Name	Method of Qualification**	Equipment Function**	Inspection Availability
*IAP04EA/C	4.16 KV Switchgear	Test (5)	A, D	Yes	*IDC01EA	250 V Battery	Test (5)	C, D	Yes
IAP04ED/*	6.9 KV Switchgear	Test (5)	A, E	"	*IDC11EA/C	125 V Battery	Test (5)	C, D	"
*IAP05E IAP05F IAP05E IAP10F IAP11E	490 V ESS Substation	Test (5)	A, D	"	*IDC21EA/B	24/48 V Battery	Test (5)	C, D	"
					*	Battery Racks	Analysis(7)	C, D, E	"
*IAP20EA/C IAP15EA/B IAP16EA/C	480 V MCC	Test (3)	A, D	"		Battery Monitors	Test (5)	C, D	"
*IDC07EA/C	Diesel Oil Day Tank	Analysis(7)	C, D, E	"	IDC02EA/B	250 V Battery Charger	Test (5)	A, C, D	"
*IDC01EA/C	Diesel Gen.	Analysis(8)	C, D	"	IDC12EA/C	125 V Battery Charger	Test (5)	A, C, D	"
					IDC22EA/D	24 V Battery Charger	Test (5)	A, C, D	"
*IPL10JA/C	D. G. Control Panel	Test (3)	C, D	"	*IIP01EA/B IIP03E IIP04E	120 V AC Dist. Panels	Test (3)	A, D	"
*IDC02AA/D IDC03AA/B IDC04AA/B	D. G. Heat Exchanger	Analysis(8)	C, D, E	"	*IDC04EA IDC05EA/C	250 V DC Dist. Cubicles	Test (5)	C, D	"
*IDC05EA/C IDC06EA/C	D. G. Exhaust Silencer	Analysis(8)	C, D, E	"	*IDC14EA/C	125 V DC Dist. Cubicles	Test (5)	C, D	"
*IDC17EA/C IDC18EA/C	14 Cylinder Exp. Joint	Analysis(8)	E	"	*IDC26EA/B	24/48 V DC Dist. Cubicles	Test (5)	C, D	"
*IDC20EA/C IDC21EA/C IDC22EA/C	12 Cylinder Exp. Joint	Analysis(8)	E	"	*IAP50EA/H IAP50F/J/N IAP50EP IAP50ER	Electrical Penetration Assemblies	Analysis(7)	C, D, E	"
	750 KVA Transformer	Test (1)	A, D	"					

*Equipment required for cold shutdown based on scenario attached (1 success path for accomplishing shutdown).

MJD/k

**The key to information referenced numerically appears on the last page of this table.

TABLE 110.6

SEISMIC QUALIFICATION SUMMARY OF CATEGORY I MECHANICAL AND ELECTRICAL EQUIPMENT

Equipment Number	Equipment Name	Method of Qualification**	Equipment Function**	Inspection Availability	Equipment Number	Equipment Name	Method of Qualification**	Equipment Function**	Inspection Availability
11N01J 11N02J 11N03J 11N04J 11N07J 11N05A	In Control Board Assemblies	Analysis (8)	C, D, E	Yes	1VG03CA/B	SGTS Cooling Fan	Analysis (9)	D	Yes
					1VG055A/B	SGTS Equip. Train	Analysis (8)	D	"
					1VG04AA/B	SGTS Heating Coil	Analysis (8)	D, E	"
	Instruments for Main Control Boards	Test (5)	C, D	"	1VG02CA/B	SGTS Fan	Analysis (9)	D	"
1A802J	Misc. Auto Control Cabinet	Analysis (8)	E	"		SGTS Temperature Transmitter	Test (4)	E	"
*1W01PA/D	RBC Water Pumps and Motors	Analysis (7)	A, D	"		Deluge Level Controller	Test (5)	E	"
*1E21-C002 1E21-C003 1E22-C003	CSCS Water leg Pumps	-	A	"		Deluge Valve MDL-5700CY	Test (5)	E	"
1E190JA/B	Pri. Cont. Sampling System, Ess. Cont. Mon. System	-	D	"		Pressure Trans.	Test (5)	E	"
*1W01PA/D	Service Water Pumps & Motors	Analysis (7)	A, D	"	1VG03YA/B 1VG04YA	SCID	Analysis (9)	D	"
1W048A/B	Travelling Water Screens	Analysis (7)	E	"		Solenoid Valve	Test (2)	D	"
1W021A/B	Service Water Strainers	Analysis (8)	E	"		Limit Switch	Test (2)	E	"
						Actuator	Analysis (7)	D	"
*1W012AA/C	RBCW Heat Exchanger	Analysis (8)	A, D	"	*1V010CA/D 1VY01C 1VY02C 1VY03C 1VY04C 1VX04CA/B 1VX01CA/B 1VX04CA/P 1VX02CA/C 1VA01C	Vent Fans	Analysis (7)	A, D	"
*1E112S 1E113S	N2 Cylinder Rack	Analysis (8)	D, E	"					
1E21-A001A/D 1E21-A002A/D 1E21-A003B/C 1E21-A003E/C 1E21-A003E/L 1E21-A004A/B 1E21-A004K 1E21-A004L 1E21-A004P 1E21-A004R 1E21-A004S	Misc. Tanks Section III	Analysis (7)	A, D	"		Resilient Isolators	Analysis (7)	E	"
						Motors	Analysis (9)	A, D	"
					*1VG02CA/B	C.R. Condensing Unit	Analysis (7)	A, D	"
					*1VX01CA/F	Switchgear Condensing Unit	Analysis (7)(8)	A, D	"

*Equipment required for cold shutdown based on scenario attached (1 success path for accomplishing shutdown).

**The key to information referenced numerically appears on the last page of this table.

TABLE 10.6

SEISMIC QUALIFICATION SUMMARY OF CATEGORY I MECHANICAL AND ELECTRICAL EQUIPMENT

Equipment Number	Equipment Name	Method of Qualification**	Equipment Function**	Inspection Availability	Equipment Number	Equipment Name	Method of Qualification**	Equipment Function**	Inspection Availability
IP181J IP184J	Control Panels	Test (1)	A, D	Yes	*IVX06AA/F	Filter for Special Coil Cabinets	Analysis (7)	A, E	Yes
	HVAC Dampers	Test (4)	E	"					
IVC11XA/B	HVAC Duct Silencers	Analysis (9)	E	"		Refrigeration Specialties Filter Dryer	-	A, D	No
	HVAC Gravity Shutters	Test (2)		"					
IVG091A/B IVG092A/B	Flow Elements	-	E	No	*IVC095A/B IVC105	Essential Package Filter Bolts	Analysis (8)	A, E	Yes
IP191J IP192J IP193J IP114JA/B	HVAC Panels	Analysis (8)	A, D	Yes		Diff. Pressure Indicating Switch MDL289-4859	Test (2)	E	"
	HVAC Instr.	-	A, D	No		Damping Framing	Analysis (7)	E	"
	Arsonia Monitoring System	-	A	"		Fan Motor	Analysis (7)	A, D	"
						Mounting Brackets	Analysis (7)	E	"
						Pressure Transmitter	Test (5)	E	"
						Deluge Valves	-	E	No
						Temperature Transmitters	-	E	"
						Essential Pressure Gauges and Thermometers	-	A, D	"
*IHC12TA/C IHC13TA/C	Cooling Water Reservoir Tank	Analysis (7)	C, D, E	Yes					
*IHC14TA/F	C.W. Expansion Tank	Analysis (7)	C, D, E	"	*IPL12JA/C	Ess. Relay Panels	Test (5)	C, D	Yes
IHD001TA/C	D.O. Storage Tank	Analysis (7)	C, D, E	"	IPL67JA/B	Remote Shutdown Panels	Test (1)	D	"
*IHR01TA/B	RBCW Expansion Tank	Analysis (8)	A, D, E	"		Fire Extinguishing System	Test (5)	C, D	"
*IHC15A/C	Air Receiver Tank	Analysis (7)	C, D, E	"	*IHD02PA/D	Fuel Oil Transfer Pumps	Analysis (7)	C, D	"
	Ess. Trans. & Sensors	Analysis (4)	A, D	"					
*IVC085A/B IVC01AA/B IVC01BA/F IVC05A IVC06S IVC07S	Special Coil Cabinets	Analysis (7)	A, D	"	*IVC03CA/B IVD01CA/C	Ventilation Fans	Analysis (7)	A, D	"
						Essential Pressure and Temperature Switches	Test (2)	A, D	"

*Equipment required for cold shutdown based on scenario attached (1 success path for accomplishing shutdown).

MJR/kk

**The key to information referenced numerically appears on the last page of this table.

TABLE 110.6

SEISMIC QUALIFICATION SUMMARY OF CATEGORY I MECHANICAL AND ELECTRICAL EQUIPMENT

Equipment Number	Equipment Name	Method of Qualification*	Equipment Function*	Inspection Availability	Equipment Number	Equipment Name	Method of Qualification*	Equipment Function*	Inspection Availability
IVC01YA/B IVC02YA/B IVC03YA/B IVC04YA/B IVC05YA/B IVC06YA/B IVC07YA/B IVC08YA/B IVC09YA/B IVC10YA/B IVC11Y	HVAC Control Dampers	Analysis (7)	E	Yes	1E12F008 1E12F009 1E12F048A/B	<u>ACTIVE VALVES</u>	Analysis (7) Analysis (7) Analysis (7)	C C A	Yes " "
	Freeze Protection Equipment	-	D, E	No		Gate Valve			
	Ess. Isolation Dampers	Analysis (7)	A, D	Yes		Gate Valve			
	Dumper Operators NH90 Series Actuator	Test (4)	A, D	"		Angle Valve			
	Misc. Control Panels	-	D, E	"					
	IPM17J IPM15J IPL79J	-	A, D, E	"					
	-	-	A, E	"					
	Switchgear for Recir. LFMC 4160V and 6900V	Test (3)	A, E	"					
	Essential Control Room Isolation Check Dampers	Analysis (7)	A, D	"					
	Limiter Motor Operators: SMB-10 SMB-1 SMB-2 SMB-3	Test (4)	A, D	"					
Post Accident Pri. Cont. Atm. Radio-activity Monitors System	Test (5)	D	"						
Main Control Room Radiation Monitors	-	D	No						

*The key to information referenced numerically appears on the last page of this table.

TABLE 110.6

SEISMIC QUALIFICATION SUMMARY OF CATEGORY I MECHANICAL AND ELECTRICAL EQUIPMENT

Equipment Number	Equipment Name	Method of Qualification**	Equipment Function**	Inspection Availability	Equipment Number	Equipment Name	Method of Qualification**	Equipment Function**	Inspection Availability
1E12F021 1E12F024A/B 1E12F040	RHR Globe Valve 10"	Analysis (7)	A, D	Yes	1VQ001A/B 1VQ002A/B 1VQ003A/B 1VQ004A/B	Primary Containment HVAC Butterfly Valve 18"	Analysis (7)	A, D	Yes
1E51F022	RCIC Globe Valve 4"	Analysis (7)	A, D	"	1WS004A/D 1WS008A/B *1WS033A/B *1WS034A/B	Service Water Butterfly Valve 24"	Analysis (8)	A, D	"
1W007A/B	Service Water Globe Valve 3"	Analysis (7)	A, D	"	*1WS037A/D	Service Water Butterfly Valve 8"	Analysis (8)	A, D	"
1E41F001A/B	Standby Liquid Control Globe Valve 3"	Analysis (7)	A, D	"	1E12F051A/B 1E12F065A/B	RHR Globe Valve 6" " " " 2.5"		A, D	"
1E12F011A/B 1E12F016A/B 1E12F027A/B 1E12F049	RHR Gate Valve 4" " " " 3"	Analysis (7) Analysis (7)	A, D A, D	" "	11N012 11N013	Inst. N2 Supply Globe Valve .75" " " " 2.5"	Test (5) and Analysis (7)	A, D	" "
1E11F009	LPCS Gate Valve 12"	Analysis (7)	A, D	"	1RE048 1RE049	Equip. Drain to Radwaste Globe Valve 2.5"	Test (5) and Analysis (7)	A, D	"
1E51F010 1E11F012 1E51F031	RCIC Gate Valve 6"	Analysis (7)	A, D	"	1RF001 1RF002	Floor Drain to Radwaste Globe Valve 2.5"	Test (5) and Analysis (7)	A, D	"
1E51F065	RCIC Gate Valve 8"	Analysis (7)	A, D	"	1WS020 1WS025 1WS030	Service Water Globe Valve 10" " " " 12"	Test (5) and Analysis (7)	A, D	"
1E0029 1E0034	Fuel Pool Cooling and Clean-up Gate Valve 12"		A, D	"	1E12F003A/B 1E12F004A/C 1E12F006A/B 1E12F016A/B 1E12F017A/B 1E12F047A/B	RHR Gate Valve 14" " " " 20" " " " 16" " " " 14" " " " 14" " " " 14"	Analysis (7)	A, D	"
1W0054 1W0055	RBCCM Gate Valve 6"	Analysis (7)	A, D	"	1E12F001	LPCS Gate Valve 20"		A, D	"
1WS005	Service Water Gate Valve 30"	Analysis (7)	A, D	"	1E12F012	LPCS Globe Valve 12"	Analysis (7)	A, D	"
1W0012A/B 1W0013A/B	Service Water Gate Valve 4"	Analysis (7)	A, D	"	1E12F087A/B 1E51F045	RHR Globe Valve 3" RCIC " " 4"	Analysis (7)	A, D	"
1WS073A/D	Service Water Globe Valve 3"	Analysis (7)	A, D	"	1WS006A/B 1WS007A/B	Service Water Butterfly Valve 30"	Analysis (7)	A, D	"
*1E12F016A/B *1E12F024A/B	RHR Butterfly Valve 16" " " " 14"	Analysis (8) Analysis (8)	A, D	" "					
1VH001A/B 1VH002A/B 1VH003A/B 1VH004A/D	Pumphouse Ventilation Butterfly Valve 12"	Analysis (8)	A, D	"					
1E11F019	Recirculation Diaphragm Operated Globe Valve .75"	-	A, D	No					

*Equipment required for cold shutdown based on scenario attached (1 success path for accomplishing shutdown).

**The key to information referenced numerically appears on the last page of this table.

MJB/ak

NOTES:

The following referenced numerical key applies to the Method of Qualification column:

1. Multifrequency random motion biaxial testing with Test Response Spectrum (TRS) enveloping the Required Response Spectrum (RRS).
2. Test input to specimen based on single axis and single frequency excitation.
3. Test input to specimen based on biaxial and single frequency excitation.
4. Test input to specimen based on single axis and multi-frequency excitation.
5. Test input to specimen based on biaxial and multifrequency excitation.
6. Test input to specimen based on fragility level excitation.
7. Analysis of specimen based on static analysis.
8. Analysis of specimen based on dynamic analysis.
9. Analysis of specimen based on static coefficient analysis.

The following referenced alphabetical key applies to the Equipment Function column.

- A. Hot Standby and Cold Shutdown
- B. Hot Standby
- C. Cold Shutdown
- D. Post LOCA
- E. Passive

The list of all the active valves and the method of qualification is included in table 110.6. There are approximately 1400 passive valves which are not listed in the above table but were qualified to the same requirements.

SARGENT & LUNDY
ENGINEERS
CHICAGO

Balance of Plant Equipment Qualification Progress

	Assessment & Complete	Requali- fication & Complete
Equipment	100.	85.
HVAC Dampers	100.	100.
Valves	100.	80.
Instrumentation	100.	50.

Balance of Plant Equipment Qualification Schedule

	April	May	June	July	August	Sept.	October
Equipment	▣	▣	▣	▣	▣	▣	
HVAC Dampers	▣	▣	▣	▣	▣	▣	
Valves	▣	▣	▣	▣	▣	▣	
Instrumentation	▣	▣	▣	▣	▣	▣	

- ▣ Engineering Effort
- ▣ Implementation of Hardware Modifications
- ▣ Testing

Wm. H. Zimmer
Project No. 4130-00

SUMMARY OF
EQUIPMENT MODIFICATIONS

Page 1 of 7
Rev. 00
Date 4-15-81

Equipment Number	Description	Modification Description
1VG02CA	Standby Gas Treatment System Fan 1A	Vibration Isolators & Mounting Bolts Strengthened
1VG02CB	Standby Gas Treatment System Fan 1B	Vibration Isolators & Mounting Bolts Strengthened
1VG03CA	Standby Gas Treatment System Cooling Fan 1A	Vibration Isolators Strengthened
1VG03CB	Standby Gas Treatment System Cooling Fan 1B	Vibration Isolators Strengthened
1VG04AA	Standby Gas Treatment System Heating Coil 1A	Reinforcement of Coil Support
1VG04AB	Standby Gas Treatment System Heating Coil 1B	Reinforcement of Coil Support
1VC11XA	Control Room HVAC Return Fan Silencer 1A	Providing Anchorage to Foundation
1VC11XB	Control Room HVAC Return Fan Silencer 1B	Providing Anchorage to Foundation

Wm. H. Zimmer
Project No. 4130-00

SUMMARY OF
EQUIPMENT MODIFICATIONS

Page 2 of 7

Rev. 00

Date 4-15-81

Equipment Number	Description	Modification Description
IVY01C	CSCS-RHR Equipment Room Cooling Fan	Vibration Isolators Strengthened
IVY02C	CSCS-LPCS/RHR Equipment Room Cooling Fan	Vibration Isolators Strengthened
IVY03C	CSCS-RCIC Equipment Room Cooling Fan	Vibration Isolators Strengthened
IVY04C	CSCS-HPCS Equipment Room Cooling Fan	Vibration Isolators Strengthened
IVY05A	CSCS-RHR Equipment Room Heat Exchanger	Additional Cabinet Anchorage & Coil Reinforcement
IVY06S	CSCS-LPCS/RHR Equipment Room Coil Cabinet (IVY07AA, IVY07AB)	Additional Cabinet Anchorage & Coil Reinforcement
IVY08A	CSCS-RCIC Equipment Room Heat Exchanger	Additional Cabinet Anchorage & Coil Reinforcement
IVY09A	CSCS-HPCS Equipment Room Heat Exchanger	Additional Cabinet Anchorage & Coil Reinforcement

Wm. H. Zimmer
Project No. 4130-00

SUMMARY OF
EQUIPMENT MODIFICATIONS

Page 3 of 7
Rev. 00
Date 4-15-81

Equipment Number	Description	Modification Description
1PL30JB	Off-Gas Instrument Panel 1B	Mounting Welds Provided
1PL65JB	Station Ventilation Purge and Prim. Cont. HVAC Panel	Additional Anchorage Provided
1C41-A002	Standby Liquid Control Test Tank	Providing Nozzle Reinforcing Pads
1WR02AA	Reactor Bldg. Closed Cooling Water Heat Exchanger 1A	Saddle Supports Modified and Additional Anchorage Provided
1WR02AB	Reactor Bldg. Closed Cooling Water Heat Exchanger 1B	Saddle Supports Modified and Additional Anchorage Provided
1WR02AC	Reactor Bldg. Closed Cooling Water Heat Exchanger 1C	Saddle Supports Modified and Additional Anchorage Provided
Detail AA	(1) Rack For Locally Mounted Instruments	Additional Anchorage Provided
Detail DD	(3) Racks For Locally Mounted Instruments	Additional Anchorage Provided
Detail JJ	(2) Racks For Locally Mounted Instruments	Additional Anchorage Provided

Wm. H. Zimmer
Project No. 4130-00

SUMMARY OF
EQUIPMENT MODIFICATIONS

Page 4 of 7
Rev. 00
Date 4-15-81

Equipment Number	Description	Modification Description
1RE01T	Reactor Bldg. Equip. Drain Tank	Additional Mounting Provided
1PS10S	Sample Station 1PL50J Chiller	Anchorage Grouting Provided
1H13-P659	Rod Sequence Control System	Mounting Welding Provided
1FC02AA	Fuel Pool Heat Exchanger 1A	Additional Bracing Provided, Reinforcing Saddle Supports, and Additional Anchorage Provided
1FC02AB	Fuel Pool Heat Exchanger 1B	Additional Bracing Provided, Reinforcing Saddle Supports, and Additional Anchorage Provided
1FW02AA	High Pressure Feedwater Heater 1A-6	Reinforcing Lower Supports
1FW02AB	High Pressure Feedwater Heater 1B-6	Reinforcing Lower Supports

Wm. H. Zimmer
Project No. 4130-00

SUMMARY OF
EQUIPMENT MODIFICATIONS

Page 5 of 7
Rev. 00
Date 4-15-81

Equipment Number	Description	Modification Description
1VC08SA	Control Room HVAC Air Handling Unit 1A	Additional Anchorage Provided
1VC08SB	Control Room HVAC Air Handling Unit 1B	Additional Anchorage Provided
1IN03DA	Drywell Pneumatic Sys. Dryer 1A Skid (1IN07FA,B; 1IN11FA,B)	Anchorage Reinforcement Provided
1IN03DB	Drywell Pneumatic Sys. Dryer 1B Skid (1IN07FC,D; 1IN11FC,D)	Anchorage Reinforcement Provided
1AP05E	480V ESS Substation 1A-1	Additional Anchorage Provided
1AP06E	480V ESS Substation 1A-2	Additional Anchorage Provided
1AP07EA	480V ESS Substation 1A-3A	Additional Anchorage Provided
1AP08EA	480V ESS Substation 1A-4A	Additional Anchorage Provided
1AP09E	480V ESS Substation 1B-1	Additional Anchorage Provided

Wm. H. Zimmer
Project No. 4130-00

SUMMARY OF
EQUIPMENT MODIFICATIONS

Page 6 of 7
Rev. 00
Date 4-15-81

Equipment Number	Description	Modification Description
1AP10E	480V ESS Substation 1B-2	Additional Anchorage Provided
1AP11EA	480V ESS Substation 1B-3A	Additional Anchorage Provided
1AP12EA	480V ESS Substation 1B-4A	Additional Anchorage Provided
1AP13E	480V ESS Substation 1C-1	Additional Anchorage Provided
1AP14EA	480V ESS Substation 1C-2A	Additional Anchorage Provided
1VG01YB	Essential Recirculation Fan Isolation Damper	Modification of Operator Mounting and/or Hangers
1VQ01Y	Primary Containment Purge Isolation Damper	Modification of Operator Mounting and/or Hangers
1VQ02Y	Primary Containment Purge Isolation Damper	Modification of Operator Mounting and/or Hangers

Wm. H. Zimmer
Project No. 4130-00

SUMMARY OF
EQUIPMENT MODIFICATIONS

Page 7 of 7
Rev. 00
Date 4-15-81

Equipment Number	Description	Modification Description
1VP01YA	Primary Containment HVAC Isolation Damper	Modification of Operator Mounting and/or Hangers
1VP01YB	Primary Containment HVAC Isolation Damper	Modification of Operator Mounting and/or Hangers
1VP10YA	Primary Containment HVAC Isolation Damper	Modification of Operator Mounting and/or Hangers
1VP11YA	Primary Containment HVAC Isolation Damper	Modification of Operator Mounting and/or Hangers
1VP11YB	Primary Containment HVAC Isolation Damper	Modification of Operator Mounting and/or Hangers

ANALYTICAL METHODS

Static Analysis: an analysis procedure used for equipment which has been demonstrated to be rigid (i.e. equipment has no natural frequencies in the frequency range of concern). This procedure evaluates the stresses and deflections resulting from steady forces acting through the center of gravity. These steady forces are the maximum forces input at the equipment base.

They are determined from the zero period acceleration (ZPA) of the appropriate response spectra.

Equivalent Static Analysis: an analysis procedure used for equipment whose dynamic characteristics have not been completely defined. This procedure evaluates the stresses and deflections resulting from steady forces acting through the center of gravity. The steady forces are the maximum forces associated with the peak response of any single degree of freedom system. They are determined from the peak acceleration of the appropriate response spectra multiplied by an appropriate amplification factor to account for the possibility of multi-mode response.

Simplified Dynamic Analysis: an analysis procedure used for equipment which can easily be modeled and whose dynamic characteristics are known. This procedure evaluates the stresses and deflections resulting from steady forces acting through the center of gravity. These steady forces are the maximum forces associated with equipment resonance. They are determined from the acceleration associated with the equipment's natural frequency multiplied by an appropriate amplification factor to account for the possible participation of higher modes.

Detail Dynamic Analysis: a finite element analysis procedure for multi-degree-of-freedom systems where the responses are determined for each mode and then combined to determine the true response and associated stresses and deflections resulting from any forcing function.

Specification No. H-2156
 Vendor: ITE Imperial
 Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page 11 of 57
 Rev. 00
 Date 4-15-81

Equipment Number	Description	S e l e c t i o n	C l a s s i f i c a t i o n	Location		Qualification Method		Results
LAP04EA LAP04EB LAP04EC	4.16 KV Switch Group	A		Auxiliary		Resonance Search 1-50 Hz Random Motion Biaxial Test FB/V and SS/V, 1-50 Hz		Natural Frequencies: Front to Back: 18 Hz Side to Side: 27 Hz TRS envelopes RRS Functional Operability Verified
LAP04ED LAP04FE	6.9 KV Switch Group	A		Auxiliary		Resonance Search 1-50 Hz Random Motion Biaxial Tests FB/V and SS/V, 1-50 Hz		Natural Frequencies: Front to Back: 10, 14, 18, 21 Hz Side to Side: 10, 19, 24, 30 Hz TRS envelopes RRS Functional Operability Verified

Specification No. H-2157Vendor: ITE Imperial

Wm. H. Zimmer

Project No. 4130-00

SUMMARY OF
EQUIPMENT QUALIFICATIONPage A2 of 57Rev. 00Date 4-15-81

Equipment Number	Description	Series	Class	Location	Qualification Method	Results
LAP05E LAP06E LAP09E LAP10E LAP13E	480 V Substation.	A		Aux. Bldg.	Random Motion Biaxial Test. EMD-000606 A resonance search test was performed from 0.5 to 50 Hz. This was followed by Random Motion Tests from 0.5 Hz to 50 Hz	Principal resonant frequencies were determined to be: FB/V: 6,8,11,19,23 & 33 Hz. SS/V: 4.5,13,18,23,30 & 43 Hz. TRS envelopes RRS Functional Operability Verified
LAP05E LAP06E LAP09E LAP10E LAP13E	750 KVA Transformer (Associated with 480V Substation).	A		Aux. Bldg.	Random Motion Biaxial Test. EMD-001235 EMD-001802 A resonance search test was performed from 2 to 30 Hz. This was followed by Random Motion Tests from 0.5 to 100 Hz	Principal Resonant frequencies were determined to be: FB/V: 2,7,9,12,15,17.5,21 & 30 Hz. SS/V: 4.4,7,8.5, 12,17 & 20 Hz. The TRS envelopes the RRS Functional Operability Verified

Specification No. H- 2158Vendor: ITE Imperial

Wm. H. Zimmer

Project No. 4130-00

SUMMARY OF
EQUIPMENT QUALIFICATIONPage 43 of 57Rev. 00Date 4-15-81

Equipment Number	Description	Series	Class	Location	Qualification Method	Results
LAP15EA LAP15EB	480 V Motor Control Center	A		Reactor	<p>Pseudo-Biaxial Sine Sweep Resonance Search 1-35 Hz</p> <p>Pseudo-Biaxial Sine Dwell for 1-26 Hz range. Narrow Band Pseudo-Biaxial Random Motion Test for 3.94-10.26 Hz range. Sine Beat Pseudo-Biaxial Tests at 8.75, 10 and 35 Hz.</p>	<p>Natural Frequencies: Front to Back: 7-8.75, 35 Hz Side to Side: 8-10, 35 Hz</p> <p>Input Accelerations greater than ZPA and TRS envelopes RRS, Functional Operability Verified for Original Qualification Criteria. Requalification to T-Quencher Criteria Not Completed.</p>
LAP16EA LAP16EB LAP16EC LAP16ED LAP16EE LAP16EF	480 V Motor Control Center	A		Auxiliary	<p>Pseudo-Biaxial Sine Sweep Resonance Search 1-35 Hz</p> <p>Pseudo-Biaxial Sine Dwell for 1-26 Hz range. Narrow Band Pseudo-Biaxial Random Motion Test for 3.94-10.26 Hz range. Sine Beat Pseudo-Biaxial Test at 8.75, 10 and 35 Hz.</p>	<p>Natural Frequencies: Front to Back: 7-8.75, 35 Hz Side to Side: 8-10, 35 Hz</p> <p>Input Accelerations greater than ZPA and TRS envelopes RRS. Functional Operability Verified.</p>

Specification No. H- 2158

Vendor: ITE Imperial

Wm. H. Zimmer

Project No. 4130-00

SUMMARY OF
EQUIPMENT QUALIFICATION

Page A4 of 57

Rev. 00

Date 4-15-81

Equipment Number	Description	S e r i e s	C l a s s	Location	Qualification Method	Results
LAP20EA LAP20EB LAP20EC	480 V Motor Control Center	A		WS Bldg.	Pseudo-Biaxial Sine Sweep Resonance Search 1-35 Hz Pseudo-Biaxial Sine Dwell for 1-26 Hz range. Narrow Band Pseudo-Biaxial Random Motion Test for 3.94-10.26 Hz range. Sine Beat Pseudo-Biaxial Test at 8.75, 10 and 35 Hz.	Natural Frequencies: Front to Back: 7-8.75, 35 Hz Side to Side: 8-10, 35 Hz Input Accelerations greater than ZPA and TRS envelopes RRS. Functional Operability Verified.

Specification No. H-2159
 Vendor: Stewart & Stevenson

Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page 45 of 57

Rev. 00

Date 4-15-81

Equipment Number	Description	S e l e c t i o n	C l a s s i f i c a t i o n	Location	Qualification Method	Results
1DG01KA 1DG01KB 1DG01KC	Diesel Generator Units	A		Aux. Bldg.	Finite Element Dynamic Analysis. EMD-002581 EMD-012939	The lowest frequency obtained from the program is 15 Hz. Element stresses representing the various parts of the DG are within allowable limits as are bolt stresses. Deflection of the generator shaft is calculated to be 0.005 inch compared to an actual air gap of 0.392 inch.
1DG02AA 1DG02AB 1DG02AC 1DG03AA 1DG03AB 1DG04AA 1DG04AB	Diesel Generator Heat Exchangers				A finite element Dynamic Analysis and Static Analysis were performed using the computer program ANSYS. A value of 1% damping was used. The maximum stresses in the component parts of the assembly and bolts are determined. The maximum generator shaft deflection is also computed.	
1DG05KA 1DG05KB 1DG05KC 1DG06KA 1DG06KB 1DG06KC	DG Exhaust Silencer 1A, 1B, 1C, 1A, 1B, 1C	P		Aux. Bldg.	Finite Element Dynamic Analysis. EMD-002581 A finite element Dynamic Analysis and Static Analysis were performed using ANSYS with 1% damping. Stresses in the equipment were calculated.	The lowest frequency obtained from the program is 30.11 Hz. Stresses within allowable limits.

Specification No. H-2159
 Vendor: Stewart & Stevenson
 Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page 16 of 57
 Rev. 00
 Date 4-15-81

Equipment Number	Description	Series	Location	Qualification Method	Results
IPL10JA IPL10JB IPL10JC	Diesel Generator Control Panels 1A, 1B, 1C	A	Auxiliary	Random Motion Biaxial Tests FB/V and SS/V, 1-40 Hz	TRS envelopes RRS. Functional Operability Verified.
IDG10CA IDG10CB IDG10CC IDG10CD IDG10CE IDG10CF	Diesel Generator Air Compressors	W	Auxiliary		
IDG17EA IDG17EB IDG17EC IDG18EA IDG18EB IDG18EC	Exhaust Expansion Joints 16 Cylinder D.G.	P	Auxiliary		

Specification No. H- 2159
 Vendor: Stewart & Stevenson
 Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page A7 of 57
 Rev. 00
 Date 4-15-81

Equipment Number	Description	S e r i e s . C l a s s	Location	Qualification Method	Results
1DG20EA 1DG20EB 1DG20EC 1DG21EA 1DG21EB 1DG21EC 1DG22EA 1DG22EB 1DG22EC	Exhaust Expansion Joints 12 Cylinder D.G.	P	Auxiliary		

Specification No. H-2163

Vendor: Gould

Wm. H. Zimmer

Project No. 4130-00

SUMMARY OF
EQUIPMENT QUALIFICATION

Page 18 of 57

Rev. 00

Date 4-15-81

Equipment Number	Description	Series	Class	Location	Qualification Method	Results
1DC01EA 1DC11EA 1DC11EB 1DC11EC 1DC21EA 1DC21EB	250V Battery 1A 125V Battery 1A,1B,1C 24/48 V Battery 1A,1B	A		Aux. Bldg.	Random Motion Biaxial Test EMD-003689 A random motion biaxial type test was performed from 1 to 40 Hz. 5 OBE tests were followed by 1 SSE test in each of two orientations. The tests were of 30 second duration each and were all analyzed at 2% damping.	TRS envelopes RRS. The equipment passed the test without compromise of structure or electrical function.
1DC01EA 1DC11EA 1DC11EB 1DC11EC 1DC21EA 1DC21EB	Battery Racks (equipment number same as battery).	P		Aux. Bldg.	Static Analysis. EMD-004697 Fundamental Natural Frequencies were determined in each direction. A static analysis was then performed using ZPA values from 1/2% OBE and 1% LTT curves. Accelerations: OBE / DBE h ₁ =0.20/0.32 h ₂ =0.18/0.28 V=0.20/0.30	Natural frequencies in each direction: h ₁ =48.59 Hz h ₂ =43.43 Hz V=46.60 Hz (rigid). Stresses within allowable limits. Structrual Integrity Demonstrated.

Specification No. H-2164
Vendor: Power Conversion Products

Wm. H. Zimmer
Project No. 4130-00

SUMMARY OF
EQUIPMENT QUALIFICATION

Page A9 of 57

Rev. 00

Date 4-15-81

Equipment Number	Description	Series	Class	Location	Qualification Method	Results
1DC02EA, EB	250V Battery Charger 1A	A		Aux. Bldg.	Random Motion Biaxial Test EMD-003274	TRS envelopes RRS. The equipment passed the test without compromise of structure or electrical function.
1DC12EA, EB, EC	125V Battery Charger 1A, 1B, 1C				A random motion biaxial type test was performed from 1 to 33 Hz. 5 OBE tests were followed by 1 SSE test in each of two orientations. The tests were of 30 second duration each and were analyzed at 1/2% OBE and 1% DBE.	
1DC13EA	125V Battery Charger Spare					
1DC22EA, EB, EC, ED	24V Battery Charger 1A, 1B, 1C, 1D					

Specification No. H-2165

Vendor: ITE Imperial

Wm. H. Zimmer

Project No. 4130-00

SUMMARY OF
EQUIPMENT QUALIFICATION

Page A10 of 57

Rev. 00

Date 4-15-81

Equipment Number	Description	S e l e c t i o n s	C l a s s i f i c a t i o n	Location		Qualification Method		Results
LIP01EA LIP01EB LIP03E LIP04E	120 VAC Distribution Panel 120 VAC Distribution Panel	A W		Aux.Bldg.		Pseudo-Biaxial Sine Sweep Resonance Search 1-35 Hz Pseudo-Biaxial Sine Dwell for 1-26 Hz range, Narrow Band Pseudo-Biaxial Random Motion Test for 3.94-10.26 Hz range. Sine Beat Pseudo-Biaxial Test at 8.75, 10 and 35 Hz.		Natural Frequencies: Front to Back: 7-8.75, 35 Hz Side to Side: 8-10, 35 Hz Input Accelerations greater than ZPA and TRS envelopes RRS. Functional operability verified.

Specification No. H-2166Vendor: ITE Imperial

Wm. H. Zimmer

Project No. 4130-00SUMMARY OF
EQUIPMENT QUALIFICATIONPage 111 of 117Rev. 00Date 4-15-81

Equipment Number	Description	Series	Class	Location	Qualification Method	Results
1DC04EA	250 VDC Main Distribution Panel 1A	A		Aux.Bldg.	Pseudo-Biaxial Sine Sweep Resonance Search 1-35 Hz Pseudo-Biaxial Sine Dwell for 1-26 Hz range. Narrow Band Pseudo-Biaxial Random Motion Test for 3.94-10.26 Hz range. Sine Beat Pseudo-Biaxial Test at 8.75,10 and 35 Hz.	Natural Frequencies: Front to Back: 7-8.75, 35 Hz Side to Side: 8-10, 35 Hz. Input Accelerations greater than ZPA and TRS envelopes RRS.Functional operability verified.
1DC05EB 1DC05EC	250 VDC Motor Control Centers	A		RX.Bldg.	Pseudo Biaxial Sine Sweep Resonance Search 1-35 Hz Psuedo-Biaxial Sine Dwell for 1-26 Hz range.Narrow Band Pseudo-Biaxial Random Motion Test for 3.94-10.26 Hz range. Sine Beat Psuedo-Biaxial Test at 8.75,10 and 35 Hz.	Natural Frequencies Front to Back: 7-8.75,35 Hz Side to Side: 8-10, 35 Hz Input Accelerations greater than ZPA and TRS envelopes RRS, function operability verified for original qualification criteria. Requalifications to T-Quencher Criteria not completed.

Specification No. H-2166
 Vendor: ITE Imperial

Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page 112 of 57

Rev. 00

Date 4-15-81

Equipment Number	Description	S e i s s	C l a s s	Location	Qualification Method	Results
IDC14EA IDC14EB IDC14EC	125 VDC Distribution Panels 1A,1B,1C	A		Aux.Bldg.	Pseudo-Biaxial Sine Sweep Resonance Search 1-35 Hz Pseudo-Biaxial Sine Dwell for 1-26 Hz range. Narrow Band Pseudo-Biaxial Random Motion Test for 3.94-10.26 Hz range. Sine Beat Pseudo-Biaxial Test at 8.75,10 and 35 Hz.	Natural Frequencies: Front to Back: 7-8.75,35 Hz Side To Side: 8-10, 35 Hz Input Accelerations greater than ZPA and TRS envelopes RRS.Functional Operability Verified.
IDC26EA IDC26EB	24/48 VDC Distribution Panels	A		Aux.Bldg.	Pseudo-Biaxial Sine Sweep Resonance Search 1-35 Hz Pseudo-Biaxial Sine Dwell for 1-26 Hz range.Narrow Band Pseudo-Biaxial Random Motion Test for 3.94-10.26 Hz range.Sine Beat Pseudo-Biaxial Test at 8.75,10 and 35 Hz.	Natural Frequencies: Front to Back: 7-8.75, 35 Hz Side to Side: 8-10, 35 Hz Input Accelerations greater than ZPA and TRS envelopes RRS.Functional Operability Verified.

Specification No. H-2167
 Vendor: Conax Corporation

Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page A13 of 57

Rev. 00

Date 4-15-81

Equipment Number	Description	S e i s .	C l a s s .	Location		Qualification Method		Results
LAP50EA, EM	Low Voltage Power Elec. Penetration Assembly E-1, E-16	P	Rx. Bldg.	Static Analysis EMD-000599 EMD-018637				The natural frequencies calculated were:
LAP50EF EJ	L.V. Control Elec. Penetration Assembly E-8, E-12	P	Rx. Bldg.	Natural frequency calculations were performed to justify a static analysis.				$h_1 = 143 \text{ Hz}$ $h_2 = 900 \text{ Hz}$ $V = 143 \text{ Hz}$
LAP50ED, EL, ES, ET, EU	L.V. Instrument Service Elec. Penetration Assembly E-5, E-15, E-3, E-11, E-14.	P	Rx. Bldg.	The required acceleration in each direction was: (OBE/DBE): $h_1 = 0.34/0.48$ $h_2 = 0.44/0.50$ $V = 0.37/0.45.$				Stresses were within the allowable limits.
LAP50EB, EE, EG, EK	L.V. Neutron Monitor Elec. Penetration Assembly E-2, E-6, E-9, E-13	P	Rx. Bldg.					Functional Integrity Verified for original qualification criteria. Requalification to T-Quencher criteria not completed.
LAP50EC, EH, EN	Control Rod Position Indicator L.V. Elec. Penetration E-4, E-10, E-17.	P	Rx. Bldg.					
LAP50EP ER	Medium Voltage Power Elec. Penetration Assembly E-18, E-19.	P	Rx. Bldg.					

Specification No. H-2175
 Vendor: United Electric Controls

Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page A14 of 57

Rev. 00

Date 4-15-81

Equipment Number	Description	Classification	Location	Qualification Method	Results
1PM01J	Generator and Station Auxiliary Control Board.	A	Aux. Bldg.	Finite Element Dynamic Analysis. EMD-004798	There were a total of 21 modes considered in the analysis. The lowest frequency obtained was 9.59 Hz. The resulting stresses at all locations were within allowable limits for both assembly #1 and assembly #2. Structural Integrity Demonstrated.
1PM02J	Turbine - Condenser and Auxiliaries Control Board.	P	Aux. Bldg.	EMD-004845 EMD-018429	
1PM03J	Generator Heaters and Auxiliaries Control Board.	P	Aux. Bldg.	A dynamic analysis was performed by the Engineering Mechanics Division on two "assemblies". Assembly #1 included panels 1PM01J, 02J, and 03J. Assembly #2 included 1PM07J and 1PM08J. Remaining Panels qualified by similarity.	
1PM04J	Generator and Transformer Recorder Panel	P	Aux. Bldg.		
1PM05J	Station Totalizing Panel.	P	Aux. Bldg.		
1PM06J	Leak Detection Panel	P	Aux. Bldg.		
1PM07J	HVAC and SGTS Panel	P	Aux. Bldg.		
1PM08J	Station Services Panel	P	Aux. Bldg.		
1PM09J	Fire Protection and Deluge Valve Control Panel.	P	Aux. Bldg.		
1PM13J	Excess Flow Check Valves Status Panel.	P	Aux. Bldg.		
1PM16J	345KV Switchyard Mimic Bus Panel.	P	Aux. Bldg.		

Specification No. H-2177
 Vendor: Fisher Controls

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page 15 of 57

Wm. H. Zimmer
 Project No. 4130-00

Rev. 00

Date 4-15-81

Equipment Number	Description	S e r i e s	C l a s s	Location		Qualification Method		Results
1PA02J	Misc. Auto. Control Panel.	P		Aux. Bldg.		<p>Finite Element Dynamic Analysis. EMD-003796 EMD-004328 A finite element dynamic analysis was performed using the program STARDYNE to determine the natural frequencies of the panel. An equivalent static analysis was then done to determine stresses in the panel. The peak value of the response spectrum curves at 2% damping was applied in each direction. OBE/DBE values of acceleration were: $h_1 = 1.0/1.5$ $h_2 = 1.0/1.5$ $V = 1.2/1.75$ Stresses from each load case were added using absolute sum method.</p>		<p>Natural frequencies were found to be: 18.74 Hz 18.87 Hz 21.28 Hz 23.73 Hz 28.32 Hz The stresses calculated by the program are within the allowable limits. Structural Integrity Demonstrated.</p>

Specification No. H-2185Vendor: Bingham Willamette

Wm. H. Zimmer

Project No. 4130-00SUMMARY OF
EQUIPMENT QUALIFICATIONPage A16 of 57Rev. 00Date 4-15-81

Equipment Number	Description	Series	Class	Location	Qualification Method	Results
LWR01PA LWR01PB LWR01PC LWR01PD	RBCCW Pumps	A		Reactor Building	Static Analysis Lowest $f_n > 66$ Hz	Acceleration levels used: $H_1 = 0.30g$, $H_2 = 0.36g$, $V = 0.70g$ Critical stress = 17,380 psi (allowable = 17,500 psi) Critical deflection = 0.0075" (allowable = 0.011") Analysis Vendor requalification not completed.
LE12C003 LE21C002 LE22C003 LE51C003	CSCS Water Leg Pumps	A		Reactor Building	Static Analysis Pump freq.: 49.7 Hz Driver freq.: 252 Hz	Acceleration levels used: $H_1 = 0.2g$, $H_2 = 0.28g$, $V = 0.14g$ Critical stress = 31,975 psi (allowable = 70,000 psi) Operability stated to be not effected even should contact occur on rotating parts. Analysis Vendor requal. not completed.

Specification No. H-2233B

Vendor: Bingham Willamette (Pumps)
Elec. Mach. Mfg. Co. (Motors)
 Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page 117 of 57
 Rev. 00
 Date 4-15-81

Equipment Number	Description	S e i s s	C l a s s	Location		Qualification Method		Results
IWS01PA IWS01PB IWS01PC IWS01PD	Service Water Pumps & Pump Motors	A		Service Water Pump Structure		Static Analysis, Pump Natural frequency: 45.9 Hz Static Analysis, Motor Natural frequency: 32 Hz		Acceleration levels used: $H_1 = H_2 = 0.90g$, $V = 0.65g$ Critical stress = 24,573 psi (allowable = 26,250 psi) Deflection = 0.0067" (Allow. = 0.011") Acceleration levels used: $H_1 = H_2 = 1.10g$, $V = 0.78g$ Critical stress = 11,250 psi (allowable = 40,000 psi) Deflection = 0.00202" (Allowable = 0.024" max.)

Specification No. H-2237
 Vendor: Rex Chainbelt Co.
 Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page 118 of 57
 Rev. 00
 Date 4/15/81

Equipment Number	Description	S e l e c t i o n	C l a s s i f i c a t i o n	Location		Qualification Method		Results
1WS03FA 1WS03FB 1WS04FA 1WS04FB	Traveling water screens	W		Service Water Pump Structure		Detailed dynamic analysis Natural freq. 17 Hz		Analysis by response spectrum Critical stress = 26.26 ksi (Allowable = 38.1 ksi)

Specification No. H- 2240
 Vendor: R. P. Adams
 Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page 111 of 507
 Rev. 1
 Date 1/15/71

Equipment Number	Description	Class. S. S.	Location	Qualification Method	Results
1WS02FA 1WS02FB	Service water strainers	P	Service Water Pump Structure	Detailed dynamic analysis Natural frequencies: 33 Hz	Analysis by response spectrum Critical stress = 29,147 psi (Allowable = 30,920 psi)
1CW03F	Cooling tower make-up water strainer	W	Cooling Tower	Static Analysis UBC, Zone 1	UBC acceleration = 0.05 g Critical stress = 1,230 psi (Allowable = 19,800 psi)

Specification No. H-2245
Vendor: Yuba Heat Transfer Co.

SUMMARY OF
EQUIPMENT QUALIFICATION

Page 100 of 57

Rev. 00

Date 7-15-81

Wm. H. Zimmer
Project No. 4130-00

Equipment Number	Description	S e l e c t i o n	C l a s s i f i c a t i o n	Location		Qualification Method		Results
IWR02AA IWR02AB IWR02AC	RBCCW Heat Exchanger	P		Reactor Building		Simplified Dynamic Analysis Natural freq.: H ₁ = Rigid, H ₂ =V=29.1, 32.6 Hz.		Acceleration levels used: H ₁ = 0.56g, H ₂ = 0.46g, V = 1.7 g Critical stress = 29,343 psi (Allowable = 35,000 psi) Structural Integrity Demonstrated for original qualification criteria. Requalification to T-Quencher criteria not completed.

Specification No. H-2256
 Vendor: Designed by S&L
 Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page 101 of 117
 Rev. 00
 Date 4-15-81

Equipment Number	Description	S e i s . C l a s s	Location	Qualification Method	Results
11N12S 11N13S	Nitrogen cylinder rack	P	Reactor Building	Detailed dynamic analysis Natural freq.: $H_1 = 37.2 \text{ Hz}$, $H_2 = 37.2 \text{ Hz}$, $V = 13.6 \text{ Hz}$ (\wedge modes)	Critical stress = 19,293 psi (Allowable = 25,500 psi) Deflections are negligible Structural Integrity Demonstrated.

Specification No. H-2273Vendor: Graver Tank

Wm. H. Zimmer

Project No. 4130-00

SUMMARY OF
EQUIPMENT QUALIFICATIONPage A22 of 57Rev. 00Date 4-15-81

Equipment Number	Description	Series	Class	Location	Qualification Method	Results
1B21-A001A 1B21-A001B 1B21-A001C 1B21-A001D	MSIV Accumulator tank	P		Prim. Cont.	Static analysis Natural freq.: $H_1 = H_2 = V = 34.6$ Hz	Accel. levels used: $H_1 = 0.55g, H_2 = 0.55g,$ $V = 1.20g$ Critical stress = 16,955 psi (Allowable = 21,600 psi)
					Static analysis Natural freq.: $H_1 = 52$ Hz, $H_2 = 122$ Hz, $V = 36$ Hz	Accel. levels used: $H_1 = 2.1$ g, $H_2 = 0.6$ g, $V = 2.8$ g Critical stress = 7,977 psi (Allowable = 9,020 psi)
1B21-A002A 1B21-A002B 1B21-A002C 1B21-A002D	MSIV Accumulator tanks	P		Prim. Cont.	Static analysis Natural freq.: $H_1 = H_2 = V = 34.6$ Hz	Accel. levels used: $H_1 = 0.55g, H_2 = 0.55g,$ $V = 1.20g$ Critical stress = 16,955 psi (Allowable = 21,600 psi)
					Static analysis Natural freq.: $H_1 = 390$ Hz, $H_2 = 1,725$ Hz $V = 107$ Hz	Accel. levels used: $H_1 = 0.36g, H_2 = 0.30$ g $V = 0.50g$ Critical stress = 5366 psi (Allowable = 9020 psi)

Specification No. H-2273Vendor: Graver Tank

Wm. H. Zimmer

Project No. 4130-00

SUMMARY OF
EQUIPMENT QUALIFICATIONPage 123 of 57Rev. 00Date 7-13-81

Equipment Number	Description	Series	Location	Qualification Method	Results
1B21-A003B 1B21-A003C 1B21-A003F 1B21-A003G 1B21-A003K 1B21-A003L	MSRV Accumulator tanks	P	Prim. Cont.	Static analysis Natural freq.: $H_1 = H_2 = V = 35 \text{ Hz}$	Accel. levels used: $H_1 = 0.55g, H_2 = 0.55g$ $V = 1.20g$ Critical stress = 16,241 psi (Allowable = 21,600 psi)
				Equivalent static analysis Natural freq.: $H_1 = 19.7 \text{ Hz}, H_2 = 35 \text{ Hz},$ $V = 44.5 \text{ Hz}$	Accel. levels used: $H_1 = 1.0 g, H_2 = 1.0g$ $V = 1.0g$ Critical stress = 22,800 psi (Allowable = 29,500 psi)
1B21-A004A/H 1B21-A004K 1B21-A004L 1B21-A004P 1B21-A004R 1B21-A004S	MSRV accumulator tanks	P	Prim. Cont.	Static analysis Natural freq.: $H_1 = H_2 = V = 34.6 \text{ Hz}$	Accel. levels used: $H_1 = 0.55g, H_2 = 0.55g$ $V = 1.20g$ Critical stress = 14,892 psi (Allowable = 16,440 psi)
				Equivalent static analysis Natural freq.: $H_1 = 854 \text{ Hz}, H_2 = 398 \text{ Hz},$ $V = 76 \text{ Hz}$	Accel. levels used: $H_1 = 1.2 g, H_2 = 1.2 g$ $V = 2.3g$ Critical stress = 29,238 psi (Allowable = 29,520 psi)

Specification No. H-2288
 Vendor: Refer to Equip. Status Sheets
 Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page A04 of 57
 Rev. 00
 Date 4-15-81

Equipment Number	Description	S e l e c t i o n C l a s s	Location	Qualification Method	Results
1VG05SA 1VG05SB	SGTS equipment trains	A	Reactor Building	Detailed dynamic analysis Natural freq.: 14.64 Hz, 31.9 Hz, 40.4 Hz	Max. stresses well within allowable limits at critical sections. Deflection analysis demonstrates operability of units.
1VG02CA 1VG02CB	SGTS primary supply Fans	A	Reactor Building	Static analysis (fan-motor-shaft assembly) Natural freq.: 229 Hz	Accel. levels used: H ₁ =9.45g, H ₂ =V=9.0g (Assem.) H ₁ =1.9g, H ₂ =3.2g, V=1.2g (Motor) Min. margin of safety (motor shaft) = 3.16 Min. margin of safety (foundation bolts) = 1.1 Min. margin of safety (base angle) = 1.0 Max. rotor assembly def = 0.002" (Allowable = 0.025") Fan-motor assembly subjected to limiting-load analysis; assembly capable of withstanding 8.10 g's

Specification No. H-2288

Vendor: Rerer to equip. status sheets

Wm. H. Zimmer

Project No. 4130-00

SUMMARY OF
EQUIPMENT QUALIFICATIONPage 105 of 57Rev. 00Date 4-15-81

Equipment Number	Description	Series Class	Location	Qualification Method	Results
1VG03CA 1VG03CB	SGTS cooling fans	A	Reactor Building	Static analysis (fan-motor assembly) Natural freq.: 182 Hz	Accel. levels used: $H_1=H_2=9.45$ g, $V=9.0$ g (Assem.) $H_1=1.9$ g, $H_2=3.2$ g, $V=1.2$ g (Motor) Min. margin of safety = 1.3 Max. rotor deflection = 0.00243" (Allowable = 0.013") Fan-motor assembly subjected to limiting-load analysis; Assembly capable of withstanding 39 g's
1VG04AA 1VG04AB	SGTS heating coils	A	Reactor Building	Detailed Dynamic Analysis Natural freq.: $H_1= 37.7$ Hz, $H_2= 11.1$ Hz, $V= 14.3$ Hz (System freq. = 56.6 Hz)	Accel. levels used: $H_1= 1.0$ g, $H_2=1.2$ g, $V= 0.9$ g Critical stress = 18,300 psi (Allowable = 38,800 psi) Operability demonstrated for original qualification criteria. Requalification to T-Quencher criteria not completed.

Specification No. H-2288

Vendor: Refer to equip. status sheets

Wm. H. Zimmer

Project No. 4130-00

SUMMARY OF
EQUIPMENT QUALIFICATION

Page 102 of 107

Rev. 03

Date 4-15-81

Equipment Number	Description	S e r i e s	C l a s s	Location	Qualification Method	Results
1VGL1YA 1VGL1YB	Backdraft dampers	A	Reactor Building	Equivalent static analysis Natural freq.: 90 Hz (min.) Equivalent static analysis Natural freq.: $H_1=V=90.6$ g, $H_2=$ rigid	Required acceleration levels: $H_1=H_2=1.12$ g, $V=1.28$ g Acceleration levels used: $H_1=H_2=V=10.0$ g Critical stress = 1,570 psi (Allowable = 20,000 psi) Accel. levels used: $H_1=10$ g, $H_2=10$ g, $V=10$ g Critical stress = 17,985 psi (Allowable = 18,000 psi) Critical deflection = 0.0025" (Allowable = 0.03")	
1VGL2YA 1VGL2YB	Backdraft Dampers	A	Reactor Building	Static analysis Natural freq.: 90 Hz (min.)	Required acceleration levels: $H_1=H_2=0.42$ g, $V=0.65$ g Acceleration levels used: H (Result.) = 1.0 g, $V=1.0$ g Critical stress = 10,333 psi (Allowable = 20,000 psi)	

Specification No. H-2288
 Vendor: American Air Filter

Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page 108 of 107

Rev. 00

Date 1/15/71

Equipment Number	Description	Series	Classification Location	Qualification Method	Results
	Hepa filters	P	1VG05SA 1VG05SB	Uniaxial sinusoidal test 2-8 Hz, 3.0 g input 8-600 Hz, 2.0 g input Natural freq. : $H_1=H_2 = 33.3 \text{ Hz}$ V = rigid	Operability (structural integrity) verified.
	SGTS pre-filters	P	1VG05SA 1VG05SB	Statis analysis Natural freq.: 226 Hz	Limit-load analysis performed and indicates failure at 366 g's Allowable stress = 22,000 psi Min. deflection margin of safety = 2.62
	Solenoid valve & piping	A	1VG05SA 1VG05SB	Uniaxial sine sweep 1-35 Hz; input: $H_1=H_2= 4.5 \text{ g}$, V = 3.0 g; Sweep: 15 sec./cycle Pseudo biaxial sine dwell @ 5, 10, 15, 21, 27, 31, 33 Hz Input: $H_1=H_2=4.5 \text{ g}$, V = 3.0 g	No resonances found Require acceleration levels: $H_1=H_2=1.12 \text{ g}$, V = 1.28 g Structural integrity and operability demonstrated.

Specification No. H-2288
 Vendor: American Air Filter

Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page 101 of 117

Rev. 00

Date 4-15-71

Equipment Number	Description	S e i s s	C l a s s	Location	Qualification Method	Results
	Solenoid Valve & Piping	A		IVG05SA IVG05SB	Uniaxial Sine Sweep 1-35 Hz; Input: $H_1=H_2=4.5\text{ g}$ $V=3.0\text{ g}$; Sweep: 15 sec/cycle Pseudo Biaxial Sine Dwell @ 5, 10, 15, 21, 27, 31, 32 Hz Input: $H_1=H_2=4.5\text{ g}$ $V=3.0\text{ g}$	No resonances found. Require acceleration levels: $H_1=H_2=1.12\text{ g}$, $V=1.28\text{ g}$ Structural integrity and operability demonstrated.
	Moisture Separator	P		IVG05SA IVG05SB	Uniaxial Sine Sweep 2-33 Hz (double sweep); Input: $H_1=H_2=0.2\text{ g}$, $V=0.1\text{ g}$ Biaxial Random Motion 1.25 - 31.5 Hz, 1/3 Octave	Natural frequencies: 26 Hz Horiz. TRS Envelops RRS Vert. TRS does not. Conservative analysis at critical locations showed stresses to be within allowables: Critical stress = 10,560 psi (allowable = 22,000 psi) Based on equivalent static analysis. Structural integrity verified.

Specification No. H-2290
 Vendor: Buffalo Forge Co.

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page 130 of 171

Wm. H. Zimmer
 Project No. 4130-00

Rev. 001

Date 11-15-81

Equipment Number	Description	S e l e c t i o n s	C l a s s	Location		Qualification Method		Results
1VC04CA 1VC04CB	Control Room HVAC Return Fans	A		Aux. Bldg.		Equivalent Static Analysis		Accelerations levels used: (Peak x 1.5): $H_1=H_2= 11.6 \text{ g}$, $V= 4.4 \text{ g}$ Critical stress = 43,440 psi (allowable = 45,000 psi) Critical deflection = 0.0044" (allowable deflection= 0.0184")
1VG01CA 1VG01CB	Reactor Building Recirculation Fans	A		Aux. Bldg.		Simplified Dynamic Analysis		Required acceleration levels: $H_1=H_2= 5.0 \text{ g}$, $V= 2.0 \text{ g}$ Critical stress = 31,537 psi (allowable = 45,000 psi) Critical deflection= 0.01752" (allowable deflection= 0.0288")
1VH01CA 1VH01CB 1VH01CC 1VH01CD	Service Water Pump Cooling Fan	A		Service Water Pump Structure		Equivalent Static Analysis Natural frequencies: <u>>36 Hz</u>		Acceleration levels used (Peak x 1.5): $H_1=H_2=3.0\text{g}$, $V = 3.3\text{g}$ Critical stress = 13,560 psi (allowable = 28,800 psi) Critical deflection = 0.00467" (allowable deflection= 0.062")

Specification No. H-2290Vendor: Buffalo Forge Co.

Wm. H. Zimmer

Project No. 4130-00

SUMMARY OF
EQUIPMENT QUALIFICATIONPage 131 of 57Rev. 02Date 4-15-81

Equipment Number	Description	Series	Location	Qualification Method	Results
1VX02CA 1VX02CC 1VX02XC	SWGR Heat Removal Fans	A	Aux. Bldg.	Equivalent Static Analysis Natural frequencies: <u>>79</u> Hz	Acceleration levels used: H ₁ = 3.0 g, H ₂ = 3.0 g, V= 3.2 g Critical Stress = 5,641 psi (Allowable Stress = 32,400 psi) Critical deflection = 0.0094" (Allowable Deflection= 0.093")
1VX04CA 1VX04CB 1VX04CC 1VX04CD 1FX04CE 1VX04CF	SWGR Heat Removal Fans	A	Aux. Bldg.	Equivalent Static Analysis Natural frequencies: <u>>31.4</u> Hz	Acceleration levels used: (Peak x 1.5): H ₁ =H ₂ =3.0g, V= 3.3g Critical Stress = 19,022 psi (Allowable = 28,000 psi) Critical deflection = 0.0281" (Allowable deflection = 0.14")
1VY01C 1VY02C 1VY04C	CSCS Equip. Room Cooling Fans	A	Reactor Building	Equivalent Static Analysis Natural frequencies: <u>>36</u> Hz	Acceleration levels used: (Peak x 1.5): H ₁ =H ₂ =3.0g, V = 3.3g Critical stress = 13,560 psi (Allowable = 28,800 psi) Critical deflection = 0.00467" (Allowable deflection = 0.062")
				Equivalent Static Analysis Natural frequencies: <u>>36</u> Hz	Acceleration levels used: (Peak x 1.5): H ₁ =H ₂ =3.0g, V = 3.3g Critical stress = 21,874 psi (Allowable = 28,800 psi) Critical deflection = 0.0047" (Allowable deflection = 0.015")

Specification No. H-2290

Vendor: Buffalo Forge Co.

Wm. H. Zimmer

Project No. 4130-00

SUMMARY OF
EQUIPMENT QUALIFICATION

Page 108 of 112

Rev. 50

Date 4-15-81

Equipment Number	Description	S e r i e s	C l a s s	Location		Qualification Method					
IVY03C	CSCS Equip. Room Cooling Fan	A		Reactor Building		Equivalent Static Analysis Natural frequencies: <u>>75 Hz</u>					
	Vibration Isolators	A		Fans (H-2290)		Equivalent Static Analysis					

Acceleration levels used:
(Peak x 1.5):
H₁=H₂=3.0g, V = 3.3g
Critical stress = 11,417 psi
(Allowable = 28,800 psi)
Critical deflection = 0.0044"
(Allowable deflection = 0.038")

Acceleration levels used:
H₁=H₂=2.2g, V = 2.3g
Critical stress = 15,762 psi
(Allowable = 28,800 psi)
Fans are to be hard mounted

Specification No. H-2293

Vendor: Trane Co.

Wm. H. Zimmer

Project No. 4130-00

SUMMARY OF
EQUIPMENT QUALIFICATION

Page A23 of 507

Rev. 00

Date 7-15-81

Equipment Number	Description	Classification	Location	Qualification Method	Results
IVC02CA IVC02CB	Control Room Condensing Units	A	Aux. Bldg.	Detailed Dynamic Analysis	Critical stress = 3,500 psi (Allowable = 3,500 psi) Critical deflection = 0.0039" (Allowable deflection= 0.0352")
IVX01CA IVX01CB IVX01CC IVX01CD IVX01CE IVX01CF	SWGR Heat Removal Condensing Units	A	Aux. Bldg.	Detailed Dynamic Analysis	Critical stress = 33,986 psi (Allowable = 34,000 psi) Critical deflection = 0.00198" (Allowable deflection= 0.0317")
IPLB3J IPLB4J IPLB5J IPLB6J IPLB7J IPLB8J IPLB9J IPLC1J	HVAC Condensing Unit Control Panels for IVC02CA/F	A	Aux. Bldg.	Biaxial Random Motion Test 1-40 Hz Fragility Test	TRS envelops RRS. Structural integrity and operability verified. Min. fragility level (random wave): H ₁ =5.0g, H ₂ =V=3.0g

Specification No. H-2298
 Vendor: Refer to Equip. Status Sht's.
 Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page 114 of 517
 Rev. 00
 Date 4-15-81

Equipment Number	Description	Classification	Location	Qualification Method	Results
1VC11XA 1VC11XB	Control Room HVAC Return Fan Silencers	A	Aux. Bldg.	Equivalent Static Analysis	Acceleration levels used: (Peak x 1.5): H ₁ =5.7g, H ₂ =11.4g, V = 4.2g Critical stress = 1,349 psi (Allowable = 1,721 psi) Structural integrity verified.
1FEVG001A 1FEVG001B	Air Flow Monitors	A	Reactor Building	Simplified Dynamic Analysis Natural frequencies: 117,405 Hz	Acceleration levels used: (Req'd) (Required): H ₁ =H ₂ =1.0g, V = 1.5g Critical stress = 3,113 psi (Allowable = 22,500 psi) No critical deflections.
1FEVG002A 1FEVG002B	Air Flow Monitors	A	Aux. Bldg.	Simplified Dynamic Analysis Natural frequencies: 15,75.3, 438 Hz	Acceleration levels used: (required): H ₁ =H ₂ =1.0g, V = 1.5g Critical stress = 13,444 psi (Allowable = 26,400 psi) Critical deflection = 0.0831" No effect on operability.

Specification No. H- 2299
 Vendor: Powers Regulator Co.

Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page A35 of 57

Rev. 00

Date 4-15-81

Equipment Number	Description	Series	Class	Location	Qualification Method	Results
1PL14JA 1PL14JB	Control Room Vent and Air Cond. Equipment Control Panel	A		Aux. Bldg.	Simplified Dynamic Analysis/ Detailed Dynamic Analysis/ Uniaxial Sine Sweep Test/ Uniaxial Sine Dwell Test	Vibration test to determine resonant freq: 8.7, 122, 15.7, 16.2 Hz. (Sweep: 0-35 Hz, 3 modes), cross-coupling noted. Structural integrity and opera- bility demonstrated by finite element analysis (response spectrum). Hand calculations supplemented the analysis: Critical stress = 12,920 psi (Allowable = 21,600 psi deflections were insignificant.
1PM19JA 1PM19JB 1PL60JA 1PL60JB 1PL60JC	Control Room Ionization Detection Relay Panels and Diesel Generator Room HVAC Control Panels	A		Aux. Bldg.	Simplified Dynamic Analysis/ Detailed Dynamic Analysis/ Uniaxial Sine Sweep Test/ Uniaxial Sine Dwell Test	Vibration test for resonance search: $f_n > 35\text{Hz}$. Structural integrity and opera- bility demonstrated by finite element analysis (response spectrum) hand calculations supplemented the analysis ($H_1=H_2=1.5$, $V = 2.5g$): Critical stress = 9,800 psi (Allowable = 25,200 psi) No critical deflections.

Specification No. H- 2299
 Vendor: Powers Regulator Co.

Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page A36 of 57

Rev. 00

Date 4-15-81

Equipment Number	Description	Series	Class Location	Qualification Method	Results
1PL6LJA 1PL6LJB	Service Water Pump Cooling Panels	A	Service Water Pump Structure	Uniaxial Sine Sweep Test 0-35 Hz Static Analysis	Closed-door case: Lowest $f_n > 35$ Hz response - 0.03 g's. Open-door case: frequency = 12.2 and 17.9 Hz (Damping of 2.9 & 2.5) Response - 0.10 and 0.23g's. Acceleration levels used: $H_1=0.20g$, $H_2=0.20g$, $V = 0.14g$ Critical section: factor of safety = 15 (min.), based on ZPA + 10% margin acceleration levels. Operability not effected.
1PL69JA 1PL69JB	SGTS Control Panels	A	Reactor Building	Uniaxial Sine Sweep Test 0-40 Hz Static Analysis	No resonant frequencies below 35 Hz. Acceleration levels used: $H_1=0.81g$, $H_2=0.74g$, $V = 4.5g$ (Critical stress = 36,000 psi) Structural integrity verified.
1PL9LJ	SWGR Heat Removal Control	A	Aux. Bldg.	Uniaxial Sine Sweep Test	Panel frequency: > 33 Hz (Open or closed door case) Door Frequency: 31.2, 31.9 Hz (Damping: 2.9, 2.5%) Response - 15h's.

Specification No. H-2299
 Vendor: Powers Regulator Co.
 Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page 127 of 131
 Rev. 00
 Date 4-15-71

Equipment Number	Description	S e r i e s . C l a s s	Location	Qualification Method	Results
1PL91J				Static Analysis	Acceleration levels used: $H_1=0.32$, $H_2=0.34$, $V = 0.70g$ Plus 1% margin. Stresses were a factor of 20 to 200 below yield. Operability not effected.

Specification No. H-2805
 Vendor: Bishopric
 Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page A-8 of 57
 Rev. 00
 Date 4-15-81

Equipment Number	Description	Sei s. .	Cl a s s	Location	Qualification Method	Results
IDG07TA IDG07TB IDG07TC	Diesel Oil Day Tanks 1A, 1B, 1C	P		Aux. Bldg.	Static Analysis OBE/SSE Input: $H_1=0.2g/0.41g$ (NS) $H_2=0.17g/0.31g$ (EW) $V=0.35g/0.55g$ Damping: 1.0%	Natural Freq. $H_1=H_2=33.$ Hz $V=182.$ Hz Worst Stresses: Shell Bending for 1.0g $\sigma_{calc} = 2.65$ ksi $S_{allow} = 22.6$ ksi Nozzles: OBE SSE $\sigma_{calc} = S_{allow} = 22.6$ ksi 24.7 ksi Anchor Bolts $\sigma_{calc} = 9.99$ 13.07 $S_{allow} = 63.$ 84.
IDG12TA IDG12TB IDB12TC	Diesel Generator Cooling Water Reservoir Tanks	P		Aux. Bldg.	Static Analysis SSE Input: $H_1=0.5g$ $H_2=0.5g$ $V=0.55g$ Damping: 1.0%	Natural Freq. $H_1=87.5$ Hz $H_2=195.$ $V=95.3$ Worst Stresses: OBE SSE Saddle/Shell $\sigma_{calc} = 10.1$ ksi 8.1 ksi $S_{allow} = 24.0$ 29.1

Specification No. H-2805
 Vendor: Bishopric
 Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page 1-4 of 57
 Rev. 00
 Date 4-15-81

Equipment Number	Description	S e r i e s	C l a s s i f i c a t i o n	Location	Qualification Method	Results															
1DG12TA 1DG12TB 1DG12TC	(Continued from previous page)				Anchor Bolts	<table border="0"> <tr> <td></td> <td>OBE</td> <td>SSE</td> </tr> <tr> <td>σ_{calc}</td> <td>= —</td> <td>1.8</td> </tr> <tr> <td>S_{allow}</td> <td>= —</td> <td>24.9</td> </tr> <tr> <td>τ_{calc}</td> <td>= —</td> <td>1.8</td> </tr> <tr> <td>S_{allow}</td> <td>= —</td> <td>13.3</td> </tr> </table>		OBE	SSE	σ_{calc}	= —	1.8	S_{allow}	= —	24.9	τ_{calc}	= —	1.8	S_{allow}	= —	13.3
	OBE	SSE																			
σ_{calc}	= —	1.8																			
S_{allow}	= —	24.9																			
τ_{calc}	= —	1.8																			
S_{allow}	= —	13.3																			
					Nozzle/Shell	<table border="0"> <tr> <td>σ_{calc}</td> <td>= 14.1</td> <td>25.2</td> </tr> <tr> <td>S_{allow}</td> <td>= 22.6</td> <td>27.4</td> </tr> </table>	σ_{calc}	= 14.1	25.2	S_{allow}	= 22.6	27.4									
σ_{calc}	= 14.1	25.2																			
S_{allow}	= 22.6	27.4																			

Specification No. H-2805
 Vendor: Bishopric
 Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page A40 of 57
 Rev. 00
 Date 4-15-81

Equipment Number	Description	Series	Class	Location		Qualification Method								
1WR03TA 1WR03TB	RBCCW Expansion Tanks	P		Rx. Bldg.		Static Analysis OBE/SSE Input $H_1=0.36g/0.53g$ (NS) $H_2=1.125g/0.9g$ (EW) $V=0.9/0.9g$ Damping 1.0%								
1DG13TA 1DG13TB 1DG13TC	Diesel Generator Cooling Water Reservoir Tanks	P		Aux. Bldg.		Static Analysis SSE Input: $H_1=H_2=0.5g$ $V=0.55g$ Damping: 1.0%								

Natural Freq.
 $H_1=14.8$ $H_2=67.9$ $V=65.4$ Hz
 Worst Stresses: OBE
 Anchor Bolts $\sigma_{calc} = 29.8$
 $S_{allow} = 63.0$
 $\tau_{calc} = 15.0$
 $S_{allow} = 31.5$
 Shell/Saddle OBE SSE
 $\sigma_{calc} = 20.97$ 21.8
 $S_{allow} = 22.6$ 24.7

Natural Freq.
 $H_1=68$ Hz $H_2=169$
 $V=239$
 Worst Stresses: OBE SSE
 Saddle $\sigma_{calc} = 5.67$ 6.92
 $S_{allow} = 24.7$ 29.1
 Nozzle/Shell
 $\sigma_{calc} = 11.58$ 20.7
 $S_{allow} = 22.6$ 27.4

Specification No. H-2805
 Vendor: Bishopric
 Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page A41 of 57
 Rev. 00
 Date 4-15-81

Equipment Number	Description	S e i s .	C l a s s	Location	Qualification Method	Results
1DG13TA 1DG13TB 1DG13TC	(Continued from previous page)					Bolts: $\sigma_{calc} =$ — OBE 1.825 SSE $S_{allow} =$ — 24.9 $\tau_{calc} =$ — 1.754 $S_{allow} =$ — 13.3
1DG14TA 1DG14TB 1DG14TC 1DG14TD 1DG14TE 1DG14TF	Diesel Generator Cooling Water Expansion Tanks	P		Aux. Bldg.	Static Analysis SSE Input: $H_1 = 0.5g$ $H_2 = 0.46g$ $V = 0.7g$ Damping: 1.0%	Natural Freq. $H_1 = 28.6$ $H_2 = 227.$ $V = 259.$ Worst Stresses: OBE SSE Shell Saddle $\sigma_{calc} =$ — 15.7 $S_{allow} =$ — 20.6 Saddle $\sigma_{calc} =$ 9.63 13.67 $S_{allow} =$ 12.6 18.9 Anchor Bolts $\sigma_{calc} =$ 6.03 9.57 $S_{allow} =$ 12.6 18.9 Nozzle $\sigma_{calc} =$ — 34.1 $S_{allow} =$ — 34.1

Specification No. H-2805Vendor: Bishopric

Wm. H. Zimmer

Project No. 4130-00

SUMMARY OF
EQUIPMENT QUALIFICATIONPage 412 of 57Rev. 00Date 4-15-81

Equipment Number	Description	Series	Class	Location	Qualification Method	Results
1DG15TA 1DG15TB 1DG15TC 1DG15TD 1DG15TE 1DG15TF 1DG15TG 1DG15TH 1DG15TI 1DG15TJ 1DG15TK 1DG15TL	Air Receiver Tanks	P		Aux. Bldg.	Static Analysis Input: $H_1=H_2=0.41g$ $V=0.55g$ Damping 1.0%	Natural Freq. $H_1=H_2=81.1 Hz$ $V=297. Hz$ Worst Stresses: Hoop Stress $\sigma_{calc} = 8.26 ksi$ $S_{allow} = 13.70$ Beam Stress $\sigma_{calc} = 4.13$ $S_{allow} = 13.70$ Skid Bolt (SSE) $\sigma_{calc} = 8.71$ $S_{allow} = 12.60$
1D001TA 1D001TB 1D001TC	Diesel Oil Storage Tanks	P		Aux. Bldg.	Static Analysis Input: $H_1=H_2=0.30g$ $V=0.70g$ Damping 1.0%	Natural Freq. $H=49.3$ $V=49.3$ Worst Stresses: SSE At Support $\tau_{calc} = 13.20 ksi$ $S_{allow} = 15.00$ Tank is Buried In Sand

Specification No. H-2812
Vendor: C&D Batteries Co.

Wm. H. Zimmer
Project No. 4130-00

SUMMARY OF
EQUIPMENT QUALIFICATION

Page 413 of 577

Re 00

Date 4-15-81

Equipment Number	Description	S e r i e s	C l a s s	Location		Qualification Method			
1DC13EB 1DC13EC	125-V Battery Chargers	A	Aux. Bldg.	Biaxial Test, Random Motion Resonance Search 1-35Hz		TRS Graph envelopes required response spectra. Test requirements exceeded specs. Post-Testing functional operability verified.			

Specification No. H-2816Vendor: Balmson Co.

Wm. H. Zimmer

Project No. 4130-00SUMMARY OF
EQUIPMENT QUALIFICATIONPage 11 of 17Rev. 20Date 1/18/81

Equipment Number	Description	Section	Location	Qualification Method	Results
IVC08SA IVC08SB IVC13AA IVC13AB	Control Room HVAC Air Handling Units Control Room HVAC Cooling Coils	A	Aux. Bldg.	Static Analysis Finite Element Analysis Input: Cabinet & Coils $H_1=H_2=0.62g$ $V=1.7g$ Damping: 1.0%	Natural Frequencies: Coils: $f_n = 57.5Hz$ Coil Support: $f_n=33.Hz$ Coil Fin Crush Press: $\sigma_{calc} = 3.43psi$ $S_{allow} = 6.5psi$ Nozzle Bolts $\sigma_{calc} = 2.29ksi$ $S_{allow} = 20.$ $\tau_{calc} = 0.81$ $S_{allow} = 10.0$ Cabinet Nat. Freq. $f_n = 36.Hz$ Cab. Worst Stresses: $\sigma_{calc} = 5.02ksi$ $S_{allow} = 21.6$ $\tau_{calc} = 0.67$ $S_{allow} = 10.8$ Anchor Bolts: $\sigma_{calc} = 17.95ksi$ $S_{allow} = 40.0$ $\tau_{calc} = 5.24$ $S_{allow} = 21.6$

Specification No. H-2816
 Vendor: Bahnson

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page 1145 of 57

Wm. H. Zimmer
 Project No. 4130-00

Rev. 00

Date 4-10-81

Equipment Number	Description	Series	Classes	Location	Qualification Method	Results
1VC13YA 1VC13YB 1VC14YA 1VC14YB 1VC15YA 1VC15YB 1VC16YA 1VC16YB	Air Foil Dampers	A		Aux. Bldg. In Equipm't No. 1VC08SA,B	Biaxial Test, Random Motion Freq. Range 1-40.Hz Req'd Input: $H_1=H_2=0.62g$ $V=0.68g$ Test Response/Input: $H_1=H_2=20g/5g$ $V=15g/5g$	Natural Freq. Damper Blade $f_n=11.Hz$ Multi-Zone Damper Blade $f_n=13.Hz$ $f_n=14.Hz$ Functionally Operable
1VH03AA 1VH03AB 1VH03AC 1VH03AD	Service Water Pump Cooling System Heat Exchangers & Cooling Coils	A		Service Water Pump Structure	Static Analysis Finite Element Analysis Req'd Input: $H_1=H_2=0.2g$ $V=0.14g$ Damping: 1.0%	Natural Freq. Coil Bank: $f_n=35.4Hz$ Header Assembly: $f_n=33.Hz$ Coil Support: $f_n=43.5Hz$ Worst Stresses: SSE Anchor Bolts: $\sigma_{calc} = 9.29ksi$ $S_{allow} = 40. ksi$ $\tau_{calc} = 3.89ksi$ $S_{allow} = 21.6 ksi$ Nozzle Pipe: $\sigma_{calc} = 13.15ksi$ $S_{allow} = 32.4$ Coil Perimeter Bolts: $\sigma_{calc} = 7.42ksi$ $S_{allow} = 20.0 ksi$ $\tau_{calc} = 5.64ksi$ $S_{allow} = 10.0 ksi$

Specification No. H-2816Vendor: Bahnson

Wm. H. Zimmer

Project No. 4130-00

SUMMARY OF
EQUIPMENT QUALIFICATIONPage 116 of 317Rev. 00Date 4-10-81

Equipment Number	Description	Series	Location	Qualification Method	Results
1VX03SA 1VX03SB 1VX03SC 1VX03SD 1VX03SE 1VX03SF	SWGR Heat Removal Air Handling Units	A	Aux. Bldg.	Static Analysis Finite Element Analysis Req'd Input: $H_1=H_2=0.46g$ $V=0.95g$ Damping: 1.0%	Natural Freq. Tube: $f_n=60$ Hz Coil Support: $f_n=33$ Hz Worst Stresses Nozzle Bolt: ksi $\sigma_{calc}=2.96$ $S_{allow}=20.0$ $\tau_{calc}=1.045$ $S_{allow}=10.0$
1VX05AA 1VX05AB 1VX05AC 1VX05AD 1VX05AE 1VX05AF	SWGR Heat Removal Cooling Coils	A	1VX03SA 1VX03SB 1VX03SC 1VX03SD 1VX03SE 1VX03SF	Static Analysis Req'd Input: $H_1=H_2=0.46g$ $V=0.55g$ Damping: 1.0%	Natural Freq. Coils: $f_n=51.5$ Hz $f_n=75.7$ Worst Stresses Anchor Bolts $\sigma_{calc}=6.01$ ksi $S_{allow}=40.0$ $\tau_{calc}=2.47$ $S_{allow}=21.6$
1VX06FA 1VX06FB 1VX06FC 1VX06FD 1VX06FE 1VX06FF	Air Handling Unit Filters	A	1VX03SA 1VX03SB 1VX03SC 1VX03SD 1VX03SE 1VX03SF	Plant Usage Experience and Engineering Judgement	The frame and keeper slot are adequate to hold the light weight filter elements at pressures much higher than an anticipated seismic event in combination with normal operation.

Specification No. H-2816

Vendor: Bahnson

Wm. H. Zimmer

Project No. 4130-00

SUMMARY OF
EQUIPMENT QUALIFICATION

Page 1117 of 592

Rev. 30

Date 11/15/81

Equipment Number	Description	Series	Class	Location		Qualification Method		Results
1VY05A 1VY06S 1VY08A 1VY09A	CSCH-RHR Equip. Room Heat Exchanger and Cooling Coil	A		Rx. Bldg.		Static Analysis Finite Element Analysis Req'd Input: $H_1=H_2=0.67g$ $V=1.2g$		Natural Freq. Coils: $f_n=35.2Hz$ $f_n=36.0$ Tube: $f_n=43.0$ Support: $f_n=53.0$ Header Assembly: $f_n=33.$ Worst Stresses: Beam $\sigma_{calc}= 6.92ksi$ $S_{allow}= 21.6$ $\tau_{calc}= 3.47$ $S_{allow}=10.8$ Anchor Bolts $\sigma_{calc}= 36.9ksi$ $S_{allow}= 48.6$ $\tau_{calc}= 11.82$ $S_{allow}= 24.3$ Nozzle Pipe Stress $\sigma_{calc}= 13.5ksi$ $S_{allow}= 35.0$ Structural Integrity Demonstrated for original qualification criteria. Requalification to T-Quencher criteria not completed.

Specification No. H-2816

Vendor: Bahnson

Wm. H. Zimmer

Project No. 4130-00

SUMMARY OF
EQUIPMENT QUALIFICATION

Page 118 of 511

Rev. 00

Date 4-15-81

Equipment Number	Description	Series	Class	Location	Qualification Method	Results
1RG10M 1RG20M	Angle Line Strainer	P		Aux. Bldg.	Uniaxial Sine Sweep & Multi-Axis 1-33Hz Sine Dwell 1 Octave/Minute Sweep 2 Required Input: (Peak x 1.5) H ₁ =H ₂ =4.2g V=2.85g	g-Level Qualification By Testing: H ₁ =8.8g H ₂ =9.2g V=6.4g Structural Integrity Demonstrated
1RG11MA 1RG11MB 1RG21MA 1RG21MB 1RG21MC 1RG21MD 1RG21ME 1RG21MF	Filter Drier	P		Aux. Bldg.	Uniaxial Sine Sweep & Multi-Axis Sine Dwell 1-33Hz Required Input: (Peak x 1.5) H ₁ =H ₂ =4.2g V=2.85g	g-Level Qualification By Testing: H ₁ =8.8g H ₂ =9.2g V=6.4g Structural Integrity Demonstrated
1RG12M 1RG22M	Moisture-Liquid Indicator	P		Aux. Bldg.	Pseudo-Biaxial, Sine Dwell and Sine Sweep 1-33Hz Required Input: H ₁ =H ₂ =V=4.2g	g-Level Qualification By Testing: H ₁ =4.8g H ₂ =9.2g V=5.0g Structural Integrity Demonstrated

Specification No. H-2817

Vendor: CVI Co.

Wm. H. Zimmer

Project No. 4130-00

SUMMARY OF
EQUIPMENT QUALIFICATION

Page A49 of 57

Rev. 00

Date 4-15-81

Equipment Number	Description	Series	Class Location	Qualification Method	Results
1VC05CA 1VC05CB	Control Room HVAC Standby Make-Up Fan	A	Aux. Bldg.	Static Analysis Accelerations OBE/SSE Horizontal: .37g/.62g Vertical: 1.95g/2.70g Damping: 1.0% Rigid Support Considerations in the model.	Natural Freq. $H_1=8$ $H_2=89$ Hz $V=115.5$ Worst Stresses Motor Hold-Down Bolts: OBE/SSE Calc. Stresses: 0.40ksi/0.73ksi Allow. Stresses: 13.1ksi/21.8ksi Foundation Bolts: Calc. Stresses: 0.40ksi/0.75ksi Allow. Stresses: 20.5ksi/34.2ksi Deflection: 5.5(10) ⁻³ in. No effect on functional operation. Fan Shaft: OBE/SSE Shear Stress: 618/838 psi Allowable: 9660/13110 psi Tensile Stress: 1207/1655 psi Allowable: 16100/21850 psi

Specification No. H-2817
 Vendor: CVI Co.

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page 150 of 57

Rev. 00

Date 4-15-81

Wm. H. Zimmer
 Project No. 4130-00

Equipment Number	Description	S e r i e s	C l a s s	Location	Qualification Method	Results
1VC09SA 1VC09SB 1VC10S	Control Room HVAC Filter Packages	A		Aux. Bldg.	Static Analysis Accelerations OBE/SSE $H_1: 0.5g/0.75g$ $H_2: 0.34g/0.5g$ $V: 1.9g/2.2g$ Damping: 1%, 2% Rigid Support Conditions	Natural Freq. $H_1=20.3$ Hz $H_2=20.3, 35.5$ Hz $V=19.3$ Hz Worst Stresses Charcoal Screen: Calc Avg $\sigma = 28.0$ ksi Peak $\sigma = 48.7$ Allow $S = 60.0$ Anchor Bolts: $\sigma_{calc} = 11.21$ ksi $\tau_{calc} = 2.33$ $S_{allow} = 32.4$ HEPA Mount. Frame $\sigma_{calc} = 26.3$ ksi $S_{allow} = 28.2$ Fan Struct. Anchor Brackets $\sigma_{calc} = 31.9$ ksi $S_{allow} = 32.4$ No critical deflections Structural Integrity Demonstrated

Specification No. H-2817
 Vendor: CVI Co.

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page 151 of 57

Wm. H. Zimmer
 Project No. 4130-00

Rev. 00

Date 4-15-71

Equipment Number	Description	Series	Class	Location	Qualification Method	Results
1VC12AA 1VC12AB	Filter Package Heat Coils Weight: 39.1bs Mounted w/6-3/8"Ø Bolts	A		Aux. Bldg.	Uniaxial & Multi-Axis Sine Sweep 2-50 ^{Hz}	Natural Freq. H ₁ =10. ^{Hz} , 14. ^{Hz} H ₂ =5., 38. V=4., 13., 22. g-Level Qualification By Testing: H ₁ =H ₂ =V=0.55g Structural Integrity Demonstrated
1VC93Y 1VC94Y	Filter Package Backflow Dampers	A		Aux. Bldg.	Equivalent Static Analysis Rigid Support Conditions Damping: 0.5%, 1% Accelerations ORE/SSE Horizontal: 7.8g/7.2g Vertical: 2.9g/2.6g	Natural Freq. f _n =22.2 ^{Hz} Worst Stresses Blade/Shaft: σ _{calc} =4.56 ksi S _{allow} =24.0 τ _{calc} =3.67 S _{allow} =14.5 Support Angle σ _{calc} =25.4 ksi S _{allow} =28.6 ksi

Specification No. H-2834

Vendor: Automation Industries, Vitro Labs Div.

Wm. H. Zimmer

Project No. 4130-00

SUMMARY OF
EQUIPMENT QUALIFICATION

Page 152 of 57

Rev. 00

Date 4-15-61

Equipment Number	Description	S e r i e s	C l a s s Location	Qualification Method	Results
1PL12JA 1PL12JB 1PL12JC	Essential Relay Panels 1A, 1B, 1C	A	Aux. Bldg.	Biaxial Random Motion; Freq. Range: 1-35. Hz	Natural Freq. H ₁ =12.5, 12.75, 12.8, 19.5, 20. Hz H ₂ =4.9, 5.0, 5.1 Hz V=20.5, 23.0, 25.0 Hz TRS Graphs Envelope Required Response Spectra - Functional Operability Verified

Specification No. H-2835
Vendor: Unit Elect. Control

Wm. H. Zimmer
Project No. 4130-00

SUMMARY OF
EQUIPMENT QUALIFICATION

Page 153 of 517

Rev. 00

Date 4-15-81

Equipment Number	Description	S e r i e s C l a s s	Location	Qualification Method	Results
1PL67JA 1PL67JB	Remote Shutdown Panels 1A, 1B	A	Aux. Bldg.	Biaxial Random Motion Test Freq. Range: 1-40 ^{Hz}	TRS Graphs Envelope Required Response Spectra - Functional Opera- bility Verified. Natural Frequencies: Front to Back: 8,40,80 Hz Side to Side: 12.5,40 Hz

Specification No. H-2836

Vendor: Chemtron Corp.

Wm. H. Zimmer

Project No. 4130-00

SUMMARY OF
EQUIPMENT QUALIFICATION

Page 104 of 59

Rev. 00

Date 9-15-81

Equipment Number	Description	S e r i e s	C l a s s	Location		Qualification Method		Results
1PLC7JA 1PLC7JB 1PLC7JC 1PLC7JD	CO ₂ Fire Protection Panels	P		Aux. Bldg.		Biaxial Random Motion Test Freq. Range: 1-40 ^{Hz}		TRS Graphs Envelope Required Response Spectra - Functional Opera- bility Verified Natural Frequencies: None in 1-100 Hz range

Specification No. H-2849
 Vendor: Crane Co.
 Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page 155 of 57
 Rev. 00
 Date 4-15-81

Equipment Number	Description	Class	Location	Qualification Method	Results
1D002PA 1D002PB 1D002PC	Diesel Fuel Oil Transfer Pumps	A	Aux. Bldg.	Static Analysis; Finite Element Dynamic Analysis Accelerations: OBE/SSE Horizontal: .5g/1.0g Verti .7g/1.0g	Natural Freq. $f_n = 127. \text{ Hz}$ Worst Stresses SSE Pump Hold Down Bolts: $\tau_{\text{calc}} = 19.7 \text{ ksi}$ $S_{\text{allow}} = 23.4$ $\sigma_{\text{calc}} = 39.6$ $S_{\text{allow}} = 54.6$ Shaft: $\sigma_{\text{calc}} = 19.6 \text{ ksi}$ $S_{\text{allow}} = 26.2$ Pump Head to Hous. Bolt.: $\tau_{\text{calc}} = 5.87 \text{ ksi}$ $S_{\text{allow}} = 12.32$ $\sigma_{\text{calc}} = 36.7$ $S_{\text{allow}} = 40.0$ Rotor/Stator Clear.: Calc $\Delta = 0.00229''$ Allow $\Delta = 0.012''$

Specification No. H-2861
 Vendor: Joy Manufacturing

Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page 156 of 177

Rev. 03

Date 4-15-81

Equipment Number	Description	Series	Location	Qualification Method	Results
IVC03CA IVC03CB	Control Room HVAC Fans 1A, 1B WT = 1.96 ^k	A	Aux. Bldg.	Statis Analysis Required Input: H ₁ = 3.9g H ₂ = 7.8g V = 2.9g Damping: 1/2% OBE	Natural Freq. H ₁ = 2775. Hz H ₂ = 425. V = 200. Worst Stress Anchor Bolt (Isolator To Fan): σ _{calc} = 47.4 ^{ksi} S _{allow} = 55.0 Deflections of Shaft Δ _{calc} = 0.0062" Δ _{allow} = 0.100"
IVD01CA IVD01CB IVD01CC	DG Room Vent. Fan Wt = 2.46 ^K	A	Aux. Bldg.	Static Analysis Required Input: H ₁ = 1.6g H ₂ = 2.0g V = 2.2g Damping: 1/2% OBE	Natural Freq. H ₁ = 1866. Hz H ₂ = 379. V = 146. Worst Stresses Anchor Bolt (Isolator To Fan): σ _{calc} = 23.6 ^{ksi} S _{allow} = 55.0 Deflection of Shaft Δ _{calc} = 0.0025 Δ _{allow} = 0.160

Specification No. H-2870
 Vendor: Chemelex Corp.
 Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page A57 of 57
 Rev. 00
 Date 4-5-91

Equipment Number	Description	S e r i e s	Location	Qualification Method	Results
1PLE7JA 1PLE7JB 1HT01E 1HT02E	Heat Trace Control Panel & Transformer	A	Aux. Bldg.	Biaxial Random Motion Frequency Range: 1-33Hz @ 1/6 Band Width Resonance Survey 1-40Hz	Natural Freq. H ₁ = 19., 20.5, 23. Hz H ₂ = 4.75, 19, 21. Hz V = 17.5 Hz TRS Graph Envelopes Required Response Spectra

Specification No. H-2289Vendor: Refer Below

Wm. H. Zimmer

Project No. 4130-00SUMMARY OF
EQUIPMENT QUALIFICATIONPage B1 of 83Rev. 00Date 4-15-81

Equipment Number	Description	Series	Class	Location	Qualification Method	Results
1VG03YA/B	Isolation Dampers (Pacific Power (Damper) Controlmatics (M.Oper) Namco (Limit Switches))	A		Aux.Bldg.	Equivalent Static Analysis Method Simplified Dynamic Analysis	Acceleration Levels Used: $H_1 = H_2 = V = 7.7 \text{ g}$ critical stress = 30,251psi (Allowable = 34,200 psi) Lowest $f_n = 18 \text{ Hz}$ Max. Calc. Acceleration: $H_1 = .48\text{g}, H_2 = .61\text{g}$ $V = 2.4\text{g}$ Therefore, past analysis (Above) by equivalent static analysis method applies.
1VG04YA/B	Isolation Dampers (Pacific Power (Damper) Controlmatics (M.Oper) Namco (Limit Switches))	A		Aux.Bldg.	Equivalent Static Analysis Method Simplified Dynamic Analysis	Acceleration Levels Used: $H_1 = H_2 = V = 7.7 \text{ g}$ Critical Stress = 30,251psi (Allowable = 34,200 psi) Lowest $f_n = 18 \text{ Hz}$ Max. Calc. Acceleration: $H_1 = .66\text{g}, H_2 = .8\text{g}$ $V = 1.7\text{g}$ Therefore, past analysis (Above) by equivalent static analysis method applies.

Specification No. H-2298

Vendor: Refer Below

Wm. H. Zimmer

Project No. 4130-00

SUMMARY OF
EQUIPMENT QUALIFICATIONPage 62 of 83Rev. 00Date 4-15-81

Equipment Number	Description	Series	Class	Location	Qualification Method	Results
1VC07Y	Backdraft Isolation Damper (AIR Balance, Model: SND-116)	P		Auxiliary	Uniaxial Sine Sweep 5-50 Hz, Input: $H_1 = 25$ g, $H_2 = 4.5$ g, $V = 2.0$ g Uniaxial Sine Dwell @ Resonant Freq.	Nat. Frequencies: $f_1 = 33$ Hz, $f_2 = 30$ Hz, $f_v = 33$ Hz Response: 25 g, 9.5 g, and 20 g, respectively. Operability (Structural integrity) Demonstrated.
1VC18YA/B	Backdraft Isolation Damper (AIR Balance, Model: SND-116)	P		Auxiliary	Uniaxial Sine Sweep 5-50 Hz, Input: $H_1 = 25$ g, $H_2 = 4.5$ g, $V = 2.0$ g Uniaxial Sine Dwell @ Resonant Freq.	Nat. Frequencies: $f_1 = 33$ Hz, $f_2 = 30$ Hz, $f_v = 33$ Hz Response: 25 g, 9.5 g, and 20 g, respectively. Operability (Structural integrity) Demonstrated.
1VC19YA/B	Fire Damper, Curtain Type (AIR Balance, Model: 319)	P		Auxiliary	Uniaxial Sine Sweep 5-60 Hz, Input 0.4 g Uniaxial Sine Dwell Dwell at 20 Hz	Nat. Frequency: 37 Hz Response: 3.50 g. Operability (Structural integrity) demonstrated during and after test. No weld defects.

Specification No. H-2298Vendor: Refer Below

Wm. H. Zimmer

Project No. 4130-00

SUMMARY OF
EQUIPMENT QUALIFICATIONPage 83 of 83Rev. 00Date 4-15-81

Equipment Number	Description	Series	Class	Location	Qualification Method	Results
IVC21YA/B	Backdraft Isolation Damper (AIR Balance, Model: SND-116)	P		Auxiliary	Uniaxial Sine Sweep 5-50 Hz, Input: $H_1 = 25$ g, $H_2 = 4.5$ g, $V = 2.0$ g. Uniaxial Sine Dwell @ Resonant Freq.	Nat. Frequencies: $f_1 = 33$ Hz, $f_2 = 30$ Hz, $f_v = 33$ Hz. Response: 25 g, 9.5 g, and 20 g, respectively. Operability (Structural integrity) Demonstrated.
IVC22YA/B	Fire Damper, Curtain Type (AIR Balance, Model: 319)	P		Auxiliary	Uniaxial Sine Sweep 5-60 Hz, Input 0.4 g. Uniaxial Sine Dwell Dwell at 20 Hz	Nat. Frequency: 37 Hz Response: 3.50 g. Operability (Structural integrity) Demonstrated during & after test. No weld defects.
IVC23YA/B	Fire Damper, Curtain Type (AIR Balance, Model: 319)	P		Auxiliary	Uniaxial Sine Sweep 5-60 Hz, Input 0.4 g. Uniaxial Sine Dwell Dwell at 20 Hz	Nat. Frequency: 37 Hz Response: 3.50 g. Operability (Structural integrity) Demonstrated during & after test. No weld defects.
IVC25YA/B	Backdraft Isolation Damper (AIR Balance, Model: SND-116)	P		Auxiliary	Uniaxial Sine Sweep 5-50 Hz, Input: $H_1 = 25$ g, $H_2 = 4.5$ g, $V = 2.0$ g. Uniaxial Sine Dwell @ Resonant Freq.	Nat. Frequencies: $f_1 = 33$ Hz, $f_2 = 30$ Hz, $f_v = 33$ Hz. Response: 25 g, 9.5 g, and 20 g, respectively. Operability (Structural integrity) Demonstrated.

Specification No. H-2298
 Vendor: Refer Below

Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page 84 of 83
 Rev. 00
 Date 4-15-81

Equipment Number	Description	S e l e c t i o n	C l a s s i f i c a t i o n	Location	Qualification Method	Results
1VC28Y	Opposed Blade Balancing Damper (Waldinger)	P		Auxiliary	Static Analysis Simplified Dynamic Analysis	Lowest $f_n = 24.8$ Hz Acceleration Levels Used: $H_1 = 1.00$ g, $H_2 = 1.00$ g, $V = 1.25$ g. Lowest $f_n = 105$ Hz Acceleration Levels Used: 5.0 g in all directions critical stress = 26,615 psi (Allowable = 32,000 psi) Max. Calc. Accelerations: $H_1 = .78$ g, $H_2 = .76$ g, $V = .68$ g.
1VC30YA/B	Backdraft Isolation Damper (AIR Balance, Model: SND-116)	P		Auxiliary	Uniaxial Sine Sweep 5-50 Hz, Input: $H_1 = 25$ g, $H_2 = 4.5$ g, $V = 2.0$ g. Uniaxial Sine Dwell @ Resonant Freq.	Nat. Frequencies: $f_1 = 33$ Hz, $f_2 = 30$ Hz, $f_v = 33$ Hz. Response: 25 g, 9.5 g, and 20 g, respectively. Operability (Structural integrity) Demonstrated.

Specification No. H-2298Vendor: Refer Below

Wm. H. Zimmer

Project No. 4130-00

SUMMARY OF
EQUIPMENT QUALIFICATIONPage B5 of 83Rev. 00Date 4-15-81

Equipment Number	Description	Series	Class	Location	Qualification Method	Results
IVC32YA/B	Backdraft Isolation Damper (AIR Balance, Model: SND-116)	P		Auxiliary	Uniaxial Sine Sweep 5-50 Hz, Input: $H_1 = 25$ g, $H_2 = 4.5$ g, $V = 2.0$ g. Uniaxial Sine Dwell @ Resonant Freq.	Nat. Frequencies: $f_1 = 33$ Hz, $f_2 = 30$ Hz, $f_v = 33$ Hz. Response: 25 g, 9.5 g, and 20 g, respectively. Operability (Structural integrity) Demonstrated.
IVC33YA	Opposed Blade Balancing Damper (Waldinger)	P		Auxiliary	Static Analysis Simplified Dynamic Analysis	Lowest $f_n = 24.8$ Hz Acceleration Levels Used: $H_1 = 1.00$ g, $H_2 = 1.00$ g, $V = 1.25$ g. Lowest $f_n = 29$ Hz Acceleration Levels Used: 5.0 g in all directions critical stress = 26,615 psi (Allow. = 32,000 psi) Max. Calc. Accelerations: $H_1 = .48$ g, $H_2 = 4.82$ g, $V = 2.36$ g.

Specification No. H-2298
 Vendor: Refer Below
 Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page 86 of 83
 Rev. 00
 Date 4-15-81

Equipment Number	Description	S e r i e s	C l a s s	Location	Qualification Method	Results
1VC33YB	Opposed Blade Balancing Damper (Waldinger)	P	Auxiliary	Static Analysis Simplified Dynamic Analysis	Lowest $f_n = 24.8$ Hz Acceleration Levels Used: $H_1 = 1.00$ g, $H_2 = 1.00$ g, $V^1 = 1.25$ g. Lowest $f_n = 29$ Hz Acceleration Levels Used: 5.0 g in all directions Critical stress = 26,615 psi. (Allowable = 32,000 psi) Max. Calc. Accelerations: $H_1 = .48$ g, $H_2 = 1.96$ g, $V^1 = .62$ g.	
1VC34Y	Fire Damper (AIR Balance, Curtain Type: Model: 319)	P	Auxiliary	Uniaxial Sine Sweep 5-60 Hz, Input 0.4 g. Uniaxial Sine Dwell Dwell at 20 Hz	Nat. Frequency: 37 Hz Response: 3.50 g. Operability (Structural integrity) Demonstrated during & after Test. No weld defects.	
1VC35Y	Fire Damper, Curtain Type (AIR Balance, Model: 319)	P	Auxiliary	Uniaxial Sine Sweep 5-60 Hz, Input 0.4 g. Uniaxial Sine Dwell Dwell at 20 Hz.	Nat. Frequency: 37 Hz Response: 3.50 g. Operability (Structural integrity) Demonstrated during & after test. No weld defects.	

Specification No. H-2298Vendor: Refer Below

Wm. H. Zimmer

Project No. 4130-00

SUMMARY OF
EQUIPMENT QUALIFICATIONPage B7 of 83Rev. 00Date 4-15-81

Equipment Number	Description	Series	Class	Location	Qualification Method	Results
1VC38Y	Fire Damper, Curtain Type (AIR Balance, Model: 319)	P		Auxiliary	Uniaxial Sine Sweep 5-60 Hz, Input 0.4 g. Uniaxial Sine Dwell Dwell at 20 Hz	Nat. Frequency: 37 Hz Response: 3.50 g. Operability (Structural Integrity) demonstrated during and after test. No weld defects.
1VC39Y	Fire Damper, Curtain Type (AIR Balance, Model: 319)	P		Auxiliary	Uniaxial Sine Sweep 5-60 Hz, Input 0.4 g. Uniaxial Sine Dwell Dwell at 20 Hz.	Nat. Frequency: 37 Hz Response: 3.50 g. Operability (Structural integrity) demonstrated during and after test. No weld defects.
1VC40Y	Opposed Blade Balancing Damper (Waldinger)	P		Auxiliary	Static Analysis Simplified Dynamic Analysis	Lowest $f_n = 24.8$ Hz Acceleration Levels Used: $H_1 = 1.00$ g, $H_2 = 1.00$ g, $V^1 = 1.25$ g. Lowest $f_n = 62$ Hz Acceleration Levels Used: 5.0 g in all directions Critical stress = 26,615 psi (Allowable = 32,000 psi) Max. Calc. Accelerations: $H_1 = .77$ g, $H_2 = .64$ g, $V^1 = .87$ g.

Specification No. H-2298
 Vendor: Refer Below
 Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page 88 of 83
 Rev. 00
 Date 4-15-81

Equipment Number	Description	Series	Class	Location	Qualification Method	Results
1VC41Y	Opposed Blade Balancing Damper (Waldinger)	P		Auxiliary	Static Analysis Simplified Dynamic Analysis	Lowest f = 24.8 Hz Acceleration Levels Used: H ₁ = 1.00 g, H ₂ = 1.00 g, V ¹ = 1.25 g. Lowest f = 73 Hz Acceleration Levels Used: 5.0g in all directions Critical Stress = 26,615 psi (Allowable = 32,000 psi) Max. Calc. Accelerations: H ₁ = .51 g, H ₂ = .62 g, V ¹ = .68 g.
1VC42Y	Fire Damper, Curtain Type (AIR Balance, Model: 319)	P		Auxiliary	Uniaxial Sine Sweep 5-60 Hz, Input 0.4 g. Uniaxial Sine Dwell Dwell at 20 Hz	Nat. Frequency: 37 Hz Response: 3.50 g. Operability (Structural Integrity) demonstrated during and after test. No weld defects.
1VC43Y	Fire Damper, Curtain Type (AIR Balance, Model: 319)	P		Auxiliary	Uniaxial Sine Sweep 5-60 Hz, Input 0.4 g. Uniaxial Sine Dwell Dwell at 20 Hz	Nat. Frequency: 37 Hz Response: 3.50 g. Operability (Structural integrity) demonstrated during and after test. No weld defects.

Specification No. H-2298
 Vendor: Refer Below
 Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page 89 of 83
 Rev. 00
 Date 4-15-81

Equipment Number	Description	S e r i e s	C l a s s	Location		Qualification Method	Results
1VC44Y	Opposed Blade Balancing Damper (Waldinger)	P		Auxiliary		Static Analysis Simplified Dynamic Analysis	Lowest $f_n = 24.8$ Hz Acceleration Levels Used: $H_1 = 1.00$ g, $H_2 = 1.00$ g, $V^1 = 1.25$ g. Lowest $f_n = 17$ Hz Acceleration Levels Used: 5.0 g in all directions. Critical stress = 26,615 psi. (Allowable = 32,000 psi) Max. Calc. Accelerations: $H_1 = .70$ g, $H_2 = .82$ g, $V^1 = 3.27$ g.
1VC45Y	Opposed Blade Balancing Damper (Waldinger)	P		Auxiliary		Static Analysis Simplified Dynamic Analysis	Lowest $f_n = 24.8$ Hz. Acceleration Levels Used: $H_1 = 1.00$ g, $H_2 = 1.00$ g, $V^1 = 1.25$ g. Lowest $f_n = 17$ Hz. 5.0 g in all directions. Critical stress = 26,615 psi. (Allowable = 32,000 psi) Max. Calc. Accelerations: $H_1 = .70$ g, $H_2 = .90$ g, $V^1 = 3.45$ g.

Specification No. H-2298
 Vendor: Refer Below
 Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page 810 of 83
 Rev. 00
 Date 4-15-81

Equipment Number	Description	S e r i e s	C l a s s	Location	Qualification Method	Results
1VC46Y	Opposed Blade Balancing Damper (Waldinger)	P	Auxiliary		Static Analysis Simplified Dynamic Analysis	Lowest $f_n = 24.8$ Hz Acceleration Levels Used: $H_1 = 1.00$ g, $H_2 = 1.00$ g, $V_1 = 1.25$ g. Lowest $f_n = 73$ Hz Acceleration Levels Used: 5.0 g in all directions. Critical stress = 26,615 psi. (Allowable = 32,000 psi) Max. Calc. Accelerations: $H_1 = .82$ g, $H_2 = .79$ g, $V_1 = .95$ g.
1VC47Y	Fire Damper, Curtain Type (AIR Balance, Model: 319)	P	Auxiliary		Uniaxial Sine Sweep 5-60 Hz, Input 0.4 g. Uniaxial Sine Dwell Dwell at 20 Hz	Nat. Frequency: 37 Hz Response: 3.50 g. Operability (Structural integrity) demonstrated during and after test. No weld defects.

Specification No. H-2298
 Vendor: Refer Below

Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page 111 of 83

Rev. 00

Date 4-15-81

Equipment Number	Description	S e r i e s	C l a s s	Location		Qualification Method		Results
1VC48Y	Opposed Blade Balancing Damper (Waldinger)	P		Auxiliary		Static Analysis Simplified Dynamic Analysis		Lowest $f_n = 24.8$ Hz Acceleration Levels Used: $H_1 = 1.00$ g, $H_2 = 1.00$ g, $V^1 = 1.25$ g. Lowest $f_n = 47$ Hz Acceleration Levels Used: 5.0g in all directions Critical Stress = 26,615 psi (Allowable = 32,000 psi) Max. Calc. Accelerations: $H_1 = 1.14$ g, $H_2 = .46$ g, $V^1 = .58$ g.
1VC49Y	Fire Damper, Curtain Type (AIR Balance, Model: 319)	P		Auxiliary		Uniaxial Sine Sweep 5-60 Hz, Input 0.4 g. Uniaxial Sine Dwell Dwell at 20 Hz		Nat. Frequency: 37 Hz Response: 3.50 g. Operability (Structural integrity) demonstrated during and after test. No weld defects.
1VC50Y	Fire Damper, Curtain Type (AIR Balance, Model: 319)	P		Auxiliary		Uniaxial Sine Sweep 5-60 Hz, Input 0.4 g. Uniaxial Sine Dwell Dwell at 20 Hz		Nat. Frequency: 37 Hz Response: 3.50 g. Operability (Structural integrity) demonstrated during and after test. No weld defects.

Specification No. H-2298
 Vendor: Refer Below

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page B12 of 83

Rev. 00

Date 4-15-81

Wm. H. Zimmer
 Project No. 4130-00

Equipment Number	Description	S e l e c t i o n s	C l a s s i f i c a t i o n	Location		Qualification Method			
1VC51Y	Fire Damper, Curtain Type (AIR Balance, Model: 319)	P		Auxiliary		Uniaxial Sine Sweep 5-60 Hz, Input 0.4 g. Uniaxial Sine Dwell Dwell at 20 Hz			Nat. Frequency: 37 Hz Response: 3.50 g. Operability (Structural integrity) demonstrated during and after test. No weld defects.
1VC52Y	Opposed Blade Balancing Damper (Waldinger)	P		Auxiliary		Static Analysis Simplified Dynamic Analysis			Lowest f_n = 24.8 Hz Acceleration Levels Used: H_1 = 1.00 g, H_2 = 1.00 g, V^1 = 1.25 g. Lowest f_n = 105 Hz Acceleration Levels Used: 5.0 g in all directions. Critical stress = 26,615 psi. (Allowable = 32,000 psi) Max. Calc. Accelerations: H_1 = .38 g, H_2 = .46 g, V^1 = .81 g.
1VC53Y	Fire Damper, Curtain Type (AIR Balance, Model: 319)	P		Auxiliary		Uniaxial Sine Sweep 5-60 Hz, Input 0.4 g. Uniaxial Sine Dwell Dwell at 20 Hz			Nat. Frequency: 37 Hz Response: 3.50 g. Operability (Structural integrity) demonstrated during and after test. No weld defects.

Specification No. H-2298
 Vendor: Refer Below
 Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page B13 of 23
 Rev. 00
 Date 4-15-81

Equipment Number	Description	S e r i e s	C l a s s	Location		Qualification Method		Results
IVC54Y	Fire Damper, Curtain Type (AIR Balance, Model: 319)	P		Auxiliary		Uniaxial Sine Sweep 5-60 Hz, Input 0.4 g. Uniaxial Sine Dwell Dwell at 20 Hz		Nat. Frequency: 37 Hz Response: 3.50 g. Operability (Structural integrity) Demonstrated during and after test. No weld defects.
IVC55Y	Fire Damper, Curtain Type (AIR Balance, Model: 319)	P		Auxiliary		Uniaxial Sine Sweep 5-60 Hz, Input 0.4 g. Uniaxial Sine Dwell Dwell at 20 Hz		Nat. Frequency: 37 Hz. Response: 3.50 g. Operability (Structural integrity) Demonstrated during and after test. No weld defects.
IVC56Y	Opposed Blade Balancing Damper (Waldinger)	P		Auxiliary		Static Analysis Simplified Dynamic Analysis		Lowest $f_n = 24.8$ Hz Acceleration Levels Used: $H_1 = 1.00$ g, $H_2 = 1.00$ g, $V^1 = 1.25$ g. Lowest $f_n = 105$ Hz Acceleration Levels Used: 5.0 g in all directions. Critical Stress = 26,615 psi. (Allowable = 32,000 psi) Max. Calc. Accelerations: $H_1 = .38$ g, $H_2 = .46$ g, $V^1 = .55$ g.

Specification No. H-2298
 Vendor: Refer Below

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page B14 of 83

Rev. 00

Date 4-15-81

Wm. H. Zimmer
 Project No. 4130-00

Equipment Number	Description	S e i s s	C l a s s	Location	Qualification Method	Results
1VC57Y	Fire Damper, Curtain Type (AIR Balance, Model: 319)	P		Auxiliary	Uniaxial Sine Sweep 5-60 Hz, Input 0.4 g. Uniaxial Sine Dwell Dwell at 20 Hz.	Nat. Frequency: 37 Hz Response: 3.50 g. Operability (Structural integrity) Demonstrated during and after test. No weld defects.
1VC58Y	Fire Damper, Curtain Type (AIR Balance, Model: 319)	P		Auxiliary	Uniaxial Sine Sweep 5-60 Hz, Input 0.4 g. Uniaxial Sine Dwell Dwell at 20 Hz.	Nat. Frequency: 37 Hz Response: 3.50 g. Operability (Structural integrity) Demonstrated during and after test. No weld defects.
1VC59Y	Opposed Blade Balancing Damper (Waldinger)	P		Auxiliary	Static Analysis Simplified Dynamic Analysis	Lowest f_n = 24.8 Hz Acceleration Levels Used: H_1 = 1.00 g, H_2 = 1.00 g, V^1 = 1.25 g. Lowest f_n = 17 Hz Acceleration Levels Used: 5.0 g in all directions Critical stress = 26,615 psi. (Allowable = 32,000 psi) Max. Calc. Accelerations: H_1 = .49 g, H_2 = .75 g, V^1 = 2.54 g.

Specification No. H-2298
 Vendor: Refer Below
 Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page 815 of 83
 Rev. 00
 Date 4-15-81

Equipment Number	Description	S e i s s	C l a s s	Location		Qualification Method		Results
1VC61Y	Fire Damper, Curtain Type (AIR Balance, Model: 319)	P		Auxiliary		Uniaxial Sine Sweep 5-60 Hz, Input 0.4 g. Uniaxial Sine Dwell Dwell at 20 Hz		Nat. Frequency: 37 Hz Response: 3.50 g. Operability (Structural integrity) Demonstrated during and after test. No weld defects.
1VC62Y	Opposed Blade Balancing Damper (Waldinger)	P		Auxiliary		Static Analysis Simplified Dynamic Analysis		Lowest $f_n = 24.8$ Hz Acceleration Levels Used: $H_1 = 1.00$ g, $H_2 = 1.00$ g, $V^1 = 1.25$ g. Lowest $f_n = 47$ Hz Acceleration Levels Used: 5.0 g in all directions Critical Stress = 26,615 psi. (Allowable = 32,000 psi) Max. Calc. Accelerations: $H_1 = .32$ g, $H_2 = .40$ g, $V^1 = .58$ g.
1VC63Y	Fire Damper, Curtain Type (AIR Balance, Model: 319)	P		Auxiliary		Uniaxial Sine Sweep 5-60 Hz, Input 0.4 g. Uniaxial Sine Dwell Dwell at 20 Hz.		Nat. Frequency: 37 Hz. Response: 3.50 g. Operability (Structural integrity) Demonstrated during and after test. No weld defects.

Specification No. H-2298
 Vendor: Refer Below
 Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page 816 of 83
 Rev. 00
 Date 4-15-81

Equipment Number	Description	S e i s s	C l a s s	Location		Qualification Method		Results
1VC64Y	Opposed Blade Balancing Damper (Waldinger)	P		Auxiliary		Static Analysis Simplified Dynamic Analysis		Lowest $f_n = 24.8$ Hz Acceleration Levels Used: $H_1 = 1.00$ g, $H_2 = 1.00$ g, $V^1 = 1.25$ g. Lowest $f_n = 47$ Hz Acceleration Levels Used: 5.0 g in all directions Critical Stress = 26,615 psi (Allowable = 32,000 psi) Max. Calc. Accelerations: $H_1 = .36$ g, $H_2 = .49$ g, $V^1 = .76$ g.
1VC65Y	Opposed Blade Balancing Damper (Waldinger)	P		Auxiliary		Static Analysis Simplified Dynamic Analysis		Lowest $f_n = 24.8$ Hz Acceleration Levels Used: $H_1 = 1.00$ g, $H_2 = 1.00$ g, $V^1 = 1.25$ g. Lowest $f_n = 47$ Hz Acceleration Levels Used: 5.0 g in all directions Critical Stress = 26,615 psi (Allowable = 32,000 psi) Max. Calc. Accelerations: $H_1 = .61$ g, $H_2 = .93$ g, $V^1 = .58$ g.

Specification No. H-2298

Vendor: Refer Below

Wm. H. Zimmer

Project No. 4130-00

SUMMARY OF
EQUIPMENT QUALIFICATIONPage B17 of 83Rev. 00Date 4-15-81

Equipment Number	Description	Series	Class Location	Qualification Method	Results
1VC66Y	Fire Damper, Curtain Type (AIR Balance, Model: 319)	P	Auxiliary	Uniaxial Sine Sweep 5-60 Hz, Input 0.4 g. Uniaxial Sine Dwell Dwell at 20 Hz	Nat. Frequency: 37 Hz Response: 3.50 g. Operability (Structural integrity) Demonstrated during and after test. No weld defects.
1VC67Y	Fire Damper, Curtain Type (AIR Balance, Model: 319)	P	Auxiliary	Uniaxial Sine Sweep 5-60 Hz, Input 0.4 g. Uniaxial Sine Dwell Dwell at 20 Hz	Nat. Frequency: 37 Hz Response: 3.50 g. Operability (Structural integrity) Demonstrated during and after test. No weld defects.
1VC68Y	Fire Damper, Curtain Type (AIR Balance, Model: 319)	P	Auxiliary	Uniaxial Sine Sweep 5-60 Hz, Input 0.4 g. Uniaxial Sine Dwell Dwell at 20 Hz	Nat. Frequency: 37 Hz. Response: 3.50 g. Operability (Structural integrity) Demonstrated during and after test. No weld defects.
1VC69Y	Backdraft Isolation Damper (AIR Balance, Model: SND-116)	P	Auxiliary	Uniaxial Sine Sweep 5-50 Hz, Input: $H_1 = 25$ g, $H_2 = 4.5$ g, $V = 2.0$ g. Uniaxial Sine Dwell @ Resonant Freq.	Nat. Frequencies: $f_1 = 33$ Hz, $f_2 = 30$ Hz, $f_v = 33^2$ Hz Response: 25 g, 9.5 g, and 20 g, respectively. Operability (Structural integrity) Demonstrated.

Specification No. H-2298Vendor: Refer Below

Wm. H. Zimmer

Project No. 4130-00

SUMMARY OF
EQUIPMENT QUALIFICATIONPage 818 of 83Rev. 00Date 4-15-81

Equipment Number	Description	Series	Class	Location	Qualification Method	Results
1VC70Y	Fire Damper, Curtain Type (AIR Balance, Model: 319)	P		Auxiliary	Uniaxial Sine Sweep 5-60 Hz, Input 0.4 g. Uniaxial Sine Dwell Dwell at 20 Hz	Nat. Frequency: 37 Hz Response: 3.50 g. Operability (Structural integrity) Demonstrated during and after test. No weld defects.
1VC71Y	Fire Damper, Curtain Type (AIR Balance, Model: 319)	P		Auxiliary	Uniaxial Sine Sweep 5-60 Hz, Input 0.4 g. Uniaxial Sine Dwell Dwell at 20 Hz	Nat. Frequency: 37 Hz Response: 3.50 g. Operability (Structural integrity) Demonstrated during and after test. No weld defects.
1VC72Y	Backdraft Isolation Damper (AIR Balance, Model: SND-116)	P		Auxiliary	Uniaxial Sine Sweep 5-50 Hz, Input $H_1 = 25$ g, $H_2 = 4.5$ g, $V = 2.0$ g. Uniaxial Sine Dwell @ Resonant Freq.	Nat. Frequencies: $H_1 = 33$ Hz, $H_2 = 30$ Hz, $V = 33$ Hz Response: 25 g, 9.5 g, and 20 g, respectively. Operability (Structural integrity) Demonstrated.

Specification No. H-2298
 Vendor: Refer Below
 Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page B19 of 83
 Rev. 00
 Date 4-15-81

Equipment Number	Description	Series	Class	Location	Qualification Method	Results
1VC73Y	Opposed Blade Balancing Damper (Waldinger)	P		Auxiliary	Static Analysis Simplified Dyanmic Analysis	Lowest $f_n = 24.8$ Hz Acceleration Levels Used: $H_1 = 1.00$ g, $H_2 = 1.00$ g, $V^1 = 1.25$ g. Lowest $f_n = 87$ Hz Acceleration Levels Used: 5.0 g in all directions. Critical stress = 26,615 psi. (Allowable = 32,000 psi) Max. Calc. Accelerations: $H_1 = .48$ g, $H_2 = .62$ g, $V^1 = .68$ g.
1VC74Y	Fire Damper, Curtain Type (AIR Balance, Model: 319)	P		Auxiliary	Uniaxial Sine Sweep 5-60 Hz, Input 0.4 g. Uniaxial Sine Dwell Dwell at 20 Hz	Nat. Frequency: 37 Hz Response: 3.50 g. Operability (Structural integrity) Demonstrated during and after test. No weld defects.
1VC75Y	Fire Damper, Curtain Type (AIR Balance, Model: 319)	P		Auxiliary	Uniaxial Sine Sweep 5-60 Hz, Input 0.4 g. Uniaxial Sine Dwell Dwell at 20 Hz	Nat. Frequency: 37 Hz Response: 3.50 g. Operability (Structural integrity) Demonstrated during and after test. No weld defects.

Specification No. H-2298
 Vendor: Refer Below

Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page 820 of 83
 Rev. 00
 Date 4-15-81

Equipment Number	Description	Class.	Location	Qualification Method	Results
1VC76Y	Opposed Blade Balancing Damper (Waldinger)	P	Auxiliary	Static Analysis Simplified Dynamic Analysis	Lowest f_n = 24.8 Hz Acceleration Levels Used: H_1 = 1.00 g, H_2 = 1.00 g, V_1 = 1.25 g. Lowest f_n = 130 Hz Acceleration Levels Used: 5.0 g in all directions Critical Stress = 26,615 psi (Allowable = 32,000 psi) Max. Calc. Accelerations: H_1 = .95 g, H_2 = 1.03 g, V_1 = 1.35 g.
1VC77Y	Fire Damper, Curtain Type (AIR Balance, Model: 319)	P	Auxiliary	Uniaxial Sine Sweep 5-60 Hz, Input 0.4 g. Uniaxial Sine Dwell Dwell at 20 Hz.	Nat. Frequency: 37 Hz Response: 3.50 g Operability (Structural integrity) Demonstrated during and after test. No weld defects.

Specification No. H-2298
 Vendor: Refer Below
 Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page B21 of 83
 Rev. 00
 Date 4-15-81

Equipment Number	Description	S e r i e s	C l a s s	Location	Qualification Method	Results
1VC79Y	Opposed Blade Balancing Damper (Waldinger)	P		Auxiliary	Static Analysis Simplified Dynamic Analysis	Lowest $f_n = 24.8$ Hz Acceleration Levels Used: $H_1 = 1.00$ g, $H_2 = 1.00$ g, $V^1 = 1.25$ g. Lowest $f_n = 130$ Hz Acceleration Levels Used: 5.0 g in all directions Critical Stress = 26,615 psi (Allowable = 32,000 psi) Max. Calc. Accelerations: $H_1 = .48$ g, $H_2 = .62$ g, $V^1 = .72$ g.
1VC80Y	Opposed Blade Balancing Damper (Waldinger)	P		Auxiliary	Static Analysis Simplified Dynamic Analysis	Lowest $f_n = 24.8$ Hz Acceleration Levels Used: $H_1 = 1.00$ g, $H_2 = 1.00$ g, $V^1 = 1.25$ g. Lowest $f_n = 87$ Hz Acceleration Levels Used: 5.0 g in all directions Critical stress = 26,615 psi (Allowable = 32,000 psi) Max. Calc. Accelerations: $H_1 = .66$ g, $H_2 = .84$ g, $V^1 = 1.52$ g.

Specification No. H-2298Vendor: Refer Below

Wm. H. Zimmer

Project No. 4130-00SUMMARY OF
EQUIPMENT QUALIFICATIONPage 822 of 83Rev. 00Date 4-15-81

Equipment Number	Description	S e i s s	C l a s s	Location	Qualification Method	Results
1VC83Y	Backdraft Isolation Damper (AIR Balance, Model: SND-116)	P		Auxiliary	Uniaxial Sine Sweep 5-50 Hz, Input: $H_1 = 25$ g, $H_2 = 4.5$ g, $V = 2.0$ g. Uniaxial Sine Dwell @ Resonant Freq.	Nat. Frequencies: $f_1 = 33$ Hz, $f_2 = 30$ Hz, $f_v = 33$ Hz. Response: 25 g, 9.5 g, and 20 g, respectively. Operability (Structural integrity) demonstrated.
1VC84Y	Fire Damper, Curtain Type (AIR Balance, Model: 319)	P		Auxiliary	Uniaxial Sine Sweep 5-60 Hz, Input 0.4 g. Uniaxial Sine Dwell Dwell at 20 Hz	Nat. Frequency: 37 Hz Response: 3.50 g. Operability (Structural integrity) Demonstrated during and after test. No weld defects.
1VC85Y	Opposed Blade Balancing Damper (Waldinger)	P		Auxiliary	Static Analysis Simplified Dyanmic Analysis	Lowest $f_n = 24.8$ Hz Acceleration Levels Used: $H_1 = 1.00$ g, $H_2 = 1.00$ g, $V^1 = 1.25$ g. Lowest $f_n = 215$ Hz Acceleration Levels Used: 5.0 g in all directions Critical Stress = 26,615 psi (Allowable = 32,000 psi) Max. Calc. Accelerations: $H_1 = .48$ g, $H_2 = .62$ g, $V^1 = 1.1$ g.

Specification No. H-2298Vendor: Refer Below

Wm. H. Zimmer

Project No. 4130-00SUMMARY OF
EQUIPMENT QUALIFICATIONPage B23 of 83Rev. 00Date 4-15-81

Equipment Number	Description	Series	Class	Location	Qualification Method	Results
1VC96Y	Fire Damper, Curtain Type (Ruskin, Model: NIBD-23)	P		Auxiliary	Biaxial Random Motion 1-40 Hz, spaced at 1/3 octave. Biaxial Sine Beat 1-32 Hz, Input 3.0 g, Beats at 1/2 octave.	TRS Envelopes RRS Structural integrity and operability verified Structural integrity and operability verified.
1VC97Y	Fire Damper, Curtain Type (Ruskin, Model: NIBD-23)	P		Auxiliary	Biaxial Random Motion 1-40 Hz, spaced at 1/3 octave. Biaxial Sine Beat 1-32 Hz, Input 3.0 g, beats at 1/2 octave.	TRS Envelopes RRS Structural integrity and operability verified. Structural integrity and operability verified
1VC98Y	Fire Damper, Curtain Type (Ruskin, Model: NIBD-23)	P		Auxiliary	Biaxial Random Motion 1-40 Hz, spaced at 1/3 octave. Biaxial Sine Beat 1-32 Hz, Input 3.0 g, beats at 1/2 octave.	TRS Envelopes RRS Structural integrity and operability verified. Structural integrity and operability verified.
1VD04YA/B/ C	Fire Damper, Curtain Type (AIR Balance, Model: 319)	P		Auxiliary	Uniaxial Sine Sweep 5-60 Hz, Input 0.4 g. Uniaxial Sine Dwell Dwell at 20 Hz	Nat. Frequency: 37 Hz Response: 3.50 g. Operability (Structural integrity) Demonstrated during and after test. No weld defects.

Specification No. H-2298
 Vendor: Refer Below
 Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page 824 of 83
 Rev. 00
 Date 4-15-81

Equipment Number	Description	Series	Class	Location	Qualification Method	Results
1VD05YA/B	Backdraft Isolation Damper (AIR Balance, Model: SNB:116)	P		Auxiliary	Uniaxial Sine Sweep 5-50 Hz, Input 4.0 g, (Horz) 2.0 g. (Vertical) Uniaxial Sine Dwell @ Resonant Freq.	Nat. Frequencies: 31.7 Hz 32.0 Hz, 32.7 Hz. Response: 20 g, 20 g, 18g respectively. Operability (Structural integrity) demonstrated.
1VD06YA/B/C	Fire Damper, Curtain Type (AIR Balance, Model: 319)	P		Auxiliary	Uniaxial Sine Sweep 5-60 Hz, Input 0.4 g. Uniaxial Sine Dwell Dwell at 20 Hz	Nat. Frequency: 37 Hz Response: 3.50 g. Operability (Structural integrity) Demonstrated during and aster test. No weld defects.
1VD09YA/B/C	External Counter Balance Gravity Shutter (Ruskin, Model: CBS-7)	P		Auxiliary	Static Analysis	Currently being relocated. Qualification pending.

Specification No. H-2298
 Vendor: Refer Below

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page B25 of 83

Wm. H. Zimmer
 Project No. 4130-00

Rev. 00

Date 4-15-81

Equipment Number	Description	Series Class	Location	Qualification Method	Results
1VG05YA/B	Backdraft Isolation Damper (AIR Balance, Model: SND-116)	P	Auxiliary	Uniaxial Sine Sweep 5-50 Hz, Input 4.0 g.(Horz) 2.0 g. (Vert.) Uniaxial Sine Dwell @ Resonant Freq.	Nat. Frequencies: 31.7 Hz 32.0 Hz, 32.7 Hz Response: 20 g, 20 g, 18 g, respectively. Operability (Structural integrity) demonstrated.
1VX01YA/B/C	Fire Damper, Curtain Type (AIR Balance, Model: 319)	P	Auxiliary	Uniaxial Sine Sweep 5-60 Hz, Input 0.4 g. Uniaxial Sine Dwell Dwell at 20 Hz	Nat. Frequency: 37 Hz Response: 3.50 g. Operability (Structural integrity) Demonstrated during and after test. No weld defects.
1VX02YA/B/C	Backdraft Isolation Damper (AIR Balance, Model: SND-116)	P	Auxiliary	Uniaxial Sine Sweep 5-50 Hz, Input 4.0 g, (Horz) 2.0 g. (Vert.) Uniaxial Sine Dwell @ Resonant Freq.	Nat. Frequencies: 31.7 Hz 32.0 Hz, 32.7 Hz. Response: 20 g, 20 g, 18g, respectively. Operability (Structural integrity) demonstrated.

Specification No. H-2298
 Vendor: Refer Below
 Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page 826 of 83
 Rev. 00
 Date 4-15-81

Equipment Number	Description	Series Class	Location	Qualification Method	Results
1VX03YA/B	Fire Damper, Curtain Type (AIR Balance, Model: 319)	P	Auxiliary	Uniaxial Sine Sweep 5-60 Hz, Input 0.4 g. Uniaxial Sine Dwell Dwell at 20 Hz	Nat. Frequency: 37 Hz. Response: 3.50 g. Operability (Structural integrity) Demonstrated during and after test. No weld defects.
1VX04YA	Opposed Blade Balancing Damper (Waldinger)	P	Auxiliary	Static Analysis Simplified Dynamic Analysis	Lowest $f_n = 24.8$ Hz. Acceleration Levels Used: $H_1 = 1.00$ g, $H_2 = 1.00$ g, $V^1 = 1.25$ g. Lowest $f_n = 215$ Hz Acceleration Levels Used: 5.0 g in all directions Critical Stress = 26,615 psi (Allowable = 32,000 psi) Max. Calc. Accelerations: $H_1 = .48$ g, $H_2 = .62$ g, $V^1 = .68$ g.

Specification No. H-2298

Vendor: Refer Below

Wm. H. Zimmer

Project No. 4130-00

SUMMARY OF
EQUIPMENT QUALIFICATION

Page B27 of 83

Rev. 00

Date 4-15-81

Equipment Number	Description	S e r i e s	C l a s s	Location	Qualification Method	Results
1VX04YB	Opposed Blade Balancing Damper (Waldinger)	P		Auxiliary	Static Analysis Simplified Dynamic Analysis	<p>Lowest $f_n = 24.8$ Hz. Acceleration Levels Used: $H_1 = 1.00$ g, $H_2 = 1.00$ g, $V^1 = 1.25$ g.</p> <p>Lowest $f_n = 215$ Hz. Acceleration Levels Used: 5.0 g's, in all directions Critical stress = 26,615 psi. (Allowable = 32,000 psi) Max. Calc. Accelerations: $H_1 = .37$ g, $H_2 = .43$ g, $V^1 = .55$ g.</p>

Specification No. H-2298
 Vendor: Refer Below

Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page B28 of 83
 Rev. 00
 Date 4-15-81

Equipment Number	Description	Series	Class	Location	Qualification Method	Results
1VX05YA/B	Fire Damper, Curtain Type (AIR Balance, Model: 319)	P		Auxiliary	Uniaxial Sine Sweep 5-60 Hz, Input 0.4 g Uniaxial Sine Dwell Dwell at 20 Hz	Nat. Frequency: 37 Hz Response: 3.50 g. Operability (Structural integrity) Demonstrated during and after test. No weld defects.
1VX06YA/B/ C	Fire Damper, Curtain Type (AIR Balance, Mdl 319)	P		Auxiliary	Uniaxial Sine Sweep 5-60 Hz, Input 0.4 g. Uniaxial Sine Dwell Dwell at 20 Hz	Nat. Frequency: 37 Hz. Response: 3.50 g. Operability (Structural integrity) Demonstrated during and after test. No weld defects.
1VX07Y	Fire Damper, Curtain Type (AIR Balance, Model: 319)	P		Auxiliary	Uniaxial Sine Sweep 5-60 Hz, Input 0.4 g. Uniaxial Sine Dwell Dwell at 20 Hz	Nat. Frequency: 37 Hz Response: 3.50 g. Operability (Structural integrity) Demonstrated during and after test. No weld defects.
1VX09Y	Fire Damper, Curtain Type (AIR Balance, Mdl 319)	P		Auxiliary	Uniaxial Sine Sweep 5-60 Hz, Input 0.4 g. Uniaxial Sine Dwell Dwell at 20 Hz	Nat. Frequency: 27 Hz. Response: 3.50 g. Operability (Structural integrity) Demonstrated during and after test. No weld defects.

Specification No. H- 2298

Vendor: Refer Below

Wm. H. Zimmer

Project No. 4130-00

SUMMARY OF
EQUIPMENT QUALIFICATIONPage 629 of 83Rev. 00Date 4-15-71

Equipment Number	Description	Series	Location	Qualification Method	Results
1VX11Y	Fire Damper (Ruskin, Curtain Type, Model: NIBD-23)	P	Auxiliary	Biaxial Random Motion 1-40 Hz, spaced at 1/3 octave. Biaxial Sine Beat 1-32 Hz, Input 3.0 g, beats at 1/2 octave.	TRS Envelopes RRS Structural integrity and operability verified Structural integrity and operability verified.
1VX12Y	Fire Damper (Ruskin, Curtain Type, Model: NIBD-23)	P	Auxiliary	Biaxial Random Motion 1-40 Hz, spaced at 1/3 octave. Biaxial Sine Beat 1-32 Hz, Input 3.0 g. beats at 1/2 octave.	TRS Envelopes RRS Structural integrity and operability verified. Structural integrity and operability verified.
1VY03Y	Opposed Blade Balancing Damper (Waldinger)	P	Reactor	Uniaxial Sine Sweep 5-60 Hz, Input 0.4 g. Uniaxial Sine Dwell Dwell at 20 Hz.	Nat. Frequency: 36 Hz. Response: 2.78 g. Operability (Structural integrity) Demonstrated during and after test. No weld defects.
1VY05Y	Opposed Blade Balancing Damper (Waldinger)	P	Reactor	Uniaxial Sine Sweep 5-60 Hz, Input 0.4 g. Uniaxial Sine Dwell Dwell at 20 Hz	Nat. Frequency: 26 Hz. Response: 2.78 g. Operability (Structural integrity) demonstrated during and after test. No weld defects.

Specification No. H-2298
 Vendor: _____ Refer Below
 Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page B30 of 83
 Rev. 00
 Date 4-15-81

Equipment Number	Description	S e l e c t i o n	C l a s s i f i c a t i o n	Location		Qualification Method		Results
1VY07Y	Opposed Blade Balancing Damper (Waldinger)	P		Reactor		Uniaxial Sine Sweep 5-60 Hz, Input 0.4 g. Uniaxial Sine Dwell Dwell at 20 Hz.		Nat. Frequency: 36 Hz. Response: 2.78 g. Operability (Structural integrity) Demonstrated during and after test. No weld defects.
1VY10Y	Opposed Blade Balancing Damper (Waldinger)	P		Reactor		Uniaxial Sine Sweep 5-60 Hz, Input 0.4 g. Uniaxial Sine Dwell Dwell at 20 Hz.		Nat. Frequency: 36 Hz. Response: 2.78 g. Operability (Structural integrity) Demonstrated during and after test. No weld defects.

Specification No. H-2868
 Vendor: Refer Below
 Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page 831 of 83
 Rev. 00
 Date 4-15-81

Equipment Number	Description	Series	Location	Qualification Method	Results
1VA01Y	Opposed Blade Balancing Damper (AWV (Damper), ITT (M.Oper.) Namco (L.Switch))	W/S	Auxiliary	Static Analysis Simplified Dynamic Analysis	Nat. Freq. > 33 Hz. Acceleration Levels Used: $H_1 = 1.0 \text{ g}$, $H_2 = 1.0 \text{ g}$, $V^1 = 3.0 \text{ g}$. Lowest $f_n = 43 \text{ Hz}$. Acceleration Levels Used: 5 g's in all directions. Max. Stress = 17.269 psi (Allowable = 19,200 psi)
1VA02Y	Opposed Blade Balancing Damper (AWV (Damper), ITT (M.Oper.) Namco (L. Switch))	W/S	Auxiliary	Static Analysis Simplified Dynamic Analysis	Lowest $f_n = 24.8 \text{ Hz}$. Acceleration Levels Used: $H_1 = 1.00 \text{ g}$, $H_2 = 1.00 \text{ g}$, $V^1 = 1.25 \text{ g's}$ Lowest $f_n \geq 40 \text{ Hz}$. Limit Load Analysis performed with a resulting allow. > 5.0 g as compared to a max. calc. acceleration of 0.95 g.
1VC01YA/B	Butterfly Isolation Damper (AWV (Damper), ITT (M. Oper.), Namco (L. Switch))	A	Auxiliary	Static Analysis Static Analysis	Nat. Freq. > 33 Hz. Acc. Levels Used: $H_1 = 1.0 \text{ g}$, $H_2 = 1.0 \text{ g}$, $V^1 = 1.25 \text{ g's}$. Lowest $f_n = 83.7 \text{ Hz}$ Acc. Levels Used: $H_1 = 1.0 \text{ g}$, $H_2 = 1.0 \text{ g}$, $V^1 = 1.25 \text{ g's}$. Max. stress = 18.5 ksi. (Allow. = 19.2 ksi)

Specification No. H-2868Vendor: Refer Below

Wm. H. Zimmer

Project No. 4130-00

SUMMARY OF
EQUIPMENT QUALIFICATIONPage B32 of 83Rev. 00Date 4-15-81

Equipment Number	Description	Series	Location	Qualification Method	Results
1VC02YA	Butterfly Isolation Damper (AWV (Damper) ITT (M.Oper), Namco (L. Switch))	A	Auxiliary	Static Analysis Simplified Dynamic Analysis	Nat. Freq. > 33 Hz. Acceleration Levels Used: $H_1 = 1.0$ g, $H_2 = 1.0$ g, $V^1 = 1.25$ g. Lowest $f_n = 111$ Hz. Acceleration Levels Used: $H_1 = 1.0$ g, $H_2 = 1.0$ g, $V^1 = 1.25$ g. Critical stress = 18,467 psi. (Allowable = 19,200 psi) Max. Calc. Acceleration $H_1 = .66$ g, $H_2 = .52$ g, $V^1 = .67$ g.
1VC02YB	Butterfly Isolation Damper (AWV (Damper) ITT (M.Oper.), Namco (L. Switch))	A	Auxiliary	Static Analysis Simplified Dynamic Analysis	Nat. Freq. > 33 Hz. Acceleration Levels Used: $H_1 = 1.0$ g, $H_2 = 1.0$ g, $V^1 = 1.25$ g. Lowest $f_n > = 111$ Hz. Acceleration Levels Used: $H_1 = 1.0$ g, $H_2 = 1.0$ g, $V^1 = 1.25$ g. Critical stress = 18,467 psi. (Allow. = 19,200 psi) Max. Calc. Acceleration: $H_1 = .66$ g, $H_2 = .85$ g, $V^1 = .67$ g.

Specification No. H-2968
 Vendor: Refer Below
 Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page 333 of 83
 Rev. 00
 Date 4-15-81

Equipment Number	Description	S e i s .	C l a s s	Location		Qualification Method		Results
1VC05Y	Butterfly Isolation Damper (AWV (Damper) ITT (M. Oper), Namco (L. Switch))	A		Auxiliary		Static Analysis Simplified Dynamic Analysis		Nat. Freq. > 33 Hz. Acceleration Levels Used: $H_1 = 1.0 \text{ g}$, $H_2 = 1.0 \text{ g}$, $V^1 = 1.25 \text{ g}$. Lowest $f_n = 58 \text{ Hz}$ Acceleration Levels Used: $H_1 = 1.0 \text{ g}$, $H_2 = 1.0 \text{ g}$, $V^1 = 1.25 \text{ g}$. Critical stress = 18,467 psi. (Allowable = 19,200 psi) Max. Calc. Accelerations: $H_1 = .50 \text{ g}$, $H_2 = .42 \text{ g}$, $V^1 = .47 \text{ g}$.
1VC06Y	Opposed Blade Balancing Damper (AWV (Damper), ITT (M. Oper) Namco (L. Switches))	A		Auxiliary		Static Analysis Simplified Dynamic Analysis		Nat. Freq. > 33 Hz Acceleration Levels Used: $H_1 = 1.0 \text{ g}$, $H_2 = 1.0 \text{ g}$, $V = 3.0 \text{ g}$. Lowest $f_n = 43 \text{ Hz}$ Acceleration Levels Used: 5.0 g in all directions. Critical stress = 17,269 psi. (Allow. = 19,200 psi) Max. Calc. Accelerations: $H_1 = 2.3 \text{ g}$, $H_2 = 1.49 \text{ g}$, $V^1 = .75 \text{ g}$.

Specification No. H-2868
 Vendor: Refer Below

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page B34 of 83

Rev. 00

Date 4-15-81

Wm. H. Zimmer
 Project No. 4130-00

Equipment Number	Description	S e r i e s	C l a s s	Location	Qualification Method	Results
IVC08YA	Opposed Blade Balancing Damper (AWV, (Damper), ITT (M. Oper) Namco (L. Switches))	A		Auxiliary	Static Analysis Simplified Dynamic Analysis	Nat. Freq. > 33 Hz. Acceleration Levels Used: H ₁ = 1.0 g, H ₂ = 1.0 g, V ¹ = 3.0 g. Lowest f _n = 43 Hz. Acceleration Levels Used: 5.0 g in all directions. Critical stress = 17,269 psi. (Allowable = 19,200 psi) Max. Calc. Accelerations: H ₁ = 1.4 g, H ₂ = 2.38 g, V ¹ = .68 g.
IVC08YB	Opposed Blade Balancing Damper (AWV (Damper) ITT (M. Oper) Namco (L. Switches))	A		Auxiliary	Static Analysis Simplified Dynamic Analysis	Nat. Freq. > 33 Hz. Acceleration Levels Used: H ₁ = 1.0 g, H ₂ = 1.0 g, V ¹ = 3.0 g. Lowest f _n = 43 Hz. Acceleration Levels Used: 5.0 g in all directions. Critical stress = 17,269 psi. (Allowable = 19,200 psi) Max. Calc. accelerations: H ₁ = .95 g, H ₂ = 1.37 g, V ¹ = .68 g.

Specification No. H-2868Vendor: Refer Below

Wm. H. Zimmer

Project No. 4130-00

SUMMARY OF

EQUIPMENT QUALIFICATION

Page 835 of 83Rev. 00Date 4-15-81

Equipment Number	Description	S e l e c t i o n s	C l a s s	Location	Qualification Method	Results
IVC09YA/B/ C/D	Opposed Blade Balancing Damper (AWV (Damper), ITT (M.Oper) Namco (L.Switches))	P		Auxiliary	Static Analysis Simplified Dynamic Analysis	Lowest $f_n = 24.8$ Hz. Acceleration Levels Used: $H_1 = H_2 = 1.00$ g, $V = 1.25$ g Lowest $f_n = 36$ Hz. Acceleration Levels Used: H (Result.) = 3.0 g, V = 5.0 g. Critical Stress = 13,330 psi. (Allowable = 19,200 psi) Max. Calc. Acceleration: $H_1 = .48$ g, $H_2 = .85$ g, $V = .85$ g.
IVC10YA	Opposed Blade Balancing Damper (AWV (Damper), ITT (M.Oper) Namco (L. Switches))	P		Auxiliary	Static Analysis Simplified Dynamic Analysis	Lowest $f_n = 24.8$ Hz Acceleration Levels Used: $H_1 = H_2 = 1.00$ g, $V = 1.25$ g. Lowest $f_n = 213$ Hz Acceleration Levels Used: H (Result.) = 3.0 g, V = 5.0 g. Critical stress = 13,330 psi. (Allowable = 19,200 psi) Max. Calc. Accelerations: $H_1 = .67$ g, $H_2 = .85$ g, $V = .85$ g.

Specification No. H-2868Vendor: Refer Below

Wm. H. Zimmer

Project No. 4130-00

SUMMARY OF
EQUIPMENT QUALIFICATIONPage 836 of 83Rev. 00Date 4-15-81

Equipment Number	Description	Series	Class	Location	Qualification Method	Results
1VC10YB	Opposed Blade Balancing Damper (AWV (Damper) ITT (M.Oper), Namco (L.Switch))	A		Auxiliary	Static Analysis Simplified Dynamic Analysis	Nat. Freq. > 33 Hz. Acceleration Levels Used: $H_1 = 1.0$ g, $H_2 = 1.0$ g, $V^1 = 3.0$ g. Lowest $f_n = 43$ Hz. Acceleration Levels Used: 5.0 g in all directions. Critical stress = 17,269 psi. (Allowable = 19,200 psi) Max. Calc. Accelerations: $H_1 = .66$ g, $H_2 = 1.17$ g, $V^1 = .69$ g.
1VC10YC	Opposed Blade Balancing Damper (AWV (Damper) ITT (M.Oper), Namco (L. Switch))	P		Auxiliary	Static Analysis Simplified Dynamic Analysis	Lowest $f_n = 24.8$ Hz. Acceleration Levels Used: $H_1 = H_2 = 1.00$ g, $V = 1.25$ g Lowest $f_n = 213$ Hz. Acceleration Levels Used: $H(\text{Result.}) = 3.0$ g, $V = 5.0$ g. Critical Stress = 13,330 psi. (Allowable = 19,200 psi) Max. Calc. Accelerations: $H_1 = .67$ g, $H_2 = 1.13$ g, $V^1 = .85$ g.

Specification No. H-2868Vendor: Refer Below

Wm. H. Zimmer

Project No. 4130-00

SUMMARY OF
EQUIPMENT QUALIFICATIONPage 337 of 83Rev. 00Date 4-15-81

Equipment Number	Description	S e l e c t i o n s	C l a s s	Location	Qualification Method	Results
1VC10YD	Opposed Blade Balancing Damper (AWV (Damper) ITT (M.Oper.) Namco (L. Switch))	P		Auxiliary	Static Analysis Simplified Dynamic	Lowest $f_n = 24.8$ Hz. Acceleration Levels Used: $H_1 = H_2 = 1.00$ g, $V = 1.25$ g Lowest $f_n = 213$ Hz. Acceleration Levels Used: H(Result.) = 3.0 g, V = 5.0 g. Critical stress = 13,330 psi. (Allowable = 19,200 psi) Max. Calc. Acceleration: $H_1 = .67$ g, $H_2 = .85$ g, $V = .85$ g.
1VC11YA	Opposed Blade Balancing Damper (AWV (Damper) ITT (M.Oper) Namco (L.Switch))	A		Auxiliary	Static Analysis Simplified Dynamic Analysis	Nat. Freq. > 33 Hz. Acceleration Levels Used: $H_1 = 1.0$ g, $H_2 = 1.0$ g, $V = 3.0$ g. Lowest $f_n = 43$ Hz. Acceleration Levels Used: 5.0 g in all directions. Critical stress = 17,269 psi. (Allowable = 19,200 psi) Max. Calc. Accelerations: $H_1 = .66$ g, $H_2 = .84$ g, $V = .68$ g.

Specification No. H-2868
 Vendor: Refer Below
 Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page 338 of 83
 Rev. 00
 Date 4-15-81

Equipment Number	Description	S e l e c t i o n	C l a s s	Location		Qualification Method		Results
1VC11VB	Opposed Blade Balancing Damper (AWV (Damper) ITT (M.Oper) Namco (L.Switch)	A		Auxiliary		Static Analysis Simplified Dynamic Analysis		Nat. Freq. > 33 Hz. Acceleration Levels Used: H ₁ = 1.0 g, H ₂ = 1.0 g, V ¹ = 3.0 g. Lowest f _n = 43 Hz. Acceleration Levels Used: 5.0 g in all directions. Critical stress = 17,269 psi. (Allowable = 19,200 psi) Max. Calc. Accelerations: H ₁ = 1.5 g, H ₂ = 2.09 g, V ¹ = 1.17 g.
1VC17YA	Opposed Blade Balancing Damper (AWV (Damper) ITT (M.Oper) Namco (L.Switch))	A		Auxiliary El. 591'-7"		Static Analysis Simplified Dynamic Analysis		Nat. freq. > 33 Hz. Acceleration Levels Used: H ₁ = 1.0 g, H ₂ = 1.0 g, V ¹ = 3.0 g. Lowest f _n = 43 Hz. Acceleration Levels Used: 5.0 g in all directions. Critical stress = 17,269 psi. (Allowable = 19,200 psi) Max. Calc. Accelerations: H ₁ = 2.93 g, H ₂ = 1.8 g, V ¹ = 1.2 g.

Specification No. H-2868
 Vendor: Refer Below
 Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page B39 of 83
 Rev. 00
 Date 4-15-81

Equipment Number	Description	S e r i e s	C l a s s	Location		Qualification Method		Results
1VC17YB	Opposed Blade Balancing Damper (AWV (Damper) ITT (M.Oper) Namco (L. Switch))	A		Auxiliary		Static Analysis Simplified Dynamic Analysis		Nat. Freq. > 33 Hz. Acceleration Levels Used: H ₁ = 1.0 g, H ₂ = 1.0 g, V ¹ = 3.0 g. Lowest f _n = 43 Hz. Acceleration Levels Used: 5.0 g in all directions. Critical stress = 17,269 psi. (Allowable = 19,200 psi) Max. Calc. Accelerations: H ₁ = 2.93 g, H ₂ = 1.8 g, V ¹ = .68 g.
1VC20YA	Opposed Blade Balancing Damper (AWV (Damper) ITT (M.Oper), Namco (L. Switch))	A		Auxiliary		Static Analysis Simplified Dynamic Analysis		Nat. Freq. > 33 Hz. Acceleration Levels Used: H ₁ = 1.0 g, H ₂ = 1.0 g, V ¹ = 3.0 g. Lowest f _n = 43 Hz. Acceleration Levels Used: 5.0 g, in all directions Critical stress = 17,269 psi. (Allowable = 19,200 psi) Max. Calc. Accelerations: H ₁ = .66 g, H ₂ = .84 g, V ¹ = .66 g.

Specification No. H-2868Vendor: Refer Below

Wm. H. Zimmer

Project No. 4130-00

SUMMARY OF
EQUIPMENT QUALIFICATIONPage 840 of 83Rev. 00Date 4-15-81

Equipment Number	Description	Series	Class	Location	Qualification Method	Results
1VC24YB	Opposed Blade Balancing Damper (AWV (Damper) ITT (M.Oper.) Namco (L.Switch)	A		Auxiliary	Static Analysis Simplified Dynamic Analysis	Nat. Freq. > 33 Hz. Acceleration Levels Used: $H_1 = 1.0$ g, $H_2 = 1.0$ g, $V^1 = 3.0$ g. Lowest $f_n = 43$ Hz Acceleration Levels Used: 5.0 g in all directions. Critical stress = 17,269 psi. (Allowable = 19,200 psi) Max. Calc. Accelerations: $H_1 = 1.54$ g, $H_2 = .84$ g, $V^1 = .68$ g.
1VC26Y	Opposed Blade Balancing Damper (AWV (Damper) ITT (M.Oper), Namco (L.Switch))	A		Auxiliary	Static Analysis Simplified Dynamic Analysis	Nat. Freq. > 33 Hz. Acceleration Levels Used: $H_1 = 1.0$ g, $H_2 = 1.0$ g, $V^1 = 3.0$ g. Lowest $f_n = 43$ Hz. Acceleration Levels Used: 5.0 g in all directions. Critical stress = 17,269 psi. (Allowable = 19,200 psi) Max. Calc. Accelerations: $H_1 = .64$ g, $H_2 = .62$ g, $V^1 = .95$ g.

Specification No. H-2868Vendor: Refer Below

Wm. H. Zimmer

Project No. 4130-00

SUMMARY OF
EQUIPMENT QUALIFICATIONPage 841 of 83Rev. 00Date 4-15-81

Equipment Number	Description	Series	Class	Location	Qualification Method	Results
1VC20YB	Opposed Blade Balancing Damper (AWV (Damper) ITT (M.Oper) Namco (L.Switch))	A	Auxiliary		Static Analysis Simplified Dynamic Analysis	Nat. Freq. > 33 Hz. Acceleration Levels Used: $H_1 = 1.0$ g, $H_2 = 1.0$ g, $V^1 = 3.0$ g. Lowest $f_n = 43$ Hz. Acceleration Levels Used: 5.0 g in all directions. Critical stress = 17,269 psi. (Allowable = 19,200 psi) Max. Calc. Accelerations: $H_1 = 1.54$ g, $H_2 = .84$ g, $V^1 = .68$ g.
1VC24YA	Opposed Blade Balancing Damper (AWV, (Damper) ITT (M.Oper.) Namco (L.Switch))	A	Auxiliary		Static Analysis Simplified Dynamic Analysis	Nat. Freq. > 33 Hz. Acceleration Levels Used: $H_1 = 1.0$ g, $H_2 = 1.0$ g, $V^1 = 3.0$ g. Lowest $f_n = 43$ Hz. Acceleration Levels Used: 5.0 g in all directions. Critical stress = 17,269 psi. (Allowable = 19,200 psi) Max. Calc. Accelerations: $H_1 = .66$ g, $H_2 = .84$ g, $V^1 = .66$ g.

Specification No. H-2868
 Vendor: Refer Below

Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page B-2 of 83

Rev. 06

Date 4-15-81

Equipment Number	Description	Series	Location	Qualification Method	Results
1VC27Y	Opposed Blade Balancing Damper (AWV (Damper) ITT (M.Oper) Namco (L. Switch))	A	Auxiliary	Static Analysis Simplified Dynamic Analysis	Lowest $f_n = 24.8$ Hz. Acceleration Levels Used: $H_1 = H_2 = 1.00$ g, $V = 1.25$ g Lowest $f_n = 173$ Hz. Acceleration Levels Used: H(Result.) = 3.0 g, V = 5.0 g. Critical stress = 13,330 psi. (Allowable = 19,200 psi) Max. Calc. Accelerations: $H_1 = .67$ g, $H_2 = .85$ g, $V = .85$ g.
1VC29YA/B	Opposed Blade Balancing Damper (AWV (Damper) ITT (M.Oper), Namco (L. Switch))	A	Auxiliary	Static Analysis Simplified Dynamic Analysis	Lowest $f_n = 24.8$ Hz. Acceleration Levels Used: $H_1 = H_2 = 1.00$ g, $V = 1.25$ g. Lowest $f_n = 173$ Hz. Acceleration Levels Used: H(Result.) = 3.0 g, V = 5.0 g. Critical stress = 13,330 psi. (Allowable = 19,200 psi) Max. Calc. Accelerations: $H_1 = .67$ g, $H_2 = .85$ g, $V = .85$ g.

Specification No. H-2868Vendor: Refer Below

Wm. H. Zimmer

Project No. 4130-00SUMMARY OF
EQUIPMENT QUALIFICATIONPage 843 of 93Rev. 00Date 4-15-81

Equipment Number	Description	Series	Class	Location	Qualification Method	Results
1VC31YA	Opposed Blade Balancing Damper (AWV (Damper) ITT (M.Oper) Namco (L. Switch))	A		Auxiliary	Static Analysis Simplified Dynamic Analysis	Lowest f_n = 24.8 Hz. Acceleration Levels Used: $H_1 = H_2 = 1.00$ g, $V=1.25$ g Lowest f_n = 173 Hz. Acceleration Levels Used: H(Result.) = 3.0 g, V = 5.0 g. Critical stress = 13,330 psi. (Allowable = 19,200 psi) Max. Calc. Accelerations: $H_1 = .48$ g, $H_2 = .62$ g, $V^1 = .85$ g.
1VC31YB	Opposed Blade Balancing Damper (AWV (Damper) ITT (M.Oper.) Namco (L. Switch))	A		Auxiliary	Static Analysis Simplified Dynamic Analysis	Lowest f_n = 24.8 Hz. Acceleration Levels Used: $H_1 = H_2 = 1.00$ g, $V=1.25$ g Lowest f_n = 48 Hz. Acceleration Levels Used: H(Result.) = 3.0 g, V = 5.0 g. Critical stress = 13,330 psi. (Allowable = 19,200 psi) Max. Calc. Accelerations: $H_1 = .48$ g, $H_2 = .62$ g, $V^1 = .85$ g.

Specification No. H-2868

Vendor: Refer Below

Wm. H. Zimmer

Project No. 4130-00

SUMMARY OF
EQUIPMENT QUALIFICATIONPage 844 of 83Rev. 00Date 4-15-81

Equipment Number	Description	Series	Class	Location	Qualification Method	Results
1VC36Y	Opposed Blade Balancing Damper (AWV (Damper) ITT (M.Oper) Namco (L. Switch))	A		Auxiliary	Static Analysis Simplified Dynamic Analysis	Lowest $f_n = 24.8$ Hz. Acceleration Levels Used: $H_1 = H_2 = 1.00$ g, $V = 1.25$ g Lowest $f_n = 39$ Hz. Acceleration Levels Used: H(Result.) = 3.0 g, V = 5.0 g. Critical stress = 13,330 psi (Allowable = 19,200 psi) Max. Calc. Accelerations: $H_1 = .67$ g, $H_2 = .85$ g, $V^1 = .85$ g.
1VC37Y	Opposed Blade Balancing Damper (AWV (Damper) ITT (M.Oper), Namco (L. Switch))	A		Auxiliary	Static Analysis Simplified Dynamic Analysis	Nat. Freq. > 33 Hz. Acceleration Levels Used: $H_1 = 1.0$ g, $H_2 = 1.0$ g, $V^1 = 3.0$ g. Lowest $f_n = 43$ Hz. Acceleration Levels Used: 5.0 g in all directions. Critical stress = 17,269 psi. (Allowable = 19,200 psi) Max. Calc. Accelerations: $H_1 = .86$ g, $H_2 = 1.83$ g, $V^1 = 1.12$ g.

Specification No. H- 2868Vendor: Refer Below

Wm. H. Zimmer

Project No. 4130-00

SUMMARY OF
EQUIPMENT QUALIFICATIONPage 845 of 83Rev. 00Date 4-15-81

Equipment Number	Description	Series	Class	Location	Qualification Method	Results
1VC82Y	Opposed Blade Balancing Damper (AWV (Damper) ITT (M.Oper), Namco (L. Switch))	A		Auxiliary	Static Analysis Simplified Dynamic Analysis	Nat. Freq. > 33 Hz. Acceleration Levels Used: $H_1 = 1.0$ g, $H_2 = 1.0$ g, $V^1 = 3.0$ g. Lowest $f_n = 43$ Hz. Acceleration Levels Used: 5.0 g, in all directions. Critical stress = 17,269 psi. (Allowable = 19,200 psi) Max. Calc. Accelerations: $H_1 = .83$ g, $H_2 = 1.24$ g, $V^1 = 1.65$ g.
1VC86Y	Opposed Blade Balancing Damper (AWV (Damper) ITT (M.Oper) Namco (L. Switch))	A		Auxiliary	Static Analysis Simplified Dynamic Analysis	Nat. Freq. > 33 Hz. Acceleration Levels Used: $H_1 = 1.0$ g, $H_2 = 1.0$ g, $V^1 = 3.0$ g. Lowest $f_n = 43$ Hz. Acceleration Levels Used: 5.0 g, in all directions. Critical stress = 17,269 psi. (Allowable = 19,200 psi) Max. Calc. Accelerations: $H_1 = 1.50$ g, $H_2 = 1.59$ g, $V^1 = .75$ g.

Specification No. H-2868

Vendor: _____ Refer Below

Wm. H. Zimmer

Project No. 4130-00

SUMMARY OF
EQUIPMENT QUALIFICATIONPage 846 of 83Rev. 00Date 4-15-81

Equipment Number	Description	Series	Class	Location	Qualification Method	Results
1VC87Y	Opposed Blade Balancing Damper (AWV (Damper) ITT (M.Oper.) Namco (L. Switch))	P		Auxiliary	Static Analysis Simplified Dynamic Analysis	Lowest $f_n = 24.8$ Hz. Acceleration Levels Used: $H_1 = H_2 = 1.00$ g, $V = 1.25$ g Lowest $f_n = 119$ Hz. Acceleration Levels Used: H(Result.) = 3.0 g, $V = 5.0$ g. Critical stress = 13,330 psi. (Allowable = 19,200 psi) Max. Calc. Accelerations: $H_1 = .43$ g, $H_2 = .41$ g, $V^1 = .95$ g.
1VC88Y	Opposed Blade Balancing Damper (AWV (Damper) ITT (M.Oper), Namco (L. Switch))	P		Auxiliary El.525'-7"	Static Analysis Simplified Dynamic Analysis	Lowest $f_n = 24.8$ Hz. Acceleration Levels Used: $H_1 = H_2 = 1.00$ g, $V = 1.25$ g Lowest $f_n = 172$ Hz. Acceleration Levels Used: H(Result) = 3.0 g, $V = 5.0$ g. Critical stress = 13,330 psi. (Allowable = 19,200 psi) Max. Calc. Accelerations: $H_1 = .42$ g, $H_2 = .41$ g, $V^1 = .95$ g.

Specification No. H-2868Vendor: Refer Below

Wm. H. Zimmer

Project No. 4130-00

SUMMARY OF
EQUIPMENT QUALIFICATIONPage 1347 of 93Rev. 00Date 4-15-81

Equipment Number	Description	Classification	Location	Qualification Method	Results
1VD01YA/B/ C/D/E/F	Opposed Blade Balancing Damper (AWV (Damper), ITT (M.Oper) Namco (L. Switch))	A	Auxiliary	Static Analysis Simplified Dynamic Analysis	Lowest $f_n = 24.8$ Hz. Acceleration Levels Used: $H_1 = H_2 = 1.00$ g, $V = 1.25$ g Lowest $f_n = 41$ Hz Acceleration Levels Used: $H(\text{Result.}) = 3.0$ g, $V = 5.0$ g. Critical Stress = 13,330 psi. (Allowable = 19,200 psi) Max. Calc. Accelerations: $H_1 = .36$ g, $H_2 = .48$ g, $V^1 = .95$ g.
1VD02YA/B/ D/E/F	Opposed Blade Balancing Damper (AWV (Damper), ITT (M.Oper) Namco (L. Switch))	A	Auxiliary	Static Analysis Simplified Dynamic Analysis	Nat. Freq. > 33 Hz. Acceleration Levels Used: $H_1 = 1.0$ g, $H_2 = 1.0$ g, $V^1 = 3.0$ g. Lowest $f_n = 43$ Hz Acceleration Levels Used: 5.0 g in all directions Critical stress = 17,269 psi. (Allowable = 19,200 psi) Max. Calc. Accelerations: $H_1 = .36$, $H_2 = .46$ g, $V^1 = .55$ g.

Specification No. H-2868Vendor: Refer Below

Wm. H. Zimmer

Project No. 4130-00SUMMARY OF
EQUIPMENT QUALIFICATIONPage 848 of 83Rev. 00Date 4-15-81

Equipment Number	Description	Series	Location	Qualification Method	Results
1VD03YA/B/ C/D/E/F/G /H/J/K/L/ M	Opposed Blade Balancing Damper (AWV (Damper), ITT (M.Oper) Namco (L. Switch))	A	Auxiliary	Static Analysis Simplified Dynamic Analysis	Lowest $f_n = 24.8$ Hz. Acceleration Levels Used: $H_1 = H_2 = 1.00$ g, $V = 1.25$ g. Lowest $f_n = 39$ Hz. Acceleration Levels Used: $H(\text{Result.}) = 3.0$ g. $V = 5.0$ g. Critical Stress = 13,330 psi. (Allowable = 19,200 psi) Max. Calc. Accelerations: $H_1 = .36$ g, $H_2 = .48$ g, $V^1 = .95$ g.
1VD07YA	Opposed Blade Balancing Damper (AWV (Damper) ITT (M.Oper) Namco (L. Switch))	P	Auxiliary	Static Analysis Simplified Dynamic Analysis	Nat. Freq. > 33 Hz. Acceleration Levels Used: $H_1 = 1.0$ g, $H_2 = 1.0$ g, $V^1 = 3.0$ g. Lowest $f_n = 4$ Hz. Acceleration Levels Used: 5.0 g in all directions. Critical stress = 17,269 psi. (Allowable = 19,200 psi) Max. Calc. Accelerations: $H_1 = .4$ g, $H_2 = .46$ g, $V^1 = .55$ g.

Specification No. H-2868
 Vendor: Refer Below
 Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page 849 of 83
 Rev. 00
 Date 4-15-81

Equipment Number	Description	Series	Location	Qualification Method	Results
1VD07YB	Opposed Blade Balancing Damper (AWV (Damper) ITT (M.Oper) Namco (L. Switch))	P	Auxiliary	Static Analysis Simplified Dynamic Analysis	Nat. Freq. > 33 Hz. Acceleration Levels Used: H ₁ = 1.0 g, H ₂ = 1.0 g, V ¹ = 3.0 g. Lowest f _n = 43 Hz Acceleration Levels Used: 5.0 g in all directions. Critical stress = 17,269 psi. (Allowable = 19,200 psi) Max. Calc. Accelerations: H ₁ = .66 g, H ₂ = .46 g, V ¹ = .55 g.
1VD07YC	Opposed Blade Balancing Damper (AWV (Damper) ITT (M.Oper), Namco (L. Switch))	P	Auxiliary	Static Analysis Simplified Dynamic Analysis	Nat. Freq. > 33 Hz. Acceleration Levels Used: H ₁ = 1.0 g, H ₂ = 1.0 g, Lowest f _n = 43 Hz. Acceleration Levels Used: 5.0 g in all directions. Critical stress = 17,269 psi. (Allowable = 19,200 psi) Max. Calc. Accelerations: H ₁ = .36 g, H ₂ = .46 g, V ¹ = .55 g.

Specification No. H-2868
 Vendor: Refer Below
 Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page 250 of 23
 Rev. 60
 Date 4-15-81

Equipment Number	Description	Series	Class	Location	Qualification Method	Results
1VQ05YA	Opposed Blade Balancing Damper (AWV (Damper) ITT (M.Oper) Namco (L. Switch))	P		Auxiliary	Static Analysis Simplified Dynamic Analysis	Lowest $f_n = 24.8$ Hz. Acceleration Levels Used: $H_1 = H_2 = 1.00$ g, $V = 1.25$ g Lowest $f_n = 43$ Hz. Acceleration Levels Used: $H(\text{Result.}) = 3.0$ g, $v = 5.0$ g. Critical stress = 13,330 psi. (Allowable = 19,200 psi) Max. Calc. Acceleration: $H_1 = .80$ g, $H_2 = .80$ g, $V^1 = .95$ g.
1VQ05YB	Opposed Blade Balancing Damper (AWV (Damper) ITT (M.Oper) Namco (L. Switch))	P		Auxiliary	Static Analysis Simplified Dynamic Analysis	Nat. Freq. > 33 Hz. Acceleration Levels Used: $H_1 = 1.0$ g, $H_2 = 1.0$ g. $V^1 = 3.0$ g. Lowest $f_n = 43$ Hz Acceleration Levels Used: 5.0 g in all directions. Critical stress = 17,269 psi. (Allowable = 19,200 psi) Max. Calc. Accelerations: $H_1 = .56$ g, $H_2 = .79$ g, $V^1 = 1.15$ g.

Specification No. H- 2868

Vendor: Refer Below

Wm. H. Zimmer

Project No. 4130-00

SUMMARY OF
EQUIPMENT QUALIFICATIONPage 351 of 43Rev. 00Date 4-15-81

Equipment Number	Description	Series	Class	Location	Qualification Method	Results
1VQ06YA	Opposed Blade Balancing Damper (AWV, (Damper) ITT (M.Oper) Namco (L. Switch))	P		Auxiliary	Static Analysis Simplified Dynamic Analysis	Lowest $f_n = 24.8$ Hz. Acceleration Levels Used: $H_1 = H_2 = 1.00g$, $V = 1.25g$. Lowest $f_n = 53$ Hz. Acceleration Levels Used: $H(\text{Result.}) = 3.0g$, $V = 5.0g$. Critical Stress = 13,330 psi (Allowable = 19,200 psi) Max. Calc. Accelerations: $H_1 = .34g$, $H_2 = .70g$, $V = .95g$.
1VQ06YB	Opposed Blade Balancing Damper (AWV, (Damper) ITT (M.Oper), Namco (L. Switch))	P		Auxiliary	Static Analysis Simplified Dynamic Analysis	Lowest $f_n = 24.8$ Hz. Acceleration Levels Used: $H_1 = H_2 = 1.00g$, $V = 1.25g$. Lowest $f_n = 53$ Hz. Acceleration Levels Used: $H(\text{Result.}) = 3.0g$, $V = 5.0g$ Critical Stress = 13,330 psi (Allowable = 19,200 psi) Max. Calc. Accelerations: $H_1 = .70g$, $H_2 = .45g$, $V = .95g$.

Specification No. H- 2868Vendor: Refer Below

Wm. H. Zimmer

Project No. 4130-00SUMMARY OF
EQUIPMENT QUALIFICATIONPage 852 of 83Rev. 00Date 4-15-81

Equipment Number	Description	S e l a s s	C l a s s	Location																																																																																																																																													
Equipment Number	Description	S	C	Location																																																																																																																																													
1VR01YA	Butterfly Isolation Damper (AWV (Damper) Bettis (Model: 721C-SR, M.Oper.) Namco (L. Switches))	W/S	Auxiliary	Simplified Dynamic Analysis																																																																																																																																													
1VR01YB/C	Butterfly Isolation Damper (AWV (Damper) Bettis (Model: 721C-SR, M.Oper), Namco (L. Switches))	W/S	Auxiliary	Simplified Dynamic Analysis																																																																																																																																													

Specification No. H- 2868Vendor: Refer Below

Wm. H. Zimmer

Project No. 4130-00

SUMMARY OF
EQUIPMENT QUALIFICATIONPage 858 of 88Rev. 00Date 4-15-81

Equipment Number	Description	Series	Class	Location	Qualification Method	Results
1VR02YA	Butterfly Isolation Damper (AWV, (Damper) Bettis (Model: 721C-SR M.Oper.) Namco (L. Switches))	W/S		Auxiliary	Simplified Dynamic Analysis	Lowest $f_n = 86$ Hz. Acceleration Levels Used: $H_1 = H_2 = V = 1.0g$. Critical Stress = 9,907 psi (Allowable = 28,700 psi) Max. Calc. Acceleration: $H_1 = .34g$, $H_2 = .41g$, $V = .55g$.
1VR02YB	Butterfly Isolation Damper (AWV (Damper) Bettis (Model: 721C-SR M.Oper) Namco (L. Switches))	W/S		Auxiliary	Simplified Dynamic Analysis	Lowest $f_n = 86$ Hz. Acceleration Levels Used: $H_1 = H_2 = V = 1.0g$ Critical Stress = 9,907 psi (Allowable = 28,700 psi) Max. Calc. Acceleration: $H_1 = .38g$, $H_2 = .37g$, $V = .86g$.

Specification No. H- 2868

Vendor: Refer Below

Wm. H. Zimmer

Project No. 4130-00

SUMMARY OF
EQUIPMENT QUALIFICATIONPage B54 of 83Rev. 00Date 4-15-81

Equipment Number	Description	S e l e c t i o n s	C l a s s	Location	Qualification Method	Results
1VR02YC	Butterfly Isolation Damper (AWV (Damper) Bettis (Model: 721C-SR M.Oper.) Namco (L. Switches))	W/S		Auxiliary	Simplified Dynamic Analysis	Lowest $f_n = 86$ Hz. Acceleration Levels Used: $H_1 = H_2 = V = 1.0g$ Critical Stress = 9,907 psi (Allowable = 28,700 psi) Max. Calc. Acceleration: $H_1 = .47g, H_2 = .41g,$ $V^1 = .55g.$
1VR03YA/B	Opposed Blade Balancing Damper (AWV, (Damper) Powers (M.Oper.) Namco (L. Switch))	W/S		Auxiliary	Static Analysis Simplified Dynamic Analysis	Nat. Freq. = 233 Hz. Acceleration Levels Used: $H_1 = 1.0g, H_2 = 1.0g,$ $V^1 = 3.0g.$ Lowest $f_n = 81.5$ Hz. Acceleration Levels Used: $H_1 = 1.0g, H_2 = 1.0g,$ $V^1 = 2.0g.$ Critical Stress = 12,142 psi (Allowable = 31,600 psi) Max. Calc. Acceleration: $H_1 = 0.62g, H_2 = 0.37g,$ $V^1 = 1.7g.$

Specification No. H- 2868
 Vendor: Refer Below

Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page 255 of 83

Rev. 00

Date 4-15-81

Equipment Number	Description	S e i s s	C l a s s	Location		Qualification Method		Results
1VR09Y	Opposed Blade Balancing Damper (AWV, (Damper) Powers (M.Oper.) Namco (L. Switch))	W/S		Auxiliary		Static Analysis Simplified Dynamic Analysis		Nat. Freq. = 233 Hz. Acceleration Levels Used: $H_1 = 1.0g$, $H_2 = 1.0g$, $V^1 = 3.0g$. Lowest $f_n > 75$ Hz. Acceleration Levels Used: $H_1 = 1.0g$, $H_2 = 1.0g$, $V^1 = 3.0g$ Critical Stress = 14,006 psi (Allowable = 31,600 psi) Max. Calc. Acceleration: $H_1 = 0.6g$, $H_2 = 0.44g$, $V^1 = 0.98g$.
1VP01YA/B	Opposed Blade Balancing Damper (AWV, (Damper) ITT (M.Oper.) Namco (L. Switches))	W/S		Reactor		Static Analysis Simplified Dynamic Analysis		Lowest $f_n = 24.8$ Hz. Acceleration Levels Used: $H_1 = 1.00g$, $H_2 = 1.00g$, $V^1 = 1.25g$. Lowest $f_n = 40$ Hz. Limit analysis performed with resulting accelerations found to be above tolerable level. Damper system is subject to modification.

Specification No. H- 2868

Vendor: _____ Refer Below

Wm. H. Zimmer

Project No. 4130-00

SUMMARY OF
EQUIPMENT QUALIFICATIONPage 856 of 88Rev. 00Date 4-15-81

Equipment Number	Description	S e r i e s	C l a s s	Location		Qualification Method		Results
1VP10YA/B	Opposed Blade Balancing Damper (AWV, (Damper) ITT (M.Oper.) Namco (L. Switches))	W/S	Reactor			Static Analysis Simplified Dynamic Analysis		Lowest $f_n = 24.8$ Hz. Acceleration Levels Used: $H_1 = 1.00g$, $H_2 = 1.00g$, $V_1 = 1.25g$ Lowest $f_n = 40$ Hz. Limit analysis performed with resulting accelerations found to be above tolerable level. Damper system is subject to modification.
1VP11YA/B	Opposed Blade Balancing Damper (AWV, (Damper) ITT (M.Oper.), Namco (L. Switches))	W/S	Reactor			Static Analysis Simplified Dynamic Analysis		Lowest $f_n = 24.8$ Hz. Acceleration Levels Used: $H_1 = 1.00g$, $H_2 = 1.00g$, $V_1 = 1.25g$ Lowest $f_n = 40$ Hz. Limit analysis performed with resulting accelerations found to be above tolerable level. Damper system is subject to modification.

Specification No. H-2868Vendor: Refer Below

Wm. H. Zimmer

Project No. 4130-00

SUMMARY OF
EQUIPMENT QUALIFICATIONPage 857 of 83Rev. 00Date 4-15-81

Equipment Number	Description	S e l e c t i o n s	C l a s s	Location	Qualification Method	Results
1VQ01Y	Butterfly Isolation Damper (AWV, (Damper), ITT (M.Oper.), Namco (L. Switches))	W/S	Reactor		Static Analysis Simplified Dynamic Analysis	Lowest $f_n = 98.7$ Hz. Acceleration Levels Used: $H_1 = H_2 = 1.0g$, $V = 3.0g$ Critical Stress = 2,895 psi (Allowable = 23,400 psi) Lowest $f_n \geq 40$ Hz. Limit load analysis performed which found acceleration levels beyond a tolerable level. Damper system is subject to modification.
1VQ02Y	Butterfly Isolation Damper (AWV, (Damper), ITT (M.Oper.), Namco (L. Switches))	W/S	Reactor		Static Analysis Simplified Dynamic Analysis	Lowest $f_n \geq 98.7$ Hz. Acceleration Levels Used: $H_1 = H_2 = 1.0g$, $V = 3.0g$ Critical Stress = 2,895 psi (Allowable = 23,400 psi) Lowest $f_n \geq 40$ Hz. Limit load analysis performed which found acceleration levels beyond a tolerable level. Damper system is subject to modification.

Specification No. H-2868Vendor: Refer Below

Wm. H. Zimmer

Project No. 4130-00

SUMMARY OF
EQUIPMENT QUALIFICATIONPage 858 of 83Rev. 00Date 4-15-81

Equipment Number	Description	Series	Class	Location	Qualification Method	Results
1VQ03Y	Butterfly Isolation Damper (AWV, (Damper), ITT (M.Oper.), Namco (L. Switches))	W/S	Reactor		Static Analysis Simplified Dynamic Analysis	Lowest $f_n = 98.7$ Hz. Acceleration Levels Used: $H_1 = H_2 = 1.0g$, $V = 3.0g$ Critical Stress = 2,895 psi (Allowable = 23,400 psi) Lowest $f_n \geq 40$ Hz. Limit load analysis performed with Max. Calc. acceleration level of 1.4g as compared to an allowable of 5.4g.
1VQ11Y	Butterfly Isolation Damper (AWV, (Damper), ITT (M.Oper.), Namco (L. Switches))	W/S	Reactor		Static Analysis Simplified Dynamic Analysis	Lowest $f_n = 98.7$ Hz. Acceleration Levels Used: $H_1 = H_2 = 1.0g$, $V = 3.0g$ Critical Stress = 2,895 psi (Allowable = 23,400 psi) Lowest $f_n \geq 40$ Hz. Limit load analysis performed with Max. Calc. acceleration level of 1.4g as compared to an allowable of 5.4g.

Specification No. H-2868Vendor: Refer Below

Wm. H. Zimmer

Project No. 4130-00

SUMMARY OF
EQUIPMENT QUALIFICATIONPage 889 of 88Rev. 00Date 1-15-81

Equipment Number	Description	S e l e c t i o n s	C l a s s	Location	Qualification Method	Results
1VQ13Y	Butterfly Isolation Damper (AWV, (Damper), Powers (M.Oper.), Namco (L. Switches))	W/S		Reactor	Static Analysis Simplified Dynamic Analysis	Lowest $f_n = 233$ Hz. Acceleration Levels Used: $H_1 = H_2 = 1.0g$, $V = 3.0g$ Critical Stress = 22,410 psi (Allowable = 32,400 psi) Lowest $f_n > 75$ Hz. Acceleration Levels Used: $H_1 = H_2 = V = 1.4g$ Critical Stress = 319 psi (Allowable = 18,000 psi) Max. Calc. Acceleration: $H_1 = H_2 = V = 1.4g$
1VQ14Y	Opposed Blade Balancing Dampers (AWV, (Damper) Powers (M.Oper.), Namco (L. Switches))	P		Reactor	Static Analysis Simplified Dynamic Analysis	Nat. Freq. > 33 Hz. Acceleration Levels Used: $H_1 = 1.0g$, $H_2 = 1.0g$, $V = 3.0g$ Lowest $f_n = 283$ Hz. Acceleration Levels Used: 6.0g's in all directions Critical Stress = 23,412 psi (Allowable = 32,000 psi) Max. Calc. Accelerations: $H_1 = 1.05g$, $H_2 = .60g$, $V = .81g$

Specification No. H- 2868Vendor: Refer Below

Wm. H. Zimmer

Project No. 4130-00

SUMMARY OF
EQUIPMENT QUALIFICATIONPage 860 of 83Rev. 00Date 4-15-81

Equipment Number	Description	Series	Class	Location	Qualification Method	Results
1VQ15Y	Opposed Blade Balancing Dampers (AWV, (Damper) Powers (M.Oper.), Namco (L. Switches))	P		Reactor	Static Analysis Simplified Dynamic Analysis	Nat. Freq. > 33 Hz. Acceleration Levels Used: $H_1 = 1.0g$, $H_2 = 1.0g$, $V^1 = 3.0g$. Lowest $f_n = 36$ Hz. Acceleration Levels Used: 6.0g's in all directions. Critical Stress = 23,412 psi (Allowable = 32,000 psi) Max. Calc. Accelerations: $H_1 = .48g$, $H_2 = .37g$, $V^1 = 1.15g$.
1VQ16YA/B	Opposed Blade Balancing Dampers (AWV, (Damper) Powers (M.Oper.), Namco (L. Switches))	P		Reactor	Static Analysis Simplified Dynamic Analysis	Nat. Freq. > 33 Hz. Acceleration Levels Used: $H_1 = 1.0g$, $H_2 = 1.0g$, $V^1 = 3.0g$. Lowest $f_n = 50$ Hz. Acceleration Levels Used: 6.0g's in all directions Critical Stress = 23,412 psi (Allowable = 32,000 psi) Max. Calc. Accelerations: $H_1 = .94g$, $H_2 = .87g$, $V^1 = 1.03g$.

Specification No. H-2868Vendor: Refer Below

Wm. H. Zimmer

Project No. 4130-00

SUMMARY OF
EQUIPMENT QUALIFICATIONPage 261 of 83Rev. 00Date 4-15-81

Equipment Number	Description	Series	Class	Location	Qualification Method	Results
1VQ17Y	Butterfly Isolation Damper (AWV, (Damper) Powers (M. Oper.), Namco (L. Switches))	W/S		Reactor	Static Analysis Simplified Dynamic Analysis	Lowest $f_n = 233$ Hz. Acceleration Levels Used: $H_1 = H_2 = 1.0g$, $V = 3.0g$. Critical Stress = 22,410 psi (Allowable = 32,400 psi) Lowest $f_n > 75$ Hz. Acceleration Levels Used: $H_1 = H_2 = V = 1.4g$. Critical Stress = 319 psi (Allowable = 18,000 psi) Max. Calc. Acceleration: $H_1 = H_2 = V = 1.4g$.
1VQ18Y	Opposed Blade Balancing Damper (AWV, (Damper), Powers (M. Oper.), Namco (L. Switches))	P		Reactor	Static Analysis Simplified Dynamic Analysis	Nat. Freq. > 33 Hz. Acceleration Levels Used: $H_1 = 1.0g$, $H_2 = 1.0g$, $V = 3.0g$. Lowest $f_n = 76$ Hz. Acceleration Levels Used: 6.0g's in all directions. Critical Stress = 23,412 psi (Allowable = 32,000 psi) Max. Calc. Accelerations: $H_1 = 5.78g$, $H_2 = 5.78g$, $V = 3.04g$.

Specification No. H- 2868Vendor: Refer Below

Wm. H. Zimmer

Project No. 4130-00

SUMMARY OF
EQUIPMENT QUALIFICATIONPage 662 of 67Rev. 00Date 4-15-81

Equipment Number	Description	Specifications	Location	Qualification Method	Results
1VR10Y	Opposed Blade Balancing Damper (AWV, (Damper) Powers (M.Oper.), Namco (L. Switches))	W/S	Reactor	Static Analysis Simplified Dynamic Analysis	Nat. Freq. > 33 Hz. Acceleration Levels Used: $H_1 = 1.0g$, $H_2 = 1.0g$, $V^1 = 3.0g$. Lowest $f_n = 44$ Hz. Acceleration Levels Used: 6.0g's in all directions. Critical Stress = 23,412 psi (Allowable = 32,000 psi) Max. Calc. Accelerations: $H_1 = .74g$, $H_2 = .74g$, $V^1 = .74g$.
1VR11Y	Opposed Blade Balancing Damper (AWV, (Damper) Powers (M.Oper.), Namco (L. Switches))	W/S	Reactor	Static Analysis Simplified Dynamic Analysis	Nat. Freq. > 33 Hz. Acceleration Levels Used: $H_1 = 1.0g$, $H_2 = 1.0g$, $V^1 = 3.0g$. Lowest $f_n = 44$ Hz. Acceleration Levels Used: 6.0g's in all directions. Critical Stress = 23,412 psi (Allowable = 32,000 psi) Max. Calc. Accelerations: $H_1 = .74g$, $H_2 = .74g$, $V^1 = .74g$.

Specification No. H- 2868
 Vendor: Refer Below
 Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page 463 of 83
 Rev. 00
 Date 4-15-81

Equipment Number	Description	S e r i e s	C l a s s	Location	Qualification Method	Results
1VR15Y	Opposed Blade Balancing Damper (AWV, (Damper) Powers (M.Oper.), Namco (L. Switches))	W/S	Reactor	Static Analysis Simplified Dynamic Analysis	Nat. Freq. > 33 Hz. Acceleration Levels Used: $H_1 = 1.0g, H_2 = 1.0g,$ $V^1 = 3.0g.$ Lowest $f_n = 44$ Hz. Acceleration Levels Used: 6.0g's in all directions. Critical Stress = 23,412 psi (Allowable = 32,000 psi) Max. Calc. Accelerations: $H_1 = .74g, H_2 = .74g,$ $V^1 = .74g.$	
1VR16Y	Opposed Blade Balancing Damper (AWV, (Damper) Powers (M.Oper.), Namco (L. Switches))	W/S	Reactor	Static Analysis Simplified Dynamic Analysis	Nat. Freq. > 33 Hz. Acceleration Levels Used: $H_1 = 1.0g, H_2 = 1.0g,$ $V^1 = 3.0g.$ Lowest $f_n = 44$ Hz. Acceleration Levels Used: 6.0g's in all directicns Critical Stress = 23,412 psi (Allowable = 32,000 psi) Max. Calc. Accelerations: $H_1 = .74g, H_2 = .74g,$ $V^1 = .74g.$	

Specification No. H- 2868Vendor: Refer Below

Wm. H. Zimmer

Project No. 4130-00SUMMARY OF
EQUIPMENT QUALIFICATIONPage 564 of 83Rev. 00Date 4-15-81

Equipment Number	Description	S e r i e s	C l a s s	Location	Qualification Method	Results
1VR21Y	Opposed Blade Balancing Damper (AWV, (Damper), Powers (M. Oper.), Namco (L. Switches))	W/S	Reactor		Static Analysis Simplified Dynamic Analysis	Nat. Freq. > 33 Hz. Acceleration Levels Used: H ₁ = 1.0g, H ₂ = 1.0g, V ₁ = 3.0g. Lowest f _n = 44 Hz. Acceleration Levels Used: 6.0g's in all directions. Critical Stress = 23,412 psi (Allowable = 32,000 psi) Max. Calc. Accelerations: H ₁ = .74g, H ₂ = .74g, V ₁ = .74g.

Specification No. H-2868
 Vendor: Refer Below

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page 665 of 763

Rev. 30

Date 4-15-81

Wm. H. Zimmer
 Project No. 4130-00

Equipment Number	Description	S e r i a l s .	C l a s s	Location	Qualification Method	Results
1VR22Y	Opposed Blade Balancing Damper (AWV, (Damper) Powers (M. Oper), Namco (L. Switches))	W/S	Reactor	Static Analysis Simplified Dynamic Analysis	Nat. Freq. > 33 Hz. Acceleration Levels Used: H ₁ = 1.0 g, H ₂ = 1.0 g, V ¹ = 3.0 g. Lowest f _n = 44 Hz. Acceleration Levels Used: 6.0 g's in all directions Critical stress = 23,412 psi. (Allowable = 32,000 psi) Max. Calc. Accelerations: H ₁ = .74 g, H ₂ = .74 g, V ¹ = .74 g.	
1VR23Y	Opposed Blade Balancing Damper (AWV, (Damper), Powers (M. Oper.), Namco (L. Switches))	W/S	Reactor	Static Analysis Simplified Dynamic Analysis	Nat. Freq. > 33 Hz. Acceleration Levels Used: H ₁ = 1.0 g, H ₂ = 1.0 g, V ¹ = 3.0 g. Lowest f _n = 44 Hz. Acceleration Levels Used: 6.0 g's in all directions. Critical stress = 23,412 psi. (Allowable = 32,000 psi) Max. Calc. Accelerations: H ₁ = .74 g, H ₂ = .74 g, V ¹ = .74 g.	

Specification No. H-2868
 Vendor: Refer Below

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page 66 of 83

Rev. 00

Date 4-15-81

Wm. H. Zimmer
 Project No. 4130-00

Equipment Number	Description	S e r i e s	C l a s s	Location	Qualification Method	Results
1VR24Y	Opposed Blade Balancing Damper (AWV, (Damper), Powers (M.Oper.), Namco (L. Switches))	W/S	Reactor	Static Analysis Simplified Dynamic Analysis	Nat. Freq. > 33 Hz. Acceleration Levels Used: $H_1 = 1.0$ g, $H_2 = 1.0$ g, $V^1 = 3.0$ g. Lowest $f_n = 44$ Hz. Acceleration Levels Used: 6.0 g's in all directions Critical stress = 23,412 psi. (Allowable = 32,000 psi) Max. Calc. Accelerations: $H_1 = .74$ g, $H_2 = .74$ g, $V^1 = .74$ g.	
1VR31Y	Opposed Blade Balancing Damper (AWV, (Damper), Powers (M. Oper.), Namco (L. Switches))	W/S	Reactor	Static Analysis Simplified Dynamic Analysis	Nat. Freq. > 33 Hz. Acceleration Levels Used: $H_1 = 1.0$ g, $H_2 = 1.0$ g, $V^1 = 3.0$ g. Lowest $f_n = 44$ Hz. Acceleration Levels Used: 6.0 g's in all directions Critical stress = 23,412 psi. (Allowable = 32,000 psi) Max. Calc. Accelerations: $H_1 = .74$ g, $H_2 = .74$ g, $V^1 = .74$ g.	

Specification No. H-2868
 Vendor: Refer Below
 Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page 267 of 83
 Rev. 00
 Date 7-15-81

Equipment Number	Description	Series	Location	Qualification Method	Results
1VY01Y	Opposed Blade Balancing Damper (AWV, (Damper) ITT (M.Oper.) Namco (L. Switches))	A	Reactor	Static Analysis Simplified Dynamic Analysis	Lowest $f_n = 24.8$ Hz Acceleration Levels Used: $H_1 = 1.00$ g, $H_2 = 1.00$ g, $V^1 = 1.25$ g. Lowest $f_n = 53$ Hz Acceleration Levels Used: H(Result.) = 3.0 g, V = 5.0 g. Critical stress = 12,467 psi. (Allowable = 19,200 psi) Max. Calc. Acceleration: $H_1 = .83$ g, $H_2 = .78$ g, $V^1 = 2.15$ g.
1VY02Y	Opposed Blade Balancing Damper (AWV, (Damper), ITT (M.Oper) Namco (L. Switches))	A	Reactor	Static Analysis Simplified Dynamic Analysis	Lowest $f_n = 24.8$ Hz. Acceleration Levels Used: $H_1 = 1.00$ g, $H_2 = 1.00$ g. $V^1 = 1.25$ g. Lowest $f_n = 39$ Hz. Acceleration Levels Used: 5.0 g's in all directions Critical stress = 18,701 psi. (Allowable = 19,200 psi) Max. Calc. Acceleration: $H_1 = .30$ g, $H_2 = .44$ g, $V^1 = .64$ g.

Specification No. H-2868
 Vendor: Refer Below

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page 868 of 83
 Rev. 00
 Date 4-15-81

Wm. H. Zimmer
 Project No. 4130-00

Equipment Number	Description	S e i s s	C l a s s	Location	Qualification Method	Results
1VY04Y	Opposed Blade Balancing Damper (AWV, (Damper), ITT (M.Oper) Namco (L.Switches))	A	Reactor	Static Analysis Simplified Dynamic Analysis	Lowest $f_n = 24.8$ Hz. Acceleration Levels Used: $H_1 = 1.00$ g, $H_2 = 1.00$ g, $V^1 = 1.25$ g. Lowest $f_n = 53$ Hz. Acceleration Levels Used: 5.0 g's in all directions Critical stress = 18,701 psi. (Allowable = 19,200 psi) Max. Calc. Acceleration: $H_1 = .70$ g, $H_2 = .75$ g, $V^1 = .78$ g.	
1VY06YA/B	Opposed Blade Balancing Damper (AWV, (Damper), ITT (M.Oper) Namco, (L. Switches))	A	Reactor	Static Analysis Simplified Dynamic Analysis	Lowest $f_n = 24.8$ Hz. Acceleration Levels Used: $H_1 = 1.00$ g, $H_2 = 1.00$ g, $V^1 = 1.25$ g. Lowest $f_n = 43$ Hz. Acceleration Levels Used: H(Result.) = 3.0 g, V = 5.0 g. Critical stress = 12,467 psi. (Allowable = 19,200 psi) Max. Calc. Acceleration: $H_1 = .37$ g, $H_2 = .37$ g, $V^1 = 1.1$ g.	

Specification No. H-2868
 Vendor: Refer Below
 Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page 869 of 83
 Rev. 00
 Date 4-15-81

Equipment Number	Description	S e l e c t i o n	C l a s s i f i c a t i o n	Location	Qualification Method	Results
1VY08Y	Opposed Blade Balancing Damper (AWV, (Damper), ITT (M.Oper), Namco (L. Switches))	W/S	Reactor		Static Analysis Simplified Dynamic Analysis	Lowest $f_n = 24.8$ Hz. Acceleration Levels Used: $H_1 = 1.00$ g, $H_2 = 1.00$ g, $V^1 = 1.25$ g. Lowest $f_n = 39$ Hz. Acceleration Levels Used: 5.0 g's in all directions Critical stress = 18,701 psi. (Allowable = 19,200 psi) Max. Calc. Acceleration: $H_1 = .30$ g, $H_2 = .44$ g. $V^1 = .64$ g.
1VY09Y	Opposed Blade Balancing Damper (AWV, (Damper) ITT (M.Oper), Namco (L. Switches))	A	Reactor		Static Analysis Simplified Dynamic Analysis	Lowest $f_n = 24.8$ Hz. Acceleration Levels Used: $H_1 = 1.00$ g, $H_2 = 1.00$ g, $V^1 = 1.25$ g. Lowest $f_n = 53$ Hz. Acceleration Levels Used: $H(\text{Result.}) = 3.0$ g, $V = 5.0$ g. Critical stress = 12,467 psi. (Allowable = 19,200 psi) Max. Calc. Acceleration: $H_1 = .50$ g, $H_2 = .85$ g, $V^1 = .80$ g.

Specification No. H-2868
 Vendor: Refer Below
 Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page B70 of 83
 Rev. 00
 Date 4-15-81

Equipment Number	Description	S e i s .	C l a s s	Location	Qualification Method	Results
1VY11Y	Opposed Blade Balancing Damper (AWV, (Damper) ITT (M.Oper) Namco (L. Switches))	A	Reactor		Static Analysis Simplified Dynamic Analysis	Lowest $f_n = 24.8$ Hz. Acceleration Levels Used: $H_1 = 1.00$ g, $H_2 = 1.00$ g, $V^1 = 1.25$ g. Lowest $f_n = 76$ Hz. Acceleration Levels Used: 5.0 g's in all directions Critical stress = 18.701 psi. (Allowable = 19,200 psi) Max. Calc. Acceleration: $H_1 = 1.26$ g, $H_2 = 1.73$ g, $V^1 = 2.14$ g.
1VY12Y	Opposed Blade Balancing Damper (AWV, (Damper) ITT (M.Oper) Namco (L. Switch))	A	Reactor		Static Analysis Simplified Dynamic Analysis	Lowest $f_n = 24.8$ Hz. Acceleration Levels Used: $H_1 = 1.00$ g, $H_2 = 1.00$ g, $V^1 = 1.25$ g. Lowest $f_n = 53$ Hz. Acceleration Levels Used: 5.0 g's in all directions Critical stress = 18.701 psi. (Allowable = 19,200 psi) Max. Calc. Acceleration: $H_1 = 1.25$ g, $H_2 = .43$ g, $V^1 = .60$ g.

Specification No. H- 2868Vendor: Refer Below

Wm. H. Zimmer

Project No. 4130-00

SUMMARY OF
EQUIPMENT QUALIFICATIONPage B71 of 73Rev. 00Date 4-15-81

Equipment Number	Description	Series	Class	Location	Qualification Method	Results
IVY13YA/B	Opposed Blade Balancing Damper (AWV, (Damper) ITT (M.Oper) Namco (L. Switch))	A		Reactor	Static Analysis Simplified Dynamic Analysis	Lowest $f_n = 24.8$ Hz. Acceleration Levels Used: $H_1 = 1.00$ g, $H_2 = 1.00$ g, $V^1 = 1.25$ g. Lowest $f_n = 53$ Hz. Acceleration Levels Used: 5.0 g's in all directions. Critical stress = 18,701 psi. (Allowable = 19,200 psi) Max. Calc. Acceleration: $H_1 = .32$ g, $H_2 = .38$ g, $V^1 = .62$ g.
IVY14Y	Opposed Blade Balancing Damper (AWV, (Damper) ITT (M.Oper.) Namco (L. Switch))	A		Reactor	Static Analysis Simplified Dynamic Analysis	Lowest $f_n = 24.8$ Hz. Acceleration Levels Used: $H_1 = 1.00$ g, $H_2 = 1.00$ g, $V^1 = 1.25$ g. Lowest $f_n = 39$ Hz. Acceleration Levels Used: 5.0 g's in all directions. Critical stress = 18,701 psi. (Allowable = 19,200 psi) Max. Calc. Acceleration: $H_1 = .44$ g, $H_2 = 1.35$ g, $V^1 = 1.1$ g.

Specification No. H-2868
 Vendor: Refer Below

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page B72 of 83

Rev. 00

Date 4-15-81

Wm. H. Zimmer
 Project No. 4130-00

Equipment Number	Description	S e i s s	C l a s s	Location	Qualification Method	Results
IVY15Y	Opposed Blade Balancing Damper (AWV, (Damper) ITT (M.Oper) Namco (L. Switch))	A	Reactor	Static Analysis Simplified Dynamic Analysis	Lowest f = 24.8 Hz. Acceleration Levels Used: $H_1 = 1.00$ g, $H_2 = 1.00$ g, $V^1 = 1.25$ g. Lowest f = 53 Hz. Acceleration Levels Used: H (Result) = 3.0 g, V = 5.0 g. Critical stress = 12,467 psi. (Allowable = 19,200 psi) Max. Calc. Acceleration: $H_1 = .75$ g, $H_2 = .58$ g, $V^1 = .80$ g.	

Specification No. H-2874
 Vendor: Refer Below

Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page 873 of 83

Rev. 00

Date 4-15-81

Equipment Number	Description	S e i s .	C l a s s	Location		Qualification Method		Results
1VG01YA	Butterfly Isolation Damper (AWV, (Damper), ITT (M.Oper.), Namco (L. Switches))	A		Reactor		<p>Static Analysis</p> <p>Lowest $f_n = 33$ Hz. Acceleration Levels Used: $H_1 = 0.60$ g, $H_2 = 0.60$ g, $V^1 = 0.65$ g. Critical stress = 7,002 psi. (Allowable = 36,000 psi)</p> <p>Simplified Dynamic Analysis</p> <p>Lowest $f_n = 70.3$ Hz. Acceleration Levels Used: $H_1 = 1.07$ g, $H_2 = 1.07$ g, $V^1 = 1.05$ g. Critical stress = 18,771 psi. (Allowable = 19,200 psi) Max. Calc. Acceleration: $H_1 = H_2 = 1.07$ g, $V^1 = 1.05$ g.</p>		

Specification No. H- 2874

Vendor: Refer Below

Wm. H. Zimmer

Project No. 4130-00

SUMMARY OF
EQUIPMENT QUALIFICATION

Page B74 of 83

Rev. 00

Date 4-15-81

Equipment Number	Description	S e l e c t i o n	C l a s s i f i c a t i o n	Location		Qualification Method		Results
IVG01YB	Butterfly Isolation Damper (AWV (Damper) ITT (M.Oper.) Namco (L. Switches))	A	Reactor			<p>Static Analysis</p> <p>Lowest $f_n = 33$ Hz. Acceleration Levels Used: $H_1 = 0.60$ g, $H_2 = 0.60$ g, $V^1 = 0.65$ g. Critical stress = 7,002 psi. (Allowable = 36,000 psi)</p> <p>Simplified Dynamic Analysis</p> <p>Lowest $f_n = 70.3$ Hz. Acceleration Levels Used: $H_1 = 1.07$ g, $H_2 = 1.07$ g, $V^1 = 1.05$ g. Critical stress = 18,771 psi. (Allowable = 19,200 psi) Max. Calc. Acceleration: $H_1 = H_2 = 1.07$ g, $V=1.05$g Damper² is subject to modifications.</p>		

Specification No. H- 3874

Vendor: Refer Below

Wm. H. Zimmer

Project No. 4130-00

SUMMARY OF
EQUIPMENT QUALIFICATION

Page 881 of 83

Rev. 00

Date 4-15-81

Equipment Number	Description	S e r i e s	C l a s s	Location	Qualification Method	Results
1VQ10Y	Butterfly Isolation Damper (AWV, (Damper) ITT (M.Oper.), Namco (L. Switches))	A		Reactor	<p>Static Analysis</p> <p>Lowest $f_n = 193$ Hz Acceleration Levels Used: $H_1 = 0.35$ g, $H_2 = 0.35$ g, $V^1 = 0.65$ g. Critical stress = 5216 psi (Allowable = 36,000 psi)</p> <p>Simplified Dynamic Analysis</p> <p>Lowest $f_n = 193$ Hz. Acceleration Levels Used: $H_1 = 0.35$ g, $H_2 = 0.35$ g, $V^1 = 0.65$ g. Critical stress = 10,409psi (Allowable = 19,200 psi) Max. Calc. Acceleration: $H_1 = 0.32$ g, $H_2 = 0.36$ g, $V^1 = 0.65$ g.</p>	

Specification No. H-2883
 Vendor: Refer Below

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page B82 of 83
 Rev. 00
 Date 4-15-81

Wm. H. Zimmer
 Project No. 4130-00

Equipment Number	Description	S e l e c t i o n s	C l a s s	Location	Qualification Method	Results
1VC89Y	Essential Isolation Check Damper (Techno Corp (Damper) Miller (M.Oper.), Namco (L. Switch))	P		Auxiliary	Simplified Dynamic Analysis	<p>Lowest $f_n = 3.21$ Hz. (Remaining $f_n > 353$ Hz) Acceleration Levels Used and Req'd. per H-2883): $H_1 = H_2 = V = 2.0$ g. Critical stress = 37,399 psi (Allowable = 41,990 psi)</p> <p>Simplified Dynamic Analysis</p> <p>Max. Calc. Acceleration: $H_1 = .87$ g, $H_2 = .95$ g, $V = 1.31$ g. Therefore, past analysis (above) applies.</p>
1VC90Y	Essential Isolation Check Damper (Techno Corp (Damper) Miller (M.Oper.), Namco (L. Switch))	P		Auxiliary	Simplified Dynamic Analysis	<p>Lowest $f_n = 3.21$ Hz. (Remaining $f_n > 353$ Hz) Accel. Levels Used (and req'd per H-2883): $H_1 = H_2 = V = 3.0$ g. Crit. Stress = 37,399 psi (Allowable = 41,990 psi)</p> <p>Simplified Dynamic Analysis</p> <p>Max. Calc. Acceleration: $H_1 = .87$ g, $H_2 = .95$ g, $V = 1.31$ g. Therefore, past analysis (above) applies.</p>

Specification No. H-2883
 Vendor: Refer Below

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page 883 of 83
 Rev. 00
 Date 4-15-81

Wm. H. Zimmer
 Project No. 4130-00

Equipment Number	Description	S e i s s	C l a s s	Location	Qualification Method	Results
IVC91Y	Essential Isolation Check Damper (Techno Corp (Damper) Miller (M.Oper.), Namco (L. Switch))	P		Auxiliary	Simplified Dynamic Analysis	<p>Lowest $f_n = 3.21$ Hz. (Remaining f_n's > 353 Hz.) Accelerationⁿ Levels Used (And req'd per H-2883): $H_1 = H_2 = V = 3.0$ g. Crit. Stress = 37,399 psi (Allowable = 41,990 psi)</p> <p>Simplified Dynamic Analysis</p> <p>Max. Calc. Acceleration: $H_1 = 1.15$ g, $H_2 = .78$ g, $V = .88$ g. Therefore, past analysis (above) applies.</p>
IVC92Y	Essential Isolation Check Damper (Techno Corp (Damper) Miller (M.Oper), Namco (L. Switch))	P		Auxiliary	Simplified Dynamic Analysis	<p>Lowest $f_n = 3.21$ Hz. (Remaining f_n's > 353 Hz) Accelerationⁿ Levels used (and req'd. per H-2883) $H_1 = H_2 = V = 3.0$ g. Crit. Stress = 37,399 psi (Allowable = 41,990 psi)</p> <p>Simplified Dynamic Analysis</p> <p>Max. Calc. Acceleration: $H_1 = 1.15$ g, $H_2 = .78$ g, $V = .88$ g. Therefore, past analysis (above) applies.</p>

Specification No. H-2191
 Vendor: Rockwell International
 Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page 21 of 45
 Rev. 00
 Date 4-15-81

Equipment Number	Description	S e l e c t i o n s	C l a s s	Location	Qualification Method	Results
1E51F065	6" Non-Slam Check Valve	A		Reactor Building	No extended part Stress evaluation for operability under nozzle loads	Rigid in all directions No limiting accelerations Obtained allowable Nozzle loads to assure operability
1E22F024	14" Non-Slam Check Valve	A		Reactor Building	No extended part Stress evaluation for operability under nozzle loads	Rigid in all directions No limiting accelerations Obtained maximum nozzle loads for operability
1B21F010A/B	18" Non-Slam Check Valve	A		Primary Cont.	No extended part Stress evaluation for operability under nozzle loads	Rigid in all directions No limiting accelerations Obtained maximum nozzle loads for operability
1B21F032A/B				Reactor Building		

Specification No. H- 2194Vendor: GPE Controls

Wm. H. Zimmer

Project No. 4130-00

SUMMARY OF
EQUIPMENT QUALIFICATIONPage 02 of 45Rev. 00Date 4-15-81

Equipment Number	Description	Series	Location	Qualification Method	Results
1E12F103A/B	1.5" Vacuum Relief Valve	A	Reactor Building	Natural Frequency Estimate Static Analysis of all critical components. Stresses limited to design allowables	Minimum Natural Frequency = 8045 Hz Qualified for Upset 3 'g' Emergency 5 'g'
1E51F082 1E51F084	2" Vacuum Relief Valve	P	Reactor Building	Natural Frequency Estimate Static Analysis	Minimum Natural Frequency = 7985 Hz Qualified for Upset 3 'g' Emergency 5 'g'
1PC005A, B, C, D 1PC006A, B, C, D	20" Vacuum Relief Valve	A	Reactor Building	Natural Frequency Analysis Static Analysis of all critical components. Stresses limited to design allowables	Minimum Natural Frequency = 967 Hz Qualified for Upset 3 'g' Emergency 5 'g'

Specification No. H-2198
 Vendor: Dragon Check Valves
 Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page 43 of 45
 Rev. 00
 Date 4-15-81

Equipment Number	Description	S e r i e s	Location	Qualification Method	Results
Total 139 Valves	Excess Flow Check	P	Reactor Building Primary Containment	All passive valves Do not have extended structure Valve body shown to be stronger than pipe	Rigid No limiting acceleration loads Nozzle loads governed by connected piping.

Specification No. H-2245
 vendor: Yuba Heat Transfer Corp.

Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page 64 of 45
 Rev. 00
 Date 4-15-81

Equipment Number	Description	S e r i e s	Location	Qualification Method	Results
1RE045A,B,C 1RE046A,B,C	.75 x 1.0" Relief Valve	P	React. Bldg	Frequency analysis of spring Static analysis of valve at critical sections Comparison of area and section modulus of valve body to connected piping	Spring frequency - 191 Hz Valve body is stronger than pipe Nozzle loads limited by con- nected piping

Specification No. H-2263Vendor: Wm. Powell Co.

Wm. H. Zimmer

Project No. 4130-00

SUMMARY OF
EQUIPMENT QUALIFICATIONPage 05 of 45Rev. 00Date 4-15-81

Equipment Number	Description	Classification	Location	Qualification Method	Results
LWR018 LWR029 LWR035A, B LWR037A, B LWR047A, B LWR067A, B	2½", M, Globe Valve	P	React. Bldg Aux. Bldg. React. Bldg React. Bldg Prim. Cont.	Qualification in progress with the vendor	
LIN061 LWS076A, B LC41F001A, B	3"-150#, M, Globe Valves	A P P	React. Bldg ↓	Qualification in progress with vendor	
LE12F040	3"-400# Mo, Globe Valves	A	↓	Finite element method Natural frequencies Simplified dynamic analysis. Stresses limited to design allowables	Natural frequencies 40Hz, 77 Hz Qualified acceleration level Upset & Emergency a = 5.0 'g', b = 5.0 'g', c = 3.5 'g'
LWS117A, B C, D	3", M, Globe Valves	P	Service Water Pump house	Qualification in progress with vendor	
LE51F022	4", Mo, Globe Valves	A	React. Bldg	Qualification in progress with vendor	
LWR038A, B	4", M, Globe Valves	P	Aux. Bldg.	Qualification in progress with vendor	
LWS040A, B, C, D, E, F, G, H	6", M, Globe Valves	P	Diesel Generator Room	Qualification in progress with vendor	

Specification No. H-2263
 Vendor: Wm. Powell Co.
 Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page 06 of 45
 Rev. 00
 Date 4-15-81

Equipment Number	Description	S e i s . C l a s s	Location	Qualification Method	Results
1E12F021 1E12F024A, B	10", Mo, Globe Valves	A	React. Bldg	Finite element analysis Natural frequency value Simplified dynamic analysis stresses limited to design allowables	Natural frequencies 26.6 Hz 44.6 Hz Qualified acceleration levels Upset & Emergency a = 1.57 'g', b = 2.70 'g' c = 2.57 'g'
1B21F314	3", Mo, Globe Valve	P	Turb. Bldg	Qualification in progress with Vendor	

Specification No. H-2264

Vendor: Wm. H. Powell Co.

Wm. H. Zimmer

Project No. 4130-00

SUMMARY OF
EQUIPMENT QUALIFICATIONPage C7 of 45Rev. 00Date 4-15-81

Equipment Number	Description	Series	Class	Location	Qualification Method	Results
1B21F501A, B	2½", Mo Gate Valves	P		Turbine Bldg.	Qualification in progress with vendor	
1CY045 1CY047 1WR017 1WR027 1WR040A, B 1WR041A, B 1WR045A, B 1WR066A, B	2½", M, Gate Valves	P		React. Bldg Prim. Cont React. Bldg " Aux. Bldg. " React. Bldg "	Qualification in progress with vendor	
1WS073A, B	3"-150#, Mo, Gate Valves	A		React. Bldg	Finite element analysis Natural frequency evaluation Static analysis	Minimum natural frequencies 74.5 Hz, 61.6 Hz Qualified acceleration level Upset & Emergency a=4.82'g', b=4.82'g', c=5.82'g'
1E12F049	3"-300#, Mo, Gate Valves	A		React. Bldg	Finite element analysis Natural frequency evaluation Simplified dynamic analysis Stresses limited to design allowables	Minimum natural frequencies 46.8 Hz, 79.4 Hz Qualified acceleration level a =3.78'g', b=3.78'g', c=2.89'g'
1B21F326	3"-600# Mo, Gate Valves	P		Aux. Bldg	Qualification in progress with vendor	
1B21F016 1B21F019 1C11F082	3"-900# Mo, Gate Valves	A		Prim. Cont React. Bldg React. Bldg	Qualification in progress with vendor	

Specification No. H-2264

Vendor: Wm. H. Powell Co.

Wm. H. Zimmer

Project No. 4130-00

SUMMARY OF
EQUIPMENT QUALIFICATIONPage C9 of 45Rev. 00Date 4-15-81

Equipment Number	Description	Series	Class	Location	Qualification Method	Results
LWS012A, B	4"-150#, Mo, Gate Valves	A		React. Bldg	Finite element analysis Natural frequency evaluation Simplified dynamic analysis Stresses limited to design allowables	Natural frequencies 55.6 Hz, 80.4 Hz Qualified acceleration level Upset & Emergency a = 5 'g', b = 5 'g', c = 4.25 'g'
LE12F064A, B, C LE21F011	4"-300#, Mo, Gate Valves	A		React. Bldg React. Bldg	Qualification in progress with vendor	
LE51F059 LE21F020 LE21F500A, B	4"-600#, Mo, Gate Valves	A P P		React. Bldg Turb. Bldg.	Qualification in progress with vendor	
LE51F008 LG33F100 LG33F101 LG33F106	4"-900#, Mo, Gate Valves	A P P P		React. Bldg Prim. Cont. ↓	Finite element method Natural frequency evaluation Simplified dynamic analysis. Stresses limited to design allowables	Natural frequencies 49.6 Hz, 81.1 Hz Qualification acceleration level Upset & Emergency - a=2.31'g', b=4.62'g', c=5.62'g'
LG33F040	4"-1500#, Mo, Gate Valves	A		React. Bldg	Qualification in progress with vendor	
LWR042A, B LE12F018A, B, C LE21F302	4", M, Gate Valves	P		Aux. Bldg. React. Bldg	Qualification in progress with vendor	
LWR073 LWR074	6", Ao, Gate Valves	A		React. Bldg	Qualification in progress with vendor	

Specification No. H- 2264

Vendor: Wm. H. Powell Co.

Wm. H. Zimmer

Project No. 4130-00

SUMMARY OF
EQUIPMENT QUALIFICATIONPage 010 of 45Rev. 00Date 4-15-81

Equipment Number	Description	S C I S S	C L A S S	Location	Qualification Method	Results
1WR054 1WR055 1E51F010 1E51F031	6"-150#, Mo, Gate Valves	P P A P		React. Bldg ↓	Finite element method Natural frequency evaluation Simplified dynamic analysis Stresses limited to design allowables	Natural frequencies 55.8 Hz, 96.8 Hz Qualification acceleration level, Upset & Emergency a = 4.1 'g', b = 4.1 'g' c = 3.05 'g'
1E51F012	6"-600#, Mo, Gate Valves	P		React. Bldg	Qualification in progress with vendor	
1E51F013 1G33F001 1G33F004	6"-900#, Mo, Gate Valves	A A A		React. Bldg Prim. Cont. React. Bldg	Qualification in progress with vendor	
1E51-F016	6", M, Gate Valves	P		React. Bldg	Qualification in progress with vendor	
1E51F068	8"-150#, Mo, Gate Valves	A		React. Bldg	Finite element analysis Natural frequency evaluation Simplified dynamic analysis Stresses limited to design allowables	Natural frequencies 38.1 Hz, 71.6 Hz Qualification acceleration level Upset & Emergency - a = 3 'g', b = 3 'g', c = 3.5 'g'
1E51F063 1E51F064	8"-900#, Mo, Gate Valves	A		Prim. Cont. React. Eldg	Finite element analysis Natural frequency evaluation Static analysis Stresses limited to design allowables	Natural frequencies 73.3 Hz, 86.6 Hz Qualification acceleration level Upset & Emergency - a = 5 'g', b = 5 'g', c = 6 'g'
1B21F310A, B	10"-600#, Mo, Gate Valves	P		Turb. Bldg	Qualification in progress with vendor	

Specification No. H-2264
 Vendor: Wm. H. Powell Co.

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page C11 of 45

Wm. H. Zimmer
 Project No. 4130-00

Rev. 00

Date 4-15-81

Equipment Number	Description	S e l e c t i o n	C l a s s	Location	Qualification Method	Results
1E12F042A,B,C 1E21F005	10"-900#, Mo, Gate Valves	A		React. Bldg	Finite element analysis Natural frequency evaluation Static Analysis Stresses limited to design allowables	Natural frequencies 74.2 Hz, 83.3 Hz Qualification acceleration level Upset & Emergency - a = 5 'g', b = 5 'g', c = 6 'g'
1FC029 1FC034 1FC035 1E12F335 1E21F309	12"-300#, M, Gate Valves	P		React. Bldg ↓	Qualification in progress with vendor	
1E22F301	14", M, Gate Valve	P		React. Bldg	Qualification in progress with vendor	
1B21F065A, B 1E12F008 1E12F009	18"-900#, Mo, Gate Valves	A		React. Bldg Prim. Cont.	Finite element method Natural frequency evaluation Static analysis Stresses limited to design allowables	Natural frequencies 59.1 Hz, 81.9 Hz Qualification acceleration level Upset & Emergency a = 5 'g', b = 5 'g', c = 3.5 'g'
1B21F011A, B 1E12F306	18"-900#, M, Gate Valves	P		Prim. Cont.	Qualification in progress with vendor	
1WS005	30"-150#, Mo, Gate Valves	P		Service Water Pump House	Finite element method Natural frequency evaluation Equivalent dynamic analysis	Natural frequencies 20.2 Hz, 33.3 Hz Qualification acceleration level Upset & Emergency a = 5 'g', b = 5 'g', c = 4.5 'g'

Specification No. H- 2264
 Vendor: Wm. H. Powell Co.
 Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page C12 of 45
 Rev. 00
 Date 4-15-81

Equipment Number	Description	S e r i e s	Location	Qualification Method	Results
1E12F011A,B 1E12F026A,B 1E12F027A,B 1WS013A,B	4", Mo, Gate Valves	A	React. Bldg	Finite element analysis Natural frequency evaluation Equivalent dynamic analysis Stresses limited to design allowables to assure operability	Minimum natural frequency = 46.9 Hz Qualification acceleration Level Upset & Emergency $a=3.75'g'$, $b=4.0'g'$, $c=4.0'g'$

Specification No. H-2265
 Vendor: Jamesbury Corp.

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page 13 of 45

Wm. H. Zimmer
 Project No. 4130-00

Rev. 00

Date 4-15-81

Equipment Number	Description	Series	Class	Location	Qualification Method	Results
LWS036A to H	6", M, Butterfly Valve	P		Diesel Gen. Room	Finite element analysis Natural frequency evaluation Static analysis	Minimum natural frequency = 118 Hz Qualification acceleration level Upset - a=3'g', b=3'g', c=4'g' Emerg.- a=5'g', b=5'g', c=6'g'
LWS037A to D	8", Mo, Butterfly Valve	P		Diesel Gen. Room	Finite element analysis Natural frequency evaluation Static analysis	Minimum natural frequency = 41.6 Hz Qualification acceleration level Upset - a=3'g', b=3'g', c=4'g' Emerg.- a=5'g', b=5'g', c=6'g'
LVH001A, B LVH002A, B LVH003A, B LVH004A, B	12", Ao, Butterfly Valves	P		Service Water Pump House	Dynamic analysis using finite element model Frequency evaluation Response spectra analysis	Minimum natural frequency = 24.1 Hz Qualified to the response spectra
1E12F068A, B	14", Mo, Butterfly Valve	P		React. Bldg	In progress	
LWS017 LWS018 LWS019 LWS021	14", M, Butterfly Valve	P		React. Bldg	In progress	
1E12F014A, B	16", Mo, Butterfly Valve	P		React. Bldg	In progress	
LWS027 LWS032	16", M, Butterfly Valve	P		React. Bldg	In progress	

Specification No. H- 2265
 Vendor: Jamesbury Corp.

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page 14 of 45

Wm. H. Zimmer
 Project No. 4130-00

Rev. 00

Date 4-15-81

Equipment Number	Description	Series Class	Location	Qualification Method	Results
1VQ001A, B 1VQ002A, B 1VQ003A, B 1VQ004A, B	18", Ao, Butterfly Valve	P	React. Bldg	In progress	
1WS016 1WS023 1WS024 1WS028 1WS029 1WS031 1WS026	18", M, Butterfly Valve	P	React. Bldg	In progress	
1WS004A, B, C, D 1WS008A, B, 1WS033A, B 1WS034A, B	24", Mo, Butterfly Valve	A	Service Water Pump House Aux. Bldg. Aux. Bldg.	Finite element analysis Natural frequency evaluation Static analysis	Minimum natural frequency = 49.8 Hz Qualification acceleration level Upset - a=3'g', b=3'g', c=4'g' Emerg.- a=5'g', b=5'g', c=6'g'
1CY008A, B	16", M, Butterfly Valve	P	Outside	Finite element analysis Natural frequency evaluation Static analysis	Minimum natural frequency = 82.2 Hz Qualification acceleration level Upset - a=3'g', b=3'g', c=4'g' Emerg.- a=5'g', b=5'g', c=6'g'
1WS070	18", M, Butterfly Valve	P	Service Water Pump House	Finite element analysis Natural frequency evaluation Static analysis	Minimum natural frequency = 38 Hz Qualification acceleration level Upset - a=3'g', b=3'g', c=4'g' Emerg.- a=5'g', b=5'g', c=6'g'

Specification No. H-2267
 Vendor: Rockwell International
 Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page 15 of 45
 Rev. 00
 Date 4-15-81

Equipment Number	Description	Series	Location	Qualification Method	Results
1E12F041A, B, C 1E12F050A, B 1E21F006 1E22F005	10", Check Valves	A A A	Prim. Cont.	In progress	
1E51F066	4", Check Valves	A	Prim. Cont.	In progress	
1WS022	12", M, Butterfly Valve	P	React. Bldg	In progress	

Specification No. H- 2266
 Vendor: Fischer Controls Corp.
 Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page C16 of 45
 Rev. 00
 Date 4-15-81

Equipment Number	Description	Series	Class	Location	Qualification Method	Results
1E51F004 1E51F005	1", Ao, Globe Valve	P		React. Bldg	Finite Element Method Natural frequency evaluation Equivalent dynamic analysis	Minimum natural frequency = 35.05 Hz Qualified to actual accelerations obtained from piping analysis
1E51F025 1E51F026	1", Ao, Globe Valve	A		React. Bldg	↓	Minimum natural frequency = 35.19 Hz Qualified to actual accelerations obtained from piping analysis
1B33F076A,B	2", M, 3-Way Valve	P		Prim. Cont.	Finite Element Method Natural frequency evaluation Static analysis	Minimum natural frequency = 89.7 Hz Qualification accelerations level for Upset & Emergency a=5'g', b=5'g', c=5'g'
1IN012 1IN013	2½", Ao, Globe Valve	A		React. Bldg	Finite element method Natural frequency evaluation Equivalent dynamic analysis Stresses limited to design Allowables to assure operability	Minimum natural frequency = 34.63 Hz Qualification acceleration level Upset & Emergency a=2.5'g', b=2.5'g', c=2.5'g'
1RE048 1RE049 1RF001 1RF002	2½", Ao, Globe Valve	A A P P		React. Bldg	↓	Minimum natural frequency = 35.48 Hz Qualification acceleration level Upset & Emergency a=3.25'g', b=3.25'g', c=3.25'g'

Specification No. H-2266
 Vendor: Fischer Controls Corp.
 Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page 17 of 45
 Rev. 00
 Date 4-15-81

Equipment Number	Description	S e r i e s	C l a s s	Location		Qualification Method		Results
1E12F065A,B	2½", Ao, Globe Valve	A		React. Bldg		Finite element method Natural frequency evaluation Equivalent dynamic analysis Stresses limited to design allowables to assure operability		Minimum natural frequency = 34.77 Hz Qualification acceleration level Upset & Emergency a=2.5'g', b=2.5'g', c=2.5'g'
1E12F051A,B	6", Ao, Globe Valve	A		↓				Minimum natural frequency = 31.7 Hz Qualified to accelerations obtained from piping analysis
1WS020	10", Ao, Globe Valve	A		↓				Minimum natural frequency = 27.1 Hz Qualified to accelerations obtained from piping analysis
1WS025	12", Ao, Globe Valve	A		↓				Minimum natural frequency = 28.45 Hz Qualified to accelerations obtained from piping analysis
1WS030	12", Ao, Globe Valve	A		↓				Minimum natural frequency = 28.3 Hz Qualified to accelerations obtained from piping analysis

Specification No. H- 2268

Vendor: J. E. Lonergan

Wm. H. Zimmer

Project No. 4130-00

SUMMARY OF
EQUIPMENT QUALIFICATION

Page C18 of 45

Rev. 00

Date 4-15-81

Equipment Number	Description	STATUS	CLASS	Location	Qualification Method	Results
LDG017A to L LDG018A to F	3/4" x 1", Relief Valve	P		Aux. Bldg. D.G.	Spring frequency Static analysis Comparison of area and section modulus of valves to connected piping	Spring frequency - 191 Hz Valve body is stronger than pipe No limitation on accelerations Nozzle loads limited by con- nected piping
1E22F014	3/4" x 1", Relief Valve	P		React. Bldg	↓	Spring frequency - 47 Hz Valve body is stronger than pipe No limitation on accelerations Nozzle loads limited by con- nected piping
1C41F029A, B	1" x 1", Relief Valves	P		React. Bldg		Spring frequency - 47 Hz Valve body is stronger than pipe No limitation on accelerations Nozzle loads limited by con- nected piping
1IN005A, B	1" x 1½", Relief Valves	P		React. Bldg		Spring frequency - 191 Hz Valve body is stronger than pipe No limitation on accelerations Nozzle loads limited by con- nected piping
1E12F005	1" x 1½", Relief Valve	P		React. Bldg		Spring frequency - 191 Hz Valve body is stronger than pipe No limitation on accelerations Nozzle loads limited by con- nected piping

Specification No. H-2268
 Vendor: J. E. Loneragan

Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page C19 of 45

Rev. 00

Date 4-15-81

Equipment Number	Description	S e l e c t i o n	C l a s s i f i c a t i o n	Location		Qualification Method			Results
1E12F030 1E21F031 1E51F017	1" x 2", Relief Valves	P		React. Bldg		Spring frequency Static analysis Comparison of area and section modulus of valves to connected piping			Spring frequency - 151 Hz Valve body is stronger than pipe No limitation on accelerations Nozzle loads limited by connected piping
1D0005B,D,F 1WR077 1E12F025A,B,C 1E22F035	1½" x 2", Relief Valves	P		D. G. React. Bldg React. Bldg React. Bldg		Spring frequency evaluation Static analysis for stresses and deflections Comparison of area and section modulus of valves to connected piping			Spring frequency - 181 Hz Valve body is stronger than pipe No limitation on accelerations Nozzle loads limited by piping
1E51F018	1½" x 3", Relief Valve	P		React. Bldg					Spring frequency - 178 Hz Valve body is stronger than pipe No limitation on accelerations Nozzle loads limited by piping
1E21F018	2" x 3", Relief Valve	P		React. Bldg					Spring frequency - 196 Hz Valve body is stronger than pipe No limitation on accelerations Nozzle loads limited by piping
1E12F036	3" x 4", Relief Valve	P		React. Bldg					Spring frequency - 191 Hz Valve body is stronger than pipe No limitation on accelerations Nozzle loads limited by piping

Specification No. H-2804
 Vendor: Dresser Industries, Inc.
 Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page C20 of 45
 Rev. 00
 Date 4-15-81

Equipment Number	Description	Series	Class	Location	Qualification Method	Results
All	½", M, Gate Valves	P		All Bldgs.	No extended part Valves shown to be stronger than pipe	Rigid in all directions No limitation on accelerations Nozzle loads limited by piping
All	½", M, Globe Valves	P		↓	↓	↓
All	¾", M, Gate Valve	P		↓	↓	↓
All	¾", M, Globe Valve	P		↓	↓	↓
1B33F013A/B 1B33F017A/B 1E32F010 1E32F011	¾", Check Valves	A		Prim. Cont. " React. Bldg "	No extended part Valves shown to be stronger than pipe Valve stresses limited to design allowables	Rigid in all directions No limitation on accelerations Allowable nozzle loads obtained to assure operability
All Other	¾", Check Valves	P		All Bldgs.	No extended part Valves shown to be stronger than pipe	Rigid in all directions No limitation on accelerations Nozzle loads limited by piping
All	1", M, Gate Valve	P		↓	↓	↓
All	1", M, Globe Valve	P		↓	↓	↓
All	1", Check Valve	P		↓	↓	↓
All	1½", M, Gate Valves	P		↓	↓	↓
All	1½", M, Globe Valves	P		↓	↓	↓

Specification No. H-2804
 Vendor: Dresser Industries, Inc.
 Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page 21 of 45
 Rev. 00
 Date 4-15-81

Equipment Number	Description	S e l e c t i o n s	C l a s s	Location	Qualification Method	Results
1C41F006 1C41F007 1C41F033A/B	1½", Check Valves	A		React. Bldg " Prim. Cont.	No extended part Valves shown to be stronger pipe Valve stresses limited to design allowables	Rigid in all directions No limitation on accelerations Allowable nozzle loads obtained to assure operability
All Other	1½", Check Valves	P		All Bldgs. ↓	No extended part Valves shown to be stronger than connected pipe ↓	Rigid in all directions No limitation on accelerations Nozzle loads limited by piping ↓
All	2", M, Gate Valves	P		↓	↓	↓
All	2", M, Globe Valves	P		↓	↓	↓
1E12F084A,B,C 1E21F033A,B,C 1E51F021 1E51F028 1E51F061 1E22F007	2", Check Valves	A		React. Bldg ↓	No extended part Valves shown to be stronger than pipe Valve stresses limited to design allowables	Rigid in all directions No limitation on accelerations Allowable nozzle loads obtained to assure operability
All Other	2", Check Valves	P		All Bldgs.	No external part Valves shown to be stronger than pipe	Rigid in all directions No limitation on accelerations Nozzle loads limited by piping

Specification No. H-2810

Vendor: Lankenheimer

Wm. H. Zimmer

Project No. 4130-00

SUMMARY OF
EQUIPMENT QUALIFICATION

Page C22 of 45

Rev. 00

Date 4-15-81

Equipment Number	Description	Class Series	Location	Qualification Method	Results
1WR009 1WR010 1WR011 1WR012 1WR019 1WR020 1WR021 1WR022 1WS081	12", Mo, Gate Valve	A →	Service Water Pump House →	Qualification in progress	
1WR002A to D 1WR026A to D	12", M, Gate Valves	P →	React. Bldg Service Water Pump House	Qualification in progress	
1WR003A,B,C 1WR004A,B,C 1WR005 1WR006 1WR007 1WR008	14", M, Gate Valves		React. Bldg C.W.P.HS React. Bldg React. Bldg C.W.P.HS C.W.P.HS	Qualification in progress	
1WS080	24", Mo, Gate Valve		S.W.P.H.	Qualification in progress	

Specification No. H-2811
 Vendor: Anchor Darling Valve Co.
 Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page C23 of 45
 Rev. 00
 Date 4-15-81

Equipment Number	Description	Series	Class	Location	Qualification Method	Results
LDG003A,B,C LDG004A,B,C LDG007A,B,C LDG008A,B,C	2½", M, Gate Valves	P		Diesel Gen. Room	Effect of extended portion negligible on frequencies Static analysis	Rigid in all directions Qualification acceleration level Upset & Emergency a=11'g', b=10'g', c=10'g'
1T49F304	4", M, Gate Valve	P		React. Bldg		
1B21F527	6", Mo, Gate Valve	P		Turbine Bldg.	Natural frequency evaluation Static analysis	Minimum natural frequencies are 160 Hz, 178 Hz. Qualification acceleration level Upset & Emergency a=6'g', b=5'g', c=5'g'
1WR134	6", M, Gate Valve	P		React. Bldg	Effect of valve extended Portion is negligible on frequencies Static analysis	Rigid in all directions Qualification acceleration level Upset & Emergency a=11'g', b=10'g', c=10'g'
1VP006A,B 1VP012A,B 1VP045A,B	8", Mo, Gate Valves	A		React. Bldg " Prim. Cont.	Natural frequency evaluation Static analysis	Minimum natural frequencies are 73.3 Hz & 161 Hz Qualification acceleration level Upset & Emergency a=6'g', b=5'g', c=5'g'
1WR133A,B	8" M, Gate Valve	P		React. Bldg	Effect of extended part is negligible on frequencies Static analysis	Rigid in all directions Qualification acceleration level Upset & Emergency a=11'g', b=10'g', c=10'g'

Specification No. H- 2811
 Vendor: Anchor Darling Valve Co.
 Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page C24 of 45
 Rev. 00
 Date 4-15-81

Equipment Number	Description	Series	Class	Location	Qualification Method	Results
1E12F391	12", M, Gate Valve	P		React. Bldg	Natural frequency evaluation Static analysis	Minimum natural frequencies are 160 Hz and 179 Hz Qualification acceleration level Upset & Emergency a=6'g', b=5'g', c=5'g'
1E12F003A,B 1E12F016A,B 1E12F017A,B 1E12F047A,B	14", Mo, Gate Valves	A		React. Bldg		Minimum natural frequencies are 71.9 Hz and 126 Hz Qualification acceleration level Upset & Emergency a=6'g', b=5'g', c=5'g'
1E12F307	14", M, Gate Valve	P		React. Bldg	Effect of valve extended portion on frequencies negligible Static analysis Comparison of valve area and section modulus with pipe	Rigid in all directions Valve body stronger than pipe Qualification acceleration level Upset & Emergency a=5'g', b=5'g', c=5'g'
1E12F006A,B	16", Mo, Gate Valve	A		React. Bldg	Natural frequency evaluation simplified dynamic analysis for stresses and deflections of all critical components to assure operability and structural integrity	Minimum natural frequencies 54.4 Hz and 80.5 Hz Qualification acceleration level Upset & Emergency a=6'g', b=5'g', c=5'g'

Specification No. H-2811
 Vendor: Anchor/Darling Co.

Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page 625 of 45

Rev. 00

Date 4-15-81

Equipment Number	Description	S e i s s C l a s s	Location	Qualification Method	Results
1E12F067 1E12F302A, B,C	16", M, Gate Valve	P	React. Bldg ↓	Natural frequency evaluation Static analysis Comparison of valve area and section modulus with pipe	Minimum natural frequency = 158 Hz Valve body stronger than pipe Qualification acceleration level Upset & Emergency a=5'g', b=5'g', c=5'g'
1E21F001	20", 150#, Mo, Gate Valve	A	↓	Natural frequency evaluation Simplified dynamic analysis	Minimum natural frequencies are 28.5 Hz and 35.1 Hz Qualification acceleration level Upset & Emergency a=.83'g', b=2.3'g', c=2.17'g'
1E12F004A,B C	20", 300#, Mo, Gate Valve	A	↓	Hand prepared static analysis Natural frequency evaluation Simplified dynamic analysis	Minimum natural frequencies 37.2 Hz and 63.9 Hz Qualification acceleration level Upset: a=4.0'g', b=3.0'g', c=3.0'g' Emergency: a=4.5'g', b=3.5'g', c=3.5'g'

Specification No. H- 2816
 Vendor: Bannson
 Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page 27 of 45
 Rev. 00
 Date 4-15-81

Equipment Number	Description	S e l a s s	C l a s s L o c a t i o n	Qualification Method	Results
IRG048A	1-1/8", M, Relief Valve	P	Aux. Bldg	All valves tested at same time Pseudo-biaxial Test Resonance Search 1-33 Hz Sine Sweep Input 1 to 10'g' Horizontal 0.5 to 5'g' Vertical Sine dwell at each restraint frequency Four orientations of 0°, 90°, 180° and 270° Duration of dwell in each orientation 240 sec. (min)	Resonances 26.5 Hz, 27.5 Hz Qualification acceleration level Upset & Emergency a=4.0'g', b=4.8'g', c=4.0'g'
IRG055A to H, J to N,P	1-3/8", Solenoid Operated Globe Valve	A			
IRG059A to H	1-3/8", Solenoid Operated Bypass Valve				
IRG045A to H	1-5/8", Solenoid Operated Globe Valve				
IRG049A to D	1-5/8", Solenoid Operated Bypass Valve				
IRG052A to F IRG053A to F IRG054A to F	1-5/8", M, Globe Valve	P			

Specification No. H-2816

Vendor: Bahnson

Wm. H. Zimmer

Project No. 4130-00

SUMMARY OF
EQUIPMENT QUALIFICATION

Page 28 of 45

Rev. 00

Date 4-15-81

Equipment Number	Description	S e l e c t i o n	C l a s s i f i c a t i o n	Location		Qualification Method		Results			
1RG080A,B 1RG082A,B	2-1/8", M, Globe Valve	P	Aux. Bldg.	All valves tested at same time, Pseudo-biaxial Test Resonance Search 1-33 Hz Sine Sweep-Input 1 to 10'g' Horizontal, 0.5 to 5'g' Vertical Sine dwell at each resonant frequency Four orientations of 0°, 90°, 180° and 270° Duration of dwell in each orientation 240 sec. (min)	Resonances 26.5 Hz, 27.5 Hz Qualification acceleration level Upset & Emergency a=4.0'g', b=4.8'g', c=4.0'g'	1RG042A,B 1RG043A,B 1RG044A,B 1RG060A,B	2-5/8", M, Globe Valve				

Specification No. H-2819
 Vendor: Anchor Darling Valve Co.
 Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page 29 of 45
 Rev. 00
 Date 4-15-81

Equipment Number	Description	S e i s .	C l a s s	Location		Qualification Method								
1DG005A,B,C 1DG006A,B,C 1SA079 1SA081	2½", M, Globe Valves	P		Aux. Bldg. Aux. Bldg. React. Bldg React. Bldg		Effect of valve extended portion on frequencies negligible Static analysis								
1E32F012	3", M, Globe Valve	P		React. Bldg		↓								
1E32F013	4", M, Globe Valve	P		React. Bldg		↓								
1E21F012	12", Mo, Globe Valve	P		React. Bldg		Natural frequencies evaluation Equivalent dynamic analysis								
						Minimum natural frequencies are 42.1 Hz & 51.0 Hz Qualification acceleration level Upset - a=1.35'g', b=1.35'g', c=1.35'g' Emerg = a=1.5'g', b=1.5'g', c=1.5'g'								

Specification No. H-2820
 Vendor: Rockwell International

Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page 30 of 45

Rev. 00

Date 4-15-81

Equipment Number	Description	Series	Class	Location	Qualification Method	Results
1E12F087A,B	3", Mo, globe valve	A		Reactor Building	Natural frequency evaluation Static analysis for stresses and deflections	Minimum natural frequencies are 69.4 Hz & 179 Hz. Qualification Acceleration level upset & emergency a-5'g', b-5'g', c-5'g'
1E51F045	4", Mo, globe valve	A		Reactor Building	Natural frequency evaluation simplified dynamic analysis	Minimum natural frequencies 46 Hz, 61 Hz Qualification acceleration level Upset: a-1.86'g', b-1.86'g', c-1.86'g' Emergency: a-2.0'g', b-2.0'g', c-2.0'g'
1E12F023	6", Mo, globe valve	P		Reactor Building	In progress	
1G33F102	6", Mo, globe valve	P		Prim. Cont.	In progress	
1E12F052A,B	8", Mo, glove valve	A		Reactor Building	In progress	
1E12F053A,B	10", Mo, globe valve	A		Reactor Building	In progress	
1E12F048A,B	14, Mo, globe valve	A		Reactor Building	In progress	

Specification No. H-2821
 Vendor: Mission Manufacturing Co.
 Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION


Page 31 of 45
 Rev. 00
 Date 4-15-81

Equipment Number	Description	Series Class	Location	Qualification Method	Results
1CY046	2½", check valve	P	Reactor Building	In progress	
1SA080					
1IN063	3", check valve	P	Reactor Building	In progress	
1WS074A,B			CW.P.HS		
1WS077A,B			Reactor Building		
1E21F303	4", check valve	P	Reactor Building	In progress	
1WR136	6", check valve	P	Prim. Cont.	In progress	
1E51F011			Reactor Building		
1E51F030	6", check valve	A	Reactor Building		
1VP046A,B	8", check valve	P	Prim. Cont.	In progress	
1E51F040	8", check valve	A	Reactor Building	In progress	

Specification No. H-2821
 Vendor: Mission Manufacturing Co.
 Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page C32 of 45
 Rev. 00
 Date 4-15-81

Equipment Number	Description	Class	Location	Qualification Method	Results
1WR001A,B,C, D	12", check valve	P	Reactor Building		
1E22F002	16", check valve	P	Reactor Building		
1E22F016	20", check valve	A	Reactor Building		
1WS003A,B,C, D	24", check valve	P	Service Water Pump House		

Specification No. H-2822
 Vendor: Anchor Darling Valve Co.
 Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page 33 of 45
 Rev. 00
 Date 4-15-81

Equipment Number	Description	S e r i e s	C l a s s	Location	Qualification Method	Results
1E21F003	12", Non-Slam Check Valve	A		Reac. Bldg.	No extended part Valve body analysis for maximum nozzle loads to assure operability	Rigid No limitation on accelerations Allowable nozzle loads obtained to assure operability
1E12F031A,B,	14", Non-Slam Check Valve	A		Reac. Bldg.	↓	↓

Specification No. H- 2823

Vendor: Wm. H. Powell Co.

Wm. H. Zimmer

Project No. 4130-00

SUMMARY OF
EQUIPMENT QUALIFICATION

Page 34 of 45

Rev. 00

Date 4-15-81

Equipment Number	Description	S e l e c t i o n	C l a s s	Location		Qualification Method		Results
1E12F039A,B C,D 1E12F304 1E12F305 1E12F306	3", Check Valves	P		React. Bldg ↓		No extended part Comparison of Valve body Area and section modulus ↓		Rigid Valve body shown to be stronger than connected piping Nozzle loads limited by piping ↓
1E12F054A,B 1E51F023	4", Check Valves	P	↓	↓		↓		
1E12F046A,B, C 1E12F089	4", Check Valves	A		↓		No extended part Static analysis for maximum nozzle loads to assure operability		Rigid No limitation on accelerations Allowable nozzle loads obtained to assure operability

Specification No. H- 2839
 Vendor: Henry Pratt Co.
 Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page 35 of 45
 Rev. 00
 Date 4-15-81

Equipment Number	Description	S e r i e s	Location	Qualification Method	Results
1WS001A,B, C,D 1WS002A,B, C,D	30", M, Butterfly Valve	P	Turb. Bld., "	Frequency evaluation Static analysis for stresses Comparison of valve body area and section modulus to con- nected piping	Natural frequencies 296 Hz 323 Hz and 573 Hz Qualification acceleration level Upset & Emergency a=5.0'g', b=5.0'g', c=5.0'g'
1WS006A,B 1WS007A,B	30", M, Butterfly Valves	P	Service Water Pump House		

Specification No. H-2852
 Vendor: Kerotest Manufacturing Corp.
 Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page 36 of 45
 Rev. 00
 Date 4-15-81

Equipment Number	Description	Series	Class	Location	Qualification Method	Results
1CM005 1CM006 1CM012 1CM014 1CM025 1CM026	1/2", Ao, Globe Valves	A		React. Bldg	Qualification in progress with Vendor	
91 Valves	1/2", M, T-Type, Globe Valves	P		All Bldgs.	No considerable valve extended part Valve body shown to be stronger than pipe	Rigid No limitation on accelerations Nozzle loads limited by connected pipe
25 Valves	1/2", M, Y-Type, Globe Valves	P				
1CM003 1CM004 1B33F019 1B33F020 1E12F060A,B 1E12F075A,B	3/4", Ao, Globe Valves	A		React. Bldg	Qualification in progress with Vendor	
				Prim. Cont. React. Bldg		
1E12F338A,B,C 1E21F330 1E22F314 1E51F317	3/4", Mo, Globe Valves	P		Prim. Cont.		

Specification No. H-2852
 Vendor: Kerotest Manufacturing Corp.

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page 37 of 45

Wm. H. Zimmer
 Project No. 4130-00

Rev. 00

Date 4-15-81

Equipment Number	Description	S e i s s	C l a s s	Location	Qualification Method	Results
574 Valves	3/4", M, Globe Valves	P		All Bldgs.	No considerable valve Extended part Valve body shown to be stronger than connected pipe	Rigid No limitation on accelerations Nozzle loads limited by connected pipe
1IN008A,B 1E12F099A,B 1E51F076	1", M, Globe Valves	P A A		React. Bldg Prim. Cont. Prim. Cont.	Qualification in progress with Vendor	
1VQ016A to H, J to N, P 1WR152 1WR153 1C41F015 1C41F018 1C41F019 1C41F020 1C41F024 1C41F025 1E12F076A, B 1E12F077A, B 1E12F078A, B 1E12F079A, B 1E12F326A, B 1E12F327A, B 1E51F334 1E51F335	1", M, Globe Valves	P		All Bldgs.	No considerable valve Extended position Valve body shown to be stronger than pipe	Rigid No limitation on accelerations Nozzle loads limited by pipe

Specification No. H-2852
 Vendor: Kerotest Manufacturing Corp.
 Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page 38 of 45
 Rev. 00
 Date 4-15-81

Equipment Number	Description	S e r i e s	C l a s s i f i c a t i o n	Location		Qualification Method	Results
1WR158A,B 1WR160A,B 1B21F067A,B, C,D 1E12F073A,B 1E12F074A,B 1E32F001A,B C,D 1E32F002A,B C,D 1E32F003A,B C,D	1½", Mo, Globe Valves	A ↓	React. Bldg React. Bldg Aux. Bldg. React. Bldg ↓	Qualification in progress with Vendor			
1WS160 1WS161 1WS162 1WS163 1C41F003A,B 1C41F008 1C41F016 1C41F017 1E12F080A,B 1E12F081A,B	1½", M, Globe Valves	P ↓	All Bldgs.	No considerable valve Extended part Valve body shown to be stronger than pipe		Rigid No limitation on accelerations Nozzle loads limited by connected pipe	

Specification No. H- 2852
 Vendor: kerotest Manufacturing Corp.
 Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page 039 of 45
 Rev. 00
 Date 4-15-81

Equipment Number	Description	S e i s s	C l a s s	Location	Qualification Method	Results
1WS014A,B 1B21F001 1B21F002 1B21F005 1E32F006 1E32F007 1E32F008 1E32F009 1E51F019 1E51F046 1E51F069 1E51F080 1E51F086	2", Mo, Globe Valves	A P P P A ↓ P	React. Bldg Prim. Cont Prim. Cont Prim. Cont React. Bldg ↓ ↓	Qualification in progress with Vendor		
IVC008A,B IVC009A,B IVC010A,B IVC011A,B IVC012A,B IVC013A,B IVC014A,B IVC015A,B IVC016A,B 1VQ021 1VQ024 1WR161 1B21F077A,B C,D 1B33F029 1B33F030	2", M, Globe Valves	P ↓	All Bldgs.	No considerable valve Extended part Valve body shown to be stronger than pipe	Rigid No limitation on accelerations Nozzle loads limited by connected pipe	

Specification No. H- 2852
 Vendor: Kerotest Manufacturing Corp.
 Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page 40 of 45
 Rev. 00
 Date 4-15-81

Equipment Number	Description	Series	Location	Qualification Method	Results
1B33F051A,B 1B33F052A,B 1C41F014 1E12F102 1E21F032 1E22F034 1E51F049 1E51F060 1E51F062 1E51F333 1T49F003 1T49F001	2", M, Globe Valves	P →	All Bldgs →	No considerable valve Extended part Valve body shown to be stronger than pipe	Rigid No limitation on accelerations Nozzle loads limited by connected pipe

Specification No. H- 2853
 Vendor: Anderson, Greenwood & Co.
 Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page 41 of 45
 Rev. 00
 Date 4-15-81

Equipment Number	Description	S e r i e s	C l a s s	Location	Qualification Method	Results
11A155A,B 1B21F036A to H, K, L, P, R, S	1/2", Check Valves	P	Prim. Cont.	No valve extended part Valve body shown to be stronger than pipe	Rigid No limitation on accelerations Nozzle loads limited by piping	
1B21F040B, C,F,G,K,L	1/2", Check Valves	A	↓	No valve extended part Valve body stresses limited to design allowables	Rigid No limitation on accelerations Allowable nozzle loads pro- vided to assure operability	
1B21F024A,B, C,D 1B21F029A,B C,D	3/4", Check Valves	A		↓	↓	
1IN006A,B	1", Check Valves	P		React. Bldg	No valve extended part Valve body shown to be stronger than pipe	Rigid No limit on accelerations Nozzle loads limited by piping

Specification No. H-2854
 Vendor: Rockwell International
 Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page C42 of 45
 Rev. 00
 Date 4-15-81

Equipment Number	Description	Seis. Class.	Location	Qualification Method	Results
1G33F103	1", M, Globe Valve	P	Prim. Cont.	In progress	
1E12F085A,B, C	2", Stop Check Valve	A ↓	React. Bldg	In progress	
1B21F034					
1E22F006					

Specification No. H- 2856
 Vendor: Contronatics
 Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page C43 of 45
 Rev. 00
 Date 4-15-81

Equipment Number	Description	S e r i e s .	C l a s s	Location	Qualification Method	Results
1CM176 to 1CM211	1/2", M, Ball Valves	P		React. Bldg.	No extended part Valve body analysis for maximum nozzle loads	Rigid Obtained maximum allowable for Upset and Emergency
1CM212 1CM213 1CM214 1CM215	3/4", M, Ball Valves	P		React. Bldg.		

Specification No. H- 2862

Vendor: Target Rock Corp.

Wm. H. Zimmer

Project No. 4130-00

SUMMARY OF
EQUIPMENT QUALIFICATION

Page 44 of 45

Rev. 00

Date 4-15-81

Equipment Number	Description	S e r i e s	C l a s s	Location	Qualification Method	Results
ICM019 ICM020 ICM021 ICM022 1B33F355B,C 1B33F356B,C	1/2", Solenoid Operated Globe Valves	A		React. Bldg	Frequency evaluation Static analysis for stresses and deflections	Minimum natural frequency = 158 Hz Qualification acceleration level Upset & Emergency a=5'g', b=5'g', c=5'g'
ICM007 ICM008 ICM009 ICM10 ICM11 ICM13 ICM23 ICM24 1B33F355A,D 1B33F356A,B 1T49F305A,B	3/4", Solenoid Operated Globe Valves	A		React. Bldg		
LIN170 LIN171	1 1/2", Solenoid Operated Globe Valves	P				
IVQ005A,B IVQ008A,B	2", Solenoid Operated Globe Valve					
LIN004A,B	1", Pressure Reg. Valves					
1E51F015	2", Pressure Reg. Valves	A				

Specification No. H-2872
 Vendor: Anderson, Greenwood & Co.
 Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page C45 of 45
 Rev. 03
 Date 4-15-81

Equipment Number	Description	S e r i e s	L o c a t i o n	Q u a l i f i c a t i o n M e t h o d	R e s u l t s
1E12F104A,B	2", Vacuum Relief Valves	P	React. Bldg	In Progress	

INSTRUMENTATION

FOR CLARITY INSTRUMENT TAG NUMBERS ARE NOT PROVIDED IN THIS SECTION, HOWEVER, THE INSTRUMENT TAG NUMBERS HAVE BEEN IDENTIFIED IN THE QUALIFICATION STATUS REPORT.

Specification No. H-2156
 Vendor: ITE Imperial Corp.

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page 01 of 56

Wm. H. Zimmer
 Project No. 4130-00

Rev. 00

Date 4-15-81

Equipment Number	Description	Series	Class Location	Qualification Method	Results
	GE Potential Transformer Model: JVM-3-643-93 AG Time Delay Relay Model: 7012-PB IR Motor Differential Relay Model: GRD-202D0541 WE Ammeter/Voltmeter Model: KA-241 ID Auxiliary Relay Model: J13 P3012 GE Lockout Relay Model: 12HEA61C233 MS Test Switch Model: DPDT-DB-RH2 GE Indicating Light Model: ET-16	A	Aux.Bldg. LAP04EA LAP04EB LAP04EC	Instruments were qualified with switchgear unit. See equipment qualification for details.	All essential instruments were monitored. There were no structural or functional abnormalities detected.

Specification No. H-2156
 Vendor: ITE Imperial Corp.

Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page D2 of 56

Rev. 00

Date 4-15-81

Equipment Number	Description	S e l e c t i o n s	C l a s s i f i c a t i o n	Location		Qualification Method		Results
	IS Ground Relay Model: GR-5 202D6141	A		Aux. Bldg LAP04EA LAP04EB LAP04EC		Instruments were qualified with switchgear unit. See equipment qualification for details.		All essential instruments were monitored. There were no structural or functional abnormalities detected.
	IS Ground Sensor Model: GS-05							
	IS Current Transformer Models: MCS-21-401153-T2 MCS-21-401153-T3 MCS-21-401153-T4 MCB-5A-401024-T5 MCS-21-401153-T5 MCS-21-401153-T6 MCS-21-401156-T6 MCS-21-401153-T7 MCB-5A-401024-T7 MC/B-5A-401024-T7 MC-5-400862-T8 MC-5-400862-T11 MC-5-400862-T13 MC/5-A1-401160-T14 MC-5S-400898-T20							

Specification No. H-2156
 Vendor: ITE Imperial Corp.

Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page D3 of 56
 Rev. 00
 Date 4-15-81

Equipment Number	Description	Series	Location	Qualification Method	Results
	GE Overcurrent Relay Models: 12IAC66B4A 12IAC66M1A 12IAC51B808 12IAC51A802 12IAC51A801A JVM-3-643-94	A →	Aux.Bldg. LAP04EA LAP04EB LAP04EC →	Instruments were qualified with switchgear unit. See equipment qualification for details. →	All essential instruments were monitored. There were no structural or functional abnormalities detected. →

Specification No. H-2157
 Vendor: ITE Impreial

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page 04 of 56
 Rev. 00
 Date 4-15-81

Wm. H. Zimmer
 Project No. 4130-00

Equipment Number	Description	S e l e c t i o n s	C l a s s i f i c a t i o n	Location		Qualification Method		Results
	GE Indicating Lamp Model: ET-16 IR Neutral Sensor Model: 609301-K1 IR Neutral Sensor Model: 609301-K2 IL Potential Transformer Model: PT-6 400765-K3 IL Potential Transformer Model: PT-16 400765-K3 IL Control Switch Model: C77 1001 1CC1 0002 IL Current Sensor Model: TKM-1 4C1181-T24	A		Aux. Bldg. LAP05E LAP06E LAP07EA/B LAP08EA/B LAP09E LAP10E LAP11EA/B LAP12EA/B LAP13E LAP14EA/B		Instruments were qualified with sub-station unit. See equipment qualification for details.		All essential instruments were monitored. There were no structural or functional abnormalities detected.

Specification No. H-2157
 Vendor: ITE Imperial

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page D5 of 56
 Rev. 00
 Date 4-15-81

Wm. H. Zimmer
 Project No. 4130-00

Equipment Number	Description	S e i s s	C l a s s	Location		Qualification Method		Results
	IL Current Transformer Model: TKM-1 401181-T21	A		Aux. Bldg. 1AP05E 1AP06E 1AP07EA/B 1AP08EA/B		Instruments were qualified with sub-station unit. See equipment qualification for details.		All essential instruments were monitored. There were no structural or functional abnormalities detected.
	IL Current Transformer Model: TKM-1 401181-T22			1AP09E 1AP10E 1AP11EA/B 1AP12EA/B				
	IL Current Transformer Model: TKM-1 4C1181-T23			1AP13E 1AP14EA/B				
	IL Ground Sensor TL-2 Model: 400 799 K6							
	ID Auxiliary Relay Model: J13P3012							
	IR Neutral Sensor Model: 609301-K2							
	IL Control Power Transformer Model: CP-6 401566-K1							
	GE Ground Relay Model: 12IAC53A803							

Specification No. H-2159
 Vendor: Stewart & Stevenson
 Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page D7 of 56
 Rev. 00
 Date 4-15-81

Equipment Number	Description	Series	Location	Qualification Method	Results
	Barton Pressure Switch Model: 288A Square D Temp. Switch Model: 9025-BCW-42 9025-BCW-45	P P	Aux. Bldg. 1DG10CF 1DG10CC	Qualification in Progress	

Specification No. H-2175
 Vendor: Unit Electric Controls, INC.
 Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page 08 of 56
 Rev. 00
 Date 4-15-81

Equipment Number	Description	S e i s s	C l a s s	Location		Qualification Method		Results
	GE Electrical Indicator Type 180. Vertical Edge- wise DC/AC.	A		Aux. Bldg. 1PM07J 1PM08J 1PM06J		Resonance Search Tests Pseudo Biaxial Sine Sweep Freq. range: 1-33 Hz Qualification Test Pseudo Biaxial Sine Beat Tests at one-half octave freq.intervals between 1-33 Hz. Resulting max. acc.: 4.97 g in all directions.		All essential equipment were monitored. No abnormalities were deducted during and after the test. Natural frequencies: 1st SS/V: 23 Hz 2nd FB/V: 28 Hz 2nd SS/V: 30 Hz
	GE Indicating Light Type ET-16	↓		1PM07J 1PM08J				No Natural Frequency in the the testing Range
	GE Control Switches Model SB-1	A		1PM01J 1PM07J 1PM08J				
	GE Aux. Relays Model: 12NG A15AS1	P		1PM08J				
	Automatic Timing & Control Inc. Auxiliary Relay Model: 305D007L20P	P		1PM08J				Natural Frequency: 1st SS/V: 22,26,30 Hz 1st FB/V: 31 Hz 2nd SS/V: 26 Hz

Specification No. H-2175
 Vendor: Unit Electric Controls, Inc.

Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page 09 of 56

Rev. 00

Date 4-15-81

Equipment Number	Description	Sei s s .	C l a s s .	Location		Qualification Method	Results	
	Transmation Signal Con- verters Model: 600 610TS 650TS	A ↓		Aux. Bldg.		Resonance Search: Uniaxial Sine Sweep Frequency Range .5 to 35 Hz	Resonance frequency are found in the horizontal direction at 8 and 19 Hz, 3.5 and 17 Hz.	
	Leeds & Northrup Pen Recorder Type: Speedomax M Mark III Model: 831 832 833				1HP13-P601		Qualification Test: Uniaxial Sine Dwell Frequency Range .5 to 35 Hz Input acceleration = 3.0g in all directions.	All essential equipment were monitored. No abnormalities were detected during and after the test.
	Electro Switch Corp. Control Switch Type Series 40				1PM08J 1PM07J 1PM06J		Qualification Tests Biaxial Random Motion Frequency Range 1-40 Hz. TRS enveloped RRS	All essential equipment were monitored throughout the test. No abnormalities were detected during and after the test.
						Seismic Qualification Report is presently being evaluated.		

Specification No. H-2188
 Vendor: Delphi
 Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page D10 of 56
 Rev. 00
 Date 4-15-81

Equipment Number	Description	S e r i e s	L o c a t i o n	Q u a l i f i c a t i o n M e t h o d	R e s u l t s
	Hydrogen and Oxygen Monitors and Transmitters	A	Aux. Bldg. 1PL40JA 1PL40JB	Equipment and instruments are being replaced.	

Specification No. H-2240
 Vendor: R. P. Adams
 Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page D11 of 56
 Rev. 00
 Date 4-15-81

Equipment Number	Description	Seis. Class.	Location	Qualification Method	Results
	Mercoid Pressure Regulator Model: BB-221-3	P ↓	SWPH LWS0?FA LWS02FB	Seismic qualification of instrument in progress	

Specification No. H-2265
 Vendor: Jamesbury Corp.

Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page D12 of 56

Rev. 00

Date 4-15-81

Equipment Number	Description	S e r i e s	C l a s s	Location		Qualification Method			
	Bettis Air Operator Air Operator T312B-SR3-12	P	↓	Rx. Bldg. 1VQ001A,B 1VQ002A,B 1VQ003A,B 1VQ004A,B		Static Analysis Input: x=5g; y=5g; z=5g			Natural frequency= 37.2 Hz Stress Max. Max. Spring Cartridge Calc. Allow Connection 19.1 105 Tensile stress ksi 19.1 105. Piston assembly tie bar 33.6 105.
	NAMCO Limit Switch EA-170	P	↓	Rx. Bldg. 1VH001A,B 1VH002A,B 1VH003A,B 1VH004A,B		Qualification Test Pseudo Biaxial sine sweep Frequency range: 1-35 Hz Input: from 3-7g in all directions			No abnormalities or struc- tural failure were detected after the test.
	ASCO Solenoid Valve Model: 831655	A	↓	1VH001A,B 1VH002A,B 1VH003A,B 1VH004A,B		Qualification Test Uniaxial Sine Sweep Frequency Range 10-40 Hz Max. input acceleration = 7.5 g			Operability was demon- strated. No abnormalities were detected. Structural integrity satisfied.
	Model: HTX8321	A	↓	1VQ001A,B 1VQ002A,B 1VQ003A,B 1VQ004A,B		Qualification Test Uniaxial Sine Sweep Frequency Range 10-40 Hz Max. input acceleration = 12.2 g			↓

SUMMARY OF
 EQUIPMENT QUALIFICATION

Specification No. H-2265
 Vendor: Jamesbury Corp.
 Wm. H. Zimmer
 Project No. 4130-00

Equipment Number	Description	S e r i e s .	C l a s s	Location	Qualification Method	Results
	Jamesbury Corp. Quadra Power Actuator F50S	A	↓	RX. Bldg. IVH002A,B IVH001A,B	Qualification Report is being evaluated at present	

Specification No. H-2288
 Vendor: American Air Filter
 Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page D14 of 56
 Rev. 00
 Date 4-15-81

Equipment Number	Description	Series	Location	Qualification Method	Results
	Mercoïd Temperature Switch DAW DAW-7036-804-S2	A	Reactor Bldg 1VG05SA/B	Resonance Search Uniaxial Sine Sweep Frequency range: 1-35 Hz Qualification Test Uniaxial Sine Dwell Frequency range: 1-35 Hz Input: horiz. = 3.0g vert. = 2.0g	No resonances found in the frequency range. All essential equipment were detected during and after the test.
	Barton Differential Pressure Transmittal Model: 385	P	↓	Resonance Search Uniaxial Sine Sweep Frequency Range: 1-35 Hz Qualification Test Uniaxial Sine Dwell at resonant frequencies. Input Acceleration: Horiz. 2.0g Vert. 1.5g	Natural Frequencies determined Horiz. (1) 4, 12, 17, 21, 28, 33 Horiz. (2) 9, 15, 18, 22, 30 Vert. = 8, 13, 29 Instrument was monitored throughout the test. No abnormalities were recorded.
	ITT Motor Operator Model: NH-95	A	↓	Qualification Test Biaxial Random Motion Frequency range: 1-33 Hz TRS enveloped RRS up to 100 Hz	All essential equipment were actuated. No abnormalities were detected during and after the test.

Specification No. H-2288
 Vendor: American Air Filter
 Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page D15 of 56
 Rev. 00
 Date 4-15-81

Equipment Number	Description	S e i s .	C l a s s Location	Qualification Method	Results
	Dwyer Magnehelic Diff. Press. Gage Model #2002 2003 2010	P	Reactor Bldg. 1VG05SA 1VG05SB	Resonance Search Uniaxial Sine Sweep Frequency range: 1-40 Hz Qualification Test Biaxial Random Motion Frequency Range: 1-40 Hz TRS enveloped RRS	No natural frequencies found in the test frequency range. All essential equipment were inspected. No abnormalities were detected during and after the test.
	Mercoid Liq. Level Switch 201WT-9806-S2	A	↓	Resonance Search Test Uniaxial Sine Sweep Frequency range: 2-33 Hz Qualification Test Uniaxial Sine Dwell Frequency Range 2-33 Hz Input accel. 2g in all directions.	No resonances found in the frequency range. All essential equipment were monitored. No abnormalities were detected during and after test.
	ATkomatic Deluge Valve Model: 5700GX	A		Resonance Search Pseudo Biaxial Sine Sweep Frequency Range 2-33 Hz Qualification Test Pseudo Biaxial Sine Dwell Input: 4.5g Horizontal 3.0g Vertical Frequency range: 2-33 Hz	No resonances found. All essential equipment were monitored. No abnormalities were detected during and after the test.

Specification No. H- 2288
 Vendor: American Air Filter
 Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page D16 of 56
 Rev. 00
 Date 4-15-81

Equipment Number	Description	S e r i e s	C l a s s i f i c a t i o n	Location		Qualification Method	Results
	Alison Temp. Sensor Model: 1052	P		RX.Bldg. 1VG05SA/B		<p>Resonance Search Uniaxial Sine Sweep Frequency range: 2-35 Hz Input acceleration = 5 g in all directions.</p> <p>Qualification Test Uniaxial Sine Sweep Frequency Range: 2-35 Hz Input acceleration = 5g in all directions.</p>	No resonances found in the frequency range. All essential parts were detected during and after the test.

Specification No. H-2288
 Vendor: American Air Filter
 Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page 017 of 56
 Rev. 00
 Date 4-15-81

Equipment Number	Description	Serials	Location	Qualification Method	Results
	Ashcroft Thermowells Model #T-38S75T060	P	Reactor Bldg. 1VG05SA	Seismic Qualification in progress	
	Ashcroft Thermometers Model #30BI60L-060	P	Reactor Bldg. 1VG05SA		

Specification No. H-2289
Vendor: Pacific Air Products
Wm. H. Zimmer
Project No. 4130-00

SUMMARY OF
EQUIPMENT QUALIFICATION

Page D18 of 56
Rev. 00
Date 4-15-81

Equipment Number	Description	S e i s . C l a s s	Location	Qualification Method	Results
	Contromatics Damper Operator Model:500-SP.	A ↓	Aux.Bldg. LVG03YA, YB LVG04YA, YB	Static Analysis Input resultant accelera- tion = 4.5g	No ndtural frequency below 33 Hz. Operability was demonstrated by showing that the operating forces are higher than the seismic forces.

Specification No. H-2289
 Vendor: Pacific Air Products

Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page D19 of 56

Rev. 00

Date 4-15-81

Equipment Number	Description	S e i s s	C l a s s	Location		Qualification Method	Results
	<p>Asco Solenoid Valve Model HT-8302-B-25-RF</p> <p>Namco Limit Switches Model: D-1200-6</p>	<p>A</p> <p>↓</p> <p>P</p> <p>↓</p>	<p>Reactor Bldg. 1VG05SA 1VG05SB</p> <p>Aux. Bldg. 1VG03YA 1VG03YB 1VG04YA 1VG04YB</p> <p>Aux. Bldg. 1VG03YA 1VG03YB 1VG04YA 1VG04YB</p>			<p>Seismic qualification of instruments are in progress</p> <p>↓</p>	

Specification No. H-2293

Vendor: Trane Company

Wm. H. Zimmer

Project No. 4130-00

SUMMARY OF
EQUIPMENT QUALIFICATION

Page D20 of 56

Rev. 00

Date 4-15-81



Equipment Number	Description	Series	Class Location	Qualification Method	Results
	GE Control Relay CR-2810-414C2 GE Control Switch CR-2940 AGASTAT Time Delay Relay 7012 GE Time Delay Relay CR-2820-B11744-2 PENN-Pressure Switch P-45NC4-43 P-45NC4-20 P-70MA-20	A	Aux. Bldg. 1PLB4J 1PLB5J 1PLB6J 1PLB7J 1PLB8J 1PLB9J 1PLC1J 1PLB3J	Qualitication Tests Biaxial Random Motion Frequency range: 1-40 Hz TRS enveloped RRS	All essential equipment were monitored. No ab- normalities were detected during and after the test.

Specification No. H-2299
 Vendor: MCC Powers
 Wm. H. Zimmer
 Project No. 4130-00





SUMMARY OF
 EQUIPMENT QUALIFICATION



Page 021 of 56
 Rev. 00
 Date 4-15-81

Equipment Number	Description	S e i s s	C l a s s	Location		Qualification Method	Results
	Transmation Current Relay Model: 210A	P		Auxiliary & Reactor Building		Resonance Search: Uniaxial Sine Sweep Frequency Range .5 to 35 Hz Qualification Test: Uniaxial Sine Dwell Frequency Range .5 to 35 Hz Input acceleration = 3.0g in all directions	All essential equipments were monitored. No abnormalities were detected. Resonance found only in the horizontal direction at 8 and 19 Hz.
	GE Indicating Lights ET-16	P ↓		LPM07J LPM08J		Resonance Search Tests Pseudo Biaxial Sine Sweep Freq. Range: 1-33 Hz Qualification Test Pseudo Biaxial Sine Beat Tests at one-half octave freq. intervals between 1-33 Hz. Resulting Max. Acc.: 4.97g in all directions.	All essential equipment were monitored. No abnormalities were deducted during and after the test. No Natural Frequency in the testing range.







**IMAGE EVALUATION
TEST TARGET (MT-3)**





**IMAGE EVALUATION
TEST TARGET (MT-3)**



Specification No. H- 2299
 Vendor: MCC Powers
 Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page D22 of 56
 Rev. 00
 Date 4-15-81

Equipment Number	Description	S e r i e s	C l a s s	Location		Qualification Method		Results
	Dwyer Differential Pressure Indicator Model: 2010 2003 2005 2001 2015	P		Aux .Bldg. 1VY01C 1VY02C 1VY03C 1VY04C 1VY05A 1VY07AA 1VY08A 1VY09A		Resonance Search: Uniaxial Sine Sweep Frequency Range 1-40 Hz Qualification Test: Biaxial Random Motion Frequency Range 1-40 Hz TRS enveloped RRS		No resonances found below 40 Hz All essential instruments were monitored. No abnormalities were detected during and after the test.
	UE Temperature Switch Series 300 F303D-5AS F302D-5AS F300-6AS	A		1VC08SA 1VC08SB 1VX01CA 1VX01CB 1VX01CC 1VX01CD 1VX01CE 1VX01CF		Resonance Search: Uniaxial Sine Sweep Frequency Range 1-40 Hz Qualification Test: Biaxial Random Motion Frequency Range 1-40 Hz TRS enveloped RRS except below 4-6 Hz Input acceleration up to 12g.		Resonance was determined in the horizontal direction at 38 Hz All essential instruments were monitored. No abnormalities were detected during and after the test.

Specification No. H- 2299
 Vendor: MCC Powers
 Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page D23 of 56
 Rev. 00
 Date 4-15-81

Equipment Number	Description	S e i s s	C l a s s	Location		Qualification Method		Results
	Love Controls Current Relay Model: 54 56 48	A		Reactor & Aux. Bldg. 1PL14JA,B 1PL60JA,B 1PL61JA,B 1PL69JA,B		Resonance Search: Uniaxial Sine Sweep Frequency Range 1-40 Hz		No resonance found in the test frequency range. All essential equipments were monitored. No abnormalities were deducted during and after the test.
	GE Transfer Switch Model: SB-1	A		1PL91J 1PL92J 1PL93J		Qualification Test: Biaxial Random Motion Frequency range 1-40 Hz TRS enveloped RRS except below 4-6 Hz		
	GE Relay HMA 11B11	A		1PM07J		Input acceleration up to 12g.		
	GE Relay 12HFA 51A49H 12HFA 51A42H	A		↓		↓		
	Agastat TDR Model: 7022 7012 7000 7032	A		↓		↓		
	Kepco Power Supply PCX72-0.3	P		↓		↓		
	ASCO 3-way Solenoid Valve HBX8320-A1	A		↓		↓		

Specification No. H-2299
 Vendor: MCC Powers

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page 024 of 56

Wm. H. Zimmer
 Project No. 4130-00

Rev. 00

Date 4-15-81

Equipment Number	Description	S e r i a l s s	C l a s s i f i c a t i o n L o c a t i o n	Qualification Method	Results
	Solon Pressure Switch 7P11ADW, 5PS11BAEW	A	Reactor & Auxiliary Building	Resonance Search: Uniaxial Sine Sweep Frequency Range 1-40 Hz	Resonance was found during a vertical sweep at 21 Hz only on 5PS11BAEW. All essential instruments were monitored. No abnormalities were detected during and after the test.
	W&T Chlorine Detector 50-125	A	↓	Qualification Test: Biaxial Random Motion Frequency Range 1-40 Hz TRS enveloped RRS except below 4-6 Hz Input acceleration up to 12g.	Resonance found at 18 Hz in the horizontal sweep
	W&T Chloring Detector 50-125D	A	↓	↓	Resonance found: horizontal 27, 30 vertical 33, 37

Specification No. H-2299
 Vendor: MCC Powers
 Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page D25 of 56
 Rev. 00
 Date 4-15-81

Equipment Number	Description	S e i s s	C l a s s	Location	Qualification Method	Results
	Delaval Level Switch 36497	A		Reactor & Auxiliary Building	Resonance Search: Uniaxial Sine Sweep Frequency Range 1-40 Hz	All essential instruments were monitored. No abnormalities were detected during and after the test.
	Dwyer DP Switch 1638-0	A		↓	Qualification Test: Biaxial Random Motion Frequency Range 1-40 Hz TRS enveloped RRS except below 4-6 Hz Input acceleration up to 12g.	
	Pyrotronics DIS3/5A	A		↓	↓	
	DIA-11	A		↓	↓	
	CTZ-2	A		↓	↓	
	DIA-10	A		↓	↓	
	ESC-1	P		↓	↓	

Specification No. H-2299
 Vendor: MCC Powers
 Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page D27 of 56
 Rev. 00
 Date 4-15-81

Equipment Number	Description	Seis. Class.	Location	Qualification Method	Results
	Pressure Indicator	P	Reactor Bldg.	Seismic Qualification in progress	
	Beta Annunciators 1211B	P	Aux. Bldg. Rx. Bldg. 1PL69JA 1PL69JB 1PL14JA 1PL14JB 1PL91J 1PL92J 1PL93J		
	Air Monitor Pressure Transmitter exactor, Series 300	P	↓		
	Power Reg. Co. Receiver Controller 185-0124	P	1PL14JA 1PL14JB		

Specification No. H-2805
 Vendor: Bishopric Products, Inc.
 Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page D28 of 54
 Rev. 00
 Date 4-15-81

Equipment Number	Description	Seis. Class.	Location	Qualification Method	Results
	Liquid Level Switches		Aux. Bldg. IDG07TA/C IDG14TA/F	Seismic Qualification of the instruments are in progress.	

Specification No. H-2809
Vendor: Rosemount, Inc.

Wm. H. Zimmer
Project No. 4130-00

SUMMARY OF
EQUIPMENT QUALIFICATION

Page D29 of 56

Rev. 00

Date 4-15-81

Equipment Number	Description	S e r i e s	C l a s s	Location		Qualification Method		Results
	Rosemount Diff. Pressure Transmitter Model: 1152DP7A22PB 1152GP7A22PB 1152GP4A22PB 1152DP4A22PB 1152DP6A22PB 1152GP9A22PB 1152GP6A22PB			Reactor Bldg.		Resonance Search Uniaxial Sine Sweep Frequency Range 1-100 Hz Qualification Test Uniaxial sine Dwell Frequency Range 1-100 Hz Input acceleration: 3.0 g in all direction.		Resonance was found at Horiz. = 22,24,61, 69,78 Hz Vert. = 68 Hz Instrument was monitored throughout the test. No abnormalities were detected.

Specification No. H- 2809

Vendor: Rosemount Inc.

Wm. H. Zimmer

Project No. 4130-00

SUMMARY OF
EQUIPMENT QUALIFICATION

Page D30 of 56

Rev. 00

Date 4-15-81

Equipment Number	Description	S e i s s .	C l a s s .	Location		Qualification Method			
	Rosemount Temperature Detector Assembly Model: 88-14 Model: 183-108-1 Model: 183-105-1 Model: 183-106-1	P		Peactor Bldg. Wall Mounted		Resonance Search: Biaxial Sine Sweep Frequency Range: 1-35 Hz Qualification Test: Biaxial Sine Sweep at resonant frequencies Input: 3.0g in all directions			Natural Frequencies FB/V = 7.4, 24 Hz FB/V = 7.6, 11, 25 Hz SS/V = 7.7, 24, Hz No abnormalities detected after the test.

Specification No. H-2816
 Vendor: Powers Regulator
 Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page D31 of 56
 Rev. 00
 Date 4-15-81

Equipment Number	Description	S e l e c t i o n	C l a s s i f i c a t i o n	Location	Qualification Method	Results
	ITT Damper Operator Model: NH-91	A ↓		Aux.Bldg. 1VC15YA 1VC15YB 1VC14YA 1VC13YB 1VC16YA 1VC14YB 1VC13YA 1VC16YB	Resonance Search Uniaxial Sine Sweep Frequency Range 1-50 Hz Qual. Test Biaxial Random Motion.Frequency Range 1-50 Hz TRS enveloped RRS	Resonance detected at 42, 48 Hz. Operators were actuated during the test. No abnormalities were detec- ted during and after test.

Specification No. H-2817Vendor: CV

Wm. H. Zimmer

Project No. 4130-00

SUMMARY OF
EQUIPMENT QUALIFICATIONPage D32 of 56Rev. 00Date 4-15-81

Equipment Number	Description	S e r i e s	C l a s s	Location	Qualification Method	Results
	Dwyer Differential Pressure Indicator, Model: 2000	P		Aux.Bldg. 1VC09SA/B 1VC10S	Resonance Search Uniaxial Sine Sweep Frequency Range 1-40 Hz Qualification Test Biaxial Random Motion Frequency Range 1-40 Hz TRS enveloped RRS	No resonances below 40 Hz All essential instruments were monitored. No abnormalities were detected during and after the test.
	Namco Limit Switch Model: EA170-11302	P		Aux. Bldg 1VC12YA 1VC12YC 1VC81YA, YB	Qualification Test Psuedo-Biaxial Sine Sweep Frequency Range 1-35 Hz Input from 3-7g in all directions.	No abnormalities or structural failure were detected after the test.
	ITT Barton Differential Pressure indicating switch Model: 289A	P		Aux.Bldg. 1VC09SA,B	Resonance Search Uniaxial Sine Sweep. Freeuency Range 1-35 Hz. Qualification Test Uniaxial Sine Dwell Frequency Range 1-35 Hz Input acceleration Horiz.= 4.0g Vert. = 2.67g	Resonant frequencies found: FB = 1, 12, 18, 32, 35Hz SS = 5, 7, 11, 17, 22, 25, 30 Hz. Vert.= 5, 7, 11, 34, 35 Hz. Instrument was monitored during the test. No abnormalities were recorded.
	Rosemount Differential Pressure Transmitter 1151DP-3-A-22.	P P P		Aux.Bldg. 1VC09SA 1VC09SB 1VC10S	Qualification Test Biaxial Random Motion Frequency range: 1-35 Hz. TRS enveloped RRS	Instrument was monitored during the test. No abnormalities were recorded during and after the test.

Specification No. H-2817

Vendor: CVI

Wm. H. Zimmer

Project No. 4130-00

SUMMARY OF
EQUIPMENT QUALIFICATION

Page D33 of 56

Rev. 00

Date 4-15-81

Equipment Number	Description	S e r i e s	C l a s s	Location	Qualification Method	Results
	ITT Damper Motor Operator NH-95	P A A A A		Aux.Bldg. 1VC12YA 1VC212YC 1VC81YA 1VC81YB 1VC82Y	Resonance Search Uniaxial Sine Sweep Frequency Range 1-50 Hz. Qualification Test Biaxial Random Motion Frequency Range 1-50 Hz TRS enveloped RRS	Resonance detected at 42, 48 Hz Operators were actuated during the test. No abnormalities were detected during and after the test
	ASCO Solenoid Valve Model: HB8320A-1	A		Aux.Bldg.	Resonance Search Uniaxial Sine Sweep Freq. Range 1-40 Hz. Qualification Test Biaxial Random Motion Frequency Range 1-40 Hz TRS enveloped RRS except below 4-6 Hz Input accel. up to 12g.	No resonance found in the test frequency range. All essential instruments were monitored. No abnormalities were detected during and after the test.

Specification No. H-2817

Vendor: CVI

Wm. H. Zimmer

Project No. 4130-00

SUMMARY OF
EQUIPMENT QUALIFICATION

Page D34 of 56

Rev. 00

Date 1/15-81

Equipment Number	Description	Seis. Class.	Location	Qualification Method	Results
	<p>Namco Limit Switch EA750-20100</p> <p>Ashcraft Bi-Metal Thermometer Model: 50A16OR-S12</p> <p>Rosemont Temp. Transmitter Model: 442A-RP-A-01</p>	<p>A</p> <p>P</p> <p>P</p>	<p>Aux. Bldg. IVC29YA, YB</p> <p>IVC09SA IVC12YA</p> <p>IVC10S</p>	<p>Seismic Qualification of instruments are in progress.</p> <p style="text-align: center;">↓</p>	

Specification No. H-2826
 Vendor: Dayton T. Brown
 Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page D35 of 56
 Rev. 00
 Date 4-15-81

Equipment Number	Description	Series	Location	Qualification Method	Results
	Aschcroft Pressure Indicator Model: 2462ASXVN	P	Reactor Bldg. Local Panel	Resonance Search: Uniaxial Sine Sweep Frequency Range: 1-35 Hz Qualification Test: Uniaxial Sine Dwell Frequency Range: 1-35 Hz Input: 3.0g to 7.5g in all directions.	No resonance found in the test frequency Structural Integrity satisfied

Specification No. H-2835
 Vendor: Unit Electric Controls, Inc.
 Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page D36 of 56
 Rev. 00
 Date 4-15-81

Equipment Number	Description	Series	Class Location	Qualification Method	Results
	GE Control Switches CR2940 Selector Cuttler Hammer Push button switches 10250T Electro Switch Control switches Series 40 GE Electrical Indicators 180 Vertical Edgewise DC Transmation Signal Converters Model: 610TS GE Control Switches SBM GE Control Switches SB-1	A	Aux. Bldg. 1PL67JA 1PL67JB	Instruments were qualified with equipment. See equipment qualification for details.	All essential equipment were monitored. No abnormalities were detected during and after the test.

Specification No. H-2866
 Vendor: ITT Barton
 Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page D37 of 56
 Rev. 00
 Date 4-15-81

Equipment Number	Description	Seis. Class	Location	Qualification Method	Results
	Barton Pressure Switches Model: 288A	A	Reactor Bldg.	Seismic qualification of instruments are in progress.	

Specification No. H-2868
 Vendor: Powers Regulator
 Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page D38 of 56
 Rev. 00
 Date 4-15-81

Equipment Number	Description	S e i s s	C l a s s	Location	Qualification Method	Results
	ITT Damper Operator Model #NH-95 NH-91 NH-95-3			Aux.Bldg. RX. Bldg. All ele- vation	Resonance Search Test Uniaxial Sine Sweep Freq. Range 1-50 Hz. Qualification Test Biaxial Random Motion Frequency Range 1-50 Hz TRS enveloped RRS	Resonance detected at 42 and 48 Hz. Operators were actuated during the test. No ab- normalities were detected during and after the test.
	GE Control Relay Model #12HFA51A49	A		Aux.Bldg. 1PL14JA	Resonance Search Test Uniaxial Sine Sweep Frequency Range 1-40 Hz Qual. Test Biaxial Random Motion . Frequency Range 1-40 Hz. TRS enveloped RRS except below 4-6 Hz. Input accel.up to 12g.	No resonance found in the test frequency range. All essential instruments were monitored. No abnormalities were detected during and after the test.
	Namco Limit Switch Model: EA-750-20100	A		Aux.Bldg. RX.Bldg. All Elevations	Seismic qualification is in progress.	

Specification No. H-2874
 Vendor: American Warming & Vent.Co.
 Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page D39 of 56
 Rev. 00
 Date 4-15-81

Equipment Number	Description	S e i s s	C l a s s	Location	Qualification Method	Results
	Namco Limit Siwtch Model: EA-740-70100	A		Aux. Bldg. 1VG06YA/ YB 1VG07YA/ YB 1VG09YA/ YB 1VG10YA/ YB 1VG01YA/ YB 1VG08YA/ YB	Seismic Qualification is in progress	
	ITT Motor Operators Model: NH.-95,91	A		Aux. Bldg. 1VG06YA/B 1VG07YA/B 1VG08YA/A 1VG09YA/B 1VG10YA/B 1VG01YA/B 1VQ10Y		

Specification No. H-2881
 Vendor: Reliance Electric Co.
 Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page D40 of 56
 Rev. 00
 Date 4-15-81

Equipment Number	Description	Series	Classification Location	Qualification Method	Results
	GE Indicating Light ET-16	A	Aux.Bldg. RX.Bldg. 1PL79J 1PM18J	Resonance Search Tests Pseudo Biaxial Sine Sweep Freq. range: 1-33 Hz Qualification Test Pseudo Biaxial Sine Beat Tests at one-half octave freq. intervals between 1-33 Hz Resulting max.acc. 4.97g in all directions.	All essential equipment were monitored. No abnorm- alities were deducted during and after the test. No natural frequency in the testing range.
	GE Test Switch CR2940	A	Aux.Bldg. 1PM18J	Qualification Test Biaxial Random Motion. Frequency range 1-40 Hz TRS enveloped RRS.	All essential equipment were monitored. No abnorm- alities were detected during and after the test.

Specification No. H-2881
 Vendor: Reliance Electric Co.
 Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page D41 of 56
 Rev. 00
 Date 4-15-81

Equipment Number	Description	S e i s s	C l a s s	Location		Qualification Method	Results
	GE Auxiliary Relay Model: 12HFA51A49H, 12HMA11B11	A		Aux.Bldg. RX. Bldg. 1PM18J 1PL79J		Resonance Search Uniaxial Sine Sweep Frequency range 1-40 Hz Qualification Test: Biaxial Random Motion Frequency range 1-40 Hz TRS enveloped RRS except below 4-6 Hz Input acceleration up to 12g.	No resonance found in the test frequency range. All essential equipment were monitored. No abnor- malities were deducte during and after the test
	WE Test Switches Type FT-1	A		Aux.Bldg. 1PM18J		See seismic qualification of siwtch gear unit under Specification H-2156 for details.	No resonances found below the test frequency. All essential instruments were monitored. No abnor- malities were detected.

Specification No. H-2898
Vendor: Eberline

Wm. H. Zimmer
Project No. 4130-00

SUMMARY OF
EQUIPMENT QUALIFICATION

Page D42 of 56
Rev. 00
Date 4-15-81

Equipment Number	Description	Classification	Location	Qualification Method	Results
	Eberline Radiation Detectors DAL-6HTC	A	Aux. Bldg. LM Duct	Seismic qualification in progress	
	Eberline Radiation Monitor DAM-1	A	LM-Wall IPMI7J		

Specification No. C-135
Vendor: Electro Switch Corp.
Wm. H. Zimmer
Project No. 4130-00

SUMMARY OF
EQUIPMENT QUALIFICATION

Page D43 of 56
Rev. 00
Date 4-15-81

Equipment Number	Description	S e i s s	C l a s s	Location		Qualification Method		Results
	Electro Switch Hand switch Series 40	A		Aux. Bldg 1PM08J		Seismic qualification are being presently evaluated		

Specification No. C-442
 Vendor: Electro Switch Corp.
 Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page D44 of 56
 Rev. 00
 Date 4-15-81

Equipment Number	Description	S e l e c t i o n	C l a s s i f i c a t i o n	Location		Qualification Method		Results
	GE Hand Switch SB-1	A		Aux.Bldg. 1PM065		Resonance Search. Uniaxial Sine Sweep Frequency Range 1-40 Hz Qualification Test: Biaxial Random Motion Frequency range 1-40 Hz TRS enveloped RRS except below 4-6 Hz Input acceleration up to 12g.		No resonance found in the test frequency range. All essential equipments were monitored. No abnormali- ties were deducted during and after the test.

Specification No. C-443
 Vendor: Electro Switch Corp.
 Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page D45 of 56
 Rev. 00
 Date 4-15-81

Equipment Number	Description	Seis. Class.	Location	Qualification Method	Results
	Electro Switch Corp. Control Switches Type Series 40	A	Aux. Bldg 1PM07J	Seismic qualification are being presently evaluated	

Specification No. C-444
Vendor: General Electro Co.
Wm. H. Zimmer
Project No. 4130-00

SUMMARY OF
EQUIPMENT QUALIFICATION

Page D46 of 56
Rev. 00
Date 4-15-81

Equipment Number	Description	S e l e c t i o n s	C l a s s	Location	Qualification Method	Results
	GE Selector Switch CR2940	A		Aux.Bldg. 1H13-P601	Qualification Tests Biaxial Random Motion Frequency range: 1-40 Hz TRS enveloped RRS	All essential equipment were monitored. No abnormalities were detected during and after the test.

Specification No. C-445
 Vendor: General Electric
 Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page D47 of 56
 Rev. 00
 Date 4-15-81

Equipment Number	Description	S e r i e s	C l a s s	Location		Qualification Method		Results
	GE Control Switch Model: SBM	A		Aux.Bldg. 1H12-P601		Resonance Search: Uniaxial Sine Sweep Freq. Range 1-40 Hz Qualification Test: Biaxial Random Motion Frequency Range 1-4 Hz TRS enveloped RRS except below 4-6 Hz. Input acceleration up to 12g.		No resonance found in the test frequency range. All essential equipments were monitored. No abnormali- ties were deducted during and after the test.

Specification No. PO-2371
 Vendor: Victoreen Inst. Div.
 Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page D48 of 56
 Rev. 00
 Date 4-15-81

Equipment Number	Description	Series	Location	Qualification Method	Results
	Victoreen Radiation Monitors Models: 847-2 846-1	P	Aux. Bldg. 1PM17J	Qualification Test Biaxial Random Motion Frequency Range 1-40 Hz TRS enveloped RRS	It was demonstrated that after the test the instruments exhibited no malfunction.

Specification No. P02720
Vendor: Elma Engineering
Wm. H. Zimmer
Project No. 4130-00

SUMMARY OF
EQUIPMENT QUALIFICATION

Page D49 of 56
Rev. 00
Date 4-15-81

Equipment Number	Description	S e i s s	C l a s s	Location	Qualification Method	Results
	Elma Engineering 24VDC Power Supply Model: 164C5261-1	P		Aux. Bldg 1PM08J	Seismic qualification in progress	

Specification No. PO-2876
Vendor: Transmation

Wm. H. Zimmer
Project No. 4130-00

SUMMARY OF
EQUIPMENT QUALIFICATION

Page D50 of 56

Rev. 00

Date 4-15-81

Equipment Number	Description	Series	Class	Location	Qualification Method	Results
	Transmation Thermo-couple Alrams Model: 610A-E(A-X-5)- 235	A		Aux.Bldg. 1PM08J 1PM07J 1PM06J	Resonance Search Uniaxial Sine Sweep Frequency Range .5-35 Hz	Resonance frequency are found in the horizontal direction at 8,16,19 Hz
	Transmation Signal Converter Model: S520A-243, 610IT-T-XS	A		1T49-P865 1T49-P866 1PL67J 1H13-P628	Qualification Test Uniaxial Sine Dwell Frequency range .5-35 Hz Input acceleration= 3.0g in all direction.	All essential were monitored. No abnormalities were detected during and after the test.

Specification No. PO-3322

Vendor: _____

Wm. H. Zimmer

Project No. 4130-00

SUMMARY OF
EQUIPMENT QUALIFICATION

Page D52 of 56

Rev. 00

Date 4-5-81

Equipment Number	Description	Class	Location	Qualification Method	Results
	Riley Co. Signal Converters Model: 86PTGF-EGB 86VTFF-EGB	A	Aux. Bldg. 1H13-P632 1H13-P642	Seismic qualification in progress	

Specification No. PO-3255
 Vendor: Leeds & Northrup
 Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page D53 of 56
 Rev. 00
 Date 4-15-51

Equipment Number	Description	S e i s . C l a s s	Location	Qualification Method	Results
	Leeds & Northrup Pen Recorder Model: Speedomax 250	A	Aux. Bldg 1H13-P601	Seismic qualification in progress	

Specification No. PO 2949

Vendor: C.S. Gordon

Wm. H. Zimmer

Project No. 4130-00

SUMMARY OF
EQUIPMENT QUALIFICATION

Page D54 of 56

Rev. 00

Date 4-15-81

Equipment Number	Description	S e r i e s	C l a s s	Location		Qualification Method		Results
	CS Gordon Thermocouples Model: 404-3107-050	A		Reactor Bldg.		Qualification Method Static Analysis Maximum acceleration used: 7.5g horiz. 2.25g vert.		Based on the analysis and the design of the thermo- couple supports the maxi- mum combined stress is 9,479 psi (max. allowable = 30,000 psi)

Specification No. B/M
 Vendor: Refer Below
 Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page D55 of 56
 Rev. 00
 Date 4-15-81

Equipment Number	Description	S e i s s	C l a s s	Location		Qualification Method		Results
	<p>GE Electrical Indicator Type 180 Vertical Edgewise</p> <p>Leeds & Northrup Pen Recorder Type: Speedomax Mark III Model: 832,833</p>	A	A	<p>Aux. Bldg. 1H13-P601 1PL67JA 1PL67JB</p> <p>Aux. Bldg. 1H13-P601</p>		<p>Resonance Search Tests Pseudo Biaxial Sine Sweep Frequency range: 1-33 Hz Qualification Test Pseudo Biaxial Sine Beat Test at on-half octave freq. intervals between 1-33 Hz. Resulting mat. acc.: 4.97g in all directions.</p> <p>Qualification Tests: Biaxial Random Motion Freq. range 1-40 Hz TRS enveloped RRS</p>		<p>All essential equipment were monitored. No abnormalities were deducted during and after the test</p> <p>Natural frequencies: 1st SS/V:123Hz 2nd FB/V:28Hz 2nd SS/V:30Hz</p> <p>All essential equipment were monitored throughout the test. No abnormalities were detected during and after the test.</p>

Specification No. B/M
 Vendor: Refer below
 Wm. H. Zimmer
 Project No. 4130-00

SUMMARY OF
 EQUIPMENT QUALIFICATION

Page DE6 of 56
 Rev. 00
 Date 4-15-81

Equipment Number	Description	Seis. Class.	Location	Qualification Method	Results
	Bailey Process Controller Model: 701	A	Aux. Bldg 1PL67J	Seismic qualification in progress	