

CONTROL BLOCK: 1

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 A L J M F 1 1 2 0 0 0 - 0 0 0 0 0 0 - 0 0 0 3 4 1 1 1 1 1 4 5
8 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 37 CAT 56

CONT

01 REPORT SOURCE L 6 0 5 0 0 0 0 3 4 8 7 0 13 11 8 8 1 5 0 4 1 1 6 0 1 1 9
7 8 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

02 At 1640 on 3-18-81 while performing surveillance test FNP-1-STP-28.2 (Diesel Generator
03 1-2A(1B) Operability Test), Diesel Generator 1B was declared inoperable when it tripped
04 on overspeed (D.G. 1-2A was inoperable at this time due to maintenance). Tech. Spec.
05 3.8.1.1, in part, requires two separate and independent D.G. sets to be operable. Tech.
06 Spec. 3.8.1.1 action statement requirements were met. Health/safety of the public
07 was not affected.

08 8 9

09 SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP. SUBCODE VALVE SUBCODE
E E 11 X 12 Z 13 Z Z Z Z Z Z 14 Z 15 Z 16
8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

17 LER/RO REPORT NUMBER 8 1 21 22 23 24 25 26 27 28 29 30 31 32
ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NPD-4 FORM SUB. PRIME COMP. SUPPLIER COMPONENT MANUFACTURER
X 13 7 19 20 21 22 23 24 25 26 27 28 29 30 31 32
33 34 35 36 37 38 39 40 41 42 43 44 45 46 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

10 Overspeed condition resulted from loss of power (blown fuses), to the speed governor.
11 No cause for fuse failure was found. The fuses were replaced, the surveillance test
12 successfully performed and D. G. 1B was returned to service at 2120 on 3-18-81.
13
14

15 FACILITY STATUS % POWER OTHER STATUS 30 METHOD OF DISCOVERY DISCOVERY DESCRIPTION 32
G 28 0 0 0 29 NA 71 Performance of surveillance test
8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

16 ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY 35 LOCATION OF RELEASE 36
Z 33 Z 34 NA NA
8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

17 PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION 39
0 0 0 37 Z 38 NA
8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

18 PERSONNEL INJURIES NUMBER DESCRIPTION 41
0 0 0 40 NA
8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

19 LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION 43
NA
8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

0 N 44 NA 63 69 80

8104280650