

CONT

[0] [1] REPORT SOURCE [L] [6] [0] [5] [0] [0] [0] [3] [3] [6] [7] [0] [3] [2] [0] [8] [1] [8] [0] [4] [1] [6] [8] [1] [9]

60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

[0] [2] | During routine operability testing of the turbine driven auxiliary feedwater pump the

[0] [3] | coupling end pump packing failed. Thus three auxiliary feedwater pumps were not

[0] [4] | operable as required by Technical Specification 3.7.1.2. Operability of the remaining

[0] [5] | two pumps was verified in accordance with Technical Specification 4.7.1.2 and plant

[0] [6] | operation continued.

[0] [7] |

[0] [8] |

[0] [9]

SYSTEM CODE [C] [H] (11) CAUSE CODE [E] (12) CAUSE SUBCODE [F] (13) COMPONENT CODE [P] [U] [M] [P] [X] [X] (14) COMP. SUBCODE [B] (15) VALVE SUBCODE [Z] (16)

9 10 11 12 13 18 19 20

(17) LER/RO REPORT NUMBER [8] [1] (21) (22) SEQUENTIAL REPORT NO: [0] [1] [4] (24) (26) OCCURRENCE CODE [0] [3] (28) (29) REPORT TYPE [L] (30) REVISION NO. [0] (32)

ACTION TAKEN [A] (18) FUTURE ACTION [Z] (19) EFFECT ON PLANT [Z] (20) SHUTDOWN METHOD [Z] (21) HOURS [0] [0] [0] [0] (22) (37) (40) ATTACHMENT SUBMITTED [N] (23) (41) NPRD-4 FORM SUB. [Y] (24) (42) PRIME COMP. SUPPLIER [A] (25) (43) COMPONENT MANUFACTURER [1] [0] [7] [5] (44) (47)

33 34 35 36 37 40 41 42 43 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

[1] [0] | Packing was about five years old. This failure is considered to be the natural end

[1] [1] | of life. The affected stuffing box was repacked and pump operability verified in

[1] [2] | accordance with Technical Specification 4.7.1.2.

[1] [3] |

[1] [4] |

[1] [5] | FACILITY STATUS [E] (28) % POWER [1] [0] [0] (29) OTHER STATUS [NA] (30) METHOD OF DISCOVERY [B] (31) DISCOVERY DESCRIPTION [Operator Observation] (32)

7 8 9 10 12 13 44 45 46 80

[1] [6] | ACTIVITY CONTENT [Z] (33) [Z] (34) AMOUNT OF ACTIVITY [NA] (35) LOCATION OF RELEASE [NA] (36)

7 8 9 10 11 44 45 80

[1] [7] | PERSONNEL EXPOSURES NUMBER [0] [0] [0] (37) TYPE [Z] (38) DESCRIPTION [NA] (39)

7 8 9 11 12 13 80

[1] [8] | PERSONNEL INJURIES NUMBER [0] [0] [0] (40) DESCRIPTION [NA] (41)

7 8 9 11 12 80

[1] [9] | LOSS OF OR DAMAGE TO FACILITY TYPE [N] (42) DESCRIPTION [NA] (43)

7 8 9 11 12 80

[2] [0] | PUBLICITY ISSUED DESCRIPTION [8104280660] (45)

7 8 9 10 80

PHONE 203-447-1791 Ext.507