

ENCLOSURE 1

Nebraska Public Power District
Cooper Nuclear Station
Docket No. 50-298

NOTICE OF VIOLATION

Based on the results of an NRC Inspection conducted during the period February 9 - March 6, 1981, and in accordance with the Interim Enforcement Policy, 45 FR 66754 (October 7, 1980), the following violation was identified.

Technical Specification 6.3.1 states that station personnel shall be provided detailed written procedures to be used for operation and maintenance of system components and systems that could have an effect on nuclear safety.

CNS Administrative Procedure 1.6, Revision 18, Section 1.6.2, which has been approved and implemented states, "Prior to signing the Clearance Order he [Shift Supervisor] will ensure it is correct."

Contrary to the above, on February 13, 1981, the Shift Supervisor signed and approved an incorrect Clearance Order No. 81-42 (A) to remove 1B Residual Heat Removal Service Water Booster Pump from service for motor maintenance. This order removed 1A Residual Heat Removal Service Water Booster Pump motor heater from service rather than the 1B motor heater. Furthermore, this Clearance Order was executed as originally written and approved.

This constitutes a Severity Level V Violation (Supplement I.E).

Pursuant to the provisions of 10 CFR 2.201, Nebraska Public Power District is hereby required to submit to this office within 25 days of the date of this Notice, a written statement or explanation in reply, including (1) the corrective steps which have been taken and the results achieved; (2) corrective steps which will be taken to avoid further violations; and (3) the date when full compliance will be achieved. Under the authority of Section 182 of the Atomic Energy Act of 1954, as amended, this response shall be submitted under oath or affirmation.

Date 3/12/81

G. L. Madsen
G. L. Madsen, Chief
Reactor Projects Branch

8104290 056