

PUBLIC SERVICE COMPANY OF COLORADO

P. O. BOX 840 · DENVER, COLORADO 80201

OSCAR R. LEE
VICE PRESIDENT

March 13, 1981
Fort St. Vrain
Unit No. 1
P-81096

To ADM/DMB:
PDR
LPDR
NSIC
ADM/TIDC
ALM, RSB



Mr. Karl V. Seyfrit
U. S. NRC
Region 14
Office of Inspection & Enforcement
611 Ryan Plaza Drive
Suite 1000
Arlington, Texas 76012

Subject: I&E Bulletin 81-01

Dear Mr. Seyfrit:

This letter is in response to the I&E Bulletin 81-01, which we offer the following:

The inspection and testing of all mechanical snubbers installed in safety related systems at Fort St. Vrain has been completed in accordance with the requirements set forth in I&E Bulletin 81-01. The procedure used to accomplish the inspection and testing is included as Attachment "A".

There are 33 mechanical snubbers installed in safety related systems at Fort St. Vrain. All were manufactured by International Nuclearsafeguards Corporation (INC). The total number and model of mechanical snubbers inspected is as follows:

1.	<u>MANUFACTURER</u>	<u>MODEL NUMBER</u>	<u>NUMBER INSTALLED</u>
	INC	MSVA-1AS	8
	INC	MSVA-1A	9
	INC	MSVA-3AS	2
	INC	MSVA-4AS	<u>14</u>
		TOTAL INSTALLED:	33

2. SPARE MECHANICAL SNUBBERS INSPECTED:

<u>MANUFACTURER</u>	<u>MODEL NUMBER</u>	<u>TOTAL NUMBER</u>
INC	MSVA-1A	25
INC	MSVA-1AS	<u>6</u>
	TOTAL SPARES:	31

8104290 658

Q

⚡

PUBLIC SERVICE COMPANY OF COLORADO

P. O. BOX 840 · DENVER, COLORADO 80201

OSCAR R. LEE
VICE PRESIDENT

Mr. Karl V. Seyfrit

Page 2

p-81096


A total of 36 mechanical snubbers were tested for operability. The model numbers and total number tested are as follows:

<u>MODEL NUMBER</u>	<u>TOTAL TESTED</u>
MSVA-1AS	1
MSVA-1A	1
MSVA-3AS	1
MSVA-4AS	2
MSVA-1AS & MSVA-1A (SPARES)	<u>31</u>
TOTAL TESTED:	36

There were no failures identified as a result of the testing program at Fort St. Vrain. We did not expect to find any inoperable mechanical snubbers in that all mechanical snubbers at Fort St. Vrain are accessible and are not subject to high humidity or corrosive atmospheres.

The requirements of I&E Bulletin 81-01 have been met by submittal of this letter. No further action concerning this matter is required by Public Service Company.

Sincerely,



O. R. Lee
Vice President

ORL/sk

cc: Director of Inspection & Enforcement
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555



PUBLIC SERVICE COMPANY OF COLORADO

P. O. BOX 840 · DENVER, COLORADO 80201

OSCAR R. LEE
VICE PRESIDENT

March 13, 1981
Fort St. Vrain
Unit No. 1
P-31096

Mr. Karl V. Seyfrit
U. S. NRC
Region 14
Office of Inspection & Enforcement
611 Ryan Plaza Drive
Suite 1000
Arlington, Texas 76012

Subject: I&E Bulletin 81-01

Dear Mr. Seyfrit:

This letter is in response to the I&E Bulletin 81-01, which we offer the following:

The inspection and testing of all mechanical snubbers installed in safety related systems at Fort St. Vrain has been completed in accordance with the requirements set forth in I&E Bulletin 81-01. The procedure used to accomplish the inspection and testing is included as Attachment "A".

There are 33 mechanical snubbers installed in safety related systems at Fort St. Vrain. All were manufactured by International Nuclearsafeguards Corporation (INC). The total number and model of mechanical snubbers inspected is as follows:

1.	<u>MANUFACTURER</u>	<u>MODEL NUMBER</u>	<u>NUMBER INSTALLED</u>
	INC	MSVA-1AS	8
	INC	MSVA-1A	9
	INC	MSVA-3AS	2
	INC	MSVA-4AS	<u>14</u>
		TOTAL INSTALLED:	33

2. SPARE MECHANICAL SNUBBERS INSPECTED:

<u>MANUFACTURER</u>	<u>MODEL NUMBER</u>	<u>TOTAL NUMBER</u>
INC	MSVA-1A	25
INC	MSVA-1AS	<u>6</u>
	TOTAL SPARES:	31



PUBLIC SERVICE COMPANY OF COLORADO

P. O. BOX 840 · DENVER, COLORADO 80201

OSCAR R. LEE
VICE PRESIDENT

Mr. Karl V. Seyfrit

Page 2

p-81096

A total of 36 mechanical snubbers were tested for operability. The model numbers and total number tested are as follows:

<u>MODEL NUMBER</u>	<u>TOTAL TESTED</u>
MSVA-1AS	1
MSVA-1A	1
MSVA-3AS	1
MSVA-4AS	2
MSVA-1AS & MSVA-1A (SPARES)	<u>31</u>
TOTAL TESTED:	36

There were no failures identified as a result of the testing program at Fort St. Vrain. We did not expect to find any inoperable mechanical snubbers in that all mechanical snubbers at Fort St. Vrain are accessible and are not subject to high humidity or corrosive atmospheres.

The requirements of I&E Bulletin 81-01 have been met by submittal of this letter. No further action concerning this matter is required by Public Service Company.

Sincerely,

O. R. Lee
Vice President

ORL/sk

cc: Director of Inspection & Enforcement
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

STATE OF COLORADO)
)
CITY AND COUNTY OF DENVER) ss.

O. R. Lee, being first duly sworn, deposes and says;
That he is Vice President of Production of Public Service
Company of Colorado, the Licensee herein; that he has read the
foregoing Application for Amendment to Appendix A of Facility
Operating License and knows the contents thereof, and that the
statements and matters set forth therein are true and correct
to the best of his knowledge, information and belief.




O. R. Lee

Subscribed and sworn to before me this 18th day of March, 1981

Witness my hand and official seal.

My commission expires, October 7, 1983.



Notary Public