

UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

PORTLAND GENERAL ELECTRIC COMPANY

THE CITY OF EUGENE, OREGON

PACIFIC POWER AND LIGHT COMPANY

DOCKET NO. 50-344

TROJAN NUCLEAR PLANT

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 59  
License No. NPF-1

1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by Portland General Electric Company, the City of Eugene, Oregon, and Pacific Power and Light Company (the licensee) dated March 16, 1981, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

8104290723


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. NPF-1 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 59, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications, except as noted in paragraphs 2.C.(10) through 2.C.(12) below.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

  
Robert A. Clark, Chief  
Operating Reactors Branch #3  
Division of Licensing

Attachment:  
Changes to the Technical  
Specifications

Date of Issuance: April 16, 1981

ATTACHMENT TO LICENSE AMENDMENT

AMENDMENT NO. 59 TO FACILITY OPERATING LICENSE NO. NPF-1

DOCKET NO. 50-344

Revise Appendix A as follows:

Remove Pages

3/4 6-5

Insert Pages

3/4 6-5

## CONTAINMENT SYSTEMS

### CONTAINMENT AIR LOCKS

#### LIMITING CONDITION FOR OPERATION

---

3.6.1.3 Each containment air lock shall be OPERABLE with:

- a. Both doors closed except when the air lock is being used for normal transit entry and exit through the containment, then at least one air lock door shall be closed, and
- b. An overall air lock leakage rate of  $\leq 0.05 L_a$  at  $P_a$ , (60 psig).

APPLICABILITY: MODES 1, 2, 3 and 4.

#### ACTION:

With an air lock inoperable, restore the air lock to OPERABLE status within 24 hours or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

#### SURVEILLANCE REQUIREMENTS

---

4.6.1.3 Each containment air lock shall be demonstrated OPERABLE:\*

- a. At least once within 3 days after opening by verifying the seal leakage is  $< 0.01 L_a$  as determined by precision flow measurement when measured for at least 30 seconds with the volume between the seals at a constant pressure of 10.0 psig.
- b. At least once per 6 months by conducting an overall air lock leakage test at  $P_a$  (60 psig) and by verifying that the overall air lock leakage rate is within its limit, and
- c. At least once per 6 months by verifying that only one door in each air lock can be opened at a time.

\* Air locks opened during periods when containment integrity is not required shall be tested at the end of such periods at not less than  $P_a$  (60 psig) (10 CFR 50, App. J, Section III.D.2.(b)(ii)).