

DERA



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

April 22, 1981

Docket No. 50-29  
LS05-81-04-029



Mr. James A. Kay  
Senior Engineering-Licensing  
Yankee Atomic Electric Company  
1671 Worcester Road  
Framingham, Massachusetts 01701

Dear Mr. Kay:

The Commission has issued the enclosed Amendment No. 67 to Facility Operating License No. DPR-3 for Yankee Nuclear Power Station (Yankee Rowe). The amendment consists of changes to the Technical Specifications in response to your application dated April 13, 1981.

The amendment modifies Technical Specification Figure 3.2.1 "Core XIV Allowable Peak Rod LHGR versus Cycle Burnup" by extending the end of cycle burnup to 16,300 MWD/MTU.

Copies of the Safety Evaluation and Notice of Issuance are also enclosed.

Sincerely,

*Dennis M. Crutchfield*  
Dennis M. Crutchfield, Chief  
Operating Reactors Branch #5  
Division of Licensing

Enclosures:

- 1. Amendment No. 67 to License No. DPR-3
- 2. Safety Evaluation
- 3. Notice of Issuance

cc w/enclosures:  
See next page

8104800 560

Mr. James A. Kay

- 2 -

April 22, 1981

cc

Mr. James E. Tribble, President  
Yankee Atomic Electric Company  
25 Research Drive  
Westborough, Massachusetts 01581

Greenfield Community College  
1 College Drive  
Greenfield, Massachusetts 01301

Chairman  
Board of Selectmen  
Town of Rowe  
Rowe, Massachusetts 01367

Energy Facilities Siting Council  
14th Floor  
One Ashburton Place  
Boston, Massachusetts 02108

Director, Criteria and Standards  
Division  
Office of Radiation Programs  
(ANR-460)  
U. S. Environmental Protection  
Agency  
Washington, D. C. 20460

U. S. Environmental Protection  
Agency  
Region I Office  
ATTN: EIS COORDINATOR  
JFK Federal Building  
Boston, Massachusetts 02203

Resident Inspector  
Yankee Rowe Nuclear Power Station  
c/o U.S. NRC  
Post Office Box 28  
Monroe Bridge, Massachusetts 01350