

TIC



UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION III
799 ROCSEVELT ROAD
GLEN ELLYN, ILLINOIS 60137

April 23, 1981

Docket No. 50-10
Docket No. 50-237
Docket No. 50-249

Commonwealth Edison Company
ATTN: Mr. Cordell Reed
Vice President
Post Office Box 767
Chicago, Illinois 60690



Gentlemen:

Attached is an addendum consisting of a Confirmatory Measurements Program data sheet for Report Nos. 50-10/80-21; 50-237/80-23; 50-249/80-27 transmitted by our letter dated November 25, 1980. The results are for those analyses which were not able to be compared during the inspection or which had to be performed by our Reference Laboratory.

Please attach the addendum to your copy of our inspection report.

We will gladly discuss any questions you have regarding this addendum.

Sincerely,

J. A. Hind
J. A. Hind, Acting Director
Division of Emergency Preparedness
and Operational Support

Attachment:
as stated

cc w/encl:
Mr. J. S. Abel, Director
of Nuclear Licensing
Mr. D. J. Scott,
Station Superintendent
Central Files
Reproduction Unit NRC 20b
AEOD
Resident Inspector, RIII
PDR
Local PDR
NSIC
TIC
Mary Jo Murray, Office of
Assistant Attorney General

TABLE II

U S NUCLEAR REGULATORY COMMISSION
 OFFICE OF INSPECTION AND ENFORCEMENT
 CONFIRMATORY MEASUREMENTS PROGRAM
 FACILITY: DRESDEN
 FOR THE 4 QUARTER OF 1980

SAMPLE	ISOTOPE	-----NRC-----		---LICENSEE---		---NRC:LICENSEE---		
		RESULT	ERROR	RESULT	ERROR	RATIO	RES	T
L WASTE	RETA	2.1E-05	9.0E-07	1.5E-05	1.0E-06	7.1E-01	2.3E+01	P
	H 3	6.0E-03	2.0E-05	6.5E-03	7.0E-04	1.1E+00	3.0E+02	A
	SR 90	0.0	2.0E-08	3.1E-08	1.2E-08	0.0	0.0	N

T TEST RESULTS:

A=AGREEMENT

D=DISAGREEMENT

P=POSSIBLE AGREEMENT

N=NO COMPARISON