TIC

UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION III
799 ROOSEVELT ROAD
GLEN ELLYN, ILLINOIS 60137

APR 23 1981

Docket No. 50-358

Cincinnati Gas and Electric
Company
ATTN: Mr. Earl A. Borgmann
Vice President
Engineering Services
and Electric Production
139 East 4th Street
Cincinnati, OH 45201

Gentlemen:

This letter confirms the phone conversation of April 16, 1981 between Mr. W. W. Schweirs and Mr. W. D. Waymire of your staff and Mr. R. F. Warnick, Mr. K. D. Ward, and Mr. P. A. Barrett of this office. During the conversation, this office's interpretation of two nondestructive examination (NDE) concerns relating to the April 8, 1981 Immediate Action Letter, was stated as follows:

(1) CG&E is required to perform an additional review, after April 8, 1981, of all QC procedures which include NDE procedures. This additional review will be performed by qualified/certified personnel from an organization other than the organization responsible for the activities covered by the procedures.

(2) CG&E or CG&E's NDE contractor is required to provide only one qualified/certified individual to verify the set-up and performance of radiography. This may be the same individual who performs the radiography. CG&E is required to provide a second independent interpretation of all radiographs made during the effective period of the applicable IAL requirement.

8105040590

APR 23 1981

If you have any questions regarding these matters, please feel free to call me.

Sincerely,

A Bert Davis

for James G. Keppler
Director

cc: J. R. Schott, Plant Superintendent
Central Files
Reproduction Unit NRC 20b
AEOD
Resident Inspector, RIII
PDR
Local PDR
NSIC
TIC
Harold W. Kohn, Power Siting Commission
Citizens Against a Radioactive Environment
Helen W. Evans, State of Ohio