

### LICENSEE EVENT REPORT

CONTROL BLOCK: \_\_\_\_\_ ①

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

⑦ ⑧ ⑨ N J O C P 1 ⑫ 0 0 - 0 0 0 0 0 - 0 0 ⑬ 4 1 1 1 1 ⑭ \_\_\_\_\_ ⑮

LICENSEE CODE 14 LICENSE NUMBER 25 LICENSE TYPE 30 CAT 58

CON'T  
⑦ ⑧ L ⑫ 0 5 0 0 0 2 1 9 ⑬ 0 3 2 8 8 1 ⑭ 0 4 2 7 8 1 ⑮

REPORT SOURCE 60 DOCKET NUMBER 68 EVENT DATE 74 REPORT DATE 80

#### EVENT DESCRIPTION AND PROBABLE CONSEQUENCES ⑩

⑦ ⑧ 0 2 On March 28, the plant was progressing towards cold shutdown to correct an  
⑦ ⑧ 0 3 increasing leak rate in the primary containment. During the normal shut-  
⑦ ⑧ 0 4 down sequence, the IRM calibration was not performed as required by Tech  
⑦ ⑧ 0 5 Spec 4.1, Table 4.1.1. The event is a Reportable Occurrence as defined by  
⑦ ⑧ 0 6 Tech Spec 6.9.2.b.3.

⑦ ⑧ ⑨ I A ⑫ D ⑬ Z Z Z Z Z Z ⑭ Z ⑮ Z ⑯ Z ⑰

SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP. SUBCODE VALVE SUBCODE

⑰ LER NO. ⑱ EVENT YEAR ⑲ SEQUENTIAL REPORT NO. ⑳ OCCURRENCE CODE ㉑ REPORT TYPE ㉒ REVISION NO.

⑳ ACTION TAKEN ㉑ FUTURE ACTION ㉒ EFFECT ON PLANT ㉓ SHUTDOWN METHOD ㉔ HOURS ㉕ ATTACHMENT SUBMITTED ㉖ NPRO-4 FORM SUB. ㉗ PRIME COMP. SUPPLIER ㉘ COMPONENT MANUFACTURER

#### CAUSE DESCRIPTION AND CORRECTIVE ACTIONS ⑳

⑦ ⑧ 1 0 Apparent cause is procedural inadequacy. The procedure did not specify  
⑦ ⑧ 1 1 the power level at which to perform the calibration. Both the IRM Calib-  
⑦ ⑧ 1 2 ration procedure and the Plant Cooldown from Hot Standby to Cold Shut-  
⑦ ⑧ 1 3 down will be revised.

⑦ ⑧ ⑨ D ⑫ 0 1 0 ⑬ NA ⑭ A ⑮ Engineer Observation

FACILITY STATUS 28 % POWER 29 OTHER STATUS 30 METHOD OF DISCOVERY 31 DISCOVERY DESCRIPTION 32

⑦ ⑧ ⑨ Z ⑫ Z ⑬ NA ⑭ NA ⑮ NA

ACTIVITY CONTENT 33 RELEASED OF RELEASE 34 AMOUNT OF ACTIVITY 35 LOCATION OF RELEASE 36

⑦ ⑧ ⑨ 0 0 0 ⑫ Z ⑬ NA

PERSONNEL EXPOSURES NUMBER 37 TYPE 38 DESCRIPTION 39

⑦ ⑧ ⑨ 0 0 0 ⑫ \_\_\_\_\_ ⑬ NA

PERSONNEL INJURIES NUMBER 40 DESCRIPTION 41

⑦ ⑧ ⑨ Z ⑫ \_\_\_\_\_ ⑬ NA

LOSS OF OR DAMAGE TO FACILITY TYPE 42 DESCRIPTION 43

⑦ ⑧ ⑨ Y ⑫ \_\_\_\_\_ ⑬ Weekly News Release

PUBLICITY ISSUED DESCRIPTION 45

⑦ ⑧ ⑨ 810505 ⑫ S11 ⑬ Jon Sklar ⑭ \_\_\_\_\_ ⑮ 609-693-6013

NAME OF PREPARER 58 59 NRC USE ONLY 80 81 PHONE