



OYSTER CREEK



NUCLEAR GENERATING STATION



Jersey Central Power & Light
Company is a Member of the
General Public Utilities System

(609) 693-6000 P.O. BOX 388 • FORKED RIVER • NEW JERSEY • 08731

April 30, 1981



Mr. Darrell G. Eisenhut, Director
Division of Licensing
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

Dear Mr. Eisenhut:

With reference to your letter of March 13, 1981 concerning the "BWR Scram Discharge System - Long Term Modifications." Each scram discharge instrument volume will be monitored by redundant and diverse instrumentation which initiates a reactor scram on one out of two twice logic. Diverse level instrumentation will be provided in accordance with Safety Criteria 3 as stipulated in your letter of December 1, 1980. If additional information is required, please contact Mr. J. Knubel at (201) 299-2264.

Very truly yours,

Ivan R. Finrock, Jr.
Ivan R. Finrock, Jr.
Vice President-JCP&L
Director-Oyster Creek

ij

8105050594

P