Georgia Power Company 333 Predmont Avenue Atlanta. Georgia 30308 Telephone 404 526-6526

Mailing Address Post Office Box 4545 Atlanta, Georgia 30302

W. E. Ehrensperger Senior Vice President & Group Executive-Power Supply



File: X7BG03-M18

GN-129

Log:

April 29, 1981

United States Nuclear Regulatory Commission Office of Inspection and Enforcement Region II - Suite 3100 101 Marietta Street Atlanta, Georgia 30303

Attention: Mr. James P. O'Rielly

Reference: Vogtle Electric Generating Plant-Units 1 and 2

50-424 and 50-425; Containment Liner Penetrations

Gentlemen:

Georgia Power Company verbally notified Mr. Paul Kellogg of the Nuclear Regulatory Commission on March 26, 1981, of a potentially significant deficiency concerning welds on containment liner penetrations.

Georgia Power Company has conducted weld inspections of the penetrations in question and has begun an engineering evaluation to determine the significance of this problem. Additionally, Georgia Power Company is reviewing the need to conduct a quality assurance audit at the vendor manufacturing facility. It is expected these evaluations will be concluded in June, 1°51. Georgia Power Company expects to submit a final report to the Commission concerning the reportability of this potential deficiency on or before July 17, 1931.

This response contains no proprietary information and may be placed in the NRC Public Document Room upon receipt.

Yours truly,

W. E. Ehrensperger

Senior Vice President & Group Executive-

Power Supply

CWH:skf

xc: See Page 2

5

B019 S1/0 Mr. James P. O'Rielly 50-424; 50-425; Containment Liner Penetrations April 2, 1981 Page 2

xc: V. S. Nuclear Regulatory Commission Attn: Victor J. Stello, Jr., Director Office of Inspection and Enforcement Washington, DC 20555

> J. H. Miller, Jr. F. G. Mitchell, Jr.

R. J. Kelly

C. F. Whitmer R. E. Conway

D. E. Dutton

R. W. Staffa

H. C. Nix

K. M. Gillespie

L. T. Gucwa

C. R. Miles, Jr.

E. D. Groover

D. L. McCrary

R. A. Thomas

O. Batum

J. A. Bailey

M. Z. Jeric

B. L. Lex