

THE CINCINNATI GAS & ELECTRIC COMPANY



E. A. BORGMANN
SENIOR VICE PRESIDENT

March 3, 1981
QA-1404

U. S. Nuclear Regulatory Commission
Region III
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Attention: Mr. James G. Keppler,
Director

RE: WM. H. ZIMMER NUCLEAR POWER STATION - UNIT I
NRC INSPECTION REPORT NO. 81-01 - DOCKET NO.
50-358, CONSTRUCTION PERMIT CPPR-88, W.O. #
57300-957, JOB E-5590

Gentlemen:

This letter constitutes our response to the subject inspection report. It is our opinion that nothing in the report or in this letter is of a proprietary nature.

Our response to the item of noncompliance cited in Appendix "A" of the report is as follows:

1. Corrective Action Taken and Results Achieved

Both the Test Coordinator and Station Superintendent have discussed the necessity for adherence to written administrative and test procedures with the NSSS Test Coordinator and the General Electric Site Operations Engineer with positive action being taken on his part to ensure compliance.

Additionally, a draft revision of SU.ACP.05, "Conduct of Preoperational Tests", is being written to more clearly state the rules for conducting preoperational tests.

Among the items to be clarified are:

- a. Use of Test Change Notices, Exceptions, Nonconformance Reports, major changes, and the chronological log and when each is applicable, and
- b. The requirements for recording instrument numbers and calibration dates on measuring and test equipment and

Mr. James G. Keppler, Director
U. S. Nuclear Regulatory Commission
Region III
March 3, 1981 - QA-1404
Page 2

other test equipment used to verify acceptance criteria.

2. Corrective Action to be Taken to Avoid Further Noncompliance

Upon final approval of this revision to SU.ACP.05, an indoctrination session will be conducted by the Test Coordinator for all System Test Coordinators, System Engineers, CG&E Staff Engineers, and other staff personnel involved in the preoperational test program.

3. Date When Full Compliance Will Be Achieved


The revision of SU.ACP.05 will be approved and preoperational test program personnel will have received the reindoctrination session by April 3, 1981.

We trust that the above will constitute an acceptable response to the subject inspection report.

Very truly yours,

THE CINCINNATI GAS & ELECTRIC COMPANY


By


E. A. BORGMANN
SENIOR VICE PRESIDENT

JFW:pa
cc: NRC Resident Inspector
Attn: F. T. Daniels

State of Ohio) ss
County of Hamilton)

Sworn to and subscribed before me this 5th day of March, 1981.


Notary Public
VIRGINIA P. MUEHEISEN
Notary Public, State of Ohio
My Commission Expires July 28, 1982