NRC FORM 366 (7-77)

U.S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

EXHIBIT A

CONTROL BLOCK: | | | | | | | (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | C A R S S 1 (2) | 0 0 - 0 0 0 0 0 - 0 0 (3) | 4 1 1 1 1 (4) | | (5)
LICENSEE CODE — LICENSE NUMBER — LICENSE TYPE — CAT

CON'T 01 | REPORT SOURCE L (6) | 0 5 0 0 0 3 1 2 (7) | 0 4 1 9 8 1 (8) | 0 5 1 8 8 1 (9)
DOCKET NUMBER — EVENT DATE — REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 On April 19, 1981, while performing routine valve testing, approximately
03 4000 gallons of Reactor Coolant was inadvertantly transfered from the RCS
04 to the Reactor Building Emergency Sump. This resulted in a slight
05 transient, the RCS pressure dropped from 224 psig to 90 psig. This
06 resulted in the RCS having to be refilled and revented. There was no
07 unmonitored release associated with this event and this did not adversely
08 affect the health and safety of the general public.

	SYSTEM CODE	CAUSE CODE	CAUSE SUBCODE	COMPONENT CODE	COMP. SUBCODE	VALVE SUBCODE
09	C F (11)	A (12)	A (13)	Z Z Z Z Z Z (14)	Z (15)	Z (16)

(17) LER/RO REPORT NUMBER	EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE	REPORT TYPE		REVISION NO.
	8 1	—	0 2 4	/	0 3	T	—	0

ACTION TAKEN	FUTURE ACTION	EFFECT ON PLANT	SHUTDOWN METHOD	HOURS (22)	ATTACHMENT SUBMITTED	NPRD-4 FORM SUB.	PRIME COMP. SUPPLIER	COMPONENT MANUFACTURER
H (18)	Z (19)	Z (20)	Z (21)	0 0 0 0	Y (23)	N (24)	Z (25)	Z 9 9 9 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 Either a breakdown in communications or a lack of complete communications.
11 A valve was opened before the proper isolation valve was completely closed.
12 The review of this occurrence by all operating personnel, as requested in
13 a memo from the Plant Superintendent, is considered adequate corrective
14 action to preclude a similar occurrence.

	FACILITY STATUS	% POWER	OTHER STATUS (30)	METHOD OF DISCOVERY	DISCOVERY DESCRIPTION (32)
15	H (28)	0 0 0 (29)	N/A	B (31)	Routine Testing

	ACTIVITY RELEASED	CONTENT OF RELEASE	AMOUNT OF ACTIVITY (35)	LOCATION OF RELEASE (36)
16	Z (33)	Z (34)	N/A	N/A

PERSONNEL EXPOSURES

	NUMBER	TYPE	DESCRIPTION (39)
17	0 0 0 (37)	Z (38)	N/A

PERSONNEL INJURIES

	NUMBER	DESCRIPTION (41)
18	0 0 0 (40)	N/A

LOSS OF OR DAMAGE TO FACILITY (43)

	TYPE	DESCRIPTION
19	Z (42)	N/A

PUBLICITY

	ISSUED	DESCRIPTION (45)	NRC USE ONLY
20	Y (44)	Local newspapers and wire services	

NAME OF PREPARER R. W. Colombo PHONE (916) 452-3211

8105270353