

LICENSEE EVENT REPORT

- 1) Control Block: | | | | | | | | 2) Licensee Code: |N|Y|R|E|G|1|
 3) License Number: |0|0|-|0|0|0|0|0|-|0|0|
 4) License Type: |4|1|1|1|1|1| 5) Cat: | | | 6) Report Source: |L|
 7) Docket Number: |0|5|0|0|0|2|4|4|
 8) Event Date: |0|4|2|0|8|1| 9) Report Date: |0|5|1|9|8|1|
 10) Event Description and Probable Consequences:

|During routine operation for achieving shutdown conditions |
 |for a refueling outage, a leaking relief valve was found on |
 |the letdown system. The relief valve had been actuated due |
 |to plugging of the CVCS letdown demineralizer. The bellows |
 |on relief valve RV 209 had failed causing RCS fluid to puddle |
 |on the auxiliary building floor. Tech Spec 6.9.2.b.4 |

- 11) System Code: |P|C| 12) Cause Code: |E| 13) Cause Subcode: |B|
 14) Comp. Code: |V|A|L|V|E|X| 15) Subcode: |H| 16) Valve Code: |B|
 17) LER/RO Report Number: |8|1|1|-|0|1|1|0|1|/|0|3|L|-|0|
 18) Action Taken: |D| 19) Future Action: |Z| 20) Effect on Plant: |Z|
 21) Shutdown Method: |Z| 22) Hours: |0|0|0|0|
 23) Attachment Submitted: |N| 24) NPRD-4 Form Submitted: |N|
 25) Prime Component Supplier: |N| 26) Manufacturer: |C|7|1|0|
 27) Cause Description and Corrective Actions:

|The Crosby relief valve, 2H3 JB-2S E 200 psi, normally |
 |discharges to the volume control tank. During shutdown, the |
 |relief valve was periodically actuated due to crud buildup |
 |causing an increase in differential pressure across the |
 |demineralizers. The bellows cracked on the relief valve |
 |allowing relieved fluid to discharge in the area. The valve |
 |was repaired and reinstalled into the system. |

- 28) Facility Status: |D| 29) % Lower: |0|0|0|
 30) Other Status: |N/A|
 31) Method of Discovery: |A|
 32) Discovery Description: |Contaminated spill|
 33) Activity Released: |Z| 34) Content of Release: |Z|
 35) Amount of Activity: |N/A|
 36) Location of Release: |N/A|
 37) Personnel Exposures Number: |0|0|0| 38) Exposures Type: |Z|
 39) Description: |N/A|
 40) Personnel Injuries Number: |0|0|0|
 41) Description: |N/A|
 42) Loss of or Damage to Facility: |0|
 43) Description: |N/A|
 44) Publicity Issued: |N|
 45) Description: |N/A|

NRC USE ONLY | | | | | | | | | | | | | |

Name of Preparer: S.M. Spector Phone: 315-524-4446 x214