

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | I | L | Z | I | S | L | 0 0 | - | 0 | 0 | 0 | 0 | 0 | - | 0 | 0 | 4 | 1 | 1 | 1 | 1 | _____
7 8 9 14 15 25 26 37 58

CON'T
0 1 | REPORT SOURCE | L | 0 5 | 0 0 | 0 2 | 9 | 5 | 7 | 0 4 | 1 | 7 | 8 | 1 | 3 | 0 5 | 1 | 5 | 8 | 1 | 9
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | While performing shiftly surveillance of the heat trace system, a heat-
0 3 | er failure alarm was noted on circuit #61012 at OLP43. This placed the
0 4 | boron injection tank in a degraded mode per T.S. 3.8.1.E. The redun-
0 5 | dant circuit (#61012 at OLP44) was switched on and verified operable.
0 6 | The health and safety of the public were not affected. Previous report
0 7 | 50-295/76-14.

0 8 | _____ 80

0 9 | SYSTEM CODE | CAUSE CODE | CAUSE SUBCODE | COMPONENT CODE | COMP. SUBCODE | VALVE SUBCODE
P | C | E | F | C | K | T | B | R | K | A | Z
9 10 11 12 13 14 15 16 17 18 19 20

17 | LER/RO REPORT NUMBER | EVENT YEAR | SEQUENTIAL REPORT NO. | OCCURRENCE CODE | REPORT TYPE | REVISION NO.
8 | 1 | 0 1 | 7 | 0 3 | L | 0
21 22 23 24 25 26 27 28 29 30 31

ACTION TAKEN | FUTURE ACTION | EFFECT ON PLANT | SHUTDOWN METHOD | HOURS | ATTACHMENT SUBMITTED | NPD-4 FORM SUB. | PRIME COMP. SUPPLIER | COMPONENT MANUFACTURER
A | Z | Z | 0 0 0 0 | N | Y | A | W 1 2 0
32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | This event was caused by the Westinghouse circuit breaker, Model No. KL
1 1 | 949 failing to remain in the closed position. The failure of the break-
1 2 | er was due to the normal frequency of operations. The faulty breaker
1 3 | was replaced. Since the only similar occurrence was 5 yrs ago, there
1 4 | are no indications of a trend. No further action is deemed necessary.

1 5 | FACILITY STATUS | % POWER | OTHER STATUS | METHOD OF DISCOVERY | DISCOVERY DESCRIPTION
C | 0 0 0 0 | NA | B | Operator Observation
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30

1 6 | ACTIVITY CONTENT | AMOUNT OF ACTIVITY | LOCATION OF RELEASE
Z | Z | NA | NA
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30

1 7 | PERSONNEL EXPOSURES | TYPE | DESCRIPTION
0 0 0 | Z | NA
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30

1 8 | PERSONNEL INJURIES | DESCRIPTION
0 0 0 | NA
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30

1 9 | LOSS OF OR DAMAGE TO FACILITY | DESCRIPTION
Z | NA
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30

2 0 | PUBLICITY ISSUED | DESCRIPTION
N | NA
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30

NAME OF PREPARER Steve Hazelrigg

PHONE 312-746-2084 Ext 347

8105280227

8105280227