NRC FORM 366 (7-77)

U.S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

Line	Field	Entry
01	Licensee Code (2)	I L Z I S 2
	License Number (3)	0 0 - 0 0 0 0 0 - 0 0
	License Type (4)	1 1 1 1
	CAT (5)	
CON'T 01	Report Source (6)	L
	Docket Number (7)	0 5 0 0 0 3 0 4
	Event Date (8)	0 3 1 3 8 0
	Report Date (9)	0 5 1 9 8 1

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 During normal surveillance for calibration the Class I pipe tunnel rad
03 monitor 2RT-PR07B was found to be out of tolerance low by about 2½ dec-
04 ades. Had there been any significant amounts of iodine released thru
05 this monitor, it would have been detected by other rad monitors too.
06 Thus there were no safety implications and the health and safety of the
07 general public were not affected.
08

System Code (11)	Cause Code (12)	Cause Subcode (13)	Component Code (14)	Comp. Subcode (15)	Valve Subcode (16)
B B	X	Z	I N S T R U	P	Z

(17) LER/RO REPORT NUMBER

Event Year		Sequential Report No.		Occurrence Code	Report Type		Revision No.
8 1	—	0 0 6	/	0 3	L	—	0

Action Taken (18)	Future Action (19)	Effect on Plant (20)	Shutdown Method (21)	Hours (22)	Attachment Submitted (23)	NPRD-4 Form Sub. (24)	Prime Comp. Supplier (25)	Component Manufacturer (26)
E	Z	Z	Z	0 0 0 0	N	N	A	N 3 0 5

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 The monitor failure occurred due to drift of the high voltage power sup-
11 ply. The power supply was adjusted and the monitor recalibrated. Drift
12 of these power supplies has not been a recurring problem. No further
13 action is deemed necessary.
14

Facility Status (28)	% Power (29)	Other Status (30)	Method of Discovery (31)	Discovery Description (32)
E	0 9 8	NA	B	Instrument Calibration

Activity Released (33)	Content of Release (34)	Amount of Activity (35)	Location of Release (36)
Z	Z	NA	NA

PERSONNEL EXPOSURES

Number (37)	Type (38)	Description (39)
0 0 0	Z	NA

PERSONNEL INJURIES

Number (40)	Description (41)
0 0 0	NA

LOSS OF OR DAMAGE TO FACILITY (43)

Type (42)	Description
Z	NA

PUBLICITY

Issued (44)	Description (45)	NRC USE ONLY
N	NA	

8105280233

NAME OF PREPARER Fred Ost PHONE: 312-746-2084 X558