



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

TERA

May 22, 1981

Docket No. 50-368



Mr. William Cavanaugh, III
Senior Vice President
Energy Supply Department
Arkansas Power & Light Company
P. O. Box 551
Little Rock, Arkansas 72203

SUBJECT: ENVIRONMENTAL QUALIFICATION OF SAFETY-RELATED ELECTRICAL EQUIPMENT

RE: ARKANSAS NUCLEAR ONE-UNIT 2, LICENSE NO. NPF-6

Reference (a) - Order for Modification of License Concerning the Environmental Qualification of Safety-Related Electrical Equipment dated October 24, 1980.

Dear Mr. Cavanaugh:

This letter transmits the Safety Evaluation for the Environmental Qualification of Safety-Related Electrical Equipment at your facility. This evaluation was based on your submittals dated February 22, April 14, June 23, October 4 and October 31, 1980. Our letter of February 25, 1981, which forwarded our preliminary results, indicated that an item-by-item re-evaluation would be required at a later date. This safety evaluation identifies the specific information required by the staff and the actions, on your part, necessary to comply with Reference (a). We request that you provide the information identified in sections 3 and 4 of this Safety Evaluation to us within 90 days of receipt of this letter.

This safety evaluation addresses only the safety-related electrical equipment exposed to a harsh environment resulting from an accident (i.e., the IEB 79-01B review). Reference (a) requires that all safety-related electrical equipment be qualified by June 30, 1982. The NRC review effort for the equipment in mild environments will be addressed by separate correspondence.

Your response may present alternatives to the staff positions in the evaluation. The staff will consider alternative approaches if these methods are within the DOR Guidelines or NUREG-0588, as appropriate. For example, an acceptable alternative to the NRC staff's temperature criterion used for the service conditions (i.e. Section 3.3) must base that service condition on the FSAR analysis or other NRC approved analysis, provided that the specific analysis, together with reference to the previous NRC acceptance of that analysis, accompanies the 90 day response. In addition, some of the information in the Safety Evaluation may require clarification. Contact your project manager for assistance in these matters.

8105290442

It remains your responsibility to assure that the qualification deadline is met for all safety-related electrical equipment. The staff's review of your response to this letter should not delay any action which is required in order to meet the deadline.

Sincerely,



Robert A. Clark, Chief
Operating Reactors Branch #3
Division of Licensing

Enclosures:

1. SER
2. TER

cc w/enclosures:
See next page

Arkansas Power & Light Company

cc:

Mr. David C. Trimble
Manager, Licensing
Arkansas Power & Light Company
P. O. Box 551
Little Rock, Arkansas 72203

Mr. James P. O'Hanlon
General Manager
Arkansas Nuclear One
P. O. Box 608
Russellville, Arkansas 72801

Mr. Robert B. Borsum
Babcock & Wilcox
Nuclear Power Generation Division
Suite 420
7735 Old Georgetown Road
Bethesda, Maryland 20014

Nick Reynolds
c/o DeBevoise & Liberman
1200 Seventeenth Street, N.W.
Washington, D. C. 20036

Arkansas Polytechnic College
Russellville, Arkansas 72801

Honorable Ermil Grant
Acting County Judge of Pope County
Pope County Courthouse
Russellville, Arkansas 72801

Mr. Charles B. Brinkman
Manager - Washington Nuclear
Operations
C-E Power Systems
4853 Cordell Avenue, Suite A-1
Bethesda, Maryland 20014

Director Criteria and Standards Division
Office of Radiation Programs (ANR-460)
U.S. Environmental Protection Agency
Washington, D. C. 20460

U.S. Environmental Protection Agency
Region VI Office
ATTN: EIS COORDINATOR
1201 Elm Street
First International Building
Dallas, Texas 75270

Director, Bureau of Environmental
Health Services
4815 West Markham Street
Little Rock, Arkansas 72201