



CHARLES CENTER - P. O. BOX 1475 - BALTIMORE, MARYLAND 21203

May 28, 1981

ARTHUR E. LUNDVALL, JR.  
VICE PRESIDENT  
SUPPLY

Mr. Harold R. Denton, Director  
Office of Nuclear Reactor Regulation  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Subject: Calvert Cliffs Nuclear Power Plant  
Units Nos. 1 & 2, Dockets Nos. 50-317 & 50-318  
Auxiliary Feedwater System (AFW)  
Supplement to Request for Amendment

References: (a) NRC letter dated 5/8/81 from R. A. Clark to  
A. E. Lundvall, Jr.  
(b) BG&E letters dated 1/22/80 and 11/10/80 from  
A. E. Lundvall, Jr. to H. R. Denton, Request  
for Amendments.

Dear Mr. Denton:

Reference (a) forwarded Amendments 54 and 37 for Units 1 and 2, respectively, with an implementation date of 6/1/81. As discussed with your staff on 5/28/81 we will be unable to meet that date and hereby request an extension of the implementation date to June 15, 1981. The reason for this request is that additional analysis time is needed to determine the proper position of the AFW throttle valves.

The Tech Specs forwarded by reference (a) requires automatic initiation of AFW flow. The AFW throttle valves are required to be set to a specific position. That position is presently being determined by an analysis that we expect to be completed in time for a 15 June 1981 implementation date.

This request has been determined to constitute a supplement to previous amendment requests, References (b), and pursuant to 10 CFR Part 170, no additional fee is required.

Sincerely,

cc: J. A. Biddison, Esquire  
G. F. Trowbridge, Esquire  
Messrs. E. L. Conner, Jr. - NRC  
R. E. Architzel - NRC

Apri 5/10

8106010412

P