



Portland General Electric Company

Bart D. Withers Vice President

May 26, 1981

Mr. W. H. ...
Regional ...
Federal Emergency Management Agency
Region X
Federal Regional Center
Bothell, WA 98011

Dear Mr. Mayer:

In response to your letter of March 23, 1981, attached are PGE's commitments to complete your proposed corrective actions on the 1981 Trojan Nuclear Plant Radiological Emergency Plan Exercise. The commitments and dates listed in the attachment are consistent with those given in your March 23 letter, with the exception of the comment on the need to improve the arrangements for the State of Washington liaison and Federal agencies at the near-site EOF. Since the NRC has not responded regarding the acceptability of the current Trojan near-site EOF, the proposed commitment date of June 30, 1981 will not be met for facility and equipment changes. Some procedural changes can be made, however. When this issue is resolved with NRC, you will be notified of the schedule for full implementation.

You will be notified if any other changes in the commitment list or schedule become necessary.

Sincerely,

Bart D. Withers
Vice President
Nuclear

Attachment

c: Mr. Lynn Frank, Director
State of Oregon
Department of Energy

Mr. Ben Bena
Cowlitz County
Emergency Services Coordinator

Mr. Jim Thomas
State of Washington
Department of Emergency Services

Mr. Robert A. Clark, Chief
Operating Reactor Branch No. 3
Division of Licensing
U. S. Nuclear Regulatory Commission

Mr. John DeFrance
Columbia County
Director of Emergency Services

Handwritten: A045 S/11

8106010520

Handwritten: F

Mr. W. H. Mayer
Regional Director
May 26, 1981

ATTACHMENT I

1981 Trojan Emergency Plan Exercise
PGE Corrective Actions

<u>Commitment</u>	<u>Commitment Date</u>
1. Improve procedures for receiving, reducing, and interpreting all plant data, offsite monitoring data, and transmitting data summaries and protective action recommendations to offsite agencies.	07/01/81
2. Improve procedures for the use of status boards to inform near-site EOF staff of major changes in the status of the plant, offsite protective action recommendations, and dose assessment results.	07/01/81
3. Improve the arrangements for the State of Washington liaison and Federal agencies at the near-site EOF.	Depends on NRC action on EOF location (see text)
4. Implement communications drills/preparedness program.	Implemented in 04/81
5. Conduct UDAC/State EOC exercise/health physics drill (including field team areas) for ingestion pathway EPZ decision making/technical assessment.	09/01/81
6. Provide better field team maps to all parties.	10/01/81
7. Execute memorandums of understanding with State of Washington and Cowlitz County on assurances of PGE's recommendations with appropriate technical/nontechnical explanations.	07/01/81